

भारत सरकार Governme**n**t of India विद्युत मंत्रालय Ministry of Power उत्तर क्षेत्रीय विद्युत समिति Northern Regional Power Committee

सं.:उ.क्षे.वि.स./प्रचालन/106/01/2021/739-780

विषय: उत्तर क्षेत्रीय विद्युत समिति की प्रचालन समन्वय उप- समिति की 191वी बैठक में स्वीकृत आऊटेज कार्यक्रम की सूची I

Subject: Outage programme approved in 191st OCC Meeting.

विद्युत् उत्पादन कंपनियों व पारेषण लाइसेंस धारकों द्वारा उत्पादन इकाइयों व पारेषण तंत्र के प्रस्तावित आऊटेज कार्यक्रमों को दिनांक 17.01.2022 में आयोजित प्रचालन समन्वय उप- समिति की 191 वी बैठक में चर्चा करने के पश्चात आऊटेज कार्यक्रम की स्वीकृत सूची को उत्तर क्षेत्रीय विद्युत समिति के वेब पोर्टल पर उपलब्ध किया गया है । सभी आऊटेज कार्यक्रम संभावित हैं एवं वास्तविक काल में ग्रिड की स्तिथि के अनुरूप प्रभावी होंगे। किसी प्रकार की त्रुटि होने पर दो कार्य दिवसों के भीतर हमें सूचित करने का कष्ट करें।

The outage programme of Generating Units and Transmission Lines proposed by Generating Companies and Transmission Licensees were discussed in the 191st OCC meeting held on 17.01.2022 and the approved list of outages program has been uploaded on NRPC web portal. All outage programmes are approved tentatively subject to real time grid conditions. Discrepancy, if any may kindly be intimated within two working days.

-sd-(सौमित्र मजूमदार) अधीक्षण अभियंता (प्रचालन)

दिनांक: 19.01.2022

सेवा में, प्रचालन समन्वय उप- समिति के सभी सदस्य I

APPROVED OUTAGE PROGRAM OF 191st OCC

									APPI	ROVED OUT	age Progran	Л OF 191st (OCC							
Sr No	Reference Number	Num	Name of Requesting	1	Element Name	Owner	Daily/ Continous	Reason	Requested From Date	Requested From Time	Requested To Date	Requested To Time		Request Type	Shutdown Status	Approved From Date	Approved From Time	Approved To Date	Approved To Time	NRPC Remarks
1	RQ81004	OCC_ 191	Agency rampur_sd	GENER ATING UNIT	68.67 MW RAMPUR HEP - UNIT 3	SJVNL	С	Annual Planned Maintenance of generating unit	18/Feb/2022	00:00	27/Feb/2022	18:00		PLANNED	Approved	18-Feb-22	00:00	27-Feb-22	18:00	
2	RQ81003	OCC_ 191	rampur_sd	GENER ATING UNIT	68.67 MW RAMPUR HEP - UNIT 5	SJVNL	С	Annual Planned Maintenance of generating unit	07/Feb/2022	00:00	16/Feb/2022	18:00		PLANNED	Approved	07-Feb-22	00:00	16-Feb-22	18:00	
3	RQ80573	OCC_ 191	jhakri_sd	GENER ATING UNIT	250 MW NATHPA- JHAKRI HPS - UNIT 2	SJVNL	С	Annual Planned Maintenance of Unit No.#02	18/Feb/2022	20:00	27/Feb/2022	18:00		PLANNED	Approved	18-Feb-22	20:00	27-Feb-22	18:00	
4	RQ80574	OCC_ 191	jhakri_sd	GENER ATING UNIT	250 MW NATHPA- JHAKRI HPS - UNIT 5	SJVNL	С	Annual Planned Maintenance of Unit No.#05	07/Feb/2022	08:00	16/Feb/2022	18:00		PLANNED	Approved	07-Feb-22	08:00	16-Feb-22	18:00	
5	RQ80757	OCC_ 191	jhajjar_sd	GENER ATING UNIT	500 MW ISTPP (JHAJJAR) - UNIT 3	APCPL	С	Annual SG, TG Overhaul & FGD gate installation	01/Feb/2022	00:00	07/Mar/2022	23:59		PLANNED	Approved	01-Feb-22	00:00	07-Mar-22	23:59	Delhi and Haryana gave its consent.
6	RQ81361	OCC_ 191	karcham_s d	GENER ATING UNIT	250 MW KARCHAM WANGTOO HPS - UNIT 3	JSW	С	Annual Maintenance of Unit 3	01/Feb/2022	00:00	25/Feb/2022	23:59		PLANNED	Approved	01-Feb-22	00:00	25-Feb-22	23:59	
7	RQ80753	OCC_ 191	ntpcncr_sd	GENER ATING UNIT	210 MW DADRI-I TPS - UNIT 3	NTPC	С	Capital over haul	01/Feb/2022	00:00	07/Mar/2022	23:05		PLANNED	Approved	01-Feb-22	00:00	07-Mar-22	23:05	Could be given
8	RQ80968	OCC_ 191	ntpcos_sd	GENER ATING UNIT	200 MW SINGRAULI STPS - UNIT 4	NTPC	С	Boiler license renewal	16/Feb/2022	00:00	19/Feb/2022	23:59		PLANNED	Rejected					request withdrawn by NTPC.
		191	_	ATING UNIT	200 MW KOLDAM HPS UNIT 4	NTPC		Annual mtc.	08/Feb/2022		12/Feb/2022		Mandatory Annual Inspection		Approved	08-Feb-22	00:00	12-Feb-22	23:59	
10	RQ80749	OCC_ 191	cpcc1_sd	LINE	800 KV HVDC KURUKSHETR A-CHAMPA (PG) CKT-2			ON load testing of both bi-poles to ascertain software functinalities (after daily testing works, all poles will be put back in service and power level as per NLDC)	26/Feb/2022	08:00	08/Mar/2022	18:00		PLANNED	Approved	26-Feb-22	08:00	08-Mar-22	18:00	Testing schedule to be shared with NRLDC/NLDC well in advance.

11	RQ80750	OCC_ 191	cpcc1_sd	CIRCUIT	800 KV HVDC KURUKSHETR A-CHAMPA (PG) CKT-3	GRID	ON load testing of both bi-poles to ascertain software functinalities (after daily testing works, all poles will be put back in service and power level as per NLDC)	26/Feb/2022	08:00	08/Mar/2022	18:00	PLANN	ED Approved	26-Feb-22	08:00	08-Mar-22	18:00	Testing schedule to be shared with NRLDC/NLDC well in advance.
12	RQ80748	OCC_ 191	cpcc1_sd	LINE	800 KV HVDC KURUKSHETR A-CHAMPA (PG) CKT-1		ON load testing of both bi-poles to ascertain software functinalities (after daily testing works, all poles will be put back in service and power level as per NLDC)	26/Feb/2022	08:00	08/Mar/2022	18:00	PLANN	Approved Approved	26-Feb-22	08:00	08-Mar-22	18:00	Testing schedule to be shared with NRLDC/NLDC well in advance.
13	RQ80751	OCC_ 191	cpcc1_sd	LINE	800 KV HVDC KURUKSHETR A-CHAMPA (PG) CKT-4		ON load testing of both bi-poles to ascertain software functinalities (after daily testing works, all poles will be put back in service and power level as per NLDC)	26/Feb/2022	08:00	08/Mar/2022	18:00	PLANN	Approved Approved	26-Feb-22	08:00	08-Mar-22	18:00	Testing schedule to be shared with NRLDC/NLDC well in advance.
14	RQ80746	OCC_ 191	cpcc1_sd	LINE	800 KV HVDC KURUKSHETR A-CHAMPA (PG) CKT-1		Installation of station grounding isolator and associated hardware in Bipole-I&II common area and station ground DCCT Improvement and upgradation of control software.	23/Feb/2022	08:00	25/Feb/2022	18:00	PLANN	Approved Approved	23-Feb-22	08:00	28-Feb-22	18:00	ATC Curtailment of 2900 MW for Bipole Outage & 5800 MW for all 4 pole outage. Subjected to WRPC approval. No other SD in WR- NR corrdor shall be allowed during pole outage

1	L5 R	Q80747	OCC_ 191	cpcc1_sd	LINE	800 KV HVDC KURUKSHETR A-CHAMPA (PG) CKT-2	С	Installation of station grounding isolator and associated hardware in Bipole-I&II common area and station ground DCCT Improvement and upgradation of control software.	23/Feb/2022	08:00	25/Feb/2022	18:00	PLANNED	Approved	23-Feb-22	08:00	28-Feb-22	18:00	ATC Curtailment of 2900 MW for Bipole Outage & 5800 MW for all 4 pole outage. Subjevted to WRPC approval. No other SD in WR- NR corrdor shall be allowed during pole outage
1	6 R	Q80745	OCC_ 191	cpcc1_sd	LINE CIRCUIT	800 KV HVDC KURUKSHETR A-CHAMPA (PG) CKT-4	C	DCCT Improvements & global injection, DC Filter / Blocking Filter hardware modification & integration, VH Arc Detection modification & integration, modification in Valve Hall iro of Positive pressure and upgradation of control software.	21/Feb/2022	08:00	25/Feb/2022	18:00	PLANNED	Approved	21-Feb-22	08:00	28-Feb-22	18:00	ATC Curtailment of 2900 MW for Bipole Outage & S800 MW for all 4 pole outage. Subjevted to WRPC approval. No other SD in WR- NR corrdor shall be allowed during pole outage
1	17 R	Q80744	OCC_ 191	cpcc1_sd	LINE	800 KV HVDC KURUKSHETR A-CHAMPA (PG) CKT-3	C	DCCT Improvements & global injection, DC Filter / Blocking Filter hardware modification & integration ,VH Arc Detection modification & integration, modification in Valve Hall iro of Positive pressure and upgradation of control software.	21/Feb/2022	08:00	25/Feb/2022	18:00	PLANNED	Approved	21-Feb-22	08:00	28-Feb-22	18:00	ATC Curtailment of 2900 MW for Bipole Outage & 5800 MW for all 4 pole outage. Subjevted to WRPC approval. No other SD in WR- NR corrdor shall be allowed during pole outage

18	RQ81029	OCC_ 191	cpcc3_sd	LINE CIRCUIT	800 KV HVDC KURUKSHETR A-CHAMPA (PG) CKT-1		Transmission Line diversion work due to construction of Bundelkhand Expressway by UPEIDA	20/Feb/2022	08:00	26/Feb/2022	18:00	All 04 poles will be under shut down during this period	PLANNED	Approved				clubbed with SI No.
19	RQ81030	OCC_ 191	cpcc3_sd	LINE CIRCUIT	800 KV HVDC KURUKSHETR A-CHAMPA (PG) CKT-2		Transmission Line diversion work due to construction of Bundelkhand Expressway by UPEIDA	20/Feb/2022	08:00	26/Feb/2022	18:00	All 04 poles will be under shut down during this period	PLANNED	Approved				clubbed with SI No. 15
20	RQ81031	OCC_ 191	cpcc3_sd	LINE CIRCUIT	800 KV HVDC KURUKSHETR A-CHAMPA (PG) CKT-3		Transmission Line diversion work due to construction of Bundelkhand Expressway by UPEIDA	20/Feb/2022	08:00	26/Feb/2022	18:00	All 04 poles will be under shut down during this period	PLANNED	Approved				clubbed with SI No. 17
21	RQ81032	OCC_ 191	cpcc3_sd	LINE CIRCUIT	800 KV HVDC KURUKSHETR A-CHAMPA (PG) CKT-4		Transmission Line diversion work due to construction of Bundelkhand Expressway by UPEIDA	20/Feb/2022	08:00	26/Feb/2022	18:00	All 04 poles will be under shut down during this period	PLANNED	Approved				clubbed with SI No. 16
22	RQ80743	OCC_ 191	cpcc1_sd	LINE CIRCUIT	800 KV HVDC KURUKSHETR A-CHAMPA (PG) CKT-2		"DCCT Improvements & global injection, DC Filter / Blocking Filter hardware modification & integration ,VH Arc Detection modification & integration, modification in Valve Hall iro of Positive pressure."	15/Feb/2022	08:00	20/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	08:00	20-Feb-22	ATC Curtailment of 2900 MW for Bipole Outage & 5800 MW for all 4 pole outage. Subjevted to WRPC approval. No other SD in WR- NR corrdor shall be allowed during pole outage

23	RQ80742	OCC_ 191	cpcc1_sd	LINE	800 KV HVDC KURUKSHETR A-CHAMPA (PG) CKT-1			"DCCT Improvements & global injection, DC Filter / Blocking Filter hardware modification & integration ,VH Arc Detection modification & integration, modification in Valve Hall iro of Positive pressure. "	15/Feb/2022	08:00	20/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	08:00	20-Feb-22	18:00	ATC Curtailment of 2900 MW for Bipole Outage & 5800 MW for all 4 pole outage. Subjevted to WRPC approval. No other SD in WR- NR corrdor shall be allowed during pole outage
24		191	cpcc3_sd		800 KV HVDC AGRA- BISHWANATH CHARIALI (PG) CKT-1		С	Transmission Line diversion work due to construction of Gorakhpur Link Expressway by UPEIDA	25/Feb/2022		28/Feb/2022		All 04 poles will be under shut down during this period		Approved	25-Feb-22	08:00	28-Feb-22	18:00	All satutory approval (El clearence, PTC approval etc) shall be provided before the charging of line. Subjected to ERPC & NERPC approval.
25	RQ81015	OCC_ 191	cpcc3_sd	LINE	800 KV HVDC AGRA- BISHWANATH CHARIALI (PG) CKT-2		C	Transmission Line diversion work due to construction of Gorakhpur Link Expressway by UPEIDA	25/Feb/2022	08:00	28/Feb/2022	18:00	All 04 poles will be under shut down during this period	PLANNED	Approved	25-Feb-22	08:00	28-Feb-22	18:00	All satutory approval (El clearence, PTC approval etc) shall be provided before the charging of line. Subjected to ERPC & NERPC approval.
26	RQ81137	OCC_ 191	cpcc3_sd	AC TRANS MISSIO N LINE CIRCUIT	765 KV ORAI- SATNA (PG) CKT-1	POWER GRID		Y-Ph L/R TO BE SWITHED OUT and SPARE TO BE TAKEN INTO SERVICE at Satna End. Dia to be kept opened	17/Feb/2022	08:00	17/Feb/2022	18:00		PLANNED	Approved	17-Feb-22	08:00	17-Feb-22	18:00	L/R Switching work to be clubbed with Line AMP Works. ATC Curtailment of 2450 MW. Subjected to WRPC approval. As intimated by CPCC-I line amp work will also be carried out.
27	RQ80674	OCC_ 191	cpcc1_sd	TRANS	765 KV PHAGI(RS)- GWALIOR(PG) (PG) CKT-2	POWER GRID	D	Insulation sleeve Installation & Maintenance work	16/Feb/2022	08:00	16/Feb/2022	18:00		PLANNED	Approved	16-Feb-22	08:00	16-Feb-22	18:00	ATC Curtailment of 450 MW. Subjected to WRPC approval

28	RQ81128	OCC_ 191	cpcc3_sd		765 KV FATEHPUR- SASARAM (PG) CKT-1	POWER GRID	D	REPLACEMENT OF FLASHED INSULATOR BY ER- 1	03/Feb/2022	08:00	03/Feb/2022 18:00		PLANNED	Approved	03-Feb-22	08:00	03-Feb-22	18:00	Subjected to ERPC approval.
29	RQ81134	OCC_ 191	cpcc3_sd	AC TRANS MISSIO N LINE CIRCUIT	765 KV ORAI- JABALPUR (PG) CKT-1	POWER GRID	D	A/R into non auto mode for Live Line OPGW Work By WR-2	01/Feb/2022	08:00	28/Feb/2022 18:00		PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	
30	RQ81067	OCC_ 191	cpcc3_sd		765 KV VARANASI(PG)- VINDHYACHA LPOOL(PG) (PVTSL) CKT-2		D	CSD Commissioning work in 765KV Varanasi- Vindhayachal ckt-2	03/Feb/2022	10:00	03/Feb/2022 14:00		PLANNED	Approved	03-Feb-22	10:00	03-Feb-22	14:00	ATC Curtailment of 1900 MW. Subjected to WRPC approval
31	RQ81066	OCC_ 191	cpcc3_sd	MISSIO N LINE	765 KV VARANASI(PG)- VINDHYACHA LPOOL(PG) (PVTSL) CKT-1		D	CSD Commissioning work in 765KV Varanasi- Vindhayachal ckt-1	02/Feb/2022	10:00	02/Feb/2022 14:00		PLANNED	Approved	02-Feb-22	10:00	02-Feb-22	14:00	ATC Curtailment of 1900 MW. Subjected to WRPC approval
32	RQ81630	OCC_ 191	cpcc2_sd		400 KV BAGLIHAR(JK) KISHENPUR(P G) (PDD JK) CKT-2	PDD JK	D	For line bay AMP works at Kishenpur SS.	28/Feb/2022	10:00	28/Feb/2022 18:00	Kindly approve	PLANNED	Approved	28-Feb-22	10:00	28-Feb-22	18:00	subject to JK consent
33	RQ81629	OCC_ 191	cpcc2_sd	MISSIO	400 KV BAGLIHAR(JK) KISHENPUR(P G) (PDD JK) CKT-1		D	For line bay AMP works at Kishenpur SS.	22/Feb/2022	10:00	22/Feb/2022 15:00	Kindly approve	PLANNED	Approved	22-Feb-22	10:00	22-Feb-22	15:00	subject to JK consent
34	RQ80918	OCC_ 191	sldcps_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV MUKTSAR- MAKHU (PS) CKT-1		D	Jumper Tightening	28/Feb/2022	09:00	28/Feb/2022 17:00		PLANNED	Approved	28-Feb-22	09:00	28-Feb-22	17:00	
35	RQ80909	OCC_ 191	sldcps_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV MUKTSAR- MAKHU (PS) CKT-1		D	Jumper Tightening	24/Feb/2022	09:00	24/Feb/2022 17:00		PLANNED	Approved	24-Feb-22	09:00	24-Feb-22	17:00	

36	RQ80913	OCC_ 191	sldcps_sd	MISSIO N LINE	400 KV TALWANDI SABOO(PSG)- DHURI(PS) (PS) CKT-2	D	Jumper Checking /Tightining and tree trimmingof tower no -150 to 170	21/Feb/2022	09:00	22/Feb/2022	17:00	PLANNED	Approved	21-Feb-22	09:00	22-Feb-22	17:00	
37	RQ80830	OCC_ 191	sldcps_sd	ORMER	400/220 KV 315 MVA ICT 2 AT NAKODAR(PS G)	D	Periodic Maintenance	18/Feb/2022	09:00	18/Feb/2022	17:00	PLANNED	Approved	18-Feb-22	09:00	18-Feb-22	17:00	
38	RQ80910	OCC_ 191	sldcps_sd	MISSIO N LINE	400 KV TALWANDI SABOO(PSG)- NAKODAR(PS G) (PS) CKT-1	D	Checking of Jumper, suspensio n clamp and Damper. Tree cutting and disc cleaning	18/Feb/2022	09:00	18/Feb/2022	17:00	PLANNED	Approved	18-Feb-22	09:00	18-Feb-22	17:00	
39	RQ80829	OCC_ 191	sldcps_sd		400/220 KV 315 MVA ICT 1 AT NAKODAR(PS G)	D	Periodic Maintenance	17/Feb/2022	09:00	17/Feb/2022	17:00	PLANNED	Approved	17-Feb-22	09:00	17-Feb-22	17:00	
40	RQ80903	OCC_ 191	sldcps_sd	MISSIO N LINE	400 KV TALWANDI SABOO(PSG)- DHURI(PS) (PS) CKT-1	D	40789B, 40889A	15/Feb/2022	09:00	15/Feb/2022	17:00	PLANNED	Approved	15-Feb-22	09:00	15-Feb-22	17:00	
41	RQ80897	OCC_ 191	sldcps_sd	MISSIO N LINE	400 KV NAKODAR(PS G)- MOGA(PG) (PS) CKT-1	D	Checking of Jumper, suspensio n clamp and Damper. Tree cutting and disc cleaning	14/Feb/2022	09:00	14/Feb/2022	17:00	PLANNED	Approved	14-Feb-22	09:00	14-Feb-22	17:00	
42	RQ80896	OCC_ 191	sldcps_sd		400 KV MUKTSAR- MAKHU (PS) CKT-1	D	Jumper Tightening	14/Feb/2022	09:00	14/Feb/2022	17:00	PLANNED	Approved	14-Feb-22	09:00	14-Feb-22	17:00	
43	RQ80901	OCC_ 191	sldcps_sd	MISSIO N LINE	400 KV TALWANDI SABOO(PSG)- DHURI(PS) (PS) CKT-1	D	Jumper Checking /Tightining and tree trimming of tower no-150 to 170	14/Feb/2022	09:00	15/Feb/2022	17:00	PLANNED	Approved	14-Feb-22	09:00	15-Feb-22	17:00	

44	RQ80866	OCC_ 191	sldcps_sd	TRANS MISSIO N LINE	400 KV TALWANDI SABOO(PSG)- DHURI(PS) (PS) CKT-1	D	Protection Testing	14/Feb/2022	09:00	14/Feb/2022	17:00	PL	ANNED	Approved	14-Feb-22	09:00	14-Feb-22	17:00	
45	RQ80891	OCC_ 191	sldcps_sd	TRANS MISSIO N LINE	400 KV RAJPURA TPS(PSG)- NAKODAR(PS G) (PS) CKT-2		Checking of Jumper,suspensio n clamp and Damper.Tree cutting and disc cleaning	11/Feb/2022	09:00	11/Feb/2022	17:00	PL	ANNED	Approved	11-Feb-22	09:00	11-Feb-22	17:00	
46	RQ80890	OCC_ 191	sldcps_sd	TRANS MISSIO N LINE	400 KV RAJPURA TPS(PSG)- NAKODAR(PS G) (PS) CKT-1		Checking of Jumper,suspensio n clamp and Damper.Tree cutting and disc cleaning	10/Feb/2022	09:00	10/Feb/2022	17:00	PL	ANNED	Approved	10-Feb-22	09:00	10-Feb-22	17:00	
47	RQ80828	OCC_ 191	sldcps_sd	ORMER	400/220 KV 315 MVA ICT 2 AT NAKODAR(PS G)	D	Periodic Maintenance	09/Feb/2022	09:00	09/Feb/2022	17:00	PL	ANNED	Approved	09-Feb-22	09:00	09-Feb-22	17:00	
48	RQ80826	OCC_ 191	sldcps_sd	ORMER	400/220 KV 500 MVA ICT 3 AT MAKHU(PS)		Nut bolt tightening and cleaning of Bay 420 CT,CB,isolators and CB and cleaning of BMK and C&R Panel and the terminal tightening of CT JB and CB MB	08/Feb/2022	09:00	08/Feb/2022	17:00	PL	ANNED	Approved	08-Feb-22	09:00	08-Feb-22	17:00	
49	RQ80827	OCC_ 191	sldcps_sd		400/220 KV 500 MVA ICT 2 AT DHURI(PS)		Complete body cleaning & Tightening of transformer bush. Tightening of links of Marshalling box of Transformer	08/Feb/2022	09:00	08/Feb/2022	17:00	- PL	ANNED	Approved	08-Feb-22	09:00	08-Feb-22	17:00	
50	RQ80887	OCC_ 191	sldcps_sd	MISSIO N LINE	400 KV TALWANDI SABOO(PSG)- NAKODAR(PS G) (PS) CKT-1		Checking of Jumper,suspensio n clamp and Damper.Tree cutting and disc cleaning	08/Feb/2022	09:00	08/Feb/2022	17:00	PL	ANNED	Approved	08-Feb-22	09:00	08-Feb-22	17:00	

		191	sldcps_sd	MISSIO N LINE CIRCUIT	MOGA(PG) (PS) CKT-1	D	Checking of Jumper, suspensio n clamp and Damper. Tree cutting and disc cleaning	07/Feb/2022		07/Feb/2022			PLANNED	Approved	07-Feb-22	09:00	07-Feb-22	17:00	
52	RQ80825	OCC_ 191	sldcps_sd		400/220 KV 500 MVA ICT 1 AT DHURI(PS)	D	Maintenance of ICT Bushing Clamps, 220 kV Output Bus bar , Transformer Cleaning	07/Feb/2022	09:00	07/Feb/2022	17:00	-	PLANNED	Approved	07-Feb-22	09:00	07-Feb-22	17:00	
53	RQ80839	OCC_ 191	sldcps_sd	ВАУ	401 MAIN BAY - 400KV TALWANDI SABOO(PSG)- MUKTSAR(PS) (PS) CKT-1 AT MUKTSAR(PS)	D	General maintenance for nut-bolt tightening,cleaning and IR of equipments.	07/Feb/2022	09:00	07/Feb/2022	17:00		PLANNED	Approved	07-Feb-22	09:00	07-Feb-22	17:00	
54	RQ80824	OCC_ 191	sldcps_sd		400/220 KV 500 MVA ICT 1 AT DHURI(PS)	D	403 89A, 402 89B isolator	04/Feb/2022	09:00	04/Feb/2022	17:00	-	PLANNED	Approved	04-Feb-22	09:00	04-Feb-22	17:00	
55	RQ80880	OCC_ 191	sldcps_sd	MISSIO	400 KV DEHAR(BB)- RAJPURA(PS) (PG) CKT-1	D	Annual protection Testing	04/Feb/2022	09:00	04/Feb/2022	17:00	Complete line shutdown request	PLANNED	Approved	04-Feb-22	09:00	04-Feb-22	17:00	
56	RQ80877	OCC_ 191	sldcps_sd		400 KV RAJPURA- DHURI (PS) CKT-1	D	Annual protection Testing	03/Feb/2022	09:00	03/Feb/2022	17:00	Complete line shutdown request	PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	17:00	
57	RQ80837	OCC_ 191	sldcps_sd	ВАУ	406 MAIN BAY - 400KV MUKTSAR- MAKHU (PS) CKT-2 AT MUKTSAR(PS)	D	General maintenance for nut-bolt tightening,cleaning and IR of equipments.	03/Feb/2022	09:00	03/Feb/2022	17:00		PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	17:00	
58	RQ80823	OCC_ 191	sldcps_sd		400/220 KV 500 MVA ICT 1 AT DHURI(PS)	D	Maintenance of 403 89L, LA (HV), LA (IV), Body Cleaning of ICT	03/Feb/2022	09:00	03/Feb/2022	17:00	-	PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	17:00	

59	RQ80822	OCC_ 191	sldcps_sd	ORMER	400/220 KV 315 MVA ICT 2 AT MAKHU(PS)	D	Nut bolt tightening and cleaning of Bay 213(IV Side) LA,CT, Isolators and CB and cleaning of BMK and C&R Panel and the terminal tightening of CT JB and CB MB	03/Feb/2022	09:00	03/Feb/2022	17:00		PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	17:00	
60	RQ80875	OCC_ 191	sldcps_sd	TRANS MISSIO N LINE	400 KV NAKODAR(PS G)- MAKHU(PS) (PS) CKT-2	D	Checking of Jumper,suspensio n clamp and Damper.Tree cutting and disc cleaning	03/Feb/2022	09:00	03/Feb/2022	17:00		PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	17:00	
61	RQ80836	OCC_ 191	sldcps_sd		420 TIE BAY - 400 KV BHIWANI(BB)- RAIPURA(PS) (BB) CKT-1 AND FUTURE AT RAIPURA(PS)	D	Annual protection Testing	02/Feb/2022	10:00	02/Feb/2022	15:00	Only bay Shutdown Required	PLANNED	Approved	02-Feb-22	10:00	02-Feb-22	15:00	
62	RQ80820	OCC_ 191	sldcps_sd	ORMER	400/220 KV 315 MVA ICT 1 AT NAKODAR(PS G)	D	Periodic Maintenance	02/Feb/2022	09:00	02/Feb/2022	17:00		PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	17:00	
	RQ80821	191		ORMER	400/220 KV 500 MVA ICT 3 AT DHURI(PS)	D	Protection Testing	02/Feb/2022	09:00	02/Feb/2022	17:00	-	PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	17:00	
64	RQ80871	OCC_ 191	sldcps_sd	TRANS MISSIO	400 KV BHIWANI(BB)- RAJPURA(PS) (PG) CKT-1	D	Annual protection Testing	01/Feb/2022	09:00	01/Feb/2022	17:00	Complete line shutdown request	PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	17:00	
65	RQ80869	OCC_ 191	sldcps_sd	TRANS MISSIO	400 KV RAJPURA- DHURI (PS) CKT-1	D	Protection Testing	01/Feb/2022	09:00	01/Feb/2022	17:00		PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	17:00	

66	RQ80819	OCC_ 191	sldcps_sd		400/220 KV 315 MVA ICT 1 AT MAKHU(PS)		D	Cleaning and Recording of IR Values of Bay 214(IV Side) CT's and CB, cleaning of CTR Panel and Terminal tightening of ICT-1 MB	01/Feb/2022	09:00	01/Feb/2022	17:00		PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	17:00	
67	RQ80870	OCC_ 191	sldcps_sd		400 KV RAJPURA- DHURI (PS) CKT-1		D	Jumper checking/Tightinin g and tree trimming of tower no -129 to 138	01/Feb/2022	09:00	01/Feb/2022	17:00		PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	17:00	
68	RQ80867	OCC_ 191	sldcps_sd	MISSIO N LINE	400 KV NAKODAR(PS G)- MAKHU(PS) (PS) CKT-1		D	Checking of Jumper,suspensio n clamp and Damper.Tree cutting and disc cleaning	01/Feb/2022	09:00	01/Feb/2022	17:00		PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	17:00	
69	RQ81635	OCC_ 191	cpcc2_sd	MISSIO N LINE	400 KV CHAMERA_2(NH)- KISHENPUR(P G) (PG) CKT-1	POWER GRID	D	For AMP works.	24/Feb/2022	09:00	24/Feb/2022	17:30	Kindly approve	PLANNED	Approved	24-Feb-22	09:00	24-Feb-22	17:30	subject to NHPC consent/Other lines from Chamera_2 must be in service
70	RQ81136	OCC_ 191	cpcc3_sd	MISSIO N LINE	400 KV RIHAND(NT)- VINDHYACHA LPOOL(PG) (PG) CKT-2	POWER GRID	D	For AMP work by WR-2. Dia to be kept open.	15/Feb/2022	08:00	15/Feb/2022	18:00		PLANNED	Rejected					request withdrawn by powergrid.Already being facilitated in Jan
71	RQ81135	OCC_ 191	cpcc3_sd	1	400 KV RIHAND(NT)- VINDHYACHA LPOOL(PG) (PG) CKT-1	POWER GRID	D	For AMP work by WR-2. Dia to be kept open.	14/Feb/2022	08:00	14/Feb/2022	18:00		PLANNED	Rejected					request withdrawn by powergrid.Already being facilitated in Jan
72	RQ80566	OCC_ 191	stuup_sd	MISSIO	(PG) CKT-1	POWER GRID	D	OVERHEAD CROSSING OF UNDERCONSTRUC TION 400 KV DC TWIN MOOSE VARANASI (PGCIL)- JAUNPUR LINE BETWEEN LOCATION NO 29 & 30	10/Feb/2022	09:00	11/Feb/2022	17:00		PLANNED	Approved	10-Feb-22	09:00	11-Feb-22	17:00	

73	RQ81130	OCC_ 191	cpcc3_sd	AC TRANS MISSIO N LINE CIRCUIT		POWER GRID	С	for Diversion work of location no 320 of 400 KV Patna - Ballia Line- 3&4 at Gyanpur, Ara by ER-1	10/Feb/2022	08:00	20/Feb/2022	18:00	PLANNED	Approved	10-Feb-22	08:00	20-Feb-22	18:00	All satutory approval (El clearence, PTC approval etc) shall be provided before the charging of line. Subjected to ERPC approval
74	RQ81129	OCC_ 191	cpcc3_sd	AC TRANS MISSIO N LINE CIRCUIT		POWER GRID	С	for Diversion work of location no 320 of 400 KV Patna - Ballia Line- 3&4 at Gyanpur, Ara by ER-1	10/Feb/2022	08:00	20/Feb/2022	18:00	PLANNED	Approved	10-Feb-22	08:00	20-Feb-22	18:00	All satutory approval (El clearence, PTC approval etc) shall be provided before the charging of line. Subjected to ERPC approval
75	RQ81146	OCC_ 191	singrauli_s d	TRANS MISSIO N LINE	400 KV SINGRAULI(N T)- VINDHYACHA L(PG) (PG) CKT-2	POWER GRID	D	3 hour shutdown for SAS work	08/Feb/2022	15:00	08/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	15:00	08-Feb-22	18:00	Subjected to WRPC approval.
76	RQ81145	OCC_ 191	singrauli_s d		400 KV SINGRAULI(N T)- VINDHYACHA L(PG) (PG) CKT-1	POWER GRID	D	4 hour shutdown for SAS work	08/Feb/2022	08:00	08/Feb/2022	12:00	PLANNED	Approved	08-Feb-22	08:00	08-Feb-22	12:00	Subjected to WRPC approval.
77	RQ81094	OCC_ 191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV BHINMAL- ZERDA (PG) CKT-1	POWER GRID	D	Yearly AMP of LTE,Line reactor and main bay circuit breaker at Kansari end by Banaskantha.	07/Feb/2022	09:00	07/Feb/2022	18:30	PLANNED	Approved	07-Feb-22	09:00	07-Feb-22	18:30	Subjected to WRPC approval.
78	RQ81046	OCC_ 191	cpcc3_sd	MISSIO N LINE	400 KV SINGRAULI(N T)- VINDHYACHA L(PG) (PG) CKT-1	POWER GRID	D	AMP work	07/Feb/2022	08:00	07/Feb/2022	18:00	PLANNED	Approved					clubbed with SI. 76
79	RQ81012	OCC_ 191	cpcc3_sd	N LINE	400 KV GORAKHPUR(POWER GRID	С	Transmission Line diversion work due to construction of Gorakhpur Link Expressway by UPEIDA	07/Feb/2022	08:00	10/Feb/2022	18:00	PLANNED	Approved	07-Feb-22	08:00	10-Feb-22	18:00	All satutory approval (El clearence, PTC approval etc) shall be provided before the charging of line. Subjected to ERPC approval

	RQ81011	191		AC TRANS MISSIO N LINE CIRCUIT	GORAKHPUR(PG)- MOTIHARI(BS) (PG) CKT-1	POWER GRID	С	Transmission Line diversion work due to construction of Gorakhpur Link Expressway by UPEIDA For Repair and	07/Feb/2022 05/Feb/2022		10/Feb/2022 09/Feb/2022		Kindly	PLANNED PLANNED	Approved Approved	07-Feb-22 05-Feb-22	08:00	10-Feb-22 09-Feb-22	18:00	All satutory approval (El clearence, PTC approval etc) shall be provided before the charging of line. Subjected to ERPC approval
		191		TRANS MISSIO N LINE CIRCUIT	DULHASTI(NH)- KISHENPUR(P G) (PG) CKT-2	GRID		rectification of tower at location no.261 and 246.					Approve							
82	RQ81132	OCC_ 191	cpcc3_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV BALIA- BIHARSHARIF F (PG) CKT-2		D	REPLACEMENT OF FLASHED INSULATOR LOC 304 AND 418 BY ER-1 WITH A/R to be disabled of Ballia-Biharsharif-1	02/Feb/2022	08:00	02/Feb/2022	18:00		PLANNED	Approved	02-Feb-22	08:00	02-Feb-22	18:00	Subjected to ERPC approval
83	RQ81634	OCC_ 191	cpcc2_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV DULHASTI(NH)- KISHENPUR(P G) (PG) CKT-2	POWER GRID	С	For repair and rectification of towers at location no. 261 and 246.	01/Feb/2022	09:00	05/Feb/2022	18:00	Kindly approve	PLANNED	Approved	01-Feb-22	09:00	05-Feb-22	18:00	subject to NHPC consent
	RQ81131	191		AC TRANS MISSIO N LINE CIRCUIT	400 KV BALIA- BIHARSHARIF F (PG) CKT-1		D	REPLACEMENT OF FLASHED INSULATOR AT LOC. 270 AND 434 BY ER-1 WITH A/R to be disabled of Ballia-Biharsharif-2	01/Feb/2022	08:00	01/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	01-Feb-22	18:00	Subjected to ERPC approval
	RQ81051	191		N LINE CIRCUIT	VINDHYACHA L(PG)- VINDHYACHA L(NT) (PG) CKT-2		D	Checking of LBB tripping for AWL-2 feeder	01/Feb/2022		01/Feb/2022		west Bus#1B and West #2B will be under S/D to perform the test	PLANNED	Approved	01-Feb-22	08:00	01-Feb-22	18:00	Both Poles will be out in case of DC SD. Subjected to WRPC approval.
86	RQ81050	OCC_ 191	cpcc3_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV VINDHYACHA L(PG)- VINDHYACHA L(NT) (PG) CKT-1	POWER GRID	D	Checking of LBB tripping for AWL-1 feeder	01/Feb/2022	08:00	01/Feb/2022	18:00	west Bus#1B and West #2B will be under S/D to perform the test	PLANNED	Approved	01-Feb-22	08:00	01-Feb-22	18:00	Both Poles will be out in case of DC SD. Subjected to WRPC approval.

	RQ81133	191	cpcc3_sd	MISSIO N LINE CIRCUIT	MUZAFFARP UR(PG) (POWERLINK) CKT-1		D	AMP OF LINE BAY EQUIPMENT AT MUZAFFARPUR	05/Feb/2022	08:00	05/Feb/2022	18:00		PLANNED	Approved	05-Feb-22	08:00	05-Feb-22	18:00	Subjected to ERPC approval
88	RQ81666	OCC_ 191	cpcc2_sd	N LINE	400 KV AMARGARH(NRSS XXIX)- WAGOORA(P G) (NRSS XXIX) CKT-2	POWER GRID,N RSS XXIX	D	SD required for re- installation of Aviation Globules after installation of OPGW under ULDC scheme. Non-auto mode is required on 400kV Amargarh- Wagoora ckt-1.	05/Feb/2022	07:00	08/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	05-Feb-22	07:00	08-Feb-22	18:00	
89	RQ81669	OCC_ 191	cpcc2_sd	MISSIO N LINE	400 KV URI_1(NH)- AMARGARH(NRSS XXIX) (NRSS XXIX) CKT-2	POWER GRID,N RSS XXIX	D	SD required for re- installation of Aviation Globules after installation of OPGW under ULDC scheme. Non-auto mode is required on 400kV Uri1- Amargarh ckt-1.	01/Feb/2022	07:00	02/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	02-Feb-22	18:00	
90	RQ80919	OCC_ 191	sldcps_sd	MISSIO N LINE	220 KV BHAKRA_R(B B)- MAHILPUR(P S) (PS) CKT-2		D	Checking of Jumper,suspensio n clamp and Damper.Tree cutting and disc cleaning	28/Feb/2022	09:00	28/Feb/2022	17:00		PLANNED	Approved	28-Feb-22	09:00	28-Feb-22	17:00	
91	RQ80912	OCC_ 191	sldcps_sd	MISSIO N LINE	220 KV NALLAGARH(PG)- MOHALI(PS) (PS) CKT-2		D	Tightening of nut bolts of jumpers of T .no 156,158,159	21/Feb/2022	09:00	21/Feb/2022	17:00		PLANNED	Approved	21-Feb-22	09:00	21-Feb-22	17:00	
92	RQ80905	OCC_ 191	sldcps_sd	MISSIO N LINE	220 KV BHAKRA_R(B B)- MAHILPUR(P S) (PS) CKT-2		D	Checking of Jumper,suspensio n clamp and Damper.Tree cutting and disc cleaning	17/Feb/2022	09:00	17/Feb/2022	17:00		PLANNED	Approved	17-Feb-22	09:00	17-Feb-22	17:00	
93	RQ80904	OCC_ 191	sldcps_sd	MISSIO N LINE	220 KV NALLAGARH(PG)- MOHALI(PS) (PS) CKT-1		D	Tightening of nut bolts of jumpers of T .no 156,158,159	16/Feb/2022	09:00	16/Feb/2022	17:00		PLANNED	Approved	16-Feb-22	09:00	16-Feb-22	17:00	

	RQ80898 RQ80894	191		MISSIO N LINE CIRCUIT AC TRANS MISSIO N LINE	220 KV PONG(BB)- DASUYA(PS) (BBMB) CKT-1 220 KV NALLAGARH(PG)- MOHALI(PS) (PS) CKT-2		D D	Checking of Jumper, suspension n clamp and Damper. Tree cutting and disc cleaning Tightening of nut bolts of jumpers of T. no 161,164,168	14/Feb/2022 11/Feb/2022		14/Feb/2022 11/Feb/2022			PLANNED	Approved Approved	14-Feb-22	09:00	14-Feb-22	17:00	
96	RQ80882	OCC_ 191	sldcps_sd	AC TRANS MISSIO N LINE	220 KV NALLAGARH(D	Tightening of nut bolts of jumpers of T .no 161,164,168	05/Feb/2022	09:00	05/Feb/2022	17:00		PLANNED	Approved	05-Feb-22	09:00	05-Feb-22	17:00	
97	RQ80878	OCC_ 191	sldcps_sd	MISSIO N LINE	220 KV JALANDHAR(PG)- KARTARPUR(PS) (PSTCL) CKT-2		D	Checking of Jumper, suspensio n clamp and Damper. Tree cutting and disc cleaning	04/Feb/2022	09:00	04/Feb/2022	17:00		PLANNED	Approved	04-Feb-22	09:00	04-Feb-22	17:00	
	RQ80872	191		MISSIO N LINE CIRCUIT	KARTARPUR(PS) (PSTCL) CKT-1		D	Checking of Jumper, suspension n clamp and Damper. Tree cutting and disc cleaning	02/Feb/2022	09:00	02/Feb/2022	17:00		PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	17:00	
99	RQ80796	OCC_ 191	sldcrs_sd	MISSIO	220 KV MODAK(RS)- BHANPURA(MP) (MPSEB) CKT-1	MPSEB	D	For quarterly & half yearly maintenance work of bay equipments at 220 KV GSS Modak	10/Feb/2022	09:00	10/Feb/2022	18:00		PLANNED	Approved	10-Feb-22	09:00	10-Feb-22	18:00	Subjected to WRPC approval. Subject to rajasthan consent
100	RQ81640	OCC_ 191	cpcc2_sd		220 KV KISHENPUR(P G)-SALAL(NH) (PG) CKT-2		D	For Repair and Rectification work of tower at location No. 131	10/Feb/2022	09:00	12/Feb/2022	18:00	Kindly approve	PLANNED	Approved	10-Feb-22	09:00	12-Feb-22	18:00	subject to NHPC and JK consent
101	RQ81639	OCC_ 191	cpcc2_sd	AC TRANS MISSIO N LINE CIRCUIT	220 KV KISHENPUR(P G)-SALAL(NH) (PG) CKT-1		D	For Repair and Rectification work of tower at location No. 131	10/Feb/2022	09:00	12/Feb/2022	18:00	Kindly approve	PLANNED	Approved	10-Feb-22	09:00	12-Feb-22	18:00	subject to NHPC and JK consent

102	RQ81694	OCC_ 191	cpcc2_sd	AC TRANS MISSIO N LINE CIRCUIT	CKT-2	POWER GRID	D	For CT DGA Sampling at Samba (PG).	02/Feb/2022	13:00	02/Feb/2022	17:00	Kindly approve	PLANNED	Approved	02-Feb-22	13:00	02-Feb-22	17:00	One ckt at time
103	RQ81693	OCC_ 191	cpcc2_sd	MISSIO	220 KV SAMBA(PG)- SAMBA(PG) (PG) CKT-1	POWER GRID	D	For CT DGA Sampling at Samba (PG).	02/Feb/2022	09:00	02/Feb/2022	13:00	Kindly approve	PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	13:00	One ckt at time
104	RQ80914	OCC_ 191	sldcps_sd	MISSIO	132 KV HAMIRPUR(H P)-CHOHAL (PS) (PSTCL) CKT-1		D	Checking of Jumper,suspensio n clamp and Damper.Tree cutting and disc cleaning	23/Feb/2022	09:00	23/Feb/2022	17:00		PLANNED	Approved	23-Feb-22	09:00	23-Feb-22	17:00	
105	RQ80883	OCC_ 191	sldcps_sd	MISSIO	132 KV KANGRA (HP)- PATHANKOT (PS) (PSTCL) CKT-1		D	Jumper tightening,Checkin g of tower accesorries	07/Feb/2022	09:00	07/Feb/2022	17:00		PLANNED	Approved	07-Feb-22	09:00	07-Feb-22	17:00	
106	RQ80873	OCC_ 191	sldcps_sd	MISSIO	132 KV HAMIRPUR(H P)-CHOHAL (PS) (PSTCL) CKT-1		D	Checking of Jumper,suspensio n clamp and Damper.Tree cutting and disc cleaning	02/Feb/2022	09:00	02/Feb/2022	17:00		PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	17:00	
107	RQ80644	OCC_ 191	stuup_sd	MISSIO	132 KV LALITPUR(UP) RAJGHAT(MP) (UP) CKT-1	UPPTCL	D	for replacement of energy meters by M/s PGCIL	08/Feb/2022	11:00	08/Feb/2022	14:00		PLANNED	Approved	08-Feb-22	11:00	08-Feb-22	14:00	Subjected to WRPC approval. Subject to UP consent.
108	RQ80920	OCC_ 191	sldcps_sd	MISSIO	220 KV MOGA(PG)- MOGAN(PS) (PSTCL) CKT-2		D	For Jumper Tightening and Tree Cutting from Tower No. 01 to 04	28/Feb/2022	09:00	28/Feb/2022	17:00		PLANNED	Approved	28-Feb-22	09:00	28-Feb-22	17:00	
109	RQ80917	OCC_ 191	sldcps_sd	AC TRANS MISSIO N LINE CIRCUIT	(PSTCL) CKT-1		D	For Jumper Tightening and Tree Cutting from Tower No. 01 to 04	26/Feb/2022	09:00	26/Feb/2022	17:00		PLANNED	Approved	26-Feb-22	09:00	26-Feb-22	17:00	

110	RQ80916	OCC_ 191	sldcps_sd	TRANS MISSIO	400 KV MUKTSAR- MAKHU (PS) CKT-1	D	For Jumper Tightening and Tree Cutting from Tower No. 163-193	25/Feb/2022	09:00	25/Feb/2022	17:00	PLANNED	Approved	25-Feb-22	09:00	25-Feb-22	17:00	
111	RQ80911	OCC_ 191	sldcps_sd	TRANS MISSIO	400 KV MUKTSAR- MAKHU (PS) CKT-2	D	For Jumper Tightening and Tree Cutting from Tower No. 163-193	24/Feb/2022	09:00	24/Feb/2022	17:00	PLANNED	Approved	24-Feb-22	09:00	24-Feb-22	17:00	
112	RQ80915	OCC_ 191	sldcps_sd	TRANS MISSIO	400 KV MUKTSAR- MAKHU (PS) CKT-1		For Jumper Tightening and Tree Cutting from Tower No. 132- 162	23/Feb/2022	09:00	23/Feb/2022	17:00	PLANNED	Approved	23-Feb-22	09:00	23-Feb-22	17:00	
113	RQ80843	OCC_ 191	sldcps_sd		410 MAIN BAY - 400KV MUKTSAR- MAKHU (PS) CKT-2 AT MAKHU(PS)		Nut bolt tightening and cleaning of Bay 208 (IV Side) CT,CB,isolators and CB and cleaning of BMK and C&R Panel and the terminal tightening of CT JB and CB MB	21/Feb/2022	09:00	21/Feb/2022	17:00	PLANNED	Approved	21-Feb-22	09:00	21-Feb-22	17:00	
114	RQ80908	OCC_ 191	sldcps_sd	TRANS MISSIO N LINE	220 KV MOGA(PG)- MEHAL- KALAN(PS) (PSTCL) CKT-2	D	Tree cutting and Jumper tightening TN 40 to 60	18/Feb/2022	09:00	18/Feb/2022	17:00	PLANNED	Approved	18-Feb-22	09:00	18-Feb-22	17:00	
115	RQ80906	OCC_ 191	sldcps_sd	TRANS MISSIO N LINE	220 KV MOGA(PG)- MEHAL- KALAN(PS) (PSTCL) CKT-2	D	Tree cutting and Jumper tightening TN 20 to 40	17/Feb/2022	09:00	17/Feb/2022	17:00	PLANNED	Approved	17-Feb-22	09:00	17-Feb-22	17:00	
116	RQ80907	OCC_ 191	sldcps_sd	TRANS MISSIO	400 KV MUKTSAR- MAKHU (PS) CKT-2		For Jumper Tightening and Tree Cutting from Tower No. 132- 162	17/Feb/2022	09:00	17/Feb/2022	17:00	PLANNED	Approved	17-Feb-22	09:00	17-Feb-22	17:00	

117	RQ80902	OCC_ 191	sldcps_sd	TRANS MISSIO N LINE	220 KV MOGA(PG)- MEHAL- KALAN(PS) (PSTCL) CKT-2	D	Tree cutting and Jumper tightening TN 1 to 20	15/Feb/2022	09:00	15/Feb/2022	17:00	PLA	ANNED	Approved	15-Feb-22	09:00	15-Feb-22	17:00	
118	RQ80899	OCC_ 191	sldcps_sd	TRANS MISSIO N LINE	220 KV MOGA(PG)- MEHAL- KALAN(PS) (PSTCL) CKT-1		Tree cutting and Jumper tightening TN 40 to 60	14/Feb/2022	09:00	14/Feb/2022	17:00	PLA	ANNED	Approved	14-Feb-22	09:00	14-Feb-22	17:00	
119	RQ80842	OCC_ 191	sldcps_sd		407 MAIN BAY - 400KV NAKODAR(PS G)- MAKHU(PS) (PS) CKT-1 AT NAKODAR(PS G)		Nut bolt tighteneing of clamp and connectors of 405 bay CB, CT and cleaning of male and female copper contact of isolators. Cleaning and terminal tighteneing of C&R panel	14/Feb/2022	09:00	14/Feb/2022	17:00	PLA	ANNED	Approved	14-Feb-22	09:00	14-Feb-22	17:00	
120	RQ80900	OCC_ 191	sldcps_sd	MISSIO N LINE	400 KV AMRITSAR(P G)- MAKHU(PS) (PSTCL) CKT-1		For Jumper Tightening and Tree Cutting from Tower No. 135-154	14/Feb/2022	09:00	14/Feb/2022	17:00	PLA	ANNED	Approved	14-Feb-22	09:00	14-Feb-22	17:00	
121	RQ80895	OCC_ 191	sldcps_sd	MISSIO N LINE	220 KV MOGA(PG)- MEHAL- KALAN(PS) (PSTCL) CKT-1	D	Tree cutting and Jumper tightening TN 20 to 40	12/Feb/2022	09:00	12/Feb/2022	17:00	PLA	ANNED	Approved	12-Feb-22	09:00	12-Feb-22	17:00	
122	RQ80892	OCC_ 191	sldcps_sd	TRANS MISSIO N LINE	220 KV MOGA(PG)- MEHAL- KALAN(PS) (PSTCL) CKT-1		Tree cutting and Jumper tightening TN 1 to 20	11/Feb/2022	09:00	11/Feb/2022	17:00	PLA	ANNED	Approved	11-Feb-22	09:00	11-Feb-22	17:00	
123	RQ80893	OCC_ 191	sldcps_sd	MISSIO N LINE	400 KV AMRITSAR(P G)- MAKHU(PS) (PSTCL) CKT-1		For Jumper Tightening and Tree Cutting from Tower No. 155- 175	11/Feb/2022	09:00	11/Feb/2022	17:00	PLA	ANNED	Approved	11-Feb-22	09:00	11-Feb-22	17:00	

124	RQ80841	OCC_ 191	sldcps_sd	ВАҮ	415 MAIN BAY - 80 MVAR BUS REACTOR NO 1 AT 400KV MAKHU(PS)	D	Cleaning and Recording of IR Values of Bay 415 CT's and CBcleaning of CTR Panel and Terminal tightening of Reactor MB, checking of HVWSS	10/Feb/2022	09:00	10/Feb/2022	17:00	PLANNED	Approved	10-Feb-22	09:00	10-Feb-22	17:00	
125	RQ80889	OCC_ 191	sldcps_sd	MISSIO N LINE	400 KV AMRITSAR(P G)- MAKHU(PS) (PSTCL) CKT-2	D	For Jumper Tightening and Tree Cutting from Tower No. 135-154	09/Feb/2022	09:00	09/Feb/2022	17:00	PLANNED	Approved	09-Feb-22	09:00	09-Feb-22	17:00	
126	RQ80840	OCC_ 191	sldcps_sd	ВАУ	421 MAIN BAY MAIN BAY - 400/220 KV 500 MVA ICT 3 AT MAKHU(PS) (PSTCL)	D	Nut bolt tightening and cleaning of Bay 420 CT,CB,isolators and CB and cleaning of BMK and C&R Panel and the terminal tightening of CT JB and CB MB	08/Feb/2022	09:00	08/Feb/2022	17:00	PLANNED	Approved	08-Feb-22	09:00	08-Feb-22	17:00	
127	RQ80888	OCC_ 191	sldcps_sd	MISSIO	220 KV JAGRAON(PS)- LUDHIANA(P G) (PSTCL) CKT-1	D	Tree cutting and Jumper tightening TN 60 to 80	08/Feb/2022	09:00	08/Feb/2022	17:00	PLANNED	Approved	08-Feb-22	09:00	08-Feb-22	17:00	
	RQ80885	191	· -	MISSIO	G) (PSTCL) CKT-1	D	Tree cutting and Jumper tightening TN 30 to 60	07/Feb/2022		07/Feb/2022		PLANNED	Approved	07-Feb-22	09:00	07-Feb-22	17:00	
129	RQ80886	OCC_ 191	sldcps_sd	MISSIO N LINE	400 KV AMRITSAR(P G)- MAKHU(PS) (PSTCL) CKT-2	D	For Jumper Tightening and Tree Cutting from Tower No. 155- 175	07/Feb/2022	09:00	07/Feb/2022	17:00	PLANNED	Approved	07-Feb-22	09:00	07-Feb-22	17:00	

130	RQ80881	OCC_ 191	sldcps_sd	MISSIO N LINE	220 KV MOGA(PG)- BADNI KALAN(PS) (PSTCL) CKT-1	D	For Jumper Tightening and Tree Cutting from Tower No. 01 to25	05/Feb/2022	09:00	05/Feb/2022	17:00	PLANNED	Approved	05-Feb-22	09:00	05-Feb-22	17:00	
131	RQ80879	OCC_ 191	sldcps_sd	MISSIO	220 KV JAGRAON(PS)- LUDHIANA(P G) (PSTCL) CKT-1	D	Tree cutting and Jumper tightening TN 10 to 30	04/Feb/2022	09:00	04/Feb/2022	17:00	PLANNED	Approved	04-Feb-22	09:00	04-Feb-22	17:00	
132	RQ80876	OCC_ 191	sldcps_sd	MISSIO N LINE CIRCUIT	220 KV LUDHIANA(P G)- SAHNEWAL(P S) (PSTCL) CKT-1	D	Tree cutting and Jumper tightening TN 270 to 290	03/Feb/2022	09:00	03/Feb/2022	17:00	PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	17:00	
133	RQ80838	OCC_ 191	sldcps_sd	BAY	412 MAIN BAY - 400/220KV 315 MVA ICT 2 AT MAKHU(PS)	D	Nut bolt tightening and cleaning of Bay 213(IV Side) LA,CT, Isolators and CB and cleaning of BMK and C&R Panel and the terminal tightening of CT JB and CB MB	03/Feb/2022	09:00	03/Feb/2022	17:00	PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	17:00	
134	RQ80874	OCC_ 191	sldcps_sd	MISSIO N LINE CIRCUIT	SAHNEWAL(P S) (PSTCL) CKT-1	D	Tree cutting and Jumper tightening TN 250 to 270	02/Feb/2022	09:00	02/Feb/2022	17:00	PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	17:00	
	RQ80868	191		TRANS MISSIO N LINE CIRCUIT	SAHNEWAL(P S) (PSTCL) CKT-1	D	Tree cutting and Jumper tightening TN 290/1 to 290/15	01/Feb/2022		01/Feb/2022		PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	17:00	
136	RQ80835	OCC_ 191	sldcps_sd		409 MAIN BAY - 400/220KV 315 MVA ICT 1 AT MAKHU(PS)	D	Cleaning and Recording of IR Values of Bay 214(IV Side) CT's and CB, cleaning of CTR Panel and Terminal tightening of ICT-1 MB	01/Feb/2022	09:00	01/Feb/2022	17:00	PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	17:00	

137	RQ81093	OCC_ 191	cpcc3_sd	HVDC LINE CIRCUIT	500 KV HVDC RIHAND- DADRI (PG) CKT-2		С	Transmission Line Diversion work due to construction of New Railway Line by JVNL	16/Feb/2022	08:00	20/Feb/2022	18:00		PLANNED	Rejected					deferred to next occ. To be clubbed with unit outage
138	RQ81092	OCC_ 191	cpcc3_sd	HVDC LINE CIRCUIT	500 KV HVDC RIHAND- DADRI (PG) CKT-1		С	Transmission Line Diversion work due to construction of New Railway Line by JVNL	16/Feb/2022	08:00	20/Feb/2022	18:00		PLANNED	Rejected					deferred to next occ. To be clubbed with unit outage
139	RQ80741	OCC_ 191	cpcc1_sd	HVDC LINE CIRCUIT	500 KV HVDC BALIA- BHIWADI (PG) CKT-2		С	For diversion work of line due to infringement in construction of Delhi-Vadodara Expressway (NH148N)	07/Feb/2022	08:00	20/Feb/2022	18:00	Shutdown requested by M/s NHAI	PLANNED	Approved	07-Feb-22	08:00	20-Feb-22	18:00	All satutory approval (El clearence, PTC approval etc) shall be provided before the charging of line. Shall not clash with Riahnd Dadri SD
140	RQ80740	OCC_ 191	cpcc1_sd	HVDC LINE CIRCUIT	500 KV HVDC BALIA- BHIWADI (PG) CKT-1		С	For diversion work of line due to infringement in construction of Delhi-Vadodara Expressway (NH148N)	07/Feb/2022	08:00	20/Feb/2022	18:00	Shutdown requested by M/s NHAI	PLANNED	Approved	07-Feb-22	08:00	20-Feb-22	18:00	All satutory approval (El clearence, PTC approval etc) shall be provided before the charging of line. Shall not clash with Riahnd Dadri SD
141	RQ80695	OCC_ 191	cpcc1_sd	HVDC LINE CIRCUIT	500 KV HVDC BALIA- BHIWADI (PG) CKT-1		D	Reverse Powerflow Testing	01/Feb/2022	08:00	08/Feb/2022	18:00	S/D may be availed from 24.01.22 to 31.01.22	PLANNED	Approved	01-Feb-22	08:00	08-Feb-22	18:00	Testing schedule to be shared with NRLDC/NLDC well in advance.
142	RQ80696	OCC_ 191	cpcc1_sd	HVDC LINE CIRCUIT	500 KV HVDC BALIA- BHIWADI (PG) CKT-2		D	Reverse Powerflow Testing	01/Feb/2022	08:00	08/Feb/2022	18:00	S/D may be availed from 24.01.22 to 31.01.22	PLANNED	Approved	01-Feb-22	08:00	08-Feb-22	18:00	Testing schedule to be shared with NRLDC/NLDC well in advance.
143	RQ80638	OCC_ 191	stuup_sd	AC TRANS MISSIO N LINE CIRCUIT	765 KV AGRA FATEHBAD(U P)- LALITPUR(LP G) (UP) CKT-1	UPPTCL	D	Routine Maintenence of line like jumper nut bolt tightenng and other work. Testing of associated Line reactor and relays at Fatehabad end	26/Feb/2022	08:00	28/Feb/2022	17:00		PLANNED	Approved					may be clubbed with unit outage

144	RQ80639	OCC_ 191	stuup_sd	MISSIO N LINE	765 KV AGRA FATEHBAD(U P)- LALITPUR(LP G) (UP) CKT-2	UPPTCL	D	OPGW stringing work between Tower No- 731- 733.	24/Feb/2022	08:00	25/Feb/2022	18:00		PLANNED	Approved					may be clubbed with unit outage
145	RQ80646	OCC_ 191	stuup_sd	MISSIO N LINE		UPPTCL	D	For annual maintenance and testing work for transmission line, line reactor and line bay equipment	08/Feb/2022	09:00	08/Feb/2022	18:00		PLANNED	Approved	08-Feb-22	09:00	08-Feb-22	18:00	
146	RQ80647	OCC_ 191	stuup_sd	AC TRANS MISSIO N LINE CIRCUIT	765 KV BARA- MAINPURI (UP) CKT-2	UPPTCL	С	Circuit Breaker maintenence , testing	07/Feb/2022	09:00	10/Feb/2022	18:00	It is conditionaly apporved in OCC 190, But not given so again applied with concern of SLDC.	PLANNED	Approved	01-Feb-22	09:00	04-Feb-22	18:00	Subjected to unit outage at Bara
147	RQ81055	OCC_ 191	cpcc3_sd	MISSIO	765 KV VARANASI- KANPUR_GIS (PG) CKT-1	POWER GRID	D	For connection of OPGW from TN 395 of 765KV Kanpur Varanasi #1 to TN 90 of 132KV Sangipur Kuna Line for repeater station	22/Feb/2022	09:00	22/Feb/2022	16:00		PLANNED	Approved	22-Feb-22	09:00	22-Feb-22	16:00	
148	RQ80694	191	· –		765 KV BHADLA- BIKANER (PG) CKT-2	POWER GRID	D	For Installation of Bird Diverters	22/Feb/2022	08:00	25/Feb/2022	18:00	Other Ckt will be in non-auto	PLANNED	Approved	22-Feb-22	14:00	25-Feb-22	23:00	
		191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	CKT-1	POWER GRID	D	For Installation of Bird Diverters	16/Feb/2022		19/Feb/2022	18:00	Other Ckt will be in non-auto	PLANNED	Approved	16-Feb-22	14:00	19-Feb-22	23:00	
150	RQ80688	OCC_ 191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	765 KV JHATIKARA- ALIGARH (PG) CKT-1	POWER GRID	С	For diversion work of line due to infringement in construction of Delhi-Vadodara Expressway (NH148N)	15/Feb/2022	08:00	01/Mar/2022	18:00	Shutdown requested by M/s NHAI	PLANNED	Rejected					deferred to next occ.

151	RQ80690	OCC_ 191	cpcc1_sd		765 KV MOGA- BHIWANI (PG) CKT-1	POWER GRID	С	For diversion work of line infringement with Northern Railway	14/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	14-Feb-22	08:00	28-Feb-22	18:00	All satutory approval (El clearence, PTC approval etc) shall be provided before the charging of line. Dates shall not clash with bikaner-moga
152	RQ80682	OCC_ 191	cpcc1_sd	TRANS MISSIO	765 KV AJMER(PG)- PHAGI(RS) (PG) CKT-2	POWER GRID	С	For Restoration of Reactor Bushing connection , kit unloading	14/Feb/2022	08:00	14/Feb/2022	18:00		PLANNED	Approved	12-Feb-22	08:00	16-Feb-22	18:00	Powergrid intimated that s/d required for impulse test of GIS
153	RQ81080	OCC_ 191	cpcc3_sd		765 KV BALIA- LUCKNOW_2 (PG) CKT-1		С	Transmission Line Diversion work due to construction of Gorakhpur Link Expressway by UPEIDA	12/Feb/2022	08:00	16/Feb/2022	18:00		PLANNED	Approved	12-Feb-22	08:00	16-Feb-22	18:00	All satutory approval (EI clearence, PTC approval etc) shall be provided before the charging of line.
154	RQ80681	OCC_ 191	cpcc1_sd	MISSIO	765 KV AJMER(PG)- PHAGI(RS) (PG) CKT-2	POWER GRID	D	For Dismantling of Kit and Restoration of BUS connection	11/Feb/2022	08:00	11/Feb/2022	18:00		PLANNED	Rejected					
155	RQ80680	OCC_ 191	cpcc1_sd	TRANS MISSIO	765 KV AJMER(PG)- PHAGI(RS) (PG) CKT-2	POWER GRID	D	For Jumper Removing of BR-2 and Switch Impulse Test	10/Feb/2022	08:00	10/Feb/2022	18:00		PLANNED	Rejected					
156	RQ80677	OCC_ 191	cpcc1_sd	TRANS MISSIO	765 KV PHAGI(RS)- BHIWANI(PG) (PG) CKT-2	POWER GRID	D	Diamond Crossing with under construction line 400 kV D/C Mohindergarh- Bhiwani TL Location no. 25-I, 25-IA, 25-II,25-IIA	10/Feb/2022	08:00	10/Feb/2022	18:00	Constructio n of 400 kV D/C Mahendrag arh-Bhiwani TL	PLANNED	Approved	10-Feb-22	08:00	10-Feb-22	18:00	All satutory approval (EI clearence, PTC approval etc.) shall be provided before the charging of line. If there is then 200- 250 MW curtailment.

157	RQ80739	OCC_ 191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	765 KV KOTESHWAR- MEERUT (PG) CKT-2	POWER GRID	D	Annual maintenance work eg.Tightening of loose condutor VD, Corona ring, arcing horn, jumper, string Hook ,BPI installation work etc	08/Feb/2022	09:00	08/Feb/2022	18:00		PLANNED	Approved	08-Feb-22	09:00	08-Feb-22	18:00	
158	RQ80679	OCC_ 191	cpcc1_sd		765 KV AJMER(PG)- PHAGI(RS) (PG) CKT-2	POWER GRID	D	Kit set up and connection Through SF6 Bushings	08/Feb/2022	08:00	08/Feb/2022	18:00	Earthing Required Both End	PLANNED	Rejected					
159	RQ80676	OCC_ 191	cpcc1_sd	MISSIO	(PG) CKT-1	POWER GRID	D	Diamond Crossing with under construction line 400 kV D/C Mohindergarh- Bhiwani TL Location no. 22-I, 22-IA, 22-II,22-IIA	07/Feb/2022	08:00	07/Feb/2022	18:00	Constructio n of 400 kV D/C Mahendrag arh-Bhiwani TL	PLANNED	Approved	07-Feb-22	08:00	07-Feb-22		All satutory approval (El clearence, PTC approval etc) shall be provided before the charging of line.If there is then 200-250 MW curtailment.
160	RQ80678	OCC_ 191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	765 KV AJMER(PG)- PHAGI(RS) (PG) CKT-2	POWER GRID	D	Kit unloading (Switching Impulse Test of GIS)	07/Feb/2022	08:00	07/Feb/2022	18:00	Earthing Required Both End	PLANNED	Rejected					
161	RQ80683	OCC_ 191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	CKT-2	POWER GRID	С	RELOCATION OF R- PH BUSHING AT TERRACE-6 DUE TO SETTLEMENT OF FOUNDATION at Kot.S/s	07/Feb/2022	08:00	14/Feb/2022	18:00	GIB relocation work at Terrace-6	PLANNED	Approved	07-Feb-22	08:00	14-Feb-22	18:00	
162	RQ80687	OCC_ 191	cpcc1_sd	MISSIO	(PG) CKT-2	POWER GRID	D	For Relay Testing and line/bay maintenance work.	03/Feb/2022	08:00	04/Feb/2022	18:00	along with Line reactor.Ckt- 1 will be in non auto mode.	PLANNED	Approved	03-Feb-22	15:00	04-Feb-22	23:00	
163	RQ81053	OCC_ 191	cpcc3_sd	AC TRANS MISSIO N LINE CIRCUIT	(PG) CKT-1	POWER GRID	D	A/R into non auto mode for Live Line OPGW Work	01/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	

164	RQ80689	OCC_ 191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	1	POWER GRID	С	For diversion work of line infringement in construction of Delhi-Vadodara Expressway (NH148N)	01/Feb/2022	08:00	15/Feb/2022	18:00	Shutdown requested by M/s NHAI.S/D may be availed from 21.01.22 to 04.02.2022	PLANNED	Approved	01-Feb-22	08:00	15-Feb-22	18:00	All satutory approval (El clearence, PTC approval etc) shall be provided before the charging of line.
165	RQ80686	OCC_ 191	cpcc1_sd	MISSIO	765 KV AJMER- BHADLA_2 (PG) CKT-1	POWER GRID	D	For Relay Testing and line/bay maintenance work.	01/Feb/2022	08:00	02/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	15:00	02-Feb-22	23:00	
166	RQ81052	OCC_ 191	cpcc3_sd		765 KV ORAI- ALIGARH (PG) CKT-1		D	A/R into non auto mode for Live Line OPGW Work	01/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	
167	RQ80807	OCC_ 191	sldcrs_sd	AC TRANS MISSIO N LINE CIRCUIT	765 KV ANTA- PHAGI (RS) CKT-2	RRVPN L	D	Maitenance of line bay equipments i.e. CVT, WT, LA & line Isolator & Maintenance of Reactors & taking R-Phase in ckt. Inplace of Spare rector and 3x80MVAr Reactor Bank of line at Phagi end	09/Feb/2022	08:00	09/Feb/2022	18:00		PLANNED	Approved	09-Feb-22	08:00	09-Feb-22	18:00	SPS at Chhabra complex to be in healthy condition and to be in service.
168	RQ80685	OCC_ 191	cpcc1_sd	MISSIO N LINE	765 KV BHADLA_2 (PG)- FATEHGARH_ II(PG) (PFTL) CKT-2	PFTL	D	For Punch points(Line maintenance work).	05/Feb/2022	17:00	05/Feb/2022	23:00	along with Line reactor.Ckt- 1 will be in non auto mode.	PLANNED	Approved	05-Feb-22	17:00	05-Feb-22	23:00	
		191	cpcc1_sd	MISSIO N LINE	765 KV BHADLA_2 (PG)- FATEHGARH_ II(PG) (PFTL) CKT-1	PFTL	D	For CSD Fine tune and punch point attending(line maintenance work)	02/Feb/2022		02/Feb/2022		along with Line reactor.Ckt- 2 will be in non auto mode.	PLANNED	Approved	02-Feb-22	17:00	02-Feb-22	23:00	
170	RQ80720	OCC_ 191	cpcc1_sd	BUS	765 KV FATEHGARH_ II(PG) - BUS 1	POWER GRID	D	For Punch points(maintenance work).	22/Feb/2022	17:00	22/Feb/2022	23:00		PLANNED	Approved	22-Feb-22	17:00	22-Feb-22	23:00	

171	RQ80721	OCC_ 191	cpcc1_sd	BUS	765 KV FATEHGARH_ II(PG) - BUS 2	POWER GRID		For Punch points(maintenance work).	12/Feb/2022	17:00	12/Feb/2022	23:00		PLANNED	Approved	12-Feb-22	17:00	12-Feb-22	23:00	
172	RQ81023	OCC_ 191	cpcc3_sd	BUS	765KV BUS 1 AT ORAI(PG)		D	AMP Works	08/Feb/2022	10:00	08/Feb/2022	18:00		PLANNED	Approved	08-Feb-22	10:00	08-Feb-22	18:00	
173	RQ80707	OCC_ 191	cpcc1_sd	BUS	765 KV BIKANER(PG) - BUS 2	POWER GRID	D	FOR AMP WORK	07/Feb/2022	10:00	07/Feb/2022			PLANNED	Approved	07-Feb-22	15:00	07-Feb-22	23:00	
	RQ80706	191		BUS	765 KV BIKANER(PG) - BUS 1		D	FOR AMP WORK	06/Feb/2022		06/Feb/2022			PLANNED	Approved	06-Feb-22	15:00	06-Feb-22	23:00	
175	RQ80708	OCC_ 191	cpcc1_sd	BUS	765KV BUS 1 AT BHIWANI(PG)	GRID	D	For Future Bay Isolator Alignment of Bay 704	03/Feb/2022	08:00	03/Feb/2022	18:00		PLANNED	Approved	03-Feb-22	08:00	03-Feb-22	18:00	
	RQ80583	191		BUS	765KV BUS 2 AT UNNAO(UP)		D	CRM Testing of 765kV Bus Isolators associated with 765kV Main Bus-2	14/Feb/2022		14/Feb/2022		DURING SHUT DOWN 1000MVA ICT I,II,III & 63MVAR BUS REACTOR WIIL BE FED THROUGH BUS-I	PLANNED	Approved	14-Feb-22	09:00	14-Feb-22	18:00	
177	RQ80582	OCC_ 191	stuup_sd	BUS	765KV BUS 1 AT UNNAO(UP)	UPPTCL	D	CRM Testing of 765kV Bus Isolators associated with 765kV Main Bus-1	12/Feb/2022	09:00	12/Feb/2022	18:00	DURING SHUT DOWN 1000MVA ICT I,II,III & 63MVAR BUS REACTOR WIIL BE FED THROUGH BUS-II .	PLANNED	Approved	12-Feb-22	09:00	12-Feb-22	18:00	

17	78 R	Q80649	OCC_ 191	stuup_sd	BUS	765KV BUS 1 AT MAINPURI(U P)	UPPTCL	D	Safety porpuse, it is very near to Line Breaker	07/Feb/2022	09:30	08/Feb/2022	17:30	It is conditionally apporved in OCC 190, But not given so again applied with concern of SLDC.	PLANNED	Approved	07-Feb-22	09:30	08-Feb-22	17:30	
			191	cpcc1_sd	BUS	765KV BUS 1 AT PHAGI(RS)			FOR RESTORATION OF REACTOR BUSHING CONNECTION AND KIT UNLOADING			14/Feb/2022		FOR RESTORATI ON OF REACTOR BUSHING CONNECTIO N AND KIT UNLOADING		Approved	12-Feb-22	08:00	12-Feb-22		Bypass arrangement to be done at Anta. Generation at Chabra Kawai Complex to be restrcted to 3500 MW. Subject to rajasthan consent
18	80 R	Q80712	OCC_ 191	cpcc1_sd	BUS	765KV BUS 2 AT PHAGI(RS)			FOR RESTORATION OF BUS CONNECTION	11/Feb/2022	08:00	11/Feb/2022	18:00	SWITCH IMPLUSE KIT SET UP AND CONNECTIO N THROUGH SF6 BUSHING		Approved	11-Feb-22	08:00	11-Feb-22		Bypass arrangement to be done at Anta. Generation at Chabra Kawai Complex to be restrcted to 3500 MW. Subject to rajasthan consent
18	81 R	Q80709	OCC_ 191	cpcc1_sd	1	765KV BUS 1 AT PHAGI(RS)			765 KV MAIN BUS- A S/D IS ALSO REQUIRED FOR 5 HOURS TO DISCOONECT MAIN BUS-A FROM REACTOR	10/Feb/2022	10:00	10/Feb/2022	14:00	BUS-A AT PHAGI(RRVP NL).	PLANNED	Approved	16-Feb-22	10:00	16-Feb-22		Bypass arrangement to be done at Anta. Generation at Chabra Kawai Complex to be restrcted to 3500 MW. Subject to rajasthan consent
18	82 R	Q80710	OCC_ 191	cpcc1_sd	BUS	765KV BUS 2 AT PHAGI(RS)			SWITCH IMPLUSE KIT SET UP AND CONNECTION THROUGH SF6 BUSHING	08/Feb/2022	08:00	08/Feb/2022	18:00	BUS-B AT PHAGI(RRVP NL).	PLANNED	Approved	17-Feb-22	08:00	17-Feb-22		Bypass arrangement to be done at Anta. Generation at Chabra Kawai Complex to be restrcted to 3500 MW. Subject to rajasthan consent

183	RQ80804	OCC_ 191	sldcrs_sd	BUS	765KV BUS 2 AT PHAGI(RS)		D	For Testing Bus Bar Stability (For commissioning work of New ICT-III of 765/400kV, 3*500 MVA)	03/Feb/2022	08:00	03/Feb/2022	18:00		PLANNED	Approved	03-Feb-22	08:00	03-Feb-22	18:00	Bypass arrangement to be done at Anta. Generation at Chabra Kawai Complex to be restrcted to 3500 MW.
184	RQ80803	OCC_ 191	sldcrs_sd	BUS	765KV BUS 1 AT PHAGI(RS)		D	For Testing Bus Bar Stability (For commissioning work of New ICT-III of 765/400kV, 3*500 MVA)	01/Feb/2022	08:00	01/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	01-Feb-22	18:00	Bypass arrangement to be done at Anta. Generation at Chabra Kawai Complex to be restreted to 3500 MW.
185	RQ80568	OCC_ 191	stuup_sd		189 MVAR BUS REACTOR NO 1 AT 765 KV ANPARA_D(U P)	UPPTCL	С	Testing of Bus Reactor CT and LA, Bay CT and Circuit Breaker (Main Bay- 706 and Tie bay- 705)	24/Feb/2022	10:00	25/Feb/2022	18:00	Annual Testing of Bus Reactor and Bay Equipments	PLANNED	Approved	24-Feb-22	10:00	25-Feb-22	18:00	
186	RQ80658	OCC_ 191	stuup_sd		189 MVAR BUS REACTOR NO 1 AT 765KV UNNAO(UP)	UPPTCL	D	Testing of 765kV equipments like CBs,CTs,Isolators etc.	10/Feb/2022	09:00	11/Feb/2022	18:00		PLANNED	Rejected					deferred to next occ.
187	RQ80714	OCC_ 191	cpcc1_sd	/MSC/ MSR	240 MVAR BUS REACTOR NO 1 AT 765KV CHITTORGAR H(PG)	POWER GRID	С	FOR AMP WORK	17/Feb/2022	09:00	17/Feb/2022	17:00		PLANNED	Rejected					deferred to next occ.
188	RQ80717	OCC_ 191	cpcc1_sd		240 MVAR BUS REACTOR NO 2 AT 765 KV PHAGI(RS)	POWER GRID	D	SWITCHING IMPLUSE TEST	14/Feb/2022	09:00	14/Feb/2022	18:00		PLANNED	Approved	14-Feb-22	09:00	14-Feb-22	12:00	
189	RQ80718	OCC_ 191	cpcc1_sd		240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_ II(PG)	POWER GRID	D	For Punch points(maintenanc e work).	12/Feb/2022	17:00	12/Feb/2022	23:00		PLANNED	Rejected					deferred to next occ.

190	RQ80716	OCC_ 191	cpcc1_sd		240 MVAR BUS REACTOR NO 2 AT 765 KV PHAGI(RS)	POWER GRID	D	SWITCHING IMPLUSE TEST	10/Feb/2022	09:00	10/Feb/2022	18:00	765 KV MAIN BUS-A S/D IS ALSO REQUIRED FOR 5 HOURS TO DISCOONEC T MAIN BUS-A FROM REACTOR		Approved	17-Feb-22	09:00	17-Feb-22	12:00	
	RQ80719	191		/MSC/ MSR	BUS REACTOR NO 1 AT 765 KV FATEHGARH_ II(PG)		D	For Punch points(maintenanc e work).	08/Feb/2022		08/Feb/2022			PLANNED	Rejected					deferred to next occ.
192	RQ80715	OCC_ 191	cpcc1_sd		240 MVAR BUS REACTOR NO 2 AT 765KV BHIWANI(PG)	POWER GRID	D	For taking Spare Bus Reactor in service	05/Feb/2022	09:00	05/Feb/2022	15:00		PLANNED	Rejected					deferred to next occ.
193	RQ80713	OCC_ 191	cpcc1_sd	/MSC/	240 MVAR BUS REACTOR NO 1 AT 765 KV KHETRI (PKTSL)	PKTSL	D	FOR TAKING R- PHASE UNIT IN SERVICE IN PLACE OF SPARE UNIT	15/Feb/2022	08:00	15/Feb/2022	18:00		PLANNED	Rejected					deferred to next occ.
194	RQ80728	OCC_ 191	cpcc1_sd	REACTO R	NON- SWITCHABLE LR ON AGRA- JHATIKARA (PG) CKT-1 @JHATIKARA(PG)	POWER GRID	D	AGRA LR CB BREAKER RECTIFICATION	26/Feb/2022	09:00	26/Feb/2022	18:00		PLANNED	Approved					To be clubbed with sl. 164
195	RQ80723	OCC_ 191	cpcc1_sd		240 MVAR SWITCHABLE LR ON 765 KV BHADLA- BIKANER (PG) CKT-1 @BIKANER(P G)	POWER GRID	D	SPARE LINE REACTOR SWITCHING	09/Feb/2022	10:00	09/Feb/2022	17:00		PLANNED	Approved					To be clubbed with sl. 149

196	RQ80722	OCC_ 191	cpcc1_sd	REACTO R	330 MVAR SWITCHABLE LR ON 765 KV BIKANER- MOGA (PG) CKT-2 @BIKANER(P G)	POWER GRID		SPARE LINE REACTOR SWITCHING	08/Feb/2022	10:00	08/Feb/2022	17:00		PLANNED	Approved					May be availed with Line SD works.
	RQ80726	191		REACTO R	NON- SWITCHABLE LR ON JHATIKARA- ALIGARH (PG) CKT-1 @JHATIKARA(PG)	POWER GRID		ALIGARH LR CB BREAKER RECTIFICATION	03/Feb/2022		04/Feb/2022			PLANNED	Rejected					To be clubbed with sl 150
198	RQ80724	OCC_ 191	cpcc1_sd	REACTO R	240 MVAR SWITCHABLE LR ON 765 KV AJMER- BHADLA_2 (PG) CKT-2 @AJMER(PG)	POWER GRID		For Relay Testing and AMP Work	03/Feb/2022	08:00	04/Feb/2022	18:00	along with line	PLANNED	Rejected					to be clubbed with line outage
199	RQ80725	OCC_ 191	cpcc1_sd	REACTO R	240 MVAR SWITCHABLE LR ON 765 KV AJMER- BHADLA_2 (PG) CKT-1 @AJMER(PG)	POWER GRID		For Relay Testing and AMP Work	01/Feb/2022	08:00	02/Feb/2022	18:00	along with line	PLANNED	Rejected					to be clubbed with line outage
200	RQ80727	OCC_ 191	cpcc1_sd	REACTO R	240 MVAR SWITCHABLE LR ON 765 KV KHETRI (PKTSL)- JHATIKARA(P G) (PKTSL) CKT-1 @JHATIKARA(PG)	PKTSL	D	For CSD TUNING	09/Feb/2022	09:00	09/Feb/2022	18:00		PLANNED	Approved	09-Feb-22	09:00	09-Feb-22	18:00	

201	RQ80648	OCC_ 191	stuup_sd	REACTO R	UPPTCL		Reactor Leakage attend, Overhauling, testing works	07/Feb/2022	09:00	10/Feb/2022	18:00	It is conditionally apporved in OCC 190, But not given so again applied with concern of SLDC.	PLANNED	Approved	07-Feb-22	09:00	10-Feb-22		line outage already Approved. To be clubbed with same.
202	RQ81037	OCC_ 191	cpcc3_sd		POWER GRID	D	AMP Works	28/Feb/2022	10:00	28/Feb/2022	18:00		PLANNED	Approved	28-Feb-22	10:00	28-Feb-22	18:00	
203	RQ80812	OCC_ 191	sldcrs_sd		POWER GRID		1.Measurement of tan-delta of CTs 2. Maintenance of CB & CTs. 3. Tightening of clamps & connectors.	23/Feb/2022	08:00	23/Feb/2022	18:00		PLANNED	Approved	23-Feb-22	08:00	23-Feb-22	18:00	
204	RQ81122	OCC_ 191	cpcc3_sd		POWER GRID	D	AMP Works	16/Feb/2022	10:00	16/Feb/2022	18:00		PLANNED	Approved	16-Feb-22	10:00	16-Feb-22	18:00	

205	RQ81121	OCC_ 191	cpcc3_sd			POWER GRID	D	AMP Works	15/Feb/2022	10:00	15/Feb/2022	18:00	PI	PLANNED	Approved	15-Feb-22	10:00	15-Feb-22	18:00	
	RQ81036	191			BAY - 330 MVAR BUS REACTOR NO 1 AT 765KV FATEHPUR(P G)	POWER GRID		AMP Works	15/Feb/2022		15/Feb/2022			PLANNED	Approved	15-Feb-22	10:00	15-Feb-22	18:00	
207	RQ80733	OCC_ 191	cpcc1_sd		704 MAIN BAY - 765 KV CHITTORGAR H- BANASKANTH A (PG) CKT-2 AT CHITTORGAR H(PG)	POWER GRID	D	FOR AMP WORK	14/Feb/2022	08:00	16/Feb/2022	18:00	Pi	PLANNED	Approved	14-Feb-22	08:00	16-Feb-22	18:00	
208	RQ80737	OCC_ 191	cpcc1_sd	ВАУ	711 TIE BAY -	POWER GRID	D	FOR AMP WORK	10/Feb/2022	08:00	10/Feb/2022	18:00	PI	PLANNED	Approved	10-Feb-22	08:00	10-Feb-22	18:00	

209	RQ80732	OCC_ 191	cpcc1_sd	ВАУ	707 MAIN BAY - 765 KV CHITTORGAR H- BANASKANTH A (PG) CKT-1 AT CHITTORGAR H(PG)		D	FOR AMP WORK	10/Feb/2022	08:00	12/Feb/2022	18:00	PLANNED	Approved	10-Feb-22	08:00	12-Feb-22	18:00	
210	RQ81042	OCC_ 191	cpcc3_sd	ВАҮ	713 MAIN BAY - 765/400KV 1500 MVA ICT 2 AT VARANASI(PG	POWER GRID	D	AMP Works	09/Feb/2022	10:00	09/Feb/2022	18:00	PLANNED	Approved	09-Feb-22	10:00	09-Feb-22	18:00	
	RQ80736	191			765/400 KV 800 MVA ICT 3 AT KOTESHWAR(PG) (POWERGRID) AND FUTURE AT 765 KV KOTESHWAR(PG) (POWERGRID)			FOR AMP WORK	09/Feb/2022		09/Feb/2022		PLANNED	Approved	09-Feb-22	08:00	09-Feb-22	18:00	
212	RQ81106	OCC_ 191	cpcc3_sd	BAY	711 TIE BAY - 765 KV AGRA- FATEHPUR (PG) CKT-2 AND FUTURE AT AGRA(PG)		D	AMP Works	08/Feb/2022	10:00	08/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	10:00	08-Feb-22	18:00	
213	RQ81043	OCC_ 191	cpcc3_sd		712 MAIN BAY - 765/400KV 1500 MVA ICT 1 AT VARANASI(PG	POWER GRID	D	AMP Works	08/Feb/2022	10:00	08/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	10:00	08-Feb-22	18:00	

	149 OCC_ cpi		240 MVAR BUS REACTOR NO 2 AT 765KV BALIA(PG) AND 765KV BALIA- LUCKNOW_2 (PG) CKT-1	POWER GRID		AMP Works	07/Feb/2022		07/Feb/2022		PLANNED	Approved	07-Feb-22	10:00	07-Feb-22	18:00	
	021 OCC_ cpi		BAY - 765/400 KV 1500 MVA ICT 1 AT BAREILLY_2(P G) (POWERGRID)			AMP Works	07/Feb/2022		07/Feb/2022		PLANNED	Approved	07-Feb-22	10:00	07-Feb-22	18:00	
	.05 OCC_cpr		BAY - 765 KV AGRA- FATEHPUR (PG) CKT-2 AND 765KV BUS 1 AT AGRA(PG)			AMP Works	07/Feb/2022		07/Feb/2022		PLANNED	Approved	07-Feb-22	10:00	07-Feb-22	18:00	
	(31 OCC_ cpi		765 KV CHITTORGAR H- BANASKANTH A (PG) CKT-2 AND 765/400 KV 1500 MVA ICT 1 AT CHITTORGAR H(PG)			FOR AMP WORK	07/Feb/2022		09/Feb/2022		PLANNED	Approved	07-Feb-22	08:00	09-Feb-22	18:00	
218 RQ807	738 OCC_cpi	cc1_sd BAY	718 MAIN BAY - 765/400KV 1500 MVA ICT 4 AT JHATIKARA(P G)	POWER GRID	D	FOR AMP WORK	07/Feb/2022	08:00	08/Feb/2022	18:00	PLANNED	Approved	07-Feb-22	08:00	08-Feb-22	18:00	

219 RQ807	729 OCC_ 191	cpcc1_sd	ВАУ	712 MAIN BAY - 765 KV AJMER- CHITTORGAR H (PG) CKT-2 AND 765KV BUS 1 AT AJMER(PG)	POWER GRID	D	FOR AMP WORK	06/Feb/2022	08:00	06/Feb/2022	18:00		PLANNED	Approved	06-Feb-22	08:00	06-Feb-22	18:00	
220 RQ811	109 OCC_ 191	cpcc3_sd	ВАУ	707 MAIN		D	AMP Works	05/Feb/2022	10:00	05/Feb/2022	18:00		PLANNED	Approved	05-Feb-22	10:00	05-Feb-22	18:00	
221 RQ808	310 OCC_ 191	cpcc2_sd	ВАУ	701 MAIN BAY - 765 KV BIKANER- MOGA (PG) CKT-1 (POWERGRID) AT MOGA			AMP of bay equipments	03/Feb/2022		03/Feb/2022		Kindly approve	PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	17:30	
222 RQ807	191		BAY	800 MVA ICT 2 AT KOTESHWAR(PG) (POWERGRID) AND 765 KV KOTESHWAR- MEERUT (PG) CKT-2 AT 765 KV KOTESHWAR(PG) (POWERGRID)	GRID		FOR AMP WORK	03/Feb/2022		03/Feb/2022			PLANNED	Approved	03-Feb-22	08:00	03-Feb-22	18:00	
223 RQ808	OCC_ 191	cpcc2_sd	ВАҮ	701 MAIN BAY - 765 KV BIKANER- MOGA (PG) CKT-1 (POWERGRID) AT MOGA	POWER GRID		AMP of bay equipments	02/Feb/2022	09:00	02/Feb/2022		Kindly approve	PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	17:30	

224	RQ80730	OCC_ 191	cpcc1_sd	ВАУ	708 TIE BAY - 765 KV CHITTORGAR H- BANASKANTH A (PG) CKT-1 AND 765/400 KV 1500 MVA ICT 2 AT CHITTORGAR H(PG)	POWER GRID	D	FOR AMP WORK	02/Feb/2022	08:00	04/Feb/2022	18:00	PLANNED	Approved	02-Feb-22	08:00	04-Feb-22	18:00	
	RQ80734	191		BAY	702 TIE BAY- 765/400 KV 800 MVA ICT 1 AT KOTESHWAR(PG) (POWERGRID) AND 240 MVAR BUS REACTOR NO 1 AT 765 KV KOTESHWAR(PG) AT 765 KV KOTESHWAR(PG) (POWERGRID)	POWER GRID	D	FOR AMP WORK	02/Feb/2022		02/Feb/2022		PLANNED	Approved	02-Feb-22	08:00	02-Feb-22	18:00	
226	RQ80813	OCC_ 191	sldcrs_sd	ВАУ	70652T TIE BAY - 765KV PHAGI(RS)- GWALIOR(PG) (UNDEF) CKT-1 AND 765KV ANTA- PHAGI (RS) CKT-1 AT PHAGI(RS)	RRVPN L	D	Measurements of operation timings of CB. Measurement of Tan-delta of Current Transformers . Tightness of clamps & conenctors	25/Feb/2022	208:00	25/Feb/2022	18:00	PLANNED	Approved	25-Feb-22	08:00	25-Feb-22	18:00	

	RQ80817	191			711 TIE BAY - 765KV AGRA FATEHBAD(U P)- LALITPUR(LP G) (UP) CKT-1 AND 765KV/400KV AGRA FATEHBAD(U P)-ICT-1 AT AGRA FATEHBAD(U P)		issued one technical advisory on minor defect In 800 kV CB's and Guide Valve replacement is to be done as these Breaker are installed in 711Bay at 765 kV s/s UPPTCL Fatehabad Agra UP.	15/Feb/2022		18/Feb/2022			PLANNED	Approved	15-Feb-22	09:00	18-Feb-22	18:00	
228	RQ80643	OCC_ 191	stuup_sd	ВАУ	710 MAIN BAY - 765KV AGRA FATEHBAD(U P)- LALITPUR(LP G) (UP) CKT-1 AT AGRA FATEHBAD(U P)	UPPTCL	Ms SIEMES has issued one technical advisory on minor defect In 800 kV CB's and Guide Valve replacement is to be done as these Breaker are installed in 710Bay at 765 kV s/s UPPTCL Fatehabad Agra UP.	11/Feb/2022	09:00	14/Feb/2022	18:00		PLANNED	Approved	11-Feb-22	09:00	14-Feb-22	18:00	
229	RQ80653	OCC_ 191	stuup_sd		710 MAIN BAY - 765 KV GR.NOIDA_2(UPC)- MAINPURI (UP) CKT-1 AT MAINPURI(U P)	UPPTCL	Circuit Breaker maintenence , testing	07/Feb/2022	09:00	08/Feb/2022	18:00	It is conditionally apporved in OCC 190, But not given so again applied with concern of SLDC.		Approved	07-Feb-22	09:00	08-Feb-22	18:00	

230	RQ80816	OCC_ 191	stuup_sd	ВАУ	708 TIE BAY - 765KV AGRA FATEHBAD(U P)- LALITPUR(LP G) (UP) CKT-2 AND 765KV/400KV AGRA FATEHBAD(U	UPPTCL	С	Ms SIEMES has issued one technical advisory on minor defect In 800 kV CB's and Guide Valve replacement is to be done as these Breaker are installed in 708Bay	05/Feb/2022	09:00	08/Feb/2022	18:00	PLANNED	Approved	05-Feb-22	09:00	08-Feb-22	18:00	
					P)-ICT-2 AT AGRA FATEHBAD(U P)			at 765 kV s/s UPPTCL Fatehabad Agra UP.											
231	RQ80642	OCC_ 191	stuup_sd	ВАУ	707 MAIN BAY - 765KV AGRA FATEHBAD(U P)- LALITPUR(LP G) (UP) CKT-2 AT AGRA FATEHBAD(U P)	UPPTCL	С	Ms SIEMES has issued one technical advisory on minor defect In 800 kV CB's and Guide Valve replacement is to be done as these Breaker are installed in 707Bay at 765 kV s/s UPPTCL Fatehabad Agra UP.	01/Feb/2022	09:00	04/Feb/2022	18:00	PLANNED	Approved	01-Feb-22	09:00	04-Feb-22	18:00	
232	RQ80805	OCC_ 191	sldcrs_sd	ORMER	765/400 KV 1500 MVA ICT 2 AT PHAGI(RS)	RRVPN L	D	Testing and maintenance of Transforers. Tightening of clamps and connectors	17/Feb/2022		18/Feb/2022		PLANNED	Approved	17-Feb-22	08:00	18-Feb-22	18:00	Loading of other ICT to be managed Locally by rajasthan SLDC
233	RQ80806	OCC_ 191	sldcrs_sd		765/400 KV 1500 MVA ICT 1 AT ANTA(RS)	RRVPN L	D	IINd HALF YEARLY MAINTENANCE	03/Feb/2022	08:00	03/Feb/2022	18:00	PLANNED	Approved	03-Feb-22	08:00	03-Feb-22	18:00	
	RQ80703	191		ORMER	765/400 KV 1500 MVA ICT 3 AT FATEHGARH_ II(PG)	POWER GRID	D	For Punch points(maintenance work).	10/Feb/2022	17:00	10/Feb/2022		PLANNED	Approved	10-Feb-22	17:00	10-Feb-22	23:00	
235	RQ80698	OCC_ 191	cpcc1_sd		765/400 KV 1500 MVA ICT 2 AT BIKANER(PG)	POWER GRID	D	FOR AMP WORK	05/Feb/2022	10:00	05/Feb/2022	17:00	PLANNED	Approved	05-Feb-22	10:00	05-Feb-22	17:00	

236	RQ80704	OCC_ 191	cpcc1_sd	ORMER	765/400 KV 1500 MVA ICT 2 AT FATEHGARH_ II(PG)	POWER GRID	D	For Punch points(maintenance work).	04/Feb/2022	17:00	04/Feb/2022	23:00		PLANNED	Approved	04-Feb-22	17:00	04-Feb-22	23:00	
237	RQ80701	OCC_ 191	cpcc1_sd	ORMER	765/400 KV 1000 MVA ICT 3 AT BHIWANI(PG)	POWER GRID	D	For Fine Tunning of HV/IV CSD Relay	04/Feb/2022	10:00	04/Feb/2022	17:00		PLANNED	Approved	04-Feb-22	10:00	04-Feb-22	17:00	
238	RQ81069	OCC_ 191	cpcc3_sd		765/400 KV 1500 MVA ICT 1 AT KANPUR_GIS(PG)	POWER GRID	D	To facilitate S/D of 400KV side Auxiliary Bus of ICT for commissioning of 400KV ICT 3 (Future) GIS Bay.	04/Feb/2022	10:00	04/Feb/2022	18:00		PLANNED	Approved	04-Feb-22	10:00	04-Feb-22	18:00	
239	RQ80697	OCC_ 191	cpcc1_sd		765/400 KV 1500 MVA ICT 1 AT BIKANER(PG)	POWER GRID	D	FOR AMP WORK	04/Feb/2022	10:00	04/Feb/2022	17:00		PLANNED	Approved	04-Feb-22	10:00	04-Feb-22	17:00	
240	RQ81039	OCC_ 191	cpcc3_sd		765/400 KV 1500 MVA ICT 2 AT LUCKNOW_2(PG)	POWER GRID	D	AMP Works	04/Feb/2022	10:00	04/Feb/2022	18:00		PLANNED	Approved	04-Feb-22	10:00	04-Feb-22	18:00	
241	RQ80705	OCC_ 191	cpcc1_sd	1	765/400 KV 1500 MVA ICT 1 AT FATEHGARH_ II(PG)	POWER GRID	D	For Punch points(maintenanc e work).	03/Feb/2022	17:00	03/Feb/2022	23:00		PLANNED	Approved	03-Feb-22	17:00	03-Feb-22	23:00	
242	RQ80700	OCC_ 191	cpcc1_sd		765/400 KV 1500 MVA ICT 2 AT BIKANER(PG)	POWER GRID	D	SPARE SWITCHING OF ICT UNIT	03/Feb/2022	10:00	03/Feb/2022	17:00	SPARE UNIT TO BE TAKEN OUT FROM ICT1- Y-PHASE	PLANNED	Approved	03-Feb-22	10:00	03-Feb-22	17:00	
243	RQ80699	OCC_ 191	cpcc1_sd		765/400 KV 1500 MVA ICT 1 AT BIKANER(PG)	POWER GRID	D	SPARE SWITCHING OF ICT UNIT	02/Feb/2022	10:00	02/Feb/2022	17:00	SPARE UNIT TO BE USED IN PLACE OF ICT-2 R PHASE	PLANNED	Approved	02-Feb-22	10:00	02-Feb-22	17:00	
244	RQ81018	OCC_ 191	cpcc3_sd	ORMER	765/400 KV 1500 MVA ICT 2 AT BAREILLY_2(P G)	POWER GRID	D	AMP Works	01/Feb/2022	09:00	01/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	18:00	

245	RQ80702	OCC_ 191	cpcc1_sd	ORMER	765/400 KV 1500 MVA ICT 1 AT JHATIKARA(P G)	POWER GRID	D	FOR AMP WORK	01/Feb/2022	08:00	01/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	01-Feb-22	18:00	
246	RQ80641	OCC_ 191	stuup_sd	ORMER	765/400 KV 1000 MVA ICT 3 AT UNNAO(UP)	UPPTCL		"1.Attending of oil leakage in Y-Phase and B-Phase unit of 1000 MVA ICT- III by M/s TBEA. 2- Testing of 765kV and 400kV equipments like CBs,CTs,CVTs,Isola tors etc."	07/Feb/2022	09:00	09/Feb/2022	18:00	Power will be flow through ICT- 1 & 2 hence there will be no power intrruption.	PLANNED	Approved	07-Feb-22	09:00	09-Feb-22	18:00	
	RQ80645	191		ORMER	765/400 KV 1500 MVA ICT 1 AT BARA(UP)	UPPTCL		For stringing work (3 Days- 01.01.2022 to 03.01.2022) and Construction of Fire wall due to induction effect in switchyard, shutdown required for safety purpose	01/Feb/2022	08:00	28/Feb/2022	19:00		PLANNED	Approved	05-Feb-22	08:00	28-Feb-22		Subjected to UPPTCL consent. Shall be clubbed with unit outage
248	RQ81297	OCC_ 191	sldcrs_sd	MISSIO N LINE	400 KV SURATGARH SCTPS(RVUN)- BIKANER(RS) (RS) CKT-1	RRVPN L		Shutdown required for Annual maintenance of transmission Line.	28/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	28-Feb-22	08:00	28-Feb-22	18:00	
249	RQ81298	OCC_ 191	sldcrs_sd	MISSIO N LINE	400 KV SURATGARH SCTPS(RVUN)- BIKANER(RS) (RS) CKT-2	RRVPN L		Auto Reclosure to be kept OFF (Disable) for safety purpose during shutdown of 400 kV SSCTPS- Bikaner (ATRL) CKT- 1.	28/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	28-Feb-22	08:00	28-Feb-22	18:00	
250	RQ81308	OCC_ 191	sldcrs_sd	TRANS MISSIO	400 KV HINDAUN(RS)- CHHABRA(RV UN) (RS) CKT- 1	RRVPN L		Half yearly Maintance & testing work	28/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	28-Feb-22	08:00	28-Feb-22	18:00	

251	RQ81314	OCC_ 191	sldcrs_sd		400 KV AKAL- RAMGARH (RS) CKT-2	RRVPN L	D	Quarterly Maintenance	25/Feb/2022	08:00	25/Feb/2022	18:00	PLANNED	Approved	25-Feb-22	08:00	25-Feb-22	18:00	
252	RQ81313	OCC_ 191	sldcrs_sd		400 KV AKAL- RAMGARH (RS) CKT-1	RRVPN L	D	Quarterly Maintenance	24/Feb/2022	08:00	24/Feb/2022	18:00	PLANNED	Approved	24-Feb-22	08:00	24-Feb-22	18:00	
253	RQ81296	OCC_ 191	sldcrs_sd		400 KV BIKANER(RS)- DEEDWANA(MTS) (RS) CKT-1	RRVPN L	D	Shutdown required for Annual maintenance of transmission Line.	21/Feb/2022	08:00	21/Feb/2022	18:00	PLANNED	Approved	21-Feb-22	08:00	21-Feb-22	18:00	
254	RQ81316	OCC_ 191	sldcrs_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV BIKANER- BHADLA (RS) CKT-1	RRVPN L	D	Quarterly Maintenance work at 400KV GSS Bhadla aongwith 50 MVAr line reactor at bhadla	18/Feb/2022	16:00	18/Feb/2022	22:00	PLANNED	Approved	18-Feb-22	16:00	18-Feb-22	22:00	
255	RQ81301	OCC_ 191	sldcrs_sd		400 KV BHILWARA- CHITTORGAR H (RS) CKT-1	RRVPN L	D	FOR MAINTAINCE WORK and Testing work	18/Feb/2022	08:00	18/Feb/2022	18:00	PLANNED	Approved	18-Feb-22	08:00	18-Feb-22	18:00	
256	RQ81325	OCC_ 191	sldcrs_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV RAJWEST(RW)-KANKANI (RS) CKT-1	RRVPN L	D	Preventive Maintenance work and Testing of Bay & Line Equipments	17/Feb/2022	08:00	18/Feb/2022	18:00	PLANNED	Approved	17-Feb-22	08:00	18-Feb-22	18:00	
257	RQ81334	OCC_ 191	sldcrs_sd		400 KV JODHPUR- KANKANI (RS) CKT-2	RRVPN L	D	Preventive Maintenance work and Testing of Bay & Line Equipments	14/Feb/2022	08:00	15/Feb/2022	18:00	PLANNED	Approved	14-Feb-22	08:00	15-Feb-22	18:00	
258	RQ80797	OCC_ 191	sldcrs_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV ANTA- KALISINDH (RS) CKT-1	RRVPN L	D	IInd HALF YEARLY MAINTENANCE	11/Feb/2022	08:00	11/Feb/2022	18:00	PLANNED	Approved	11-Feb-22	08:00	11-Feb-22	18:00	Generation at Kalisindh restricted to 1100MW

259	RQ81327	OCC_ 191	sldcrs_sd	AC TRANS MISSIO N LINE CIRCUIT	CKT-1	RRVPN L	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS at Both END	10/Feb/2022	08:00	11/Feb/2022	18:00	PLANNED	Approved	10-Feb-22	08:00	11-Feb-22	18:00	
260	RQ81312	OCC_ 191	sldcrs_sd		400 KV AKAL- JODHPUR (RS) CKT-1	RRVPN L	D	Quarterly Maintenance	10/Feb/2022	08:00	10/Feb/2022	18:00	PLANNED	Approved	10-Feb-22	08:00	10-Feb-22	18:00	
261	RQ81305	OCC_ 191	sldcrs_sd	AC TRANS MISSIO N LINE CIRCUIT		RRVPN L	D	Half Yearly maintenance work of associated equipments of 400 KV Ajmer-Phagi CKT-II Line & Bay (410) & TIE bay 400 KV Ajmer- Phagi CKT-II (411)	10/Feb/2022	08:00	10/Feb/2022	18:00	PLANNED	Approved	10-Feb-22	08:00	10-Feb-22	18:00	
262	RQ81293	OCC_ 191	sldcrs_sd		400 KV AKAL- JAISALMER (RS) CKT-1	RRVPN L	D	Quarterly Maintenance	08/Feb/2022	08:00	08/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	08:00	08-Feb-22	18:00	
263	RQ81304	OCC_ 191	sldcrs_sd	AC TRANS MISSIO N LINE CIRCUIT		RRVPN L	D	Half Yearly maintenance work of associated equipments of 400 KV Ajmer-Phagi CKT-I Line & Bay (407) & TIE bay 400 KV Ajmer- Phagi CKT-I (408)	08/Feb/2022	08:00	08/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	08:00	08-Feb-22	18:00	
264	RQ81320	OCC_ 191	sldcrs_sd		(RS) CKT-1	RRVPN L	D	Half yearly Maintance & testing work	08/Feb/2022	08:00	08/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	08:00	08-Feb-22	18:00	
265	RQ81317	OCC_ 191	sldcrs_sd		CKT-1	RRVPN L	D	Routine Maintenance at both end alongwith 50MVAR line reactor at Merta	07/Feb/2022	08:00	07/Feb/2022	18:00	PLANNED	Approved	07-Feb-22	08:00	07-Feb-22	18:00	

266	RQ81333	OCC_ 191	sldcrs_sd		400 KV JODHPUR- KANKANI (RS) CKT-1	RRVPN L	D	Preventive Maintenance work and Testing of Bay & Line Equipments	07/Feb/2022	08:00	08/Feb/2022	18:00	PLANNE	Approved	07-Feb-22	08:00	08-Feb-22	18:00	
267	RQ81326	OCC_ 191	sldcrs_sd		400 KV BHADLA- MERTA (RS) CKT-1	RRVPN L	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	05/Feb/2022	18:00	05/Feb/2022	22:00	PLANNE	O Approved	05-Feb-22	18:00	05-Feb-22	22:00	
268	RQ81331	OCC_ 191	sldcrs_sd		400 KV MERTA- HEERAPURA (RS) CKT-1	RRVPN L	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	04/Feb/2022	08:00	04/Feb/2022	18:00	PLANNE	O Approved	04-Feb-22	08:00	04-Feb-22	18:00	
269	RQ80798	OCC_ 191	sldcrs_sd	1	, ,	RRVPN L	D	IInd HALF YEARLY MAINTENANCE	04/Feb/2022	08:00	04/Feb/2022	18:00	PLANNE	O Approved	04-Feb-22	08:00	04-Feb-22	18:00	Generation at Kalisindh restricted to 1100MW
270	RQ81324	OCC_ 191	sldcrs_sd	MISSIO	400 KV KANKANI- JAISALMER (RS) CKT-2	RRVPN L		Preventive Maintenance work and Testing of Bay & Line Equipments	04/Feb/2022	08:00	05/Feb/2022	18:00	PLANNE	Approved	04-Feb-22	08:00	05-Feb-22	18:00	
271	RQ81167	OCC_ 191	cpcc1_sd		400 KV BIKANER(RS)- SIKAR(PG) (RS) CKT-2	RRVPN L	D	For Charging of Line Reactor AMP Work	02/Feb/2022	17:30	02/Feb/2022	18:30	PLANNE	O Approved	02-Feb-22	17:30	02-Feb-22	18:30	
272	RQ81164	OCC_ 191	cpcc1_sd	MISSIO	400 KV BIKANER(RS)- SIKAR(PG) (RS) CKT-2	RRVPN L	D	For S/D of Line Reactor AMP Work	02/Feb/2022	09:00	02/Feb/2022	10:00	PLANNE	O Approved	02-Feb-22	09:00	02-Feb-22	10:00	
273	RQ81166	OCC_ 191	cpcc1_sd		(RS) CKT-1	RRVPN L	D	For Charging of Line Reactor AMP Work	01/Feb/2022	17:30	01/Feb/2022	18:30	PLANNE	O Approved	01-Feb-22	17:30	01-Feb-22	18:30	

274	RQ81163	OCC_ 191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	(RS) CKT-1	RRVPN L	D	For S/D of Line Reactor AMP Work	01/Feb/2022	09:00	01/Feb/2022	10:00	PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	10:00	
275	RQ81332	OCC_ 191	sldcrs_sd	AC TRANS MISSIO N LINE CIRCUIT	(RS) CKT-1	RRVPN L	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	01/Feb/2022	08:00	01/Feb/2022	18:00	PLANNED	Approved	01-Feb-22	08:00	01-Feb-22	18:00	
276	RQ81328	OCC_ 191	sldcrs_sd	AC TRANS MISSIO N LINE CIRCUIT			D	Preventive Maintenance work and Testing of Bay & Line Equipments	01/Feb/2022	08:00	02/Feb/2022	18:00	PLANNED	Approved	01-Feb-22	08:00	02-Feb-22	18:00	
277	RQ81300	OCC_ 191	sldcrs_sd	MISSIO	400 KV BHADLA(RS)- BHADLA(PG) (PG) CKT-2	POWER GRID	D	Quarterly Maintenance work at 400KV GSS Bhadla	26/Feb/2022	16:00	26/Feb/2022	22:00	PLANNED	Approved	26-Feb-22	16:00	26-Feb-22	22:00	
278	RQ81091	OCC_ 191	cpcc3_sd	1	400 KV FATEHPUR- MAINPURI (PG) CKT-2	POWER GRID	D	For replacement of defective M/s BHEL make insulator string of Gantry tower from CLRI	26/Feb/2022	09:00	26/Feb/2022	18:00	PLANNED	Approved	26-Feb-22	09:00	26-Feb-22	18:00	
279	RQ81502	OCC_ 191	cpcc1_sd	1	400 KV NEEMRANA- MANESAR (PG) CKT-2	POWER GRID	С	For diversion work of line due to infringement in construction of Delhi-Gurugram- SNB Regional Rapid Transit System (RRTS) corridor of M/s NCRTC	26/Feb/2022	08:00	13/Mar/2022	18:00	PLANNED	Approved	10-Feb-22	08:00	25-Feb-22	18:00	Require CEA clearance before charging/no other S/D from both end/ANNEXURE B-7 UNDERTAKING
280	RQ81501	OCC_ 191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV NEEMRANA- MANESAR (PG) CKT-1	POWER GRID	С	For diversion work of line due to infringement in construction of Delhi-Gurugram-SNB Regional Rapid Transit System (RRTS) corridor of M/s NCRTC	26/Feb/2022	08:00	13/Mar/2022	18:00	PLANNED	Approved	10-Feb-22	08:00	25-Feb-22	18:00	Require CEA clearance before charging/no other S/D from both end/ANNEXURE B-7 UNDERTAKING

281	RQ81230	OCC_ 191	cpcc1_sd		400 KV ROORKEE(PG): KASHIPUR(UK) (PG) CKT-1	POWER GRID	D	AMP OF LINE EQUIPMENT OF POWERGRID OWNED BAYS AT PTCUL KASHIPUR	25/Feb/2022	09:00	25/Feb/2022	18:00		PLANNED	Approved	25-Feb-22	09:00	25-Feb-22	18:00	
282	RQ81551	OCC_ 191	cpcc2_sd		400 KV ABDULLAPUR- KURUKSHETR A (PG) CKT-2	POWER GRID	D	For AMP works with non-auto reclose mode on 400kV Abdullapur- Kurukshetra ckt-1 during shut down period.	25/Feb/2022	09:00	25/Feb/2022	18:00	Kindly approve	PLANNED	Approved	25-Feb-22	09:00	25-Feb-22	18:00	
283	RQ81220	OCC_ 191	cpcc1_sd	MISSIO	400 KV JAIPUR SOUTH-KOTA (PG) CKT-1	POWER GRID	D	Jumper Anchoring work at LOC No. 476	25/Feb/2022	09:00	25/Feb/2022	18:00	A/R of 400 KV RAPP D- Jaipur South Line	PLANNED	Approved	25-Feb-22	09:00	25-Feb-22	18:00	
284	RQ81221	OCC_ 191	cpcc1_sd	MISSIO	400 KV JAIPUR SOUTH-KOTA (PG) CKT-1	POWER GRID	D	Jumper Anchoring work at LOC No. 476	25/Feb/2022	08:00	25/Feb/2022	18:00	A/R of 400 KV RAPP D- Jaipur South Line	PLANNED	Approved	25-Feb-22	08:00	25-Feb-22	18:00	
285	RQ81299	OCC_ 191	sldcrs_sd	MISSIO	400 KV BHADLA(RS)- BHADLA(PG) (PG) CKT-1	POWER GRID	D	Quarterly Maintenance work at 400KV GSS Bhadla	24/Feb/2022	16:00	24/Feb/2022	22:00		PLANNED	Approved	24-Feb-22	16:00	24-Feb-22	22:00	
286	RQ80775	OCC_ 191	sldchr_sd	MISSIO N LINE	400 KV BAHADURGA RH(PG)- KABULPUR(H V) (PG) CKT-1	POWER GRID	D	Oil leakage from R- ph of line CVT	24/Feb/2022	10:00	24/Feb/2022	16:00		PLANNED	Approved	24-Feb-22	10:00	24-Feb-22	16:00	
287	RQ81068	OCC_ 191	cpcc3_sd	MISSIO	400 KV ALLAHABAD- KANPUR_GIS (PG) CKT-2	POWER GRID	D	AMP work	24/Feb/2022	09:00	24/Feb/2022	17:00		PLANNED	Approved	24-Feb-22	09:00	24-Feb-22	17:00	
288	RQ81090	OCC_ 191	cpcc3_sd	MISSIO	400 KV FATEHPUR- MAINPURI (PG) CKT-1	POWER GRID	D	For replacement of defective M/s BHEL make insulator string of Gantry tower from CLRI	24/Feb/2022	09:00	24/Feb/2022	18:00		PLANNED	Approved	24-Feb-22	09:00	24-Feb-22	18:00	

	RQ81550	191		CIRCUIT	400 KV ABDULLAPUR- KURUKSHETR A (PG) CKT-1		D	For AMP works with non-auto reclose mode on 400kV Abdullapur- Kurukshetra ckt-2 during shut down period.	24/Feb/2022		24/Feb/2022		Kindly approve	PLANNED	Approved	24-Feb-22	09:00	24-Feb-22	18:00	
290	RQ81074	OCC_ 191	cpcc3_sd		400 KV KANPUR(PG)- PANKI(UP) (PG) CKT-2	POWER GRID	С	For retrofitment of 89A isolator at Panki end under Add -Cap	24/Feb/2022	08:00	26/Feb/2022	18:00		PLANNED	Approved	24-Feb-22	08:00	26-Feb-22	18:00	subject to UP consent
291	RQ81228	OCC_ 191	cpcc1_sd	MISSIO N LINE	400 KV BAREILLY_2(P G)- KASHIPUR(UK) (PG) CKT-1	POWER GRID	D	AMP OF LINE EQUIPMENT OF POWERGRID OWNED BAYS AT PTCUL KASHIPUR	24/Feb/2022	08:00	24/Feb/2022	18:00		PLANNED	Approved	24-Feb-22	08:00	24-Feb-22	18:00	
292	RQ81010	OCC_ 191	cpcc3_sd	MISSIO N LINE	400 KV SINGRAULI(N T)- LUCKNOW(U P) (PG) CKT-1	POWER GRID	D	For Transfer bus Pantograph isolator retrofitment work at Lucknow(UP)(SD of Transfer bus shall also be required along with line for facilitating isolator retrofit work.)	23/Feb/2022	10:00	25/Feb/2022	18:00		PLANNED	Approved	23-Feb-22	10:00	25-Feb-22	18:00	subject to NTPC and UP
293	RQ81571	OCC_ 191	cpcc2_sd	MISSIO N LINE	400 KV CHAMERA_2(NH)- CHAMBA(PG) (PG) CKT-1	POWER GRID	D	For Interconnection of Bus Bar for construction of new 400KV 125MVAR Bus Reactor bay(408) & 02 No Line bays. 400KV Lahal 1 Bay (409) & 400KV Lahal 2 Bay(410).	23/Feb/2022	10:00	26/Feb/2022	18:00	Kindly approve	PLANNED	Approved	23-Feb-22	10:00	26-Feb-22	18:00	Subject to necessary CEA/FTC clearance if any required/NHPC CONSENT.no other s/d to be given from chamera-II
294	RQ81231	OCC_ 191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV ROORKEE(PG): KASHIPUR(UK) (PG) CKT-2	POWER GRID	D	AMP OF LINE EQUIPMENT OF POWERGRID OWNED BAYS AT PTCUL KASHIPUR	23/Feb/2022	09:00	23/Feb/2022	18:00		PLANNED	Approved	23-Feb-22	09:00	23-Feb-22	18:00	

	RQ81089	191		MISSIO	400 KV ALLAHABAD- FATEHPUR (PG) CKT-2	POWER GRID		For replacement of defective M/s BHEL make insulator string of Gantry tower from CLRI AMP OF LINE	22/Feb/2022 22/Feb/2022		22/Feb/2022 22/Feb/2022		PLANNED		22-Feb-22	09:00	22-Feb-22	18:00	
230	NQ81229	191	cpcc1_su	TRANS MISSIO N LINE	BAREILLY_2(P	-	J	EQUIPMENT OF POWERGRID OWNED BAYS AT PTCUL KASHIPUR	22/160/2022	08.00	22/160/2022	18.00	FLANNED	Арргочец	22-1 60-22	08.00	22-1 60-22	18.00	
297	RQ81078	OCC_ 191	cpcc3_sd	MISSIO N LINE	400 KV LUCKNOW_1(PG)- BASTI(UP) (PG) CKT-1	POWER GRID	С	Transmission Line Diversion work due to construction of Outer Ring Road by NHAI	22/Feb/2022	08:00	03/Mar/2022	18:00	PLANNED	Approved	22-Feb-22	08:00	03-Mar-22	18:00	Require CEA clearance before charging/ANNEXUR E B-7 UNDERTAKING
298	RQ81072	OCC_ 191	cpcc3_sd	MISSIO	400 KV KANPUR- BALLABHGAR H (PG) CKT-1	POWER GRID	D	Checking of R and Y ph Reactor current for connection as compensating current with main- 2 protection	21/Feb/2022	09:00	21/Feb/2022	13:00	PLANNED	Approved	21-Feb-22	09:00	21-Feb-22	13:00	
299	RQ81200	OCC_ 191	cpcc1_sd	MISSIO	400 KV BHIWANI- HISSAR (PG) CKT-2	POWER GRID	С	Stringing of 400 kV D/C Mahendragarh- Bhiwani TL at Loc.34/0-35/0	21/Feb/2022	08:00	22/Feb/2022	18:00	PLANNED	Approved	21-Feb-22	08:00	22-Feb-22	18:00	
300	RQ81201	OCC_ 191	cpcc1_sd	1	HISSAR (PG) CKT-3	POWER GRID	С	Stringing of 400 kV D/C Mahendragarh- Bhiwani TL at Loc.34/0-35/0	21/Feb/2022	08:00	22/Feb/2022	18:00	PLANNED	Approved	21-Feb-22	08:00	22-Feb-22	18:00	
301	RQ81085	OCC_ 191	cpcc3_sd	MISSIO	400 KV KANPUR- AGRA (PG) CKT-1	POWER GRID	D	Insulator replacement work with Polymer	20/Feb/2022	08:00	20/Feb/2022	18:00	PLANNED	Approved	20-Feb-22	08:00	20-Feb-22	18:00	

302	RQ81174	OCC_ 191	cpcc1_sd	TRANS MISSIO N LINE	400 KV CHITTORGAR H(RS)- KANKROLI(PG) (PG) CKT-1		For AMP of Terminal equipment at SEB (RRVPNL) end & Line maintenance works	19/Feb/2022	08:00	19/Feb/2022	18:00	Auto recloses to be kept non auto mode of RAPPC- CHITTORGA RH LINE & RAPPC - KANKROLI LINE & RRVPNL - (CHITTORGA RH) - KANKROLI LINE (PG)	PLANNED	Approved	19-Feb-22	08:00	19-Feb-22	18:00	
303	RQ81084	OCC_ 191	cpcc3_sd	TRANS	400 KV AGRA- JAIPUR SOUTH (PG) CKT-2	POWER GRID	Insulator replacement work with Polymer	19/Feb/2022	08:00	19/Feb/2022	18:00		PLANNED	Approved	19-Feb-22	08:00	19-Feb-22	18:00	
304	RQ81570	OCC_ 191	cpcc2_sd	TRANS MISSIO N LINE	400 KV CHAMERA_2(NH)- CHAMBA(PG) (PG) CKT-1	POWER GRID	For Interconnection of Bus Bar for construction of new 400KV 125MVAR Bus Reactor bay(408) & 02 No Line bays. 400KV Lahal 1 Bay (409) & 400KV Lahal 2 Bay(410).	18/Feb/2022	09:00	21/Feb/2022	18:00	Kindly approve	PLANNED	Approved	18-Feb-22	09:00	21-Feb-22		Subject to necessary CEA/FTC clearance if any required/NHPC CONSENT.no other s/d to be given from chamera-II
305	RQ81330	OCC_ 191	sldcrs_sd	TRANS MISSIO	400 KV KOTA(PG)- MERTA(RS) (PG) CKT-1	POWER GRID	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	18/Feb/2022	08:00	18/Feb/2022	18:00		PLANNED	Approved	18-Feb-22	08:00	18-Feb-22	18:00	

306	RQ81175	OCC_ 191	cpcc1_sd	MISSIO	400 KV RAPS_C(NP)- CHITTORGAR H(RS) (PG) CKT-1	POWER GRID	D	For AMP of Terminal equipment at SEB (RRVPNL) end & Line maintenance works	18/Feb/2022	08:00	18/Feb/2022	18:00	Auto recloses to be kept non auto mode at both end of following line i) RAPPC- CHITTORGA RH LINE , ii) RAPPC - KANKROLI LINE , iii) RRVPNL - (CHITTORGA RH) - KANKROLI LINE	PLANNED	Approved	18-Feb-22	08:00	18-Feb-22	18:00	
307	RQ81083	OCC_ 191	cpcc3_sd	AC TRANS MISSIO N LINE CIRCUIT	SOUTH (PG) CKT-1	POWER GRID	D	Insulator replacement work with Polymer	18/Feb/2022	08:00	18/Feb/2022	18:00		PLANNED	Approved	18-Feb-22	08:00	18-Feb-22	18:00	
308	RQ81173	OCC_ 191	cpcc1_sd	MISSIO	400 KV RAPS_C(NP)- CHITTORGAR H(RS) (PG) CKT-1	POWER GRID	D	For AMP of Terminal equipment at SEB (RRVPNL) end & Line maintenance works	18/Feb/2022	08:00	18/Feb/2022	18:00		PLANNED	Approved	18-Feb-22	08:00	18-Feb-22	18:00	
309	RQ81088	OCC_ 191	cpcc3_sd	MISSIO	400 KV ALLAHABAD- FATEHPUR (PG) CKT-1	POWER GRID	D	For replacement of defective M/s BHEL make insulator string of Gantry tower from CLRI	17/Feb/2022	09:00	17/Feb/2022	18:00		PLANNED	Approved	17-Feb-22	09:00	17-Feb-22	18:00	
310	RQ81073	OCC_ 191	cpcc3_sd	MISSIO	400 KV KANPUR- BALLABHGAR H (PG) CKT-2	POWER GRID		For changing the orientation of LA of line reactor (non-switchable) at Kanpur end	17/Feb/2022	09:00	17/Feb/2022	17:00		PLANNED	Approved	17-Feb-22	09:00	17-Feb-22	17:00	
311	RQ81511	OCC_ 191	cpcc1_sd	MISSIO	400 KV BHIWADI- NEEMRANA (PG) CKT-2	POWER GRID	D	AMP Activities	17/Feb/2022	09:00	17/Feb/2022	18:00		PLANNED	Approved	17-Feb-22	09:00	17-Feb-22	18:00	

312	RQ81329	OCC_ 191	sldcrs_sd		400 KV SHREE CEMENT(SCL)- MERTA(RS) (PG) CKT-1		D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	17/Feb/2022	08:00	17/Feb/2022	18:00		PLANNED	Approved	17-Feb-22	08:00	17-Feb-22	18:00	
313	RQ81082	OCC_ 191	cpcc3_sd	AC TRANS MISSIO N LINE CIRCUIT		POWER GRID	D	Insulator replacement work with Polymer	17/Feb/2022	08:00	17/Feb/2022	18:00		PLANNED	Approved	17-Feb-22	08:00	17-Feb-22	18:00	
314	RQ81683	OCC_ 191	cpcc2_sd	MISSIO	400 KV MOGA- FATEHABAD (PG) CKT-1	POWER GRID	D	For correction of Isolator orientation to prevent phase-to- phase flashover.	16/Feb/2022	08:00	16/Feb/2022	18:00	Kindly approve	PLANNED	Approved	16-Feb-22	08:00	16-Feb-22	18:00	
315	RQ81081	OCC_ 191	cpcc3_sd	AC TRANS MISSIO N LINE CIRCUIT		POWER GRID	D	Insulator replacement work with Polymer	16/Feb/2022	08:00	16/Feb/2022	18:00		PLANNED	Approved	16-Feb-22	08:00	16-Feb-22	18:00	
316	RQ81659	OCC_ 191	cpcc2_sd	MISSIO N LINE	400 KV AMRITSAR- PARBATI POOLING BANALA (PG) CKT-1	POWER GRID	D	SD Required for re- installation of Aviation Globules after installation of OPGW under ULDC scheme. Nonn- auto mode is required on 400kV Amritsar-Jalandhar ckt-2, 400kV Jalandhar- Hamirpur ckt-1 & 400kV Hamirpur- Parbati Pooling Banala ckt-1.			28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	16-Feb-22	07:00	28-Feb-22	18:00	Only One ckt at a time will be approved from Parbati Banala one day
317	RQ81161	OCC_ 191	cpcc1_sd	MISSIO N LINE	400 KV BAWANA CCGTB(DTL)- BAHADURGA RH(PG) (PG) CKT-1	POWER GRID	С	Diversion/Relocati on of Tower at Tower Location 55 BBTL	15/Feb/2022	09:00	24/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	09:00	24-Feb-22	18:00	Require CEA clearance before charging/ANNEXUR E B-7 UNDERTAKING
318	RQ81232	OCC_ 191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV KOTA(PG)- MERTA(RS) (PG) CKT-1	POWER GRID	D	For AMP of Line .	15/Feb/2022	09:00	16/Feb/2022	18:00	Non Auto mode of other ckt	PLANNED	Approved	15-Feb-22	09:00	16-Feb-22	18:00	

319	RQ81510	OCC_ 191	cpcc1_sd	MISSIO	400 KV BHIWADI- NEEMRANA (PG) CKT-1	POWER GRID	D	AMP Activities	15/Feb/2022	09:00	15/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	09:00	15-Feb-22	18:00	
320	RQ81162	OCC_ 191	cpcc1_sd	MISSIO N LINE	400 KV BAWANA CCGTB(DTL)- BHIWANI(PG) (PG) CKT-1	POWER GRID	С	Diversion/Relocati on of Tower at Tower Location 55 BBTL	15/Feb/2022	09:00	24/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	09:00	24-Feb-22	18:00	
321	RQ81202	OCC_ 191	cpcc1_sd			POWER GRID	D	Stringing of 400 kV D/C Mahendragarh- Bhiwani TL at Loc.39/0-40/0	15/Feb/2022	08:00	15/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	08:00	15-Feb-22	18:00	
322	RQ81056	OCC_ 191	cpcc3_sd	MISSIO	400 KV ALLAHABAD- FATEHPUR (PG) CKT-1	POWER GRID	D	A/R into non auto mode for Live Line OPGW Work	15/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	08:00	28-Feb-22	18:00	
323	RQ81057	OCC_ 191	cpcc3_sd	MISSIO	400 KV KANPUR- BALLABHGAR H (PG) CKT-1	POWER GRID		A/R into non auto mode for Live Line OPGW Work	15/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	08:00	28-Feb-22	18:00	
324	RQ81070	OCC_ 191	cpcc3_sd	MISSIO	400 KV KANPUR(PG)- AURAIYA(NT) (PG) CKT-1	POWER GRID	D	CT Oil sampling at Auraiya(NTPC) end	11/Feb/2022	09:00	11/Feb/2022	12:00		PLANNED	Approved	11-Feb-22	09:00	11-Feb-22	12:00	
325	RQ81199	OCC_ 191	cpcc1_sd	MISSIO	400 KV NEEMRANA- MANESAR (PG) CKT-2	POWER GRID	D	FOR AMP of line	11/Feb/2022	08:00	11/Feb/2022	18:00		PLANNED	Approved	11-Feb-22	08:00	11-Feb-22	18:00	
326	RQ81548	OCC_ 191	cpcc2_sd	MISSIO	400 KV DEHRADUN- ABDULLAPUR (PG) CKT-1	POWER GRID	D	For AMP works.	10/Feb/2022	09:00	10/Feb/2022	18:00	Kindly approve	PLANNED	Approved	10-Feb-22	09:00	10-Feb-22	18:00	

327	RQ81059	OCC_ 191	cpcc3_sd	MISSIO N LINE	400 KV SINGRAULI(N T)- ALLAHABAD(PG) (PG) CKT- 1	POWER GRID		For OPGW installation in river crossing, as there is earth wire joint in mid span (168- 169; River crossing)	10/Feb/2022	09:00	10/Feb/2022	15:00		PLANNED	Approved	10-Feb-22	09:00	10-Feb-22	15:00	
328	RQ81509	OCC_ 191	cpcc1_sd		400 KV BHIWADI- HISSAR (PG) CKT-3	POWER GRID	D	AMP Activities	10/Feb/2022	09:00	10/Feb/2022	18:00		PLANNED	Approved	10-Feb-22	09:00	10-Feb-22	18:00	
329	RQ81319	OCC_ 191	sldcrs_sd	MISSIO	400 KV SIKAR(PG)- RATANGARH(RS) (PG) CKT- 2	POWER GRID	D	Maintenance work of bay equipments, isolators and testing work of bay equipments.	10/Feb/2022	08:00	10/Feb/2022	18:00		PLANNED	Approved	10-Feb-22	08:00	10-Feb-22	18:00	
330	RQ81044	OCC_ 191	cpcc3_sd	MISSIO N LINE	400 KV SINGRAULI(N T)- ANPARA(UP) (PG) CKT-1	POWER GRID	D	AMP work and PLCC testing at Anpara(UP)	10/Feb/2022	08:00	10/Feb/2022	18:00		PLANNED	Approved	11-Feb-22	08:00	11-Feb-22	18:00	
331	RQ81616	OCC_ 191	cpcc2_sd	MISSIO N LINE	400 KV AMRITSAR- PARBATI POOLING BANALA (PG) CKT-1	POWER GRID		Non-auto mode required for OPGW installation works under ULDC scheme.	10/Feb/2022	07:00	15/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	10-Feb-22	07:00	15-Feb-22	18:00	
332	RQ81142	OCC_ 191	singrauli_s d	TRANS MISSIO N LINE	400 KV SINGRAULI(N T)- FATEHPUR(P G) (PG) CKT-1	POWER GRID	D	3 hour shutdown for SAS work	09/Feb/2022	15:00	09/Feb/2022	18:00		PLANNED	Approved	09-Feb-22	15:00	09-Feb-22	18:00	
333	RQ81141	OCC_ 191	singrauli_s d	TRANS MISSIO N LINE	400 KV SINGRAULI(N T)- ALLAHABAD(PG) (PG) CKT- 3	POWER GRID	D	4 hour shutdown for SAS work	09/Feb/2022	08:00	09/Feb/2022	12:00		PLANNED	Approved	12-Feb-22	08:00	12-Feb-22	12:00	
334	RQ81061	OCC_ 191	cpcc3_sd		400 KV KANPUR_GIS- LUCKNOW_2 (PG) CKT-2	POWER GRID	D	AMP work	08/Feb/2022	09:00	08/Feb/2022	18:00		PLANNED	Approved	08-Feb-22	09:00	08-Feb-22	18:00	

335	RQ81045	OCC_ 191	cpcc3_sd	TRANS MISSIO N LINE	400 KV SINGRAULI(N T)- RIHAND(NT) (PG) CKT-1	POWER GRID	D	AMP work at Rihand(NTPC)	08/Feb/2022	08:00	08/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	08:00	08-Feb-22	18:00	
336	RQ81058	OCC_ 191	cpcc3_sd	TRANS MISSIO N LINE	400 KV SINGRAULI(N T)- ALLAHABAD(PG) (PG) CKT-	POWER GRID	D	A/R into non auto mode for Live Line OPGW Work	08/Feb/2022	08:00	25/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	08:00	25-Feb-22	18:00	
337	RQ81144	OCC_ 191	singrauli_s d	TRANS MISSIO N LINE	400 KV SINGRAULI(N T)- RIHAND(NT) (PG) CKT-2	POWER GRID	D	3 hour shutdown for SAS work	07/Feb/2022	15:00	07/Feb/2022	18:00	PLANNED	Approved	07-Feb-22	15:00	07-Feb-22	18:00	
338	RQ81008	OCC_ 191	sldchr_sd	TRANS MISSIO N LINE	400 KV BALLABHGAR H(PG)- NAWADA(HV) (PG) CKT-1	POWER GRID	D	For gen mtc for TIE- 2, and line bay	07/Feb/2022	10:00	07/Feb/2022	18:00	PLANNED	Approved	07-Feb-22	10:00	07-Feb-22	18:00	
339	RQ81508	OCC_ 191	cpcc1_sd	TRANS MISSIO	400 KV BHIWADI- HISSAR (PG) CKT-2	POWER GRID	D	AMP Activities	07/Feb/2022	09:00	07/Feb/2022	18:00	PLANNED	Approved	07-Feb-22	09:00	07-Feb-22	18:00	
340	RQ81143	OCC_ 191	singrauli_s d	TRANS MISSIO N LINE	400 KV SINGRAULI(N T)- RIHAND(NT) (PG) CKT-1	POWER GRID	D	4 hour shutdown for SAS work	07/Feb/2022	08:00	07/Feb/2022	12:00	PLANNED	Approved	14-Feb-22	08:00	14-Feb-22	12:00	
341	RQ80564	OCC_ 191	stuup_sd	MISSIO	400 KV SARNATH(UP) VARANASI(PG) (PG) CKT-1		D	OVERHEAD CROSSING OF UNDERCONSTRUC TION 400 KV DC TWIN MOOSE VARANASI (PGCIL) JAUNPUR LINE BETWEEN LOCATION NO 06	05/Feb/2022	09:00	06/Feb/2022	17:00	PLANNED	Approved	05-Feb-22	09:00	06-Feb-22	17:00	

342	RQ80565	OCC_ 191	stuup_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV SARNATH(UP) VARANASI(PG) (PG) CKT-2		D	OVERHEAD CROSSING OF UNDERCONSTRUC TION 400 KV DC TWIN MOOSE VARANASI (PGCIL)- JAUNPUR LINE BETWEEN LOCATION NO 06	05/Feb/2022	09:00	06/Feb/2022	17:00		PLANNED	Approved	05-Feb-22	09:00	06-Feb-22	17:00	
	RQ81503	191		AC TRANS MISSIO N LINE CIRCUIT	CKT-1	POWER GRID	D	For upgradation of Isolators form 2000A to 3000A required for Bus Splitting scheme under SS34 Pkg			06/Feb/2022			PLANNED	Approved	05-Feb-22	09:00	06-Feb-22	18:00	
344	RQ81179	OCC_ 191	cpcc1_sd	MISSIO	400 KV AGRA- JAIPUR SOUTH (PG) CKT-2	POWER GRID	С	For NHAI Diversion Work	05/Feb/2022	08:00	14/Feb/2022	18:00		PLANNED	Approved	05-Feb-22	08:00	14-Feb-22	18:00	Require CEA clearance before charging/ANNEXUR E B-7 UNDERTAKING/No other S/D from Jaipur
345	RQ81178	OCC_ 191	cpcc1_sd		CKT-1	POWER GRID	С	For NHAI Diversion Work	05/Feb/2022	08:00	14/Feb/2022	18:00		PLANNED	Approved	05-Feb-22	08:00	14-Feb-22	18:00	Require CEA clearance before charging/ANNEXUR E B-7 UNDERTAKING/No other S/D from Jaipur
	RQ81573	191		N LINE CIRCUIT		POWER GRID		For crossing of GIS Duct of new reactor bay over existing GIS ducts as SF6 to air bushing is very near to working area and due to space constains at site, shutdown of bay requires	04/Feb/2022		06/Feb/2022		Kindly approve	PLANNED	Approved	04-Feb-22	09:00	06-Feb-22	18:00	
347	RQ81505	OCC_ 191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV BHIWANI- HISSAR (PG) CKT-3	POWER GRID	С	Shiting of LA to new location for Bypass arrangement of 400kV Mgrh-Bwn D/C & Hisar-Bwn D/C line at Bhiwani under SS34	03/Feb/2022	09:00	04/Feb/2022	18:00		PLANNED	Approved	03-Feb-22	09:00	04-Feb-22	18:00	require CEA clearance/FTC clearance before availing shutdown

348	RQ81507	OCC_ 191	cpcc1_sd		400 KV BALLABHGAR H- MAHARANIB AGH (PG) CKT		D	AMP Purpose	03/Feb/2022	09:00	03/Feb/2022	18:00		PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	18:00	
349	RQ81223	OCC_ 191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	CKT-2	POWER GRID	С	For restoration of 400 kV Main Bus-I	02/Feb/2022	09:00	04/Feb/2022	20:00		PLANNED	Approved	02-Feb-22	09:00	04-Feb-22	20:00	
350	RQ81225	OCC_ 191	cpcc1_sd	MISSIO	400 KV BAGHPAT- DEHRADUN (PG) CKT-1	POWER GRID	С	For restoration of 400 kV Main Bus-I	02/Feb/2022	09:00	04/Feb/2022	20:00		PLANNED	Approved	02-Feb-22	09:00	04-Feb-22	20:00	
351	RQ81222	OCC_ 191	cpcc1_sd		CKT-1	POWER GRID	С	For restoration of 400 kV Main Bus-I	02/Feb/2022	09:00	04/Feb/2022	20:00		PLANNED	Approved	02-Feb-22	09:00	04-Feb-22	20:00	
352	RQ81224	OCC_ 191	cpcc1_sd	MISSIO	R (PG) CKT-1	POWER GRID	С	For restoration of 400 kV Main Bus-I	02/Feb/2022	09:00	04/Feb/2022	20:00		PLANNED	Approved	02-Feb-22	09:00	04-Feb-22	20:00	
353	RQ81504	OCC_ 191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	CKT-2	POWER GRID	С	Shiting of LA to new location for Bypass arrangement of 400kV Mgrh-Bwn D/C & Hisar-Bwn D/C line at Bhiwani under SS34	01/Feb/2022	09:00	02/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	09:00	02-Feb-22		require CEA clearance/FTC clearance before availing shutdown
354	RQ81572	OCC_ 191	cpcc2_sd	AC TRANS MISSIO N LINE CIRCUIT	(PG) CKT-1	POWER GRID	D	For crossing of GIS Duct of new reactor bay over existing GIS ducts as SF6 to air bushing is very near to working area and due to space constains at site,shutdown of bay requires	01/Feb/2022	09:00	03/Feb/2022	18:00	Kindly approve	PLANNED	Approved	01-Feb-22	09:00	03-Feb-22	18:00	

355	RQ81676	OCC_ 191	cpcc2_sd		400 KV CHAMBA- JALANDHAR (PG) CKT-2	POWER GRID	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	08:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	
356	RQ81071	OCC_ 191	cpcc3_sd		CKT-1	POWER GRID	С	For commissioning of Series line reactor at Kanpur 400kV end	01/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	
357	RQ81344	OCC_ 191	cpcc1_sd	MISSIO	400 KV DADRI(NT)- PANIPAT(BB) (PG) CKT-2	POWER GRID	D	Auto Reclose off is required for OPGW laying (completed 110 out of 116 Kms) under reliable communication replacement project.	01/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	
358	RQ81343	OCC_ 191	cpcc1_sd	MISSIO	400 KV DADRI(NT)- MURADNAGA R_2(UP) (PG)	POWER GRID	D	OPGW laying shall be started in this line under Reliable Comunication package (Auto Reclose off) - 40 Kms	01/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	
	RQ81349	191		MISSIO N LINE	400 KV BALLABHGAR H(PG)- NAWADA(HV) (PG) CKT-1	POWER GRID	D	Auto Reclose off is required for rectiifcation, if required under Reliable communication replacement project.	01/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	Only one non Auto from nawada end
360	RQ81339	OCC_ 191	cpcc1_sd	MISSIO	(PG) CKT-1	POWER GRID	D	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE stringing works (185 out of 186 completed - only 3 span balance) under Reliable Comunication package (Auto Reclose off)	01/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	

361	RQ81338	OCC_ 191	cpcc1_sd	MISSIO	400 KV RAPS_D(NP)- KOTA(PG) (PG) CKT-1	POWER GRID	D	"Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE stringing works (39 out of 55Kms completed) under Reliable Comunication package (Auto Reclose off) Towers (MCT) are common in forest Area"	01/Feb/2022	08:00	28/Feb/2022	18:00	PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	
362	RQ81345	OCC_ 191	cpcc1_sd	MISSIO	400 KV DADRI(NT)- MAHARANIB AGH(PG) (PG) CKT-1	POWER GRID	D	Auto Reclose off is required for replacement of OPGW from Dadri gantry to Maharanibagh LILO point under reliable communication replacement project. (35 Kms)	01/Feb/2022	08:00	28/Feb/2022	18:00	PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	
363	RQ81346	OCC_ 191	cpcc1_sd		400 KV BASSI- BHIWADI (PG) CKT-1	POWER GRID	D	Auto Reclose off is required for rectiifcation of Bassi - Bhiwadi under Reliable communication replacement project.	01/Feb/2022	08:00	28/Feb/2022	18:00	PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	
364	RQ81347	OCC_ 191	cpcc1_sd	MISSIO	400 KV BHIWANI(BB) HISSAR(PG) (PG) CKT-1	POWER - GRID	D	Auto Reclose off is required for OPGW laying (completed 35 out of 36 Kms) under reliable communication replacement project.	01/Feb/2022	08:00	28/Feb/2022	18:00	PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	

365	RQ81340	OCC_ 191	cpcc1_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV RAPS_C(NP)- KOTA(PG) (PG) CKT-1	POWER GRID	D	"Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE stringing works (39 out of 55Kms completed) under Reliable Comunication package (Auto Reclose off) Towers (MCT) are common in forest Area"	01/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	
366	RQ81619	OCC_ 191	cpcc2_sd		400 KV AMRITSAR- JALANDHAR (PG) CKT-2	POWER GRID	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	
367	RQ81675	OCC_ 191	cpcc2_sd	MISSIO	400 KV CHAMBA- JALANDHAR (PG) CKT-1	POWER GRID	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	
368	RQ81621	OCC_ 191	cpcc2_sd		400 KV JALANDHAR- HAMIRPUR (PG) CKT-1	POWER GRID	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	
369	RQ81658	OCC_ 191	cpcc2_sd	MISSIO N LINE	400 KV AMRITSAR- PARBATI POOLING BANALA (PG) CKT-1	POWER GRID	D	SD Required for re- installation of Aviation Globules after installation of OPGW under ULDC scheme. Nonn- auto mode is required on 400kV Amritsar-Jalandhar ckt-2, 400kV Jalandhar- Hamirpur ckt-1 & 400kV Hamirpur- Parbati Pooling Banala ckt-1.	01/Feb/2022	07:00	09/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	09-Feb-22		Only One ckt at a time will be approved from Parbati Banala one day

370	RQ81623	OCC_ 191	cpcc2_sd	MISSIO N LINE	400 KV HAMIRPUR- PARBATI POOLING BANALA (PG) CKT-1	POWER GRID	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	
371	RQ80774	OCC_ 191	sldchr_sd	MISSIO N LINE	400 KV DEEPALPUR(J HKT)- KABULPUR(H V) (HVPNL) CKT-2	HVPNL	D	For AMP work and the availability of power supply of line could not be affect and it would be charged through TIE CB	26/Feb/2022	09:00	26/Feb/2022	17:00		PLANNED	Approved	26-Feb-22	09:00	26-Feb-22	17:00	
372	RQ81002	OCC_ 191	sldchr_sd	MISSIO	400 KV CLP JHAJJAR(CLP)- DHANODA(H V) (HVPNL) CKT-1	HVPNL	D	For isolator jaw replacement work	25/Feb/2022	07:00	25/Feb/2022	19:00		PLANNED	Approved	25-Feb-22	07:00	25-Feb-22	19:00	
373	RQ80671	OCC_ 191	sldchr_sd	MISSIO	400 KV CLP JHAJJAR(CLP)- DHANODA(H V) (HVPNL) CKT-1	HVPNL	D	Gen mtc of line isolator and allied equipment	22/Feb/2022	09:00	22/Feb/2022	16:00		PLANNED	Approved	22-Feb-22	09:00	22-Feb-22	16:00	
	RQ80777	191		MISSIO N LINE	KABULPUR(H V) (HVPNL) CKT-2	HVPNL	С	For over hauling of CB mechanism due to increasing closing time. The availability of power supply of line could not be affect and it would be charged through TIE CB (4TCB).			19/Feb/2022			PLANNED	Approved	17-Feb-22	09:00	19-Feb-22	18:00	
375	RQ80776	OCC_ 191	sldchr_sd	MISSIO N LINE	400 KV DEEPALPUR(J HKT)- KABULPUR(H V) (HVPNL) CKT-1	HVPNL	С	For over hauling of CB mechanism due to increasing closing time. The availability of power supply of line could not be affect and it would be charged through TIE CB (3TCB).	14/Feb/2022	09:00	16/Feb/2022	18:00		PLANNED	Approved	14-Feb-22	09:00	16-Feb-22	18:00	

376	RQ80957	OCC_ 191	sldchr_sd	MISSIO	400 KV DHANODA- DAULATABAD (HV) CKT-2	HVPNL	D	For half yearly mtc of line	11/Feb/2022	10:00	11/Feb/2022	17:00	PLANNED	Approved	11-Feb-22	10:00	11-Feb-22	17:00	
377	RQ80956	OCC_ 191	sldchr_sd	MISSIO	400 KV DHANODA- DAULATABAD (HV) CKT-1	HVPNL	D	For half yearly mtc of line	10/Feb/2022	10:00	10/Feb/2022	17:00	PLANNED	Approved	10-Feb-22	10:00	10-Feb-22	17:00	
378	RQ80954	OCC_ 191	sldchr_sd	MISSIO	400 KV DHANODA- DAULATABAD (HV) CKT-2	HVPNL	D	For testing of master control unit (MCU), testing of Bus bar protection with Bus-2	08/Feb/2022	10:00	08/Feb/2022	11:30	PLANNED	Approved	08-Feb-22	10:00	08-Feb-22	11:30	
379	RQ80673	OCC_ 191	sldchr_sd	MISSIO	400 KV DHANODA- DAULATABAD (HV) CKT-2	HVPNL	D	To provide pilot disk on the line and repair the worn out conductor of line	08/Feb/2022	09:00	08/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	09:00	08-Feb-22	18:00	
380	RQ80948	OCC_ 191	sldchr_sd	MISSIO N LINE	400 KV JHAJJAR(APCL)- DAULATABAD (HV) (HV) CKT- 2	HVPNL	D	For testing of Master control unit (MCU), testing of bus bar protection with bus-1	07/Feb/2022	14:00	07/Feb/2022	15:30	PLANNED	Approved	07-Feb-22	14:00	07-Feb-22	15:30	
381	RQ80950	OCC_ 191	sldchr_sd	MISSIO	400 KV DHANODA- DAULATABAD (HV) CKT-1	HVPNL	D	For testing of Master control unit (MCU), testing of bus bar protection with bus-1	07/Feb/2022	14:00	07/Feb/2022	15:30	PLANNED	Approved	07-Feb-22	14:00	07-Feb-22	15:30	
382	ROS0951	occ	sldchr sd	AC	400 KV	HVPNL	D	For testing of	07/Feb/2022	12:00	07/Feb/2022	13:30	PLANNED	Approved	07-Feb-22	12:00	07-Feb-22	13:30	
		191	sldchr sd	TRANS MISSIO	DHANODA- DAULATABAD (HV) CKT-2			Master control unit (MCU), testing of bus bar protection with bus-1 For testing of											

384	RQ80952	OCC_ 191	sldchr_sd	MISSIO N LINE	400 KV GURGAON(P G)- DAULATABAD (HV) (HV) CKT- 1	HVPNL		For testing of Master control unit (MCU), testing of bus bar protection with bus-1	07/Feb/2022	10:00	07/Feb/2022	11:30	PLA	ANNED	Approved	07-Feb-22	10:00	07-Feb-22	11:30	
385	RQ80947	OCC_ 191	sldchr_sd	MISSIO N LINE	400 KV JHAJJAR(APCL)- DAULATABAD (HV) (HV) CKT- 1	HVPNL		For testing of Master control unit (MCU), testing of bus bar protection with bus-1	07/Feb/2022	10:00	07/Feb/2022	11:30	PLA	ANNED	Approved	07-Feb-22	10:00	07-Feb-22	11:30	
386	RQ80672	OCC_ 191	sldchr_sd	MISSIO	400 KV DHANODA- DAULATABAD (HV) CKT-1	HVPNL	D	To provide pilot disk on the line and repair the worn out conductor of line	03/Feb/2022	09:00	03/Feb/2022	18:00	PLA	ANNED	Approved	03-Feb-22	09:00	03-Feb-22	18:00	
387	RQ80992	OCC_ 191	sldcdv_sd	MISSIO N LINE	400 KV JHAJJAR(APCL)- MUNDKA(DV) (APCL) CKT-1	APCPL		Tan Delta testing of Line CVT of Jhajjar Circuit 1 and Bay 415	25/Feb/2022	15:00	25/Feb/2022	16:00	PLA	ANNED	Approved	25-Feb-22	15:00	25-Feb-22	16:00	
388	RQ80990	OCC_ 191	sldcdv_sd	MISSIO N LINE	400 KV JHAJJAR(APCL)- MUNDKA(DV) (APCL) CKT-1	APCPL		Replairing/ replacement of Bus 1 clamps below jackbus of Jhajjar Circuit 1	19/Feb/2022	10:00	19/Feb/2022	17:00	PLA	ANNED	Approved	19-Feb-22	10:00	19-Feb-22	17:00	
389	RQ80991	OCC_ 191	sldcdv_sd	MISSIO N LINE	400 KV JHAJJAR(APCL)- MUNDKA(DV) (APCL) CKT-2	APCPL	D	Maintenance of line isolators	04/Feb/2022	10:00	04/Feb/2022	17:00	PLA	ANNED	Approved	04-Feb-22	10:00	04-Feb-22	17:00	
390	RQ80965	OCC_ 191	stuup_sd	MISSIO	400 KV SARNATH- AZAMGARH (UP) CKT-1	UPPTCL		For Installation and commissioning of two nos. line wave trap, Commissioning of One No. PLCC cabinet with protection coupler and General maintenance work	25/Feb/2022	10:00	26/Feb/2022	18:00	PLA	ANNED	Approved	25-Feb-22	10:00	26-Feb-22		CEA safety CLEARANE REQUIRED

391	RQ80936	OCC_ 191	stuup_sd	MISSIO	TANDA(NT)- SULTANPUR(UP) (UP) CKT-	UPPTCL	D	For Routine bay maintenance	24/Feb/2022	10:00	24/Feb/2022	18:00		PLANNED	Approved	24-Feb-22	10:00	24-Feb-22	18:00	
392	RQ80941	OCC_ 191	stuup_sd	AC TRANS MISSIO N LINE CIRCUIT		UPPTCL	D	shut down required for painting of high voltage insulation	24/Feb/2022	08:00	28/Feb/2022	17:00		PLANNED	Approved	24-Feb-22	08:00	28-Feb-22	17:00	
393	RQ81027	OCC_ 191	stuup_sd	AC TRANS MISSIO N LINE CIRCUIT	400 KV AGRA- AGRA FATEHBAD (UP) CKT-1	UPPTCL	D	Jumper Change & tightening	22/Feb/2022	10:00	23/Feb/2022	17:00		PLANNED	Approved	22-Feb-22	10:00	23-Feb-22	17:00	
394	RQ80939	OCC_ 191	stuup_sd	MISSIO	ALIGARH- MURADNAGA R_1 (UP) CKT-	UPPTCL		Jumper tighteing and misc. line maintenance work. 2. Replacement of disc insulator by polymer insulator at critical locations.	20/Feb/2022	10:00	22/Feb/2022	18:00	There will be no any supply interruption due to this shut down	PLANNED	Approved	20-Feb-22	10:00	22-Feb-22	18:00	
395	RQ81054	OCC_ 191	stuup_sd	MISSIO	400 KV AGRA FATEHBAD- AGRA SOUTH (UP) CKT-1	UPPTCL	D	Routine maintenance of line and bay	19/Feb/2022	09:00	21/Feb/2022	17:00		PLANNED	Approved	19-Feb-22	09:00	21-Feb-22	17:00	
396	RQ80982	OCC_ 191	stuup_sd		400 KV BAREILLY- UNNAO (UP) CKT-1	UPPTCL	D	1. Testing of Circuit Breakers, CTs, CVTs and Line Reactor Bushing at 400 KV S/S Unnao. 2. preventive maintenace	19/Feb/2022	09:00	19/Feb/2022	17:00		PLANNED	Approved	19-Feb-22	09:00	19-Feb-22	17:00	
397	RQ80964	OCC_ 191	stuup_sd	1	TANDA(NT)- AZAMGARH(UP) (UP) CKT-	UPPTCL		For configuration of additional feature in Distance protection Relay & testing of same, General Maintenance	18/Feb/2022	10:00	19/Feb/2022	18:00		PLANNED	Approved	18-Feb-22	10:00	19-Feb-22	18:00	

	RQ80958	191		MISSIO N LINE CIRCUIT	MURADNAGA R_2- MATHURA (UP) CKT-1	UPPTCL		RRTS Corridor work of NCRTC under 400 KV Mathura(Manth)- Muradnagar Line between Tower no 497A(Monopole)- 498B .	18/Feb/2022		28/Feb/2022		(Electrical), NCRTC , Ghaziabad requested for 18.02.2022 to 28.02.2022 Shutdown of 400 KV Mathura- Muradnagar Line for RRTS corridor work.	PLANNED	Approved	18-Feb-22	07:00	28-Feb-22	21:00	
399	RQ80981	OCC_ 191	stuup_sd	MISSIO	UNNAO- LUCKNOW (UP) CKT-1	UPPTCL		1. Diversion / Height raising work due to construction of outer ring road for NHAI. 2.Routine Protection Testing and Preventive Maintenance of Bay at 400 KV S/S Unnao.	17/Feb/2022	08:00	27/Feb/2022	17:00	Diversion / Height raising work due to construction of outer ring road for NHAI		Approved	17-Feb-22	08:00	27-Feb-22		Require CEA clearance before charging/ANNEXUR E B-7 UNDERTAKING/
400	RQ80946	OCC_ 191	stuup_sd	MISSIO	400 KV AGRA FATEHBAD- MATHURA (UP) CKT-2	UPPTCL	D	Jumper Change & tightening	15/Feb/2022	10:00	16/Feb/2022	17:00		PLANNED	Approved	15-Feb-22	10:00	16-Feb-22	17:00	
401	RQ80942	OCC_ 191	stuup_sd		400 KV REWA ROAD-PANKI (UP) CKT-1	UPPTCL		Shifting of panki- reewa road bay from Bay no. 406 to Bay no. 407 at 400 KV S/S Panki	13/Feb/2022	08:00	17/Feb/2022	17:00		PLANNED	Approved	13-Feb-22	08:00	17-Feb-22		FTC/CEA SAFETY CLEARANCE REQUIRED

402	RQ80938		stuup_sd			UPPTCL	D	For Tree triming	12/Feb/2022	10:30	12/Feb/2022	17:30	There will	PLANNED	Approved	12-Feb-22	10:30	12-Feb-22	17:30	
		191		TRANS MISSIO	GR.NOIDA_2(be no any							
					GR.NOIDA(UP								supply interruption							
					C) (UP) CKT-2								due to this							
													shut down							
													.Load of sub							
													station will be feed							
													through							
													400KV							
													(765KV S/S)							
													Greater							
													Noida to 400KV Sub							
													station							
													Greater							
													Noida ckt-i ,							
													400Kv Dadri Line and							
													400KV							
													Nawada							
													Line.							
403	RQ80937		stuup_sd			UPPTCL	D	For Routine bay	10/Feb/2022	10:00	10/Feb/2022	18:00		PLANNED	Approved	10-Feb-22	10:00	10-Feb-22	18:00	
		191			OBRA_B- SULTANPUR			maintenance												
					(UP) CKT-1															
				CIRCUIT																
404	RQ80569	occ	stuun sd	AC	400 KV AGRA	LIPPTCI	D	1. AMP of 400kV	08/Feb/2022	08:00	09/Feb/2022	18:00	Shutdown	PLANNED	Approved	08-Feb-22	08:00	09-Feb-22	18:00	
		191	staap_sa		SOUTH(UP)-	011102		Firozabad- Agra	00,100,2022	00.00	03/102/2022	20.00	will be		7.pp.01cu	00.00.22	00.00	05 105 22	10.00	
					FIROZABAD(P			South Line .					taken on							
				N LINE CIRCUIT	JFTL) (UP)			2.Routine					Daily basis							
				CIRCUIT	CKI-1			maintenance of line and bay.												
405	RQ80567		stuup_sd			UPPTCL		Testing of Line CT,	07/Feb/2022	10:00	08/Feb/2022	17:00	Annual	PLANNED	Approved	07-Feb-22	10:00	08-Feb-22	17:00	
		191			ANPARA-			Line CVT, LA, Bay					Testing of							
					ANPARA_D (UP) CKT-1			CT and Circuit breaker (Main Bay-					Line and Bay Equipments							
				CIRCUIT				404 and Tie bay-					Equipments							
								405)												
406	RQ80940	OCC_ 191	stuup_sd		400 KV MUZAFFARN	UPPTCL	1	Lopping chopping of trees ,jumper	07/Feb/2022	08:00	11/Feb/2022	17:00		PLANNED	Approved	07-Feb-22	08:00	11-Feb-22	17:00	
		191			AGAR-ATAUR			teightening &												
					(UP) CKT-1			damaged												
		1		LOUDGLUT	I	ı	ı	1												
				CIRCUIT				conductor repair												

407	RQ80963	OCC_ 191	stuup_sd	MISSIO	BANDA- REWA ROAD (UP) CKT-2	UPPTCL	D	For work of Installation of Counters (for Tx & Rx) in PLCC Cabinets of 400 KV Banda-Rewaroad D/C lines	06/Feb/2022	08:00	07/Feb/2022	18:00	Above work will be done by M/S ZIV engineer	PLANNED	Approved	06-Feb-22	08:00	07-Feb-22	18:00	
408	RQ80962	OCC_ 191	stuup_sd	TRANS MISSIO	BANDA- REWA ROAD (UP) CKT-1	UPPTCL	D	For work of Installation of Counters (for Tx & Rx) in PLCC Cabinets of 400 KV Banda-Rewaroad D/C lines	04/Feb/2022	08:00	05/Feb/2022	18:00	Above work will be done by M/S ZIV engineer	PLANNED	Approved	04-Feb-22	08:00	05-Feb-22	18:00	
409	RQ80983	OCC_ 191	stuup_sd	MISSIO	BAREILLY- UNNAO (UP) CKT-2	UPPTCL		1. for repalcement of old defctive circuit breaker with new spring charge . 2. Testing of Circuit Breakers, CTs, CVTs and Line Reactor Bushing at 400 KV S/S Unnao.	01/Feb/2022	10:00	20/Feb/2022	19:00	line will remain energised through transfer bus	PLANNED	Rejected					deferred to next OCC
410	RQ80570	OCC_ 191	stuup_sd	TRANS MISSIO N LINE	400 KV AGRA FATEHBAD(U P)- FIROZABAD(P JFTL) (UP) CKT-1	UPPTCL	D	1. AMP of 400kV Firozabad-765kV Fatehabad Line. 2. Replacement of B Phase CVT at Fatehabad end.	01/Feb/2022	08:00	02/Feb/2022	18:00	Shutdown will be taken on Daily basis	PLANNED	Approved	01-Feb-22	08:00	02-Feb-22	18:00	State electrical inspector approval required
411	RQ80943	OCC_ 191	stuup_sd		400 KV PANKI- ALIGARH (UP) CKT-1	UPPTCL	D	Bay tightening and Maintenance.	01/Feb/2022	08:00	02/Feb/2022			PLANNED	Approved	01-Feb-22	08:00	02-Feb-22	17:00	
412	RQ81602	OCC_ 191	cpcc2_sd	TRANS MISSIO N LINE		JPL,HB PCL	D	Non-auto mode required for OPGW installation works under ULDC scheme.	25/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	25-Feb-22	07:00	28-Feb-22	18:00	

413	RQ81656	OCC_ 191	cpcc2_sd	TRANS MISSIO N LINE		JPL,HB PCL	D	SD required for re- installation of Aviation Globules after installation of OPGW under ULDC scheme. Non-auto mode is required on 400kV Baspa - Karcham Wangtoo ckt-1.	21/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	21-Feb-22	07:00	28-Feb-22	18:00	
414	RQ81655	OCC_ 191	cpcc2_sd	MISSIO N LINE CIRCUIT		JPL,HB PCL	D	SD required for re- installation of Aviation Globules after installation of OPGW under ULDC scheme. Non-auto mode is required on 400kV Karcham Wangtoo- Nathpajhakri ckt-2.	16/Feb/2022	07:00	24/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	16-Feb-22	07:00	24-Feb-22	18:00	
415	RQ81598	OCC_ 191	cpcc2_sd	MISSIO N LINE CIRCUIT		JPL,HB PCL	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	15/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	15-Feb-22	18:00	
416	RQ81607	OCC_ 191	cpcc2_sd	MISSIO N LINE		JPL,HB PCL	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	20/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	20-Feb-22	18:00	
	RQ81606	191	· -	MISSIO N LINE CIRCUIT	BASPA(JP)- KARCHAM WANGTOO(JS W) (HBPCL) CKT-1	JPL,HB PCL	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	
418	RQ81599	OCC_ 191	cpcc2_sd	MISSIO N LINE CIRCUIT		JPL,HB PCL	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	

419	RQ81707	OCC_ 191	cpcc2_sd	MISSIO	PARBATI_2(N H)-SAINJ(HP) (PKTCL) CKT-1	PKTCL	D	Non-auto mode required for OPGW installation works under ULDC scheme.	25/Feb/2022	07:00	28/Feb/2022 1		Kindly approve	PLANNED	Rejected					Consent denied by indigrid
420	RQ81664	OCC_ 191	cpcc2_sd	MISSIO	400 KV PARBATI_3(N H)-SAINJ(HP) (PKTCL) CKT-1	PKTCL	D	SD required for removal of Aviation Globules for OPGW installation works under ULDC scheme.	25/Feb/2022	07:00	28/Feb/2022 1		Kindly approve.	PLANNED	Rejected					Consent denied by indigrid
421	RQ81708	OCC_ 191	cpcc2_sd		PARBATI_3(N H)-SAINJ(HP) (PKTCL) CKT-1	PKTCL	D	Non-auto mode required for OPGW installation works under ULDC scheme.	21/Feb/2022	07:00	24/Feb/2022 1	8:00	Kindly approve	PLANNED	Rejected					Consent denied by indigrid
422	RQ81661	OCC_ 191	cpcc2_sd		PARBATI_2(N H)-SAINJ(HP) (PKTCL) CKT-1	PKTCL	D	SD required for removal of Aviation Globules for OPGW installation works under ULDC scheme.	21/Feb/2022	07:00	24/Feb/2022 1	8:00	Kindly approve.	PLANNED	Rejected					Consent denied by indigrid
423	RQ81632	OCC_ 191	cpcc2_sd		PARBATI_3(N H)-SAINJ(HP) (PKTCL) CKT-1	PKTCL	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	20/Feb/2022 1	8:00	Kindly approve.	PLANNED	Rejected					Consent denied by indigrid
424	RQ81631	OCC_ 191	cpcc2_sd		400 KV PARBATI_2(N H)-SAINJ(HP) (PKTCL) CKT-1	PKTCL	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	20/Feb/2022 1		Kindly approve.	PLANNED	Rejected					Consent denied by indigrid
425	RQ81470	OCC_ 191	bbmb_sd	MISSIO N LINE	PANCHKULA(POWER GRID,B BMB		For change earthwire from TL No. 660-662	23/Feb/2022	08:00	25/Feb/2022 1	.8:00		PLANNED	Approved	23-Feb-22	08:00	25-Feb-22	18:00	

	RQ81654	191		TRANS MISSIO N LINE CIRCUIT	S(HP)- SORANG(GRE	HPPTCL ,JPL,GR EENKO	D	SD Required for re- installation of Aviation Globules after installation of OPGW under ULDC scheme. Non-auto mode is required on 400kV Kala Amb -Wangtoo ckt- 1.			28/Feb/2022		Kindly approve.	PLANNED	Approved	23-Feb-22	07:00	28-Feb-22	18:00	
427	RQ81595	OCC_ 191	cpcc2_sd	TRANS MISSIO	SORANG(GRE	HPPTCL ,JPL,GR EENKO	D	Non-auto mode required for OPGW installation works under ULDC scheme.	16/Feb/2022	07:00	22/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	16-Feb-22	07:00	22-Feb-22	18:00	
428	RQ81653	OCC_ 191	cpcc2_sd	MISSIO	SORANG(GRE	HPPTCL ,JPL,GR EENKO	D	SD Required for re- installation of Aviation Globules after installation of OPGW under ULDC scheme. Non-auto mode is required on 400kV Kala Amb -Wangtoo ckt- 1.	06/Feb/2022	07:00	15/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	06-Feb-22	07:00	15-Feb-22	18:00	
	RQ81593	191		TRANS MISSIO N LINE CIRCUIT	S(HP)- SORANG(GRE	HPPTCL ,JPL,GR EENKO	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	05/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	05-Feb-22	18:00	
430	RQ81628	OCC_ 191	cpcc2_sd	TRANS MISSIO N LINE	400 KV KOLDAM(NT)- PARBATI POOLING BANALA(PG) (PKTCL) CKT-1	PKTCL, POWER GRID	D	Non-auto mode required for OPGW installation works under ULDC scheme.	23/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Rejected					Consent denied by indigrid
431	RQ81660	OCC_ 191	cpcc2_sd	MISSIO N LINE	400 KV KOLDAM(NT)- PARBATI POOLING BANALA(PG) (PKTCL) CKT-1	PKTCL, POWER GRID	D	SD required for re- installation of Aviation Globules after installation of OPGW under ULDC scheme. Non-auto mode is required on 400kV Nalagarh- Banala Ckt-I.	10/Feb/2022	07:00	22/Feb/2022	18:00	Kindly approve.	PLANNED	Rejected					Consent denied by indigrid

	RQ81627	191		MISSIO N LINE CIRCUIT	400 KV KOLDAM(NT)- PARBATI POOLING BANALA(PG) (PKTCL) CKT-1	GRID	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	09/Feb/2022		Kindly approve.	PLANNED	Rejected					Consent denied by indigrid
433	RQ81673	OCC_ 191	cpcc2_sd	MISSIO N LINE	400 KV PARBATI_3(N H)-PARBATI POOLING BANALA(PG) (PKTCL) CKT-1	PKTCL, POWER GRID	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	
434	RQ81652	OCC_ 191	cpcc2_sd	MISSIO N LINE		PKATL,J PL,GRE ENKO	D	SD required for re- installation of Aviation Globules after installation of OPGW under ULDC scheme. Non-auto mode is required on 400kV Kala Amb-Wangtoo ckt- 1.	23/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	23-Feb-22	07:00	28-Feb-22	18:00	
435	RQ81590	OCC_ 191	cpcc2_sd	MISSIO N LINE		PKATL,J PL,GRE ENKO	D	Non-auto mode required for OPGW installation works under ULDC scheme.	16/Feb/2022	07:00	22/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	16-Feb-22	07:00	22-Feb-22	18:00	
		191	cpcc2_sd	MISSIO N LINE	AMB(PKTL)- SORANG(GRE ENKO) (GREENKO) CKT-1		D	SD required for re- installation of Aviation Globules after installation of OPGW under ULDC scheme. Non-auto mode is required on 400kV Kala Amb-Wangtoo ckt- 1.	06/Feb/2022		15/Feb/2022		Kindly approve.	PLANNED	Approved	06-Feb-22	08:00	15-Feb-22	18:00	
437	RQ81587	OCC_ 191	cpcc2_sd	MISSIO N LINE		PKATL,J PL,GRE ENKO	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	05/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	05-Feb-22	18:00	

	RQ81079	191		MISSIO N LINE	400 KV LUCKNOW_1(PG)- BASTI(UP) (PG) CKT-2	POWER GRID,U PPTCL	С	Transmission Line Diversion work due to construction of Outer Ring Road by NHAI	22/Feb/2022		03/Mar/2022		PLANNED	Rejected					Duplicate entry
439	RQ81007	OCC_ 191	sldchr_sd	MISSIO N LINE	400 KV GR.NOIDA(UP C)- NAWADA(HV) (PG) CKT-1	PPTCL	D	For gen mtc for TIE- 1, and line bay	21/Feb/2022	10:00	21/Feb/2022	16:00	PLANNED	Approved	21-Feb-22	10:00	21-Feb-22	16:00	
440	RQ80572	OCC_ 191	stuup_sd	MISSIO	400 KV DADRI(NT)- GR.NOIDA(UP C) (PG) CKT-1	POWER GRID,U PPTCL	D	For general maintenance & routine testing work.	18/Feb/2022	10:30	18/Feb/2022	15:00	PLANNED	Approved	18-Feb-22	10:30	18-Feb-22	15:00	
	RQ80945	191		MISSIO N LINE	400 KV AGRA(UP)- AGRA FATEHBAD(U P) (PG) CKT-2	POWER GRID,U PPTCL	D	Jumper Change & tightening	18/Feb/2022	10:00	18/Feb/2022	17:00	PLANNED	Approved	18-Feb-22	10:00	18-Feb-22	17:00	
442	RQ80949	OCC_ 191	stuup_sd	MISSIO N LINE	400 KV AGRA(PG)- AGRA FATEHBAD(U P) (PG) CKT-1	POWER GRID,U PPTCL	D	Jumper Change & tightening	17/Feb/2022	10:00	17/Feb/2022	17:00	PLANNED	Approved	17-Feb-22	10:00	17-Feb-22	17:00	
443	RQ81006	OCC_ 191	cpcc3_sd	MISSIO N LINE	400 KV UNNAO(UP)- JEHTA_HARD OI ROAD (UP) (PG) CKT-2	POWER GRID,U PPTCL	D	AMP WORK	10/Feb/2022	08:00	10/Feb/2022	18:00	PLANNED	Approved	10-Feb-22	08:00	10-Feb-22	18:00	
444	RQ81005	OCC_ 191	cpcc3_sd	MISSIO N LINE	400 KV UNNAO(UP)- JEHTA_HARD OI ROAD (UP) (PG) CKT-1		D	AMP work	08/Feb/2022	08:00	08/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	08:00	08-Feb-22	18:00	
445	RQ81077	OCC_ 191	cpcc3_sd	MISSIO N LINE	400 KV LUCKNOW_1(PG)- LUCKNOW(U P) (PG) CKT-1	POWER GRID,U PPTCL	С	Transmission Line Diversion work due to construction of Outer Ring Road by NHAI	04/Feb/2022	08:00	13/Feb/2022	18:00	PLANNED	Approved	04-Feb-22	08:00	13-Feb-22	18:00	Require CEA clearance before charging/ANNEXUR E B-7 UNDERTAKING/one S/D from Lucknow at a time from lucknow PG

446	RQ81076	OCC_ 191	cpcc3_sd	TRANS MISSIO N LINE		POWER GRID,U PPTCL	Transmission Line Diversion work due to construction of Outer Ring Road by NHAI	04/Feb/2022	08:00	13/Feb/2022	18:00		PLANNED	Approved	04-Feb-22	08:00	13-Feb-22	18:00	Require CEA clearance before charging/ANNEXUR E B-7 UNDERTAKING/one S/D from Lucknow at a time from lucknow PG
447	RQ80935	OCC_ 191	stuup_sd	MISSIO N LINE	400 KV LUCKNOW_1(PG)- LUCKNOW(U P) (PG) CKT-1	POWER GRID,U PPTCL	Diversion / Height raising work due to construction of outer ring road for NHAI	02/Feb/2022	08:00	15/Feb/2022	17:30	Diversion / Height raising work due to construction of outer ring road for NHAI	PLANNED	Rejected					Duplicate entry
448	RQ80934	OCC_ 191	stuup_sd	TRANS MISSIO N LINE	SULTANPUR(POWER GRID,U PPTCL	For Routine bay maintenance	01/Feb/2022	10:00	01/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	10:00	01-Feb-22	18:00	
449	RQ81348	OCC_ 191	cpcc1_sd	MISSIO N LINE	400 KV GR.NOIDA(UP C)- NAWADA(HV) (PG) CKT-1	POWER GRID,U PPTCL	Relay setting may be changed from Auto reclose to Non-auto reclose mode for OPGW LIVE LINE stringing works under Reliable Communication scheme	01/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	Only one non Auto from nawada end
450	RQ81295	OCC_ 191	sldcrs_sd	TRANS MISSIO	(PG) CKT-1	POWER GRID,R RVPNL	Quarterly Maintenance work at 400KV GSS Bhadla along with 50 MVAR line reactor at Bhadla	21/Feb/2022	16:00	21/Feb/2022	22:00		PLANNED	Rejected					consent denied by powergrid.deferred to next occ
451	RQ81615	OCC_ 191	cpcc2_sd	TRANS MISSIO N LINE	400 KV KARCHAM WANGTOO(JS W)- WANGTO_GI S(HP) (HPPTCL) CKT- 2	HPPTCL ,JPL	Non-auto mode required for OPGW installation works under ULDC scheme.	21/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	21-Feb-22	07:00	28-Feb-22	18:00	

452	RQ81657	OCC_ 191	cpcc2_sd	MISSIO N LINE CIRCUIT	400 KV KARCHAM WANGTOO(JS W)- WANGTO_GI S(HP) (HPPTCL) CKT- 2	HPPTCL ,JPL	D	SD required for re- installation of Aviation Globules after installation of OPGW under ULDC scheme. Non-auto mode is required on 400kV Karcham Wangtoo- Wangtoo Ckt-1.	15/Feb/2022	07:00	20/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	15-Feb-22	07:00	20-Feb-22	18:00	
453	RQ81612	OCC_ 191	cpcc2_sd	MISSIO N LINE CIRCUIT	400 KV KARCHAM WANGTOO(JS W)- WANGTO_GI S(HP) (HPPTCL) CKT- 2	HPPTCL ,JPL	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	14/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	14-Feb-22	18:00	
454	RQ81611	OCC_ 191	cpcc2_sd	TRANS MISSIO N LINE CIRCUIT	400 KV KARCHAM WANGTOO(JS W)- WANGTO_GI S(HP) (HPPTCL) CKT-	HPPTCL ,JPL	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	
455	RQ81171	OCC_ 191	sldcdv_sd	TRANS MISSIO	400 KV BAWANA- MUNDKA (DV) CKT-2	DTL	С	commissioning of BCPU/MU under PSDF scheme.	16/Feb/2022	10:00	17/Feb/2022	22:00		PLANNED	Approved	16-Feb-22	10:00	17-Feb-22	22:00	
456	RQ81170	OCC_ 191	sldcdv_sd	MISSIO	400 KV BAWANA- MUNDKA (DV) CKT-1	DTL	С	commissioning of BCPU/MU under PSDF scheme.	14/Feb/2022	10:00	15/Feb/2022	22:00		PLANNED	Approved	14-Feb-22	10:00	15-Feb-22	22:00	
457	RQ81169	OCC_ 191	sldcdv_sd	MISSIO N LINE	MANDOLA(P	DTL	С	commissioning of BCPU/MU under PSDF scheme.	11/Feb/2022	10:00	12/Feb/2022	22:00		PLANNED	Approved	11-Feb-22	10:00	12-Feb-22	22:00	
458	RQ81168	OCC_ 191	sldcdv_sd	MISSIO N LINE	400 KV MANDOLA(P G)- BAWANA(DV) (DV) CKT-1	DTL	С	commissioning of BCPU/MU under PSDF scheme.	09/Feb/2022	10:00	10/Feb/2022	22:00		PLANNED	Approved	09-Feb-22	10:00	10-Feb-22	22:00	

459	RQ81108	OCC_ 191	apl_sd	MISSIO N LINE	400 KV MAHINDERG ARH(APL)- DHANODA(H V) (ATIL) CKT- 2	ATIL	C	Continous shutdown required for completion of all erection activities of New 12 ohm Series Reactor for 400 KV MAHINDERGARH(APL)- DHANODA(HV) (ATIL) CKT-2.	16/Feb/2022	08:00	28/Feb/2022	18:00	Continous shutdown required for completion of all erection activities of New 12 ohm Series Reactor for 400 KV MAHINDER GARH(APL)-DHANODA(HV) (ATIL) CKT-2.	PLANNED	Approved	16-Feb-22	08:00	28-Feb-22	18:00	HVDC Mahindergarh to be restricted to 1750 MW. ATC Curtailment of 200- 250 MW.
460	RQ81107	OCC_ 191	apl_sd	MISSIO N LINE	400 KV MAHINDERG ARH(APL)- DHANODA(H V) (ATIL) CKT- 1	ATIL		Continous shutdown required for completion of all erection activities of New 12 ohm Series Reactor for 400 KV MAHINDERGARH(APL)- DHANODA(HV) (ATIL) CKT-1.	01/Feb/2022	08:00	15/Feb/2022	18:00	Continous shutdown required for completion of all erection activities of New 12 ohm Series Reactor for 400 KV MAHINDER GARH(APL)-DHANODA(HV) (ATIL) CKT-1.	PLANNED	Approved	01-Feb-22	08:00	15-Feb-22	18:00	HVDC Mahindergarh to be restricted to 1750 MW. ATC Curtailment of 200- 250 MW.
461	RQ81371	OCC_ 191	indigrid_sd	TRANS MISSIO	400 KV KADARPUR - PRITHALA (GPTL) CKT-2	GPTL	D	Annual preventive maintenance	16/Feb/2022	08:00	16/Feb/2022	20:00	AMP Work	PLANNED	Approved	16-Feb-22	08:00	16-Feb-22	20:00	
462	RQ81370	OCC_ 191	indigrid_sd	TRANS MISSIO	400 KV KADARPUR - SOHNA ROAD (GPTL) CKT-1	GPTL		Annual preventive maintenance	14/Feb/2022	08:00	14/Feb/2022	20:00	AMP Work	PLANNED	Approved	14-Feb-22	08:00	14-Feb-22	20:00	

463	RQ81706	OCC_ 191	cpcc2_sd	MISSIO N LINE	AMB(PKTL)- WANGTO_GI		D	SD required for re- installation of Aviation Globules after installation of OPGW under ULDC scheme. Non Auto mode is required on 400kV Kala Amb-Sorang ckt-1 & 400kV Sorang- Wangtoo ckt-1.	16/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve	PLANNED	Approved	16-Feb-22	07:00	28-Feb-22	18:00	
464	RQ81649	OCC_ 191	cpcc2_sd	MISSIO N LINE	AMB(PKTL)- WANGTO_GI	PKATL, HPPTCL ,JPL	D	Non-auto mode required for OPGW installation works under ULDC scheme.	16/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	16-Feb-22	07:00	28-Feb-22	18:00	
465	RQ81583	OCC_ 191	cpcc2_sd	MISSIO N LINE	400 KV KALA AMB(PKTL)- WANGTO_GI S(HP) (HPPTCL) CKT- 1		D	Non-auto mode required for OPGW installation works under ULDC scheme.	11/Feb/2022	07:00	15/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	11-Feb-22	07:00	15-Feb-22	18:00	
	RQ81648	191		MISSIO N LINE	AMB(PKTL)- WANGTO_GI S(HP) (HPPTCL) CKT- 1			SD required for re- installation of Aviation Globules after installation of OPGW under ULDC scheme. Non Auto mode is required on 400kV Kala Amb-Sorang ckt-1 & 400kV Sorang- Wangtoo ckt-1.	01/Feb/2022	07:00	10/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	10-Feb-22	18:00	
467	RQ81100	OCC_ 191	sldcuk_sd	MISSIO N LINE	400 KV RISHIKESH(UK)- NEHTAUR(UP) (UK) CKT-1	PTCUL	D	for lopping chopping of trees and removing of bird nest and maintenance work	15/Feb/2022	09:00	15/Feb/2022	17:00		PLANNED	Approved	15-Feb-22	09:00	15-Feb-22	17:00	
468	RQ81315	OCC_ 191	sldcrs_sd		400 KV ALWAR(ATIL)- HINDAUN(RS) (ATIL) CKT-1	ATSL	D	Shutdown required for Annual maintenance of transmission Line.	15/Feb/2022	08:00	15/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	08:00	15-Feb-22	18:00	

469	RQ81549	OCC_ 191	cpcc2_sd	TRANS MISSIO N LINE	400 KV ABDULLAPUR (PG)-KALA AMB(PKTL) (JPL) CKT-1	PKATL,J PL	D	For line bay AMP works at Abdullapur SS.	11/Feb/2022	09:00	11/Feb/2022	15:00	Kindly approve	PLANNED	Approved	11-Feb-22	09:00	11-Feb-22	15:00	
470	RQ81601	OCC_ 191	cpcc2_sd	TRANS MISSIO N LINE CIRCUIT		POWER GRID,P ATRAN		For AMP works with non-auto reclose mode on 400kV Kaithal- Patran ckt-1 during shut down period.	03/Feb/2022	10:00	03/Feb/2022	12:00	Kindly approve	PLANNED	Approved	03-Feb-22	10:00	03-Feb-22	12:00	
471	RQ81600	OCC_ 191	cpcc2_sd	TRANS MISSIO N LINE	400 KV PATRAN(PAT R)- KAITHAL(PG) (PATRAN) CKT-1	POWER GRID,P ATRAN	D	For AMP works with non-auto reclose mode on 400kV Kaithal- Patran ckt-2 during shut down period.	01/Feb/2022	10:00	01/Feb/2022	12:00	Kindly approve	PLANNED	Approved	01-Feb-22	10:00	01-Feb-22	12:00	
472	RQ80994	OCC_ 191	sldcdv_sd	TRANS MISSIO N LINE CIRCUIT		POWER GRID,D TL		For Line CVT Tan Delta Testing as per PMS Schedule.	02/Feb/2022	12:30	02/Feb/2022	17:00		PLANNED	Approved	02-Feb-22	12:30	02-Feb-22	17:00	
473	RQ80993	OCC_ 191	sldcdv_sd	TRANS MISSIO N LINE CIRCUIT	400 KV BAMNOLI(DV)- TUGHLAKABA D(PG) (DTL) CKT-1	POWER GRID,D TL		For Line CVT Tan Delta Testing as per PMS Schedule.	02/Feb/2022	08:00	02/Feb/2022	12:30		PLANNED	Approved	02-Feb-22	08:00	02-Feb-22	12:30	
474	RQ80996	OCC_ 191	sldcdv_sd	AC TRANS MISSIO N LINE	400 KV BAMNOLI(DV)- JHATIKARA(P G) (DTL) CKT- 2	POWER GRID,D TL		For Line CVT Tan Delta Testing as per PMS Schedule.	01/Feb/2022	12:30	01/Feb/2022	17:00		PLANNED	Approved	01-Feb-22	12:30	01-Feb-22	17:00	
475	RQ80995	OCC_ 191	sldcdv_sd	TRANS MISSIO N LINE	400 KV BAMNOLI(DV)- JHATIKARA(P G) (DTL) CKT- 1	POWER GRID,D TL		For Line CVT Tan Delta Testing as per PMS Schedule.	01/Feb/2022	08:00	01/Feb/2022	12:30		PLANNED	Approved	01-Feb-22	08:00	01-Feb-22	12:30	

4	76 R	Q81404	OCC_ 191	cpcc1_sd	TRANS MISSIO N LINE	400 KV BAMNOLI(DV)- JHATIKARA(P G) (DTL) CKT- 2	POWER GRID,D TL	For connecting LILO Line with Ckt- 1 of 400KV D/C Bamnauli-Jhatikala Line	01/Feb/2022	07:00	02/Feb/2022	18:30	Due to Pollution restrictions imposed by (Governmen tNational Green Tribunal Act, 2010), the S/d of 400KV D/C Bamnauli- Jhatikala Line could not be availed in Dec 2021.S/D may be availed from 28.01.22 to 29.01.22	Approved	01-Feb-22	07:00	02-Feb-22	to be taken on weekend.Require CEA clearance/FTC clearance before availing shutdown
4	77 R	Q81403	OCC_ 191	cpcc1_sd	TRANS MISSIO N LINE	400 KV BAMNOLI(DV)- JHATIKARA(P G) (DTL) CKT- 1	POWER GRID,D TL	For connecting LILO Line with Ckt- 1 of 400KV D/C Bamnauli-Jhatikala Line	01/Feb/2022	07:00	02/Feb/2022	18:30	Due to Pollution restrictions imposed by (Governmen tNational Green Tribunal Act, 2010), the S/d of 400KV D/C Bamnauli- Jhatikala Line could not be availed in Dec 2021.S/D may be availed from 28.01.22 to 29.01.22	Approved	01-Feb-22	07:00	02-Feb-22	to be taken on weekend.Require CEA clearance/FTC clearance before availing shutdown

	RQ81120	191		TRANS MISSIO N LINE CIRCUIT	UNCHAHAR(NTB) (PUTL) CKT-1	PUTL	D	For Relay testing	01/Feb/2022		01/Feb/2022			PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	18:00	
479	RQ81350	OCC_ 191	cpcc1_sd	TRANS MISSIO	400 KV NEEMRANA(P G)-BABAI(RS) (NRSS36) CKT- 1	RSS36	D	Auto Reclose off is required for OPGW rectification works under Fibre Optics Communication Package (Additional Requirement)	01/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	18:00	
480	RQ81646	OCC_ 191	cpcc2_sd	TRANS MISSIO	A(PG)- MALERKOTLA		D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Rejected					Consent denied by Sekura
481	RQ81647	OCC_ 191	cpcc2_sd	MISSIO	MALERKOTLA		D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Rejected					Consent denied by Sekura
482	RQ81189	OCC_ 191	sldcrs_sd		400KV BUS 2 AT BHADLA(RS)	RRVPN L	D	Quarterly Maintenance work at 400KV GSS Bhadla	28/Feb/2022	16:00	28/Feb/2022	22:00		PLANNED	Approved	28-Feb-22	16:00	28-Feb-22	22:00	
483	RQ81198	OCC_ 191	sldcrs_sd		400KV BUS 2KANKANI(RS)	RRVPN L	D	Preventive Maintenance work and Testing of Bay & Equipments	28/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	28-Feb-22	08:00	28-Feb-22	18:00	
484	RQ81197	OCC_ 191	sldcrs_sd	BUS	400KV BUS 1KANKANI(RS)	RRVPN L	D	Preventive Maintenance work and Testing of Bay & Equipments	27/Feb/2022	08:00	27/Feb/2022	18:00		PLANNED	Approved	27-Feb-22	08:00	27-Feb-22	18:00	
485	RQ81184	OCC_ 191	sldcrs_sd		400KV BUS 2 AT MERTA(RS)	RRVPN L	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	25/Feb/2022	08:00	25/Feb/2022	18:00		PLANNED	Approved	25-Feb-22	08:00	25-Feb-22	18:00	
486	RQ80800	OCC_ 191	sldcrs_sd	1	400KV BUS 2 AT ANTA(RS)	RRVPN L	D	IInd HALF YEARLY MAINTENANCE	25/Feb/2022	08:00	25/Feb/2022	18:00		PLANNED	Approved	25-Feb-22	08:00	25-Feb-22	18:00	

487	RQ81183	OCC_ 191	sldcrs_sd	BUS	400KV BUS 1 AT MERTA(RS)	RRVPN L	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	24/Feb/2022	08:00	24/Feb/2022	18:00	PLANNED	Approved	24-Feb-22	08:00	24-Feb-22	18:00	
488	RQ81187	OCC_ 191	sldcrs_sd	BUS	400KV BUS 1 AT BABAI(RS)		D	Quarterly Maintenance	24/Feb/2022	08:00	24/Feb/2022	18:00	PLANNED	Approved	24-Feb-22	08:00	24-Feb-22	18:00	
489	RQ81191	OCC_ 191	sldcrs_sd	BUS	AT CHITTORGAR H(RS)	RRVPN L	С	FOR MAINTAINCE WORK and Testing work of Bus (its connected isolators and breakers)	23/Feb/2022	09:30	25/Feb/2022	16:00	PLANNED	Approved	23-Feb-22	09:30	25-Feb-22	16:00	
490	RQ80799	OCC_ 191	sldcrs_sd	BUS	400KV BUS 1 AT ANTA(RS)		D	IInd HALF YEARLY MAINTENANCE	23/Feb/2022	08:00	23/Feb/2022	18:00	PLANNED	Approved	23-Feb-22	08:00	23-Feb-22	18:00	
491	RQ81188	OCC_ 191	sldcrs_sd	BUS	400KV BUS 2 AT BABAI(RS)		D	Quarterly Maintenance	17/Feb/2022	08:00	17/Feb/2022	18:00	PLANNED	Approved	17-Feb-22	08:00	17-Feb-22	18:00	
492	RQ81196	OCC_ 191	sldcrs_sd	BUS	AT RATANGARH(RS)	RRVPN L	D	Maintenance work of bay equipments, isolators and testing work of bay equipments.	12/Feb/2022	08:00	12/Feb/2022	18:00	PLANNED	Approved	12-Feb-22	08:00	12-Feb-22	18:00	
493	RQ81195	OCC_ 191	sldcrs_sd	BUS	400KV BUS 2 AT HINDAUN(RS)	L	D	Half yearly Maintenance & testing work	10/Feb/2022	08:00	10/Feb/2022	18:00	PLANNED	Approved	10-Feb-22	08:00	10-Feb-22	18:00	
494	RQ81186	OCC_ 191	sldcrs_sd	BUS	400KV BUS 2 AT AKAL(RS)	RRVPN L	D	Quarterly Maintenance	10/Feb/2022	08:00	10/Feb/2022	18:00	PLANNED	Approved	10-Feb-22	08:00	10-Feb-22	18:00	
495	RQ81194	OCC_ 191	sldcrs_sd	BUS	400KV BUS 1 AT HINDAUN(RS)	L	D	Half yearly Maintenance & testing work	09/Feb/2022	08:00	09/Feb/2022	18:00	PLANNED	Approved	09-Feb-22	08:00	09-Feb-22	18:00	
	RQ81190	191		BUS	400KV BUS 1 AT BIKANER(RS)	L	D	Routine Maintenance	09/Feb/2022	08:00	09/Feb/2022		PLANNED	Approved	09-Feb-22	08:00	09-Feb-22	18:00	
497	RQ81185	OCC_ 191	sldcrs_sd	BUS	400KV BUS 1 AT AKAL(RS)	RRVPN L	D	Quarterly Maintenance	08/Feb/2022	08:00	08/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	08:00	08-Feb-22	18:00	
498	RQ80802	OCC_ 191	sldcrs_sd	BUS	400KV BUS 2 AT PHAGI(RS)		D	For Testing Bus Bar Stability (For commissioning work of New ICT-III of 765/400kV, 3*500 MVA)	07/Feb/2022	08:00	07/Feb/2022	18:00	PLANNED	Approved	07-Feb-22	08:00	07-Feb-22	18:00	Could be given

499	RQ80801	OCC_ 191	sldcrs_sd	BUS	400KV BUS 1 AT PHAGI(RS)		D	For Testing Bus Bar Stability (For commissioning work of New ICT-III of 765/400kV, 3*500 MVA)	05/Feb/2022	08:00	05/Feb/2022	18:00	PLAI	NNED	Approved	05-Feb-22	08:00	05-Feb-22	18:00	Could be given
500	RQ81402	OCC_ 191	cpcc1_sd	BUS	400KV BUS 4 AT MANDOLA(P G)	POWER GRID	D	For new Busbar Protection testing	28/Feb/2022	09:30	28/Feb/2022	18:30	PLAI	NNED	Approved	28-Feb-22	09:30	28-Feb-22	18:30	
501	RQ81412	OCC_ 191	cpcc1_sd	BUS	400KV BUS 4 AT BALLABHGAR H(PG)	POWER GRID	D	For Bus Bar Protection Retrofitment work	28/Feb/2022	09:00	28/Feb/2022	18:00	PLAI	NNED	Approved	28-Feb-22	09:00	28-Feb-22	18:00	One BUS S/D at a time
502	RQ81410	OCC_ 191	cpcc1_sd	BUS	400KV BUS 2 AT BALLABHGAR H(PG)	POWER GRID	D	For Bus Bar Protection Retrofitment work	28/Feb/2022	09:00	28/Feb/2022	18:00	PLAI	NNED	Approved	28-Feb-22	09:00	28-Feb-22	18:00	One BUS S/D at a time
503	RQ81401	OCC_ 191	cpcc1_sd	BUS	400KV BUS 3 AT MANDOLA(P G)	POWER GRID	D	For new Busbar Protection testing	27/Feb/2022	09:30	27/Feb/2022	18:30	PLAI	NNED	Approved	27-Feb-22	09:30	27-Feb-22	18:30	
504	RQ81409	OCC_ 191	cpcc1_sd	BUS	400KV BUS 1 AT BALLABHGAR H(PG)	POWER GRID	D	For Bus Bar Protection Retrofitment work	27/Feb/2022	09:00	27/Feb/2022	18:00	PLAI	NNED	Approved	27-Feb-22	09:00	27-Feb-22	18:00	One BUS S/D at a time
505	RQ81411	OCC_ 191	cpcc1_sd	BUS	400KV BUS 3 AT BALLABHGAR H(PG)	POWER GRID	D	For Bus Bar Protection Retrofitment work	27/Feb/2022	09:00	27/Feb/2022	18:00	PLAI	NNED	Approved	27-Feb-22	09:00	27-Feb-22	18:00	One BUS S/D at a time
506	RQ81281	OCC_ 191	cpcc1_sd	BUS	KOTESHWAR(PG) - 400KV - BUS 1	POWER GRID	D	FOR AMP WORK	27/Feb/2022	08:00	27/Feb/2022	18:00	PLAI	NNED	Approved	27-Feb-22	08:00	27-Feb-22	18:00	
507	RQ81280	OCC_ 191	cpcc1_sd	BUS	400 KV BHADLA_2 (PG) - BUS 2	POWER GRID	D	Bus extension work	26/Feb/2022	12:00	26/Feb/2022	23:30	PLAI	NNED	Approved	26-Feb-22	16:00	26-Feb-22	23:30	Could be taken from 16:00 Hrs/Subject to FTC clearance if any
508	RQ81400	OCC_ 191	cpcc1_sd	BUS	400KV BUS 2 AT MANDOLA(P G)	POWER GRID	D	For new Busbar Protection testing	26/Feb/2022	09:30	26/Feb/2022	18:30	PLAI	NNED	Approved	26-Feb-22	09:30	26-Feb-22	18:30	
509	RQ81525	OCC_ 191	cpcc1_sd	BUS	400KV BUS 1 AT MEERUT(PG)	POWER GRID	D	FOR AMP WORK	26/Feb/2022	08:00	26/Feb/2022	18:00	PLAI	NNED	Approved	26-Feb-22	08:00	26-Feb-22	18:00	
510	RQ81279	OCC_ 191	cpcc1_sd	BUS	400 KV BHADLA_2 (PG) - BUS 1	POWER GRID	D	Bus extension work	25/Feb/2022	12:00	25/Feb/2022	23:30	PLAI	NNED	Approved	25-Feb-22	16:00	25-Feb-22	23:30	Could be taken from 16:00 Hrs/Subject to FTC clearance if any

511	RQ81705	OCC_ 191	cpcc2_sd	BUS	400KV BUS 2 AT AMRITSAR(P G)	POWER GRID	D	For AMP works.	25/Feb/2022	10:00	25/Feb/2022	17:00	Kindly approve	PLANNED	Approved	25-Feb-22	10:00	25-Feb-22	17:00	
512	RQ81564	OCC_ 191	cpcc2_sd	BUS	400KV BUS 2 AT ABDULLAPUR (PG)	POWER GRID	D	For AMP works.	25/Feb/2022	10:00	25/Feb/2022	17:00	Kindly approve	PLANNED	Approved	25-Feb-22	10:00	25-Feb-22	17:00	
513	RQ81399	OCC_ 191	cpcc1_sd	BUS	400KV BUS 1 AT MANDOLA(P G)	POWER GRID	D	For new Busbar Protection testing	25/Feb/2022	09:30	25/Feb/2022	18:30		PLANNED	Approved	25-Feb-22	09:30	25-Feb-22	18:30	
514	RQ81517	OCC_ 191	cpcc1_sd	BUS	400KV BUS 2 AT BHIWANI(PG)	POWER GRID	D	For Erection of CVT and Bypass Isolators for Bus Splitting scheme under SS34 Pkg	25/Feb/2022	09:00	28/Feb/2022	18:00		PLANNED	Approved	25-Feb-22	09:00	28-Feb-22	18:00	CEA safety CLEARANE REQUIRED
515	RQ81704	OCC_ 191	cpcc2_sd	BUS	400KV BUS 1 AT AMRITSAR(P G)	POWER GRID	D	For AMP works.	24/Feb/2022	10:00	24/Feb/2022	17:00	Kindly approve	PLANNED	Approved	24-Feb-22	10:00	24-Feb-22	17:00	
		191	cpcc2_sd	BUS	400KV BUS 1 AT ABDULLAPUR (PG)	GRID	D	For AMP works.	24/Feb/2022		24/Feb/2022		Kindly approve	PLANNED	Approved	24-Feb-22	10:00	24-Feb-22	17:00	
517	RQ81424	OCC_ 191	cpcc1_sd	BUS	400 KV FATEHGARH- II(PG) - BUS 2	POWER GRID	D	FOR AMP WORK	23/Feb/2022	17:00	23/Feb/2022	23:00		PLANNED	Approved	23-Feb-22	17:00	23-Feb-22	23:00	
518	RQ81033	OCC_ 191	cpcc3_sd	BUS	400KV BUS 2 AT SHAHJAHANP UR(PG)	GRID	D	AMP Works	23/Feb/2022	10:00	23/Feb/2022	18:00		PLANNED	Approved	23-Feb-22	10:00	23-Feb-22	18:00	
		191	cpcc1_sd	BUS	400KV BUS 1 AT BHIWANI(PG)	POWER GRID	D	For Bus Bar stability of Bay 416 and 422 after shifting of 765kV ICT-I under Bay Extension work SS34 Pkg	23/Feb/2022		25/Feb/2022	18:00		PLANNED	Approved	23-Feb-22	09:00	25-Feb-22	18:00	
520	RQ81569	OCC_ 191	cpcc2_sd	BUS	400KV BUS 2 AT CHAMBA(PG)	POWER GRID	C	For Interconnection of Bus Bar for construction of new 400KV 125MVAR Bus Reactor bay(408) & 02 No Line bays. 400KV Lahal 1 Bay (409) & 400KV Lahal 2 Bay(410).	23/Feb/2022	09:00	26/Feb/2022	18:00	Kindly approve	PLANNED	Approved	23-Feb-22	09:00	26-Feb-22	18:00	Subject to necessary CEA/FTC clearance if any required/subject to NHPC CONSENT

521	RQ81685	OCC_ 191	cpcc2_sd	BUS	400KV BUS 2 AT PANCHKULA(PG)	POWER GRID	D	For AMP works.	23/Feb/2022	09:00	23/Feb/2022	17:00	Kindly approve	PLANNED	Approved	23-Feb-22	09:00	23-Feb-22	17:00	
522	RQ81684	OCC_ 191	cpcc2_sd	BUS	400KV BUS 1 AT PANCHKULA(PG)	POWER GRID	D	For AMP works.	22/Feb/2022	09:00	22/Feb/2022	17:00	Kindly approve	PLANNED	Approved	22-Feb-22	09:00	22-Feb-22	17:00	
523	RQ81284	OCC_ 191	cpcc1_sd	BUS	400KV BUS 2 AT NEEMRANA(P G)	GRID	D	AMP work.	22/Feb/2022	08:00	22/Feb/2022	20:00		PLANNED	Approved	22-Feb-22	08:00	22-Feb-22	20:00	
524	RQ81283	OCC_ 191	cpcc1_sd	BUS	400KV BUS 1 AT NEEMRANA(P G)	GRID	D	AMP work.	21/Feb/2022	08:00	21/Feb/2022	20:00		PLANNED	Approved	21-Feb-22	08:00	21-Feb-22	20:00	
525	RQ81568	OCC_ 191	cpcc2_sd	BUS	400KV BUS 1 AT CHAMBA(PG)	POWER GRID	С	For Interconnection of Bus Bar for construction of new 400KV 125MVAR Bus Reactor bay(408) & 02 No Line bays. 400KV Lahal 1 Bay (409) & 400KV Lahal 2 Bay(410).	18/Feb/2022	09:00	21/Feb/2022	18:00	Kindly approve	PLANNED	Approved	18-Feb-22	09:00	21-Feb-22	18:00	Subject to necessary CEA/FTC clearance if any required/subject to NHPC CONSENT
526	RQ81269	OCC_ 191	cpcc1_sd	BUS	400KV BUS 2 AT MAHARANIB AGH(PG)	POWER GRID	С	" Integration of Newly installed Recator bus bar with exiting 400kV Bus Bar"	18/Feb/2022	08:00	20/Feb/2022	18:00		PLANNED	Approved	18-Feb-22	08:00	20-Feb-22	18:00	to be taken on weekend.Delhi consent/FTC clearance required
527	RQ81286	OCC_ 191	cpcc1_sd	BUS	400KV BUS 2 AT TUGHLAKABA D(PG)	GRID	D	FOR AMP WORK	17/Feb/2022	09:00	17/Feb/2022	18:00		PLANNED	Approved	17-Feb-22	09:00	17-Feb-22	18:00	
		191	cpcc1_sd	BUS	400 KV BIKANER(PG) BUS 2		D	PEAK ERECTION ACTIVITY AND EARTHWIRE ERECTION STRINGING WORK	16/Feb/2022		16/Feb/2022			PLANNED	Approved	16-Feb-22	10:00	16-Feb-22	17:00	
529	RQ81022	OCC_ 191	cpcc3_sd	BUS	400KV BUS 1 AT ORAI(PG)	POWER GRID	D	AMP Works	15/Feb/2022	10:00	15/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	10:00	15-Feb-22	18:00	
530	RQ81268	OCC_ 191	cpcc1_sd	BUS	400KV BUS 1 AT MAHARANIB AGH(PG)	POWER GRID	С	" Integration of Newly installed Recator bus bar with exiting 400kV Bus Bar"	15/Feb/2022	08:00	17/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	08:00	17-Feb-22	18:00	to be taken on weekend.Delhi consent/FTC clearance required

531	RQ81518	OCC_ 191	cpcc1_sd	BUS	400KV BUS 1 AT BHIWANI(PG)	POWER GRID	D	For Bus Bar stability of Bay 419 after shifting of 765kV ICT-I form Bay 416 to 419 under Bay Extension work SS34 Pkg	14/Feb/2022	09:00	16/Feb/2022 18	3:00		PLANNED	Approved	14-Feb-22	09:00	16-Feb-22	18:00	
532	RQ81102	OCC_ 191	cpcc3_sd	BUS	A00KV BUS 2 AT KANPUR_GIS(PG)	POWER GRID	С	Extension of 400KV Existing Bus -2 with GE(GIS) by bus coupling module for commissioning of 400KV Ghatampur line-2 & ICT 3 (Future)	11/Feb/2022	10:00	20/Feb/2022 18	3:00		PLANNED	Approved	11-Feb-22	10:00	20-Feb-22	18:00	
533	RQ81025	OCC_ 191	cpcc3_sd	BUS	400KV BUS 2 AT BAREILLY(PG)	POWER GRID	D	AMP Works	10/Feb/2022	10:00	10/Feb/2022 18	3:00		PLANNED	Approved	10-Feb-22	10:00	10-Feb-22	18:00	
534	RQ81575	OCC_ 191	cpcc2_sd	BUS	400KV BUS 2 AT FATEHABAD(PG)	POWER GRID	D	For AMP works.	10/Feb/2022	10:00	10/Feb/2022 17		indly pprove	PLANNED	Approved	10-Feb-22	10:00	10-Feb-22	17:00	
535	RQ81285	OCC_ 191	cpcc1_sd	BUS	400KV BUS 1 AT TUGHLAKABA D(PG)	POWER GRID	D	FOR AMP WORK	10/Feb/2022	09:00	10/Feb/2022 18	3:00		PLANNED	Approved	10-Feb-22	09:00	10-Feb-22	18:00	
		191	cpcc2_sd	BUS	400KV BUS 2 AT KAITHAL(PG)	GRID	D	For AMP works.	10/Feb/2022		10/Feb/2022 17	a	indly pprove	PLANNED	Approved	10-Feb-22	09:00	10-Feb-22	17:30	
		191	cpcc2_sd	BUS	400KV BUS 2 AT PATIALA(PG)	POWER GRID	D	For AMP works.	09/Feb/2022		09/Feb/2022 18	a	indly ipprove	PLANNED	Approved	09-Feb-22	09:00	09-Feb-22	18:00	
		191	cpcc1_sd	BUS	FATEHGARH- II(PG) - BUS 1		D	FOR AMP WORK	08/Feb/2022		08/Feb/2022 23			PLANNED	Approved	08-Feb-22	17:00	08-Feb-22	23:00	
		191	cpcc2_sd	BUS	FATEHABAD(PG)	GRID	D	For AMP works.	08/Feb/2022	10:00	08/Feb/2022 17		indly pprove	PLANNED	Approved	08-Feb-22	10:00	08-Feb-22	17:00	
540	RQ81024	OCC_ 191	cpcc3_sd	BUS	400KV BUS 1	POWER GRID	D	AMP Works	08/Feb/2022	10:00	08/Feb/2022 18	3:00		PLANNED	Approved	08-Feb-22	10:00	08-Feb-22	18:00	
541	RQ81688	OCC_ 191	cpcc2_sd	BUS	400KV BUS 1 AT PATIALA(PG)	POWER GRID	D	For AMP works.	08/Feb/2022	09:00	08/Feb/2022 18		indly pprove	PLANNED	Approved	08-Feb-22	09:00	08-Feb-22	18:00	

542	RQ81604	OCC_ 191	cpcc2_sd	BUS	400KV BUS 1 AT KAITHAL(PG)	POWER GRID	D	For AMP works.	07/Feb/2022	09:00	07/Feb/2022	17:30	Kindly approve	PLANNED	Approved	07-Feb-22	09:00	07-Feb-22	17:30	
543	RQ81620	OCC_ 191	cpcc2_sd	BUS	400KV BUS 2 AT KISHENPUR(P G)	POWER GRID	D	For Installation of IPS Aluminum tube conductor and replacement of Dropper from JackBus to Bus Isolator in 01 No. 400KV, 125MVAR Reactor bay in Bay No 427.BB Stability works for upcoming 01 No. 400KV 125 MVAR Reactor bay in Bay No 427.	04/Feb/2022	09:00	05/Feb/2022	18:00	Kindly approve	PLANNED	Approved	04-Feb-22	09:00	05-Feb-22	18:00	
	RQ81553	191		BUS	400KV BUS 2 AT ABDULLAPUR (PG)	GRID	D	For AMP works.	03/Feb/2022	09:00	04/Feb/2022		Kindly approve	PLANNED	Approved	03-Feb-22	09:00	04-Feb-22	18:00	
545	RQ81276	OCC_ 191	cpcc1_sd	BUS	400KV BUS 2 AT JAIPUR SOUTH(PG)	POWER GRID	D	AMP OF BUS	03/Feb/2022	09:00	03/Feb/2022	18:00		PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	18:00	
546	RQ81271	OCC_ 191	cpcc1_sd	BUS	400KV BUS 2 AT BHIWADI(PG)	POWER GRID	D	AMP OF BUS	03/Feb/2022	09:00	03/Feb/2022	18:00		PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	18:00	
547	RQ81267	OCC_ 191	cpcc1_sd	BUS	400KV BUS 1 AT BAGHPAT(PG)	POWER GRID	С	For restoration of 400 kV Main Bus-I	02/Feb/2022	09:00	04/Feb/2022	20:00		PLANNED	Approved	02-Feb-22	09:00	04-Feb-22	20:00	
548	RQ81270	OCC_ 191	cpcc1_sd	BUS	400KV BUS 1 AT BHIWADI(PG)	POWER GRID	D	AMP OF BUS	02/Feb/2022	09:00	02/Feb/2022	18:00		PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	18:00	
		191	cpcc3_sd	BUS	400KV BUS 1 AT KANPUR_GIS(PG)	GRID	С	Extension of 400KV Existing Bus -1 with GE(GIS) by bus coupling module for commissioning of 400KV Ghatampur line-2 & ICT 3 (Future)	01/Feb/2022		10/Feb/2022			PLANNED	Approved	01-Feb-22	10:00	10-Feb-22	18:00	CEA safety CLEARANE REQUIRED
550	RQ81275	OCC_ 191	cpcc1_sd	BUS	400KV BUS 1 AT JAIPUR SOUTH(PG)	POWER GRID	D	AMP OF BUS	01/Feb/2022	09:00	01/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	18:00	

551	RQ81552	locc	cpcc2_sd	BUS	400KV BUS 1	POWER	D	For AMP works.	01/Feb/2022	09:00	02/Feb/2022	18:00	Kindly	PLANNED	Approved	01-Feb-22	09:00	02-Feb-22	18:00	
		191			AT	GRID			,,		,,		approve							
					ABDULLAPUR (PG)															
552	RQ81099		cpcc3_sd		400KV BUS 1			Shut down	01/Feb/2022	09:00	01/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	18:00	
		191			AT	GRID		required on												
					SHAHJAHANP UR(PG)			25.01.22 for AMP work												
553	RQ81104	occ	cpcc3_sd	BUS	400KV BUS 1	UPPTCL	С	For retrofitment of	24/Feb/2022	10:00	26/Feb/2022	18:00		PLANNED	Approved	24-Feb-22	10:00	26-Feb-22	18:00	subject to UP
		191	-,		AT PANKI(UP)			89A isolator at	, ,		-0,100,-00									consent
								Panki end under												
FF4	RQ80865	000	atuun ad	BUS	400KV BUS 2	LIDDTCI		ADDCAP Replacement of	23/Feb/2022	10.00	27/Feb/2022	10.00		PLANNED	Annuound	23-Feb-22	10:00	27-Feb-22	18:00	State electrical
554	KŲŏUŏDO	191	stuup_su	воз	AT	UPPICE		pantograph Bus	23/FED/2022	10:00	27/Feb/2022	18:00		PLANNED	Approved	23-Feb-22	10:00	27-Feb-22	18:00	inspector approval
					SULTANPUR(isolator of bus												required
					UP)			coupler bay under												
	RQ80864	000	stuup sd	BUS	400KV BUS 1	LIDDTCI		B Bus Replacement of	18/Feb/2022	10.00	22/Feb/2022	10.00		PLANNED	A	18-Feb-22	10:00	22-Feb-22	10.00	State electrical
555	KQ80864	191	stuup_sa		AT	UPPICE		pantograph Bus	18/Feb/2022	10:00	22/Feb/2022	18:00		PLANNED	Approved	18-Feb-22	10:00	22-Feb-22	18:00	inspector approval
					SULTANPUR(isolator of bus												required
					UP)			coupler bay under												
				2112				A Bus	10/= 1 /0000		10/5 1 /0000									
556	RQ80922	191	stuup_sd	1	400KV BUS 2 AT ORAI(UP)	UPPICL		for routine testing and maintenance.	18/Feb/2022	09:30	18/Feb/2022	17:00		PLANNED	Approved	18-Feb-22	09:30	18-Feb-22	17:00	
		131			AT ONAI(OT)			and maintenance.												
557	RQ80863	_	stuup_sd	BUS	400KV BUS 2	UPPTCL		Pantograph	17/Feb/2022	10:00	18/Feb/2022	18:00	Pantograpg	PLANNED	Approved	17-Feb-22	10:00	18-Feb-22	18:00	
		191			AT			replacement work					h .							
					BAREILLY(UP)								replacemen t work is							
													also							
													proposed in							
													400 kv							
													breaker							
													replacemen t shutdown							
													period for							
													replacing							
													fixed							
													contact we							
													need shutdown of							
													mainbus I							
													for two days							
													1.							

558	RQ80862	OCC_ 191	stuup_sd	BUS	ATAUR(UP)	UPPTCL		For annual maintenance & Testing work (Load will not interrupt during Bus-2 Shutdown as load will be feed by Bus-1)	11/Feb/2022	09:30	11/Feb/2022	16:00	PLANNED	Approved	11-Feb-22	09:30	11-Feb-22	16:00	
559	RQ80861	OCC_ 191	stuup_sd	BUS	400KV BUS 1 AT ATAUR(UP)		D	For annual maintenance & Testing work (Load will not interrupt during Bus-1 Shutdown as load will be feed by Bus-2)	09/Feb/2022	09:30	09/Feb/2022		PLANNED	Approved	09-Feb-22	09:30	09-Feb-22	16:00	
	RQ80860	191		BUS	400KV BUS 2 AT ALIGARH(UP)			Stringing work of 400 KV Shamli bay (under construction)	05/Feb/2022		06/Feb/2022		PLANNED	Approved	05-Feb-22	09:00	06-Feb-22	17:00	
	RQ80859	191		BUS	400KV BUS 1 AT ALIGARH(UP)			Stringing work of 400 KV Shamli bay (under construction)	03/Feb/2022		04/Feb/2022		PLANNED	Approved	03-Feb-22	09:00	04-Feb-22	17:00	
562	RQ80854	OCC_ 191	sldcps_sd	BUS	AT MAKHU(PS)	PSTCL	D	Nut bolt tightening of upper clamp and connectors of isolator of bus bar- 1	24/Feb/2022	08:00	24/Feb/2022	18:00	PLANNED	Approved	24-Feb-22	08:00	24-Feb-22	18:00	
	RQ80850	191		BUS	400KV BUS 2 AT MUKTSAR(PS)		D	General maintenance for nut-bolt tightening,cleaning and IR of equipments.	22/Feb/2022		22/Feb/2022		PLANNED	Approved	22-Feb-22	08:00	22-Feb-22	18:00	
		191	sldcps_sd	BUS	AT MAKHU(PS)			Nut bolt tightening of upper clamp and connectors of isolator of bus bar- 2			22/Feb/2022		PLANNED	Approved	22-Feb-22	08:00	22-Feb-22	18:00	
565	RQ80852	OCC_ 191	sldcps_sd	BUS	AT MAKHU(PS)	PSTCL		Nut bolt tightening of upper clamp and connectors of isolator of bus bar- 2	17/Feb/2022	08:00	17/Feb/2022	18:00	PLANNED	Approved	17-Feb-22	08:00	17-Feb-22	18:00	

566	RQ80851	OCC_ 191	sldcps_sd	BUS	400KV BUS 1 AT MAKHU(PS)	PSTCL		Nut bolt tightening of upper clamp and connectors of isolator of bus bar- 1	15/Feb/2022	08:00	15/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	08:00	15-Feb-22	18:00	
567	RQ80849	OCC_ 191	sldcps_sd	BUS	400KV BUS 2 AT MUKTSAR(PS)	PSTCL		General maintenance for nut-bolt tightening,cleaning and IR of equipments.	10/Feb/2022	08:00	10/Feb/2022	18:00		PLANNED	Approved	10-Feb-22	08:00	10-Feb-22	18:00	
	RQ81182	191	-	BUS	400KV BUS 1 AT KAWAI SCTPS(APR)		С	Annual maintenance of 400 KV Bus connecting isolators.	23/Feb/2022		24/Feb/2022			PLANNED	Approved	23-Feb-22	09:00	24-Feb-22	19:00	
569	RQ80857	OCC_ 191	sldcps_sd	BUS	400KV BUS 2 AT NAKODAR(PS G)	PSPCL	D	Periodic Maintenance	22/Feb/2022	08:00	22/Feb/2022	18:00		PLANNED	Approved	22-Feb-22	08:00	22-Feb-22	18:00	
570	RQ80856	OCC_ 191	sldcps_sd	BUS	400KV BUS 1 AT NAKODAR(PS G)	PSPCL		Periodic Maintenance	15/Feb/2022	08:00	15/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	08:00	15-Feb-22	18:00	
571	RQ80578	OCC_ 191	jhakri_sd	BUS	400KV BUS 2 AT NATHPA JHAKRI(SJ)	SJVNL		Inspection of Bus Disconnector (Q2) of Unit No.#02	19/Feb/2022	10:00	20/Feb/2022	16:00		PLANNED	Approved	19-Feb-22	10:00	20-Feb-22	16:00	
572		191	sldchr_sd	BUS	400KV BUS 2 AT DEEPALPUR(J HKT)	JHAJJA	D	FOR AMP WORK	17/Feb/2022	09:00	17/Feb/2022	17:00		PLANNED	Approved	17-Feb-22	09:00	17-Feb-22	17:00	
573	RQ80754	OCC_ 191	sldchr_sd	BUS	400KV BUS 1 AT DEEPALPUR(J HKT)	JHAJJA	D	FOR AMP WORK	16/Feb/2022	09:00	16/Feb/2022	17:00		PLANNED	Approved	16-Feb-22	09:00	16-Feb-22	17:00	
574	RQ80973	OCC_ 191	singrauli_s d	BUS	400KV BUS 3 AT SINGRAULI(N T)	NTPC		For ST-2 Numerical differential Bus bar protection commissioning	17/Feb/2022	08:00	17/Feb/2022	18:00	shutdown of Bus is not required. Only bus bar protection to be kept out during mentioned period.	PLANNED	Approved	20-Feb-22	08:00	20-Feb-22		shutdown of Bus is not required. Only bus bar protection to be kept out during mentioned period.

575	RQ80975		singrauli_s d	BUS	400KV BUS6 AT SINGRAULI(N T)	NTPC	D	For ST-2 Numerical differential Bus bar protection commissioning	17/Feb/2022	08:00	17/Feb/2022	18:00	shutdown of Bus is not required. Only bus bar protection to be kept out during mentioned period.	PLANNED	Approved	20-Feb-22	08:00	20-Feb-22	18:00	shutdown of Bus is not required. Only bus bar protection to be kept out during mentioned period.
576	RQ80974	OCC_ 191	singrauli_s d	BUS	400KV BUS 4 AT SINGRAULI(N T)	NTPC	D	For ST-2 Numerical differential Bus bar protection commissioning	17/Feb/2022	08:00	17/Feb/2022	18:00	shutdown of Bus is not required. Only bus bar protection to be kept out during mentioned period.	PLANNED	Approved	20-Feb-22	08:00	20-Feb-22	18:00	shutdown of Bus is not required. Only bus bar protection to be kept out during mentioned period.
577	RQ80972	OCC_ 191	singrauli_s d	BUS	400KV BUS 4 AT SINGRAULI(N T)	NTPC	С	for attending isolator problem of TBC Bus-4 isolator	04/Feb/2022	08:00	05/Feb/2022	18:00	Lines and generator will be shifted to other bus. No outage of line is required	PLANNED	Approved	04-Feb-22	08:00	05-Feb-22	18:00	Lines and generator will be shifted to other bus. No outage of line is required
578	RQ80971	OCC_ 191	singrauli_s d	BUS	400KV BUS 3 AT SINGRAULI(N T)	NTPC	С	for attending hot spot at 400Kv Bus section -1 isolator at Bus-3 side for B phase	01/Feb/2022	08:00	02/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	02-Feb-22		Lines and generator will be shifted to other bus. No outage of line is required
579	RQ81489	OCC_ 191	bbmb_sd	BUS	400KV BUS 2 AT DEHAR(BB)		D	To replace old semi pantograph type isolator no. 414 (From 08-02- 2022 to 15-02- 2022)	14/Feb/2022		15/Feb/2022			PLANNED	Approved	14-Feb-22	08:00	15-Feb-22	18:00	
580	RQ81488	OCC_ 191	bbmb_sd	BUS	400KV BUS 2 AT DEHAR(BB)	ВВМВ	D	To replace old semi pantograph type isolator no. 414 (From 08-02- 2022 to 15-02- 2022)	08/Feb/2022	08:00	09/Feb/2022	18:00		PLANNED	Approved	08-Feb-22	08:00	09-Feb-22	18:00	

581	RQ81614	OCC_ 191	cpcc2_sd	BUS	400KV BUS 2 AT KALA AMB(PKTL)	PKATL	D	For AMP works.	11/Feb/2022	09:00	11/Feb/2022	17:00	Kindly approve	PLANNED	Approved	11-Feb-22	09:00	11-Feb-22	17:00	
	RQ81613	191		BUS	400KV BUS 1 AT KALA AMB(PKTL)		D	For AMP works.	10/Feb/2022		10/Feb/2022		Kindly approve	PLANNED	Approved	10-Feb-22	09:00	10-Feb-22	17:00	
	RQ80960	191	_	BUS	400KV BUS 2 AT DAULATABAD (HV)	HVPNL		For testing of master control unit (MCU), testing of Bus bar protection with Bus-2	08/Feb/2022	10:00	08/Feb/2022	21:00		PLANNED	Approved	08-Feb-22	10:00	08-Feb-22	21:00	
584	RQ80959	OCC_ 191	sldchr_sd	BUS	400KV BUS 1 AT DAULATABAD (HV)	HVPNL	D	For testing of Master control unit (MCU), testing of bus bar protection with bus-1	07/Feb/2022	10:00	07/Feb/2022	21:00		PLANNED	Approved	07-Feb-22	10:00	07-Feb-22	21:00	
	RQ81193	191		BUS	400KV BUS 2 AT DEEDWANA(MTS)		D	For annual preventive maintenance purpose	08/Feb/2022		08/Feb/2022			PLANNED	Approved	08-Feb-22	08:00	08-Feb-22	18:00	
	RQ81192	OCC_ 191	sldcrs_sd	BUS	400KV BUS 1 AT DEEDWANA(MTS)	MTSCL	D	For annual preventive maintenance purpose	07/Feb/2022		07/Feb/2022	18:00		PLANNED	Approved	07-Feb-22	08:00	07-Feb-22	18:00	
587	RQ80989	OCC_ 191	sldcdv_sd		AT BAWANA(DV)	DTL	D	To Carryout the Capacitance & Tan delta testing of CB'S grading capacitor, CT, & Bus CVT as per PMS.	05/Feb/2022	09:00	05/Feb/2022	17:00		PLANNED	Approved	05-Feb-22	09:00	05-Feb-22	17:00	
	RQ81273	191		BUS	400 KV KHETRI (PKTSL) - BUS 2	PKTSL		For Bus Stringing in Bikaner Bay Area	03/Feb/2022		03/Feb/2022			PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	18:00	
	RQ81272	191		BUS	400 KV KHETRI (PKTSL) - BUS 1	PKTSL		For Bus Stringing in Bikaner Bay Area	02/Feb/2022		02/Feb/2022			PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	18:00	
590	RQ81256	OCC_ 191	sldcrs_sd	LINE REACTO R	80 MVAR SWITCHABLE LR ON 400 KV BABAI(RS)- SURATGARH SCTPS(RVUN) (RS) CKT-2 @BABAI(RS)	RRVPN L	D	Quarterly Maintenance	25/Feb/2022	08:00	25/Feb/2022	18:00		PLANNED	Approved	25-Feb-22	08:00	25-Feb-22	18:00	

591	RQ81257	OCC_ 191	sldcrs_sd	REACTO R	80 MVAR SWITCHABLE LR ON 400 KV BABAI(RS)- SURATGARH SCTPS(RVUN) (RS) CKT-1 @BABAI(RS)	RRVPN L	D	Quarterly Maintenance	18/Feb/2022	08:00	18/Feb/2022	18:00	PLANNED	Approved	18-Feb-22	08:00	18-Feb-22	18:00	
592	RQ81289	OCC_ 191	cpcc1_sd	REACTO R		RRVPN L		For Line Reactor AMP Work	02/Feb/2022	09:00	02/Feb/2022	18:00	PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	18:00	
593	RQ81288	OCC_ 191	cpcc1_sd	REACTO R		RRVPN L		For Line Reactor AMP Work	01/Feb/2022	09:00	01/Feb/2022	18:00	PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	18:00	
		191	sldcup_sd	LINE REACTO R	50 MVAR NON- SWITCHABLE LR ON 400 KV MUZAFFARN AGAR(UP)- VISHNUPRAY AG(JP) (UP) CKT-1 @MUZAFFAR NAGAR(UP)	UPPTCL		For Tan Delta testing	12/Feb/2022		12/Feb/2022		PLANNED	Approved	12-Feb-22	10:00	12-Feb-22	14:00	
595	RQ81287	OCC_ 191	cpcc1_sd	REACTO R		POWER GRID		For Line Reactor AMP Work	03/Feb/2022	09:00	03/Feb/2022	18:00	PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	18:00	
596	RQ81252	OCC_ 191	sldcrs_sd	BR/BSR /MSC/ MSR		RRVPN L		Half yearly Maintenance & testing work	23/Feb/2022	08:00	23/Feb/2022	18:00	PLANNED	Approved	23-Feb-22	08:00	23-Feb-22	18:00	

597	RQ81251	OCC_ 191	sldcrs_sd	/MSC/	50 MVAR BUS REACTOR NO 1 AT 400KV AKAL(RS)		D	ATTEND OIL LEAKAGE OF MAINTANK	22/Feb/2022	08:00	22/Feb/2022	18:00	PLANNED	Approved	22-Feb-22	08:00	22-Feb-22	18:00	
598	RQ81254	OCC_ 191	sldcrs_sd	/MSC/	125 MVAR BUS REACTOR NO 1 AT 400 KV AKAL(RS)	RRVPN L	D	Quarterly Maintenance	21/Feb/2022	08:00	21/Feb/2022	18:00	PLANNED	Approved	21-Feb-22	08:00	21-Feb-22	18:00	
	RQ80809	191		/MSC/ MSR	BUS REACTOR NO 1 AT 400KV PHAGI(RS)			For the measurement of Tan Delta Bushings. Other maintenance work of Reactor. Tightening of clamp connectors of equipments.	21/Feb/2022		21/Feb/2022		PLANNED	Approved	21-Feb-22	08:00	21-Feb-22	18:00	
600	RQ81255	OCC_ 191	sldcrs_sd	BR/BSR /MSC/ MSR	80 MVAR BUS REACTOR NO 1 AT 400 KV BABAI(RS)		D	Quarterly Maintenance	17/Feb/2022	09:30	17/Feb/2022	15:00	PLANNED	Approved	17-Feb-22	09:30	17-Feb-22	15:00	
601	RQ81250	OCC_ 191	sldcrs_sd	/MSC/	80 MVAR BUS REACTOR NO 1 AT 400KV CHITTORGAR H(RS)		D	FOR MAINTAINCE WORK and Testing work	17/Feb/2022	08:00	17/Feb/2022	18:00	PLANNED	Approved	17-Feb-22	08:00	17-Feb-22	18:00	
602	RQ81253	OCC_ 191	sldcrs_sd	/MSC/	125 MVAR BUS REACTOR NO 1 AT 400KV MERTA(RS)	RRVPN L	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	03/Feb/2022	08:00	03/Feb/2022	18:00	PLANNED	Approved	03-Feb-22	08:00	03-Feb-22	18:00	
603	RQ81415	OCC_ 191	cpcc1_sd	/MSC/	125 MVAR BUS REACTOR NO 1 AT 400 KV FATEHGARH_ II(PG)		D	FOR AMP WORK	22/Feb/2022	17:00	22/Feb/2022	23:00	PLANNED	Approved	22-Feb-22	17:00	22-Feb-22	23:00	
604	RQ80932	OCC_ 191	stuup_sd	/MSC/ MSR	80 MVAR BUS REACTOR NO 1 AT 400KV AGRA SOUTH(UP)	UPPTCL	D	Routine testing and maintenance	21/Feb/2022	10:30	22/Feb/2022	18:30	PLANNED	Approved	21-Feb-22	10:30	22-Feb-22	18:30	

605	RQ80921	OCC_ 191	stuup_sd	/MSC/	63 MVAR BUS REACTOR NO 1 AT 400KV ORAI(UP)	UPPTCL	С	for replacement of 400 kv R & Y phase bushing of 63 mvar reactor.	21/Feb/2022	09:30	26/Feb/2022	18:00		PLANNED	Rejected					deferred to next OCC
606	RQ80928	OCC_ 191	stuup_sd		63 MVAR BUS REACTOR NO 1 AT 400KV MURADNAGA R_2(UP)	UPPTCL	D	preventive maintenance and testing and tightening work	21/Feb/2022	09:00	21/Feb/2022	17:00		PLANNED	Approved	21-Feb-22	09:00	21-Feb-22	17:00	
607	RQ80931	OCC_ 191	stuup_sd		63 MVAR BUS REACTOR NO 1 AT 400KV MUZAFFARN AGAR(UP)	UPPTCL	С	For oil filtration	08/Feb/2022	10:00	11/Feb/2022	16:00		PLANNED	Approved	08-Feb-22	10:00	11-Feb-22	16:00	
608	RQ80923	OCC_ 191	stuup_sd	/MSC/	80 MVAR BUS REACTOR NO 1 AT 400KV BAREILLY(UP)	UPPTCL	С	bus reactor is energised through transfer bus ,there is no separate bus for bus reactor	01/Feb/2022	10:00	20/Feb/2022	19:00		PLANNED	Rejected					deferred to next OCC
609	RQ80933	OCC_ 191	stuup_sd	/MSC/	125 MVAR BUS REACTOR NO 1 AT 400KV BARA(UP)	UPPTCL	С	Construction of Fire wall due to induction effect in switchyard, shutdown required for safety purpose	01/Feb/2022	08:00	28/Feb/2022	19:00		PLANNED	Approved	01-Feb-22	08:00	28-Feb-22	19:00	
	RQ81292	191		/MSC/ MSR	125 MVAR BUS REACTOR NO 1 AT 400KV KOTESWAR(T H)		С	FOR ATTENDING PRD LEAKAGE	16/Feb/2022		17/Feb/2022			PLANNED	Rejected					deferred to next OCC
	RQ81414	191		/MSC/	80 MVAR BUS REACTOR NO 1 AT 400KV BALLABHGAR H(PG)		D	For onload testing & tuning of CSD	10/Feb/2022	09:00	10/Feb/2022	18:00		PLANNED	Approved	10-Feb-22	09:00	10-Feb-22	18:00	
612	RQ81530	OCC_ 191	cpcc1_sd	BR/BSR /MSC/ MSR	225 MVAR BUS SERIES REACTOR NO 1 AT 400 KV MANDOLA(P G)	POWER GRID	D	FOR AMP WORK	06/Feb/2022	08:00	06/Feb/2022	18:00	75 MVAR BUS series reactor	PLANNED	Approved	06-Feb-22	08:00	06-Feb-22	18:00	

613	RQ81680	OCC_ 191	cpcc2_sd	/MSC/	125 MVAR BUS REACTOR NO 2 AT 400 KV MOGA(PG)	POWER GRID	D	For rectification of FO temperature sensor.	04/Feb/2022	08:00	04/Feb/2022	18:00	Kindly approve	PLANNED	Approved	04-Feb-22	08:00	04-Feb-22	18:00	
		191	cpcc1_sd		125 MVAR BUS REACTOR NO 1 AT 400KV JIND(PG)	POWER GRID	D	VFTD of neutral bushing	01/Feb/2022		01/Feb/2022			PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	18:00	
615	RQ81519	OCC_ 191	cpcc1_sd	1 '	125 MVAR BUS REACTOR NO 1 AT 400KV SONIPAT(PG)	POWER GRID	D	Retrofitting of REF and Diffrential relay	01/Feb/2022	09:00	02/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	09:00	02-Feb-22	18:00	
		191	cpcc1_sd	/MSC/ MSR	225 MVAR BUS SERIES REACTOR NO 1 AT 400 KV BALLABHGAR H(PG)	POWER GRID	С	For Replacement of R-ph Series Reactor	01/Feb/2022	09:00	03/Feb/2022			PLANNED	Approved	01-Feb-22	09:00	03-Feb-22	18:00	CEA safety CLEARANE REQUIRED
617	RQ80858	OCC_ 191	sldcps_sd	BR/BSR /MSC/ MSR	80 MVAR BUS REACTOR NO 1 AT 400KV MAKHU(PS)	PSTCL	D	Cleaning and Recording of IR Values of Bay 415 CT's and CBcleaning of CTR Panel and Terminal tightening of Reactor MB, checking of HVWSS	10/Feb/2022	08:00	10/Feb/2022	18:00		PLANNED	Approved	10-Feb-22	08:00	10-Feb-22	18:00	
618	RQ81498	OCC_ 191	bbmb_sd	ВАУ	407 TIE BAY - 400KV PANCHKULA(PG)- PANIPAT(BB) (BB) CKT-1 AND 400KV DADRI(NT)- PANIPAT(BB) (PG) CKT-2 AT PANIPAT(BB)	ВВМВ	D	Y. MTC.	28/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	28-Feb-22	08:00	28-Feb-22	18:00	
619	RQ81493	OCC_ 191	bbmb_sd	ВАУ	X2 MAIN BAY 400/220 KV 500 MVA ICT 2 AT PANIPAT(BB) (BBMB)	ВВМВ	D	Y. MTC.	16/Feb/2022	08:00	16/Feb/2022	18:00		PLANNED	Approved	16-Feb-22	08:00	16-Feb-22	18:00	

620 R	RQ81495	OCC_ 191	bbmb_sd	401 MAIN BAY - 400KV PANCHKULA(PG)- PANIPAT(BB) (BB) CKT-1 AT PANIPAT(BB)	ВВМВ	D	Y. MTC.	14/Feb/2022	08:00	14/Feb/2022	18:00	PLANNED	Approved	14-Feb-22	08:00	14-Feb-22	18:00	
		191		BAY - 400 KV FATEHGARH_ II(PG)- FATEHGARH POOLING(FBT L) (FBTL) CKT- 2 (POWERGRID) AT 400 KV FATEHGARH_ II(PG)			FOR AMP WORK	26/Feb/2022		26/Feb/2022		PLANNED	Approved	26-Feb-22	17:00	26-Feb-22	23:00	
622 R	RQ81497	OCC_ 191	bbmb_sd		POWER GRID	D	Y. MTC.	26/Feb/2022	08:00	26/Feb/2022	18:00	PLANNED	Approved	26-Feb-22	08:00	26-Feb-22	18:00	
623 R	RQ81427	OCC_ 191	cpcc1_sd	421 MAIN	POWER GRID	D	FOR AMP WORK	24/Feb/2022	17:00	24/Feb/2022	23:00	PLANNED	Approved	24-Feb-22	17:00	24-Feb-22	23:00	

		191	bbmb_sd	BAY - 400/220 KV 450 MVA ICT 1 AT PANIPAT(BB) AND 400KV BUS 2 AT PANIPAT(BB) AT 400 KV PANIPAT(BB)	POWER GRID		Y. MTC.	22/Feb/2022		22/Feb/2022			PLANNED	Approved	22-Feb-22	08:00	22-Feb-22	18:00	
		191	_	BAY - 400 KV DADRI(NT)- PANIPAT(BB) (PG) CKT-1 AT 400KV PANIPAT(BB)				21/Feb/2022		21/Feb/2022			PLANNED	Approved	21-Feb-22	08:00	21-Feb-22	18:00	
626	RQ81537	OCC_ 191	cpcc1_sd	BAY - 125 MVAR BUS REACTOR NO 1 AT 400 KV MEERUT(PG) (POWERGRID) AND 400/220 KV 315 MVA ICT 1 AT MEERUT(PG) AT 400 KV MEERUT(PG) (POWERGRID)	POWER GRID		CB Pole Overhauling	18/Feb/2022	08:00	21/Feb/2022	18:00		PLANNED	Approved	18-Feb-22	08:00	21-Feb-22	18:00	
627	RQ81494	OCC_ 191	bbmb_sd	X3-CB TIE BAY - 400/220 KV 450 MVA ICT 2 AT PANIPAT(BB) AND 400 KV DADRI(NT)- PANIPAT(BB) (PG) CKT-1 AT 400 KV PANIPAT(BB)	GRID	D	Y. MTC.	18/Feb/2022	08:00	18/Feb/2022	18:00	ı	PLANNED	Approved	18-Feb-22	08:00	18-Feb-22	18:00	

628	RQ81448	OCC_ 191	cpcc1_sd	ВАУ	418 MAIN BAY - 400KV MAINPURI- BALLABHGAR H (PG) CKT-1 AT BALLABHGAR H(PG)	POWER GRID	C	For CB replacement work	17/Feb/2022	08:00	21/Feb/2022	18:00		PLANNED	Approved	17-Feb-22	08:00	21-Feb-22	18:00	CEA safety CLEARANE REQUIRED
629	RQ81430	OCC_ 191	cpcc1_sd	ВАҮ	407 MAIN	POWER GRID		" ICT-4 is last equipment. so to intregate the Bus Bar, SF6 gas will reduce to this bay also. Therefore its shut down required. "	15/Feb/2022	09:00	20/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	09:00	20-Feb-22	18:00	CEA CLEARANCE
	RQ81677	191		BAY	407 MAIN BAY - 400KV MOGA- HISSAR (PG) CKT-1 AT MOGA(PG)	POWER GRID		works.	15/Feb/2022		01/Mar/2022		approve	PLANNED	Approved	15-Feb-22	08:00	01-Mar-22	18:00	
631	RQ81582	OCC_ 191	cpcc1_sd	BAY	416 MAIN BAY - 765/400KV 1000 MVA ICT 1 AT BHIWANI(PG)	POWER GRID		For Re- commissioning of Protection System of 416 Bay as per upcoming series reactor under SS34 Package	15/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	08:00	28-Feb-22	18:00	
632	RQ81584	OCC_ 191	cpcc1_sd	ВАУ	417 TIE BAY - 400KV BHIWANI- HISSAR (PG) CKT-1 AND 765/400KV 1000 MVA ICT 1 AT BHIWANI(PG)	POWER GRID		For Replacement of existing CB with CB having closing resistor under Bay extn Pkg SS34	15/Feb/2022	08:00	25/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	08:00	25-Feb-22	18:00	CEA safety CLEARANE REQUIRED
633	RQ81702	OCC_ 191	cpcc1_sd	ВАҮ	497 MAIN BAY - 400 KV MEERUT(PG)- MUZAFFARN AGAR(UP) (PG) CKT-1 AT MUZAFFARN AGAR(UP)		D	FOR AMP WORK	14/Feb/2022	08:00	14/Feb/2022	18:00		PLANNED	Approved	14-Feb-22	08:00	14-Feb-22	18:00	

634	RQ81444	OCC_ 191	cpcc1_sd	ВАҮ	418 MAIN BAY - 400 KV ROORKEE(PG)- KASHIPUR(UK) (PG) CKT-1 AT KASHIPUR(UK)	POWER GRID	D	FOR AMP WORK	13/Feb/2022	08:00	13/Feb/2022	18:00	400KV MAIN BAY NO. 418 (MAIN BAY OF KASHIPUR- ROORKEE- CKT-I) AT PTCUL, KASHIPUR	PLANNED	Approved	13-Feb-22	08:00	13-Feb-22	18:00	
	RQ81535	191			BAY - 400KV MEERUT- MANDOLA (PG) CKT-2 AT MEERUT(PG)	POWER GRID		CB Pole Overhauling	12/Feb/2022		17/Feb/2022			PLANNED	Approved	12-Feb-22	08:00	17-Feb-22	18:00	
	RQ81442	191			BAY - 400 KV BAREILLY_2(P G)- KASHIPUR(UK) (PG) CKT-1 (POWERGRID) AT BAREILLY_2(PG)				11/Feb/2022		11/Feb/2022		MAIN BAY NO. 416 (MAIN BAY OF KASHIPUR- BAREILLY CKT-I) AT PTCUL, KASHIPUR	PLANNED	Approved	11-Feb-22	08:00	11-Feb-22	18:00	
	RQ81541	191		BAY	BAY - 400 KV MEERUT(PG)- MUZAFFARN AGAR(UP) (PG) CKT-1 (POWERGRID) AND FUTURE AT 400 KV MEERUT(PG) (POWERGRID)			and commissioning	11/Feb/2022		13/Feb/2022			PLANNED	Approved	11-Feb-22	08:00	13-Feb-22	18:00	
638	RQ81547	OCC_ 191	cpcc1_sd	ВАУ		POWER GRID		Retrofitting of old BHEL CB with new GE CB	11/Feb/2022	08:00	20/Feb/2022	18:00		PLANNED	Approved	11-Feb-22	08:00	20-Feb-22		CEA CLEARANE REQUIRED

639	RQ81546	OCC_ 191	cpcc1_sd		POWER GRID	С	Retrofitting of old BHEL CB with new GE CB	11/Feb/2022	08:00	20/Feb/2022	18:00	400kV Bay No 407 Agra 1 Main Bay	PLANNED	Approved	11-Feb-22	08:00	20-Feb-22	18:00	CEA CLEARANE REQUIRED
640	RQ81439	OCC_ 191	cpcc1_sd	413 MAIN BAY - 400 KV ROORKEE(PG)- KASHIPUR(UK) (PG) CKT-2 (POWERGRID)		D	FOR AMP WORK	10/Feb/2022	08:00	10/Feb/2022	18:00	400KV MAIN BAY NO. 415 (MAIN BAY OF KASHIPUR- ROORKEE- CKT-II) AT PTCUL, KASHIPUR	PLANNED	Approved	10-Feb-22	08:00	10-Feb-22	18:00	
641	RQ81542	OCC_ 191	cpcc1_sd		POWER GRID	C	CSD Installation and commissioning	09/Feb/2022	08:00	10/Feb/2022	18:00		PLANNED	Approved	09-Feb-22	08:00	10-Feb-22	18:00	
642	RQ81441	OCC_ 191	cpcc1_sd		POWER GRID	D	FOR AMP WORK	08/Feb/2022	08:00	08/Feb/2022	18:00	400KV MAIN BAY NO. 413 (MAIN BAY OF KASHIPUR- BAREILLY CKT-II) AT PTCUL, KASHIPUR	PLANNED	Approved	08-Feb-22	08:00	08-Feb-22	18:00	

643	RQ81447	OCC_ 191	cpcc1_sd	ВАУ	417 TIE BAY - 400 KV MAINPURI- BALLABHGAR H (PG) CKT-1 AND FUTURE AT BALLABHGAR H(PG)	POWER GRID	С	For CB replacement work	08/Feb/2022	08:00	14/Feb/2022	18:00	F	PLANNED	Approved	08-Feb-22	08:00	14-Feb-22	18:00	CEA safety CLEARANE REQUIRED
		191	cpcc1_sd	ВАУ	BAY - 400KV BUS 2 AT MEERUT(PG) (POWERGRID) AT 400 KV MEERUT(PG)	POWER GRID		CSD Installation and commissioning	07/Feb/2022	08:00	08/Feb/2022		F	PLANNED	Approved	07-Feb-22	08:00	08-Feb-22	18:00	
645	RQ81528	OCC_ 191	cpcc1_sd	ВАУ	422 MAIN BAY - 400KV MEERUT(PG)- MANDOLA(P G) (PL) CKT-3 AT MANDOLA(P G)	POWER GRID		ABB BREAKER OVERHAULLING	07/Feb/2022	08:00	11/Feb/2022	18:00	F	PLANNED	Approved	07-Feb-22	08:00	11-Feb-22	18:00	
646	RQ80967	OCC_ 191	stuup_sd	ВАУ	497 MAIN BAY - 400 KV MEERUT(PG)- MUZAFFARN AGAR(UP) (PG) CKT-1 AT MUZAFFARN AGAR(UP)	POWER GRID		For Breaker testing and Maintenance	06/Feb/2022	10:00	06/Feb/2022	16:00	F	PLANNED	Approved	06-Feb-22	10:00	06-Feb-22	16:00	
647	RQ81534	OCC_ 191	cpcc1_sd	BAY	408 MAIN BAY - 400 KV MEERUT- BAGHPAT (PG) CKT-2 AT MEERUT	POWER GRID		CB Pole Overhauling	06/Feb/2022	08:00	11/Feb/2022	18:00	F	PLANNED	Approved	06-Feb-22	08:00	11-Feb-22	18:00	
648	RQ81540	OCC_ 191	cpcc1_sd	ВАУ	411 MAIN BAY - 125 MVAR BUS REACTOR NO 1 AT 400 KV MEERUT(PG) (POWERGRID) AT 400 KV MEERUT(PG)	POWER GRID		CSD Installation and commissioning	05/Feb/2022	08:00	06/Feb/2022	18:00	F	PLANNED	Approved	05-Feb-22	08:00	06-Feb-22	18:00	

		191	cpcc1_sd		BAY - 400KV MEERUT(PG)- MANDOLA(P G) (PL) CKT-4 AT MANDOLA(P G)	POWER GRID		ABB BREAKER OVERHAULLING	04/Feb/2022		07/Feb/2022			PLANNED	Approved	04-Feb-22	08:00	07-Feb-22	18:00	
650	RQ81445	OCC_ 191	cpcc1_sd	ВАУ		POWER GRID	D	FOR AMP WORK	02/Feb/2022	08:00	02/Feb/2022	18:00		PLANNED	Approved	02-Feb-22	08:00	02-Feb-22	18:00	
651	RQ81618	OCC_ 191	cpcc2_sd	ВАУ	400/220KV 315 MVA ICT 3 AT KISHENPUR(P G) AND FUTURE	POWER GRID		For Installation of IPS Aluminum tube conductor and replacement of Dropper from JackBus to Bus Isolator in 01 No. 400KV, 125MVAR Reactor bay in Bay No 427.	01/Feb/2022	09:00	20/Feb/2022	18:00	Kindly approve	PLANNED	Approved	01-Feb-22	09:00	20-Feb-22	18:00	
	RQ81446	191			400 KV MAINPURI- BALLABHGAR H (PG) CKT-2 AND FUTURE AT BALLABHGAR H(PG)	POWER GRID		For CB replacement work	01/Feb/2022		07/Feb/2022			PLANNED	Approved	01-Feb-22	08:00	07-Feb-22		CEA safety CLEARANE REQUIRED
653	RQ81581	OCC_ 191	cpcc1_sd	ВАУ				For Shiting of 765kV ICT-I from Bay 416 to 419 under Bay Extension Work SS34	01/Feb/2022	08:00	15/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	15-Feb-22	18:00	

654	RQ81533	OCC_ 191	cpcc1_sd	ВАУ	40708 TIE BAY - 400 KV MEERUT- BAGHPAT (PG) CKT-1 AND 400 KV MEERUT- BAGHPAT (PG) CKT-2 AT 400 KV MEERUT(PG)			CB Pole Overhauling	01/Feb/2022	08:00	05/Feb/2022	18:00	PLANNED	Approved	01-Feb-22	08:00	05-Feb-22	18:00	
	RQ81529	191		ВАУ	419 MAIN BAY - 400KV MEERUT- MANDOLA (PG) CKT-2 AT MANDOLA(P G)			CGL BREAKER OVERHAULLING	01/Feb/2022		04/Feb/2022		PLANNED	Approved	01-Feb-22	08:00	04-Feb-22	18:00	
656	RQ81527	OCC_ 191	cpcc1_sd	ВАУ	426 TIE BAY - 400KV MEERUT(PG)- MANDOLA(P G) (PL) CKT-4 AND FUTURE AT MANDOLA(P G)	POWER GRID		ABB BREAKER OVERHAULLING	01/Feb/2022	08:00	04/Feb/2022	18:00	PLANNED	Approved	01-Feb-22	08:00	04-Feb-22	18:00	
657	RQ80984	OCC_ 191	singrauli_s d	BAY	424-BS BUS SECTIONALIZ ER BAY - 400KV BUS 2 AT SINGRAULI(N T) AND 400KV BUS 4 AT SINGRAULI(N T) AT 400 KV SINGRAULI(N T)	NTPC	С	for SAS Integration	23/Feb/2022	08:00	26/Feb/2022	18:00	PLANNED	Approved	23-Feb-22	08:00	26-Feb-22	18:00	

		191			413 BUS SECTIONALIZ ER BAY - 400KV BUS 1 AT SINGRAULI(N T) AND 400KV BUS 3 AT SINGRAULI(N T) AT 400 KV SINGRAULI(N T)	NTPC	C	for SAS Integration			22/Feb/2022			PLANNED	Approved	19-Feb-22	08:00	22-Feb-22	18:00	
659	RQ80980	OCC_ 191	singrauli_s d	ВАУ	405 BUS COUPLER BAY - 400KV BUS 1 AT SINGRAULI(N T) AND 400KV BUS 2 AT SINGRAULI(N T)	NTPC	С	for Isolator SAS Integration work	14/Feb/2022	08:00	15/Feb/2022	18:00		PLANNED	Approved	14-Feb-22	08:00	15-Feb-22	18:00	
660	RQ81062	OCC_ 191	stuup_sd	ВАУ	410 MAIN BAY - 400/220KV 315 MVA ICT 3 AT SARNATH(UP)	UPPTCL		Major overhauling of Main Circuit Breaker	21/Feb/2022	10:00	27/Feb/2022	18:00	315MVA ICT- 03 will remain charged through TBC Circuit Breaker & there will be no outage.	PLANNED	Approved	21-Feb-22	10:00	27-Feb-22	18:00	
	RQ80970	191		ВАУ	COUPLER BAY - 400KV BUS 1 AT MUZAFFARN AGAR(UP) AND 400KV BUS 2 AT MUZAFFARN AGAR(UP)	UPPTCL		Breaker testing and Maintenance	17/Feb/2022		17/Feb/2022			PLANNED	Approved	17-Feb-22	10:00	17-Feb-22	16:00	
662	RQ80969	OCC_ 191	stuup_sd	ВАУ	492 MAIN BAY - 400/220KV 315 MVA ICT 3 AT MUZAFFARN AGAR(UP)	UPPTCL		For Breaker testing and Maintenance	16/Feb/2022	10:00	16/Feb/2022	16:00		PLANNED	Approved	16-Feb-22	10:00	16-Feb-22	16:00	

		191	stuup_sd	ВАУ	406 BUS COUPLER BAY - 400KV BUS 1 AT ATAUR(UP) AND 400KV BUS 2 AT ATAUR(UP)	UPPTCL	D	For annual maintenance & Testing work (Load will not interrupt during bus coupler bay Shutdown as load will be feed by Bus-1 & Bus-2)	14/Feb/2022	09:30	14/Feb/2022	16:00		PLANNED	Approved	14-Feb-22	09:30	14-Feb-22	16:00	
664	RQ81063	OCC_ 191	stuup_sd	BAY	402 TIE BAY - 765/400KV 1000 MVA ICT 1 AT ANPARA_D(U P) AND 765/400KV 1000 MVA ICT 2 AT ANPARA_D(U P)	UPPTCL	D	Testing of Bay CT and Circuit breaker (Tie bay- 402)	11/Feb/2022	10:00	11/Feb/2022	18:00	Annual Testing of Bay Equipments. Note:- ICT will remain in charged condition through 401 Main bay	PLANNED	Approved	11-Feb-22	10:00	11-Feb-22	18:00	
665	RQ81261	OCC_ 191	sldcrs_sd	ВАУ	413 MAIN BAY - 400KV CHHABRA(RV UN)-KAWAI SCTPS(APR) (RS) CKT-1 AT KAWAI SCTPS(APR)	APL	С	Circuit Breaker Overhauling	18/Feb/2022	08:00	19/Feb/2022	18:00		PLANNED	Approved	18-Feb-22	08:00	19-Feb-22	18:00	
666	RQ81262	OCC_ 191	sldcrs_sd	ВАУ	403 MAIN BAY - 400KV ANTA(RS)- KAWAI SCTPS(APR) (RS) CKT-1 AT KAWAI SCTPS(APR)	APL	С	Circuit Breaker Overhauling	16/Feb/2022	08:00	17/Feb/2022	18:00		PLANNED	Approved	16-Feb-22	08:00	17-Feb-22	18:00	
667	RQ81260	OCC_ 191	sldcrs_sd	ВАҮ	414 TIE BAY - 400KV CHHABRA(RV UN)-KAWAI SCTPS(APR) (RS) CKT-1 AND FUTURE AT KAWAI SCTPS(APR)	APL	D	Annual maintenance and testing of bay equipment's. (CT & Breaker)	08/Feb/2022	08:00	08/Feb/2022	18:00		PLANNED	Approved	08-Feb-22	08:00	08-Feb-22	18:00	

66	RQ8125	8 OCC_ 191	sldcrs_sd	ВАУ	401 MAIN BAY - 63 MVAR BUS REACTOR NO 1 AT 400 KV KAWAI SCTPS(APR)	APRL		Circuit Breaker Overhauling	14/Feb/2022	08:00	15/Feb/2022	18:00		PLANNED	Approved	14-Feb-22	08:00	15-Feb-22	18:00	
669	RQ8125	9 OCC_ 191	sldcrs_sd	BAY	410 MAIN BAY - 400/11 KV 80 MVA ST 2 AT KAWAI SCTPS(APR)	APRL		Annual maintenance and testing of bay equipment's. (CT & Breaker)	10/Feb/2022	08:00	10/Feb/2022	18:00		PLANNED	Approved	10-Feb-22	08:00	10-Feb-22	18:00	
670	RQ8144	3 OCC_ 191	cpcc1_sd		417 TIE BAY - 400KV ROORKEE(PG): KASHIPUR(UK) (PG) CKT-1 AND 400KV BAREILLY(PG)- KASHIPUR(UK) (PG) CKT-1 AT KASHIPUR(UK)		D	FOR AMP WORK	12/Feb/2022	08:00	12/Feb/2022	18:00	400KV TIE BAY NO. 417 (TIE BAY OF KASHIPUR- BAREILLY CKT-I AND KASHIPUR- ROORKEE- CKT-I) AT PTCUL, KASHIPUR	PLANNED	Approved	12-Feb-22	08:00	12-Feb-22	18:00	
67	RQ8144	0 OCC_ 191	cpcc1_sd	ВАУ	414 TIE BAY - 400KV ROORKEE(PG)- KASHIPUR(UK) (PG) CKT-2 AND 400KV BAREILLY(PG)- KASHIPUR(UK) (PG) CKT-2 AT KASHIPUR(UK)		D	FOR AMP WORK	09/Feb/2022	08:00	09/Feb/2022	18:00	400KV TIE BAY NO. 414 (TIE BAY OF KASHIPUR- BAREILLY CKT-II AND KASHIPUR- ROORKEE- CKT-II) AT PTCUL, KASHIPUR	PLANNED	Approved	09-Feb-22	08:00	09-Feb-22	18:00	

672	RQ80571	OCC_ 191	stuup_sd	ВАУ	411 TIE BAY - 400 KV AGRA SOUTH(UP)- FIROZABAD(P JFTL) (UP) CKT-1 (PJFTL) AND FUTURE AT 400 KV FIROZABAD(P JFTL) (PJFTL)	PJFTL	D	Annual Maintenance Plan (AMP)	10/Feb/2022	08:00	11/Feb/2022	18:00	АМР	PLANNED	Approved	10-Feb-22	08:00	11-Feb-22	18:00	
673	RQ80839	OCC_ 191	sldcps_sd	ВАУ	401 MAIN BAY - 400KV TALWANDI SABOO(PSG)- MUKTSAR(PS) (PS) CKT-1 AT MUKTSAR(PS)		D	General maintenance for nut-bolt tightening,cleaning and IR of equipments.	07/Feb/2022	09:00	07/Feb/2022	17:00		PLANNED	Approved	07-Feb-22	09:00	07-Feb-22	17:00	
674	RQ80837	OCC_ 191	sldcps_sd	ВАУ	406 MAIN BAY - 400KV MUKTSAR- MAKHU (PS) CKT-2 AT MUKTSAR(PS)		D	General maintenance for nut-bolt tightening, cleaning and IR of equipments.	03/Feb/2022	09:00	03/Feb/2022	17:00		PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	17:00	
675	RQ80836	OCC_ 191	sldcps_sd	ВАУ	420 TIE BAY - 400 KV BHIWANI(BB)- RAJPURA(PS) (BB) CKT-1 AND FUTURE AT RAJPURA(PS)		D	Annual protection Testing	02/Feb/2022	10:00	02/Feb/2022	15:00	Only bay Shutdown Required	PLANNED	Approved	02-Feb-22	10:00	02-Feb-22	15:00	
676	RQ81394	OCC_ 191	cpcc1_sd		400/220 KV 500 MVA ICT 5 AT FATEHGARH_ II(PG)	POWER GRID	D	FOR AMP WORK	28/Feb/2022	17:00	28/Feb/2022	23:00		PLANNED	Approved	28-Feb-22	17:00	28-Feb-22	23:00	
677	RQ81397	OCC_ 191	cpcc1_sd		400/220 KV 500 MVA ICT 4 AT FATEHGARH_ II(PG)	POWER GRID	D	FOR AMP WORK	25/Feb/2022	17:00	25/Feb/2022	23:00		PLANNED	Approved	25-Feb-22	17:00	25-Feb-22	23:00	
678	RQ81398	OCC_ 191	cpcc1_sd		400/220 KV 500 MVA ICT 3 AT FATEHGARH_ II(PG)	POWER GRID	D	FOR AMP WORK	23/Feb/2022	17:00	23/Feb/2022	23:00		PLANNED	Approved	23-Feb-22	17:00	23-Feb-22	23:00	

679	RQ81396	OCC_ 191	cpcc1_sd	ORMER	400/220 KV 500 MVA ICT 2 AT FATEHGARH_ II(PG)	POWER GRID	D	FOR AMP WORK	21/Feb/2022	17:00	21/Feb/2022	23:00		PLANNED	Approved	21-Feb-22	17:00	21-Feb-22	23:00	
680	RQ81395	OCC_ 191	cpcc1_sd	ORMER		POWER GRID	D	FOR AMP WORK	19/Feb/2022	17:00	19/Feb/2022	23:00		PLANNED	Approved	19-Feb-22	17:00	19-Feb-22	23:00	
681	RQ81244	OCC_ 191	cpcc1_sd	ORMER	1 AT BIKANER(PG)	POWER GRID	D	PEAK ERECTION ACTIVITY AND EARTHWIRE ERECTION STRINGING WORK	19/Feb/2022	10:00	21/Feb/2022	18:00		PLANNED	Approved	19-Feb-22	10:00	21-Feb-22	18:00	
682	RQ81561	OCC_ 191	cpcc2_sd	ORMER	400/220 KV 315 MVA ICT 2 AT AMRITSAR(P G)	POWER GRID	D	For AMP works.	17/Feb/2022	10:00	17/Feb/2022	18:00	Kindly approve	PLANNED	Approved	17-Feb-22	10:00	17-Feb-22	18:00	
683	RQ81103	OCC_ 191	cpcc3_sd	ORMER	400/220 KV 315 MVA ICT 2 AT KANPUR(PG)	POWER GRID		For realignment of 89C TBC isolator of ICT 2	16/Feb/2022	10:00	16/Feb/2022	18:00		PLANNED	Approved	16-Feb-22	10:00	16-Feb-22	18:00	
684	RQ81243	OCC_ 191	cpcc1_sd	ORMER	400/220 KV 500 MVA ICT 2 AT BIKANER(PG)	POWER GRID	D	PEAK ERECTION ACTIVITY AND EARTHWIRE ERECTION STRINGING WORK	16/Feb/2022	10:00	18/Feb/2022	18:00		PLANNED	Approved	16-Feb-22	10:00	18-Feb-22	18:00	
685	RQ81560	OCC_ 191	cpcc2_sd	ORMER	400/220 KV 500 MVA ICT 3 AT AMRITSAR(P G)	POWER GRID	D	For AMP works.	16/Feb/2022	10:00	16/Feb/2022	18:00	Kindly approve	PLANNED	Approved	16-Feb-22	10:00	16-Feb-22	18:00	
686	RQ81013	OCC_ 191	cpcc3_sd	ORMER	400/220 KV 500 MVA ICT 1 AT LUCKNOW_1(PG)		D	AMP Works	16/Feb/2022	09:00	16/Feb/2022	18:00		PLANNED	Approved	16-Feb-22	09:00	16-Feb-22	18:00	
687	RQ81559	OCC_ 191	cpcc2_sd	ORMER	400/220 KV 315 MVA ICT 1 AT AMRITSAR(P G)	POWER GRID	D	For AMP works.	15/Feb/2022	10:00	15/Feb/2022	18:00	Kindly approve	PLANNED	Approved	15-Feb-22	10:00	15-Feb-22	18:00	

688	RQ81513	OCC_ 191	cpcc1_sd		400/220 KV 500 MVA ICT 4 AT MAHARANIB AGH(PG)	POWER GRID	С	"ICT-4 is last equipment. so to intregate the Bus Bar, SF6 gas will reduce to this bay also. Therefore its shut down required. "	15/Feb/2022	09:00	20/Feb/2022	18:00	PLANNED	Approved	15-Feb-22	09:00	20-Feb-22	18:00	CEA CLEARANCE
689	RQ81369	OCC_ 191	cpcc1_sd		400/220 KV 500 MVA ICT 3 AT SONIPAT(PG)	POWER GRID	D	Fine Tuning of CSD installed in newly commissioned 500 MVA ICT-III	15/Feb/2022	08:00	15/Feb/2022	18:00	PLANNED	Approved	15-Feb-22	08:00	15-Feb-22	18:00	
690	RQ81240	OCC_ 191	cpcc1_sd		400/220 KV 315 MVA ICT 2 AT BHINMAL(PG)	POWER GRID	С	AMP purpose and for attend oil leakage	11/Feb/2022	09:00	12/Feb/2022	18:00	PLANNED	Approved	11-Feb-22	09:00	12-Feb-22	18:00	
691	RQ81368	OCC_ 191	cpcc1_sd			POWER GRID	D	Construction works for Integarartion of new 220 Line Bay(213 and 214) with Bus-2.	11/Feb/2022	08:00	12/Feb/2022	18:00	PLANNED	Approved	11-Feb-22	08:00	12-Feb-22	18:00	
692	RQ81239	OCC_ 191	cpcc1_sd		1 '	POWER GRID	С	AMP purpose and for attend oil leakage	09/Feb/2022	09:00	10/Feb/2022	18:00	PLANNED	Approved	09-Feb-22	09:00	10-Feb-22	18:00	
693	RQ81038	OCC_ 191	cpcc3_sd	ORMER	400/220 KV 500 MVA ICT 3 AT FATEHPUR(P G)	POWER GRID	D	AMP Works	08/Feb/2022	10:00	08/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	10:00	08-Feb-22	18:00	
694	RQ81524	OCC_ 191	cpcc1_sd		1 '	POWER GRID	D	FOR AMP WORK	08/Feb/2022	08:00	08/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	08:00	08-Feb-22	18:00	
695	RQ81165	OCC_ 191	sldcdv_sd			POWER GRID	С	commissioning of BCPU/MU under PSDF scheme.	07/Feb/2022	10:00	08/Feb/2022	22:00	PLANNED	Approved	07-Feb-22	10:00	08-Feb-22	22:00	

696	RQ81626	OCC_ 191	cpcc2_sd		400/220 KV 315 MVA ICT 3 AT KISHENPUR(P G)	POWER GRID	D	For BB extension work/ BB Teed Stability test works for upcoming 01 No. 400KV 125 MVAR Reactor bay in Bay No 427.	07/Feb/2022	09:00	07/Feb/2022	18:00	Kindly approve	PLANNED	Approved	07-Feb-22	09:00	07-Feb-22	18:00	
697	RQ81238	OCC_ 191	cpcc1_sd	ORMER	400/220 KV 500 MVA ICT 3 AT SIKAR(PG)	POWER GRID	С	To attend oil leakage from bell tank of ICT-2 at Sikar Ss	05/Feb/2022	08:00	19/Feb/2022	18:00		PLANNED	Approved	05-Feb-22	08:00	19-Feb-22	18:00	
698	RQ81577	OCC_ 191	cpcc2_sd	ORMER	400/220 KV 315 MVA ICT 1 AT HAMIRPUR(P G)	POWER GRID	D	For SF6 Top-up in GIS GC01 Compartment of Bay 204 (ICT-1). We will require shutdown of Bay 204 (ICT-I) and 220 kV Bus-I for the said top-up simultaneously	03/Feb/2022	11:00	03/Feb/2022	12:00	Kindly approve	PLANNED	Approved	03-Feb-22	11:00	03-Feb-22	12:00	
699	RQ81514	OCC_ 191	cpcc1_sd	ORMER	400/220 KV 315 MVA ICT 2 AT SONIPAT(PG)	POWER GRID	D		03/Feb/2022	09:00	03/Feb/2022	18:00		PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	18:00	
700	RQ81242	OCC_ 191	cpcc1_sd	ORMER	400/220 KV 500 MVA ICT 1 AT JIND(PG)	POWER GRID	D	Oil sampelling of R- phase HV side bushing for DGA testing.	03/Feb/2022	09:00	03/Feb/2022	18:00		PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	18:00	
701	RQ81515	OCC_ 191	cpcc1_sd		400/220 KV 315 MVA ICT 1 AT SONIPAT(PG)	POWER GRID	D	Retrofitting of REF and Differential relay	02/Feb/2022	09:00	02/Feb/2022	18:00		PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	18:00	
702	RQ81591	OCC_ 191	cpcc2_sd	1	400/220 KV 315 MVA ICT 1 AT JALANDHAR(PG)	POWER GRID	D	For safe working condition during BB Stabilty testing for upcoming 02 no.s 220kV 25 MVAR Bus Reactor Extension work at Jalandhar due to high induction.	02/Feb/2022	09:00	02/Feb/2022	19:00	Kindly approve	PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	19:00	
703	RQ81241	OCC_ 191	cpcc1_sd	ORMER	400/220 KV 315 MVA ICT 2 AT BASSI(PG)	POWER GRID	С	Complete Overhauling work of ICT-02	02/Feb/2022	08:00	14/Feb/2022	18:00		PLANNED	Approved	02-Feb-22	08:00	14-Feb-22	18:00	

704	RQ81245	OCC_ 191	cpcc1_sd		400/220 KV 315 MVA ICT 2 AT KOTA(PG)	POWER GRID	D	Oil sampling of 03 nos of CT ,	01/Feb/2022	10:00	01/Feb/2022	13:00		PLANNED	Approved	01-Feb-22	10:00	01-Feb-22	13:00	
705	RQ81237	OCC_ 191	cpcc1_sd		400/220 KV 315 MVA ICT 3 AT SAHARANPU R(PG)	POWER GRID	D	AMP Purpose	01/Feb/2022	09:00	02/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	09:00	02-Feb-22	18:00	
706	RQ81512	OCC_ 191	cpcc1_sd		400/220 KV	POWER GRID	D	AMP Purpose	01/Feb/2022	09:00	01/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	18:00	
707	RQ81097	OCC_ 191	cpcc3_sd		400/220 KV 315 MVA ICT 2 AT SOHAWAL(PG	POWER GRID	D	Shut down required on 24.01.22 to complete balance AMP work	01/Feb/2022	09:00	01/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	18:00	
708	RQ81247	OCC_ 191	cpcc1_sd		400/220 KV 315 MVA ICT 2 AT ROORKEE(PG)		D	OIL SAMPLING OF CTs	01/Feb/2022	09:00	01/Feb/2022	13:00	S/D may be availed on dt 22.01.2022	PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	13:00	
709	RQ81679	OCC_ 191	cpcc2_sd		400/220 KV 315 MVA ICT 4 AT MOGA(PG)	POWER GRID	D	For correction of Isolator orientation to prevent phase-to- phase flashover.	01/Feb/2022	08:00	01/Feb/2022	18:00	Kindly approve	PLANNED	Approved	01-Feb-22	08:00	01-Feb-22	18:00	
710	RQ81479	OCC_ 191	bbmb_sd		400/220 KV 500 MVA ICT 4 AT BALLABHGAR H(PG)		D	For Automation of Sub-staton.	01/Feb/2022	07:00	01/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	07:00	01-Feb-22	18:00	
711	RQ80988	OCC_ 191	sldcdv_sd	1	` '	DTL	D	TAN Delta testing & General Maintenance	28/Feb/2022	10:00	28/Feb/2022	17:00		PLANNED	Approved	28-Feb-22	10:00	28-Feb-22	17:00	
712	RQ81147	OCC_ 191	sldcdv_sd		` '	DTL	D	Replacement of Y phase 220kV CT incomer side due to leakage of oil and higher tan delta value.	03/Feb/2022	10:00	03/Feb/2022	17:00		PLANNED	Approved	03-Feb-22	10:00	03-Feb-22	17:00	State electrical inspector approval required

713	RQ80778	OCC_ 191	sldchr_sd	ORMER	400/220 KV 315 MVA ICT 2 AT KABULPUR(H V)	HVPNL	D	Oil leakage from NCT of ICT	25/Feb/2022	10:00	25/Feb/2022	16:00	PLANNED	Approved	25-Feb-22	10:00	25-Feb-22	16:00	
714	RQ80779	OCC_ 191	sldchr_sd	ORMER	400/220 KV 315 MVA ICT 2 AT DEEPALPUR(J HKT)	HVPNL	D	FOR AMP WORK	25/Feb/2022	09:00	25/Feb/2022	17:00	PLANNED	Approved	25-Feb-22	09:00	25-Feb-22	17:00	
715	RQ81388	OCC_ 191	sldchr_sd	ORMER	400/220 KV 315 MVA ICT 4 AT DAULATABAD (HV)	HVPNL		For testing of master control unit (MCU), testing of Bus bar protection with Bus-2	08/Feb/2022	14:00	08/Feb/2022	15:30	PLANNED	Approved	08-Feb-22	14:00	08-Feb-22	15:30	
716	RQ81387	OCC_ 191	sldchr_sd	ORMER	400/220 KV 315 MVA ICT 3 AT DAULATABAD (HV)	HVPNL		For testing of master control unit (MCU), testing of Bus bar protection with Bus-2	08/Feb/2022	14:00	08/Feb/2022	15:30	PLANNED	Approved	08-Feb-22	14:00	08-Feb-22	15:30	
717	RQ81386	OCC_ 191	sldchr_sd	ORMER	400/220 KV 315 MVA ICT 1 AT DAULATABAD (HV)	HVPNL		For testing of master control unit (MCU), testing of Bus bar protection with Bus-2	08/Feb/2022	12:00	08/Feb/2022	13:30	PLANNED	Approved	08-Feb-22	12:00	08-Feb-22	13:30	
718	RQ80961	OCC_ 191	sldchr_sd	ORMER	400/220 KV 315 MVA ICT 2 AT DAULATABAD (HV)	HVPNL		For testing of master control unit (MCU), testing of Bus bar protection with Bus-2	08/Feb/2022	12:00	08/Feb/2022	13:30	PLANNED	Approved	08-Feb-22	12:00	08-Feb-22	13:30	
719	RQ81205	OCC_ 191	sldcrs_sd	ORMER	400/220 KV 315 MVA ICT 2 AT HINDAUN(RS)	RRVPN L	D	Half yearly Maintance & testing work	25/Feb/2022	08:00	25/Feb/2022	18:00	PLANNED	Approved	25-Feb-22	08:00	25-Feb-22	18:00	
720	RQ81204	OCC_ 191	sldcrs_sd	ORMER	400/220 KV 315 MVA ICT 1 AT HINDAUN(RS)	RRVPN L	D	Half yearly Maintance & testing work	24/Feb/2022	08:00	24/Feb/2022	18:00	PLANNED	Approved	24-Feb-22	08:00	24-Feb-22	18:00	
721	RQ81213	OCC_ 191	sldcrs_sd	I	400/220 KV 315 MVA ICT 1 AT KANKANI(RS)	RRVPN L		Preventive Maintenance work and Testing of Bay & Equipments	24/Feb/2022	08:00	25/Feb/2022	18:00	PLANNED	Approved	24-Feb-22	08:00	25-Feb-22	18:00	

722	RQ81214	OCC_ 191	sldcrs_sd	TRANSF 400/220 K ORMER 500 MVA I		D	Preventive Maintenance work	21/Feb/2022	08:00	22/Feb/2022	18:00	PLANNED	Approved	21-Feb-22	08:00	22-Feb-22	18:00	
				2 AT KANKANI(I			and Testing of Bay & Equipments											
723	RQ81210	OCC_ 191	sldcrs_sd	TRANSF 400/220 K ORMER 500 MVA I		С	ATTEND OIL LEAKAGE OF	14/Feb/2022	08:00	18/Feb/2022	18:00	PLANNED	Approved	14-Feb-22	08:00	18-Feb-22	18:00	
				4 AT AKAL(RS)			MAINTANK											
724	RQ81266	OCC_ 191	sldcrs_sd	TRANSF 400/220 K ORMER 315 MVA I 3 AT AJMER(RS)	CT L	D	Half Yearly maintenance work of 400/220 KV, 315 MVA ICT-III (KANOHAR) & associated equipments of Bay (418).	11/Feb/2022	08:00	11/Feb/2022	18:00	PLANNED	Approved	11-Feb-22	08:00	11-Feb-22	18:00	
725	RQ81203	OCC_ 191	sldcrs_sd	TRANSF 400/220 K ORMER 315 MVA I 2 AT MERTA(RS	CT L	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	09/Feb/2022	08:00	09/Feb/2022	18:00	PLANNED	Approved	09-Feb-22	08:00	09-Feb-22	18:00	
726	RQ81265	OCC_ 191	sldcrs_sd	TRANSF 400/220 K ORMER 315 MVA I 1 AT AJMER(RS)	/ RRVPN	D	Half Yearly maintenance work of 400/220 KV , 315 MVA ICT-I (ALSTOM) & associated equipments of Bay (409) .	09/Feb/2022	08:00	09/Feb/2022	18:00	PLANNED	Approved	09-Feb-22	08:00	09-Feb-22	18:00	
727	RQ81212	OCC_ 191	sldcrs_sd	TRANSF 400/220 K ORMER 315 MVA I 1 AT MERTA(RS	CT L	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	08/Feb/2022	08:00	08/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	08:00	08-Feb-22	18:00	
	RQ81211	191	sldcrs_sd	TRANSF 400/220 K ORMER 315 MVA I 2 AT BIKANER(F	CT L	D	Routine Maintenance	08/Feb/2022	08:00	08/Feb/2022	18:00	PLANNED	Approved	08-Feb-22	08:00	08-Feb-22	18:00	
	RQ81207	191		TRANSF 400/220 K ORMER 315 MVA I 3 AT RATANGAI RS)	CT L		Maintenance work of bay equipments, isolators and testing work of bay equipments.			05/Feb/2022		PLANNED	Approved	05-Feb-22	08:00	05-Feb-22	18:00	
	RQ81206	191		TRANSF 400/220 K ORMER 315 MVA I 3 AT AKAL(RS)	CT L		Quarterly Maintenance	04/Feb/2022		04/Feb/2022		PLANNED	Approved	04-Feb-22	08:00	04-Feb-22	18:00	
731	RQ81208	OCC_ 191	sldcrs_sd	TRANSF 400/220 K ORMER 315 MVA I 1 AT BIKANER(F	CT L	D	Routine Maintenance	03/Feb/2022	08:00	03/Feb/2022	18:00	PLANNED	Approved	03-Feb-22	08:00	03-Feb-22	18:00	

732	RQ81215	OCC_ 191	sldcrs_sd	ORMER	400/220 KV 500 MVA ICT 1 AT	RRVPN L	D	Quarterly Maintenance	02/Feb/2022	08:00	02/Feb/2022	18:00	PLANNED	Approved	02-Feb-22	08:00	02-Feb-22	18:00	
733	RQ80795	OCC_ 191	stuup_sd	TRANSF ORMER	AKAL(RS) 400/220 KV 315 MVA ICT 3 AT SULTANPUR(UP)	UPPTCL	D	For Routine bay maintenance	22/Feb/2022	10:00	22/Feb/2022	18:00	PLANNED	Approved	22-Feb-22	10:00	22-Feb-22	18:00	
734	RQ80853	OCC_ 191	stuup_sd	ORMER	- /	UPPTCL	D	For Annual Maintenance & Testing work of ICT	22/Feb/2022	10:00	22/Feb/2022	12:00	PLANNED	Approved	22-Feb-22	10:00	22-Feb-22	12:00	
735	RQ80794	OCC_ 191	stuup_sd	ORMER	400/220 KV 240 MVA ICT 2 AT SULTANPUR(UP)	UPPTCL	С	For overhauling of circuit breaker	21/Feb/2022	10:00	23/Feb/2022	18:00	PLANNED	Approved	21-Feb-22	10:00	23-Feb-22	18:00	
736	RQ80577	OCC_ 191	stuup_sd	ORMER	400/220 KV 500 MVA ICT 6 AT GR.NOIDA(UP C)	UPPTCL	D	For general maintenance work.	20/Feb/2022	10:30	20/Feb/2022	15:00	PLANNED	Approved	20-Feb-22	10:30	20-Feb-22	15:00	
737	RQ81009	OCC_ 191	stuup_sd	ORMER	400/220 KV 315 MVA ICT 1 AT SULTANPUR(UP)	UPPTCL	D	For Routine bay maintenance	18/Feb/2022	10:00	18/Feb/2022	18:00	PLANNED	Approved	18-Feb-22	10:00	18-Feb-22	18:00	
738	RQ80815	OCC_ 191	stuup_sd	ORMER	400/220 KV 315 MVA ICT 2 AT MURADNAGA R 2(UP)	UPPTCL	D	preventive maintenance and testing and tightening work	17/Feb/2022	09:00	17/Feb/2022	17:00	PLANNED	Approved	17-Feb-22	09:00	17-Feb-22	17:00	
739	RQ80793	OCC_ 191	stuup_sd	TRANSF ORMER		UPPTCL	D	preventive maintenace	15/Feb/2022	10:00	15/Feb/2022	17:00	PLANNED	Approved	15-Feb-22	10:00	15-Feb-22	17:00	
740	RQ80848	OCC_ 191	stuup_sd	ORMER	400/132 KV 200 MVA ICT 1 AT NEHTAUR(UP)	UPPTCL	D	200MVA ICT-1 &2 shutdown are required simultaneously for annual maintenance of LV side 132kv Bus	15/Feb/2022	10:00	15/Feb/2022	13:00	PLANNED	Approved	15-Feb-22	10:00	15-Feb-22	13:00	

741	RQ80847	OCC_ 191	stuup_sd	ORMER	400/132 KV 200 MVA ICT 2 AT NEHTAUR(UP)	UPPTCL	D	200MVA ICT-1 &2 shutdown are required simultaneously for annual maintenance of LV side 132kv Bus	15/Feb/2022		15/Feb/2022			PLANNED	Approved	15-Feb-22	10:00	15-Feb-22	13:00	
742	RQ80832	OCC_ 191	stuup_sd	ORMER	400/220 KV 315 MVA ICT 2 AT PANKI(UP)	UPPTCL	D	Bay tightening and Maintenance.	11/Feb/2022	08:00	12/Feb/2022	17:00		PLANNED	Approved	11-Feb-22	08:00	12-Feb-22	17:00	
743	RQ80576	OCC_ 191	stuup_sd	ORMER	400/220 KV 315 MVA ICT 2 AT GR.NOIDA(UP C)	UPPTCL	D	For general maintenance work	10/Feb/2022	10:30	10/Feb/2022	16:00		PLANNED	Approved	10-Feb-22	10:30	10-Feb-22	16:00	
744	RQ80834	OCC_ 191	stuup_sd	ORMER	400/220 KV 240 MVA ICT 2 AT ORAI(UP)	UPPTCL	D	for routine testing and maintenance.	10/Feb/2022	09:30	10/Feb/2022	18:00		PLANNED	Approved	10-Feb-22	09:30	10-Feb-22	18:00	
745	RQ80814	OCC_ 191	stuup_sd	ORMER	400/220 KV 240 MVA ICT 1 AT MURADNAGA R_2(UP)	UPPTCL	D	preventive maintenance and testing and tightening work	10/Feb/2022	09:00	10/Feb/2022	17:00		PLANNED	Approved	10-Feb-22	09:00	10-Feb-22	17:00	
746	RQ80831	OCC_ 191	stuup_sd	ORMER	400/220 KV 315 MVA ICT 1 AT PANKI(UP)	UPPTCL	D	Bay tightening and Maintenance.	09/Feb/2022	08:00	10/Feb/2022	17:00		PLANNED	Approved	09-Feb-22	08:00	10-Feb-22	17:00	
		191	stuup_sd	TRANSF ORMER	400/220 KV 500 MVA ICT 1 AT MORADABAD (UP)	UPPTCL	D	Annual Maintanance of Transformer, Testing of CT, Busing tan delta. & Clampes and connectors Checking.	08/Feb/2022		09/Feb/2022		Annual Maintananc e of Transformer , Testing of CT, Busing tan delta. & Clampes and connectors Checking.	PLANNED	Approved	08-Feb-22	10:00	09-Feb-22	18:00	
748	RQ80833	OCC_ 191	stuup_sd	ORMER	400/220 KV 315 MVA ICT 1 AT ORAI(UP)	UPPTCL	D	for routine testing and maintenance.	08/Feb/2022	09:30	08/Feb/2022	18:00	power will evacuate from 315 MVA ICT-1.	PLANNED	Approved	08-Feb-22	09:30	08-Feb-22	18:00	
749	RQ80818	OCC_ 191	stuup_sd	TRANSF ORMER		UPPTCL	D	For Tan Delta testing	07/Feb/2022	10:00	07/Feb/2022	17:00		PLANNED	Approved	07-Feb-22	10:00	07-Feb-22	17:00	

750	RQ80845	OCC_ 191	stuup_sd	ORMER	400/220 KV 315 MVA ICT 2 AT GORAKHPUR(UP)	UPPTCL	D	For replacement of 70KN Disc Insulator by 120 KN Disc Insulator in 220 KV Main Bus-II & Jack Bus	04/Feb/2022	10:00	04/Feb/2022	15:00	Supply Not affected	PLANNED	Approved	04-Feb-22	10:00	04-Feb-22	15:00	State electrical inspector approval required
751	RQ80792	OCC_ 191	stuup_sd	ORMER	400/220 KV 315 MVA ICT 3 AT BAREILLY(UP)	UPPTCL	D	preventive maintenace	04/Feb/2022	10:00	04/Feb/2022	19:00		PLANNED	Approved	04-Feb-22	10:00	04-Feb-22	19:00	
	RQ80846	191		ORMER	240 MVA ICT 3 AT GORAKHPUR(UP)	UPPTCL	D	For replacement of 70KN Disc Insulator by 120 KN Disc Insulator in 220 KV Main Bus-II & Jack Bus			04/Feb/2022		Supply Not affected	PLANNED	Approved	04-Feb-22	10:00	04-Feb-22	15:00	State electrical inspector approval required
753	RQ80844	OCC_ 191	stuup_sd	ORMER	400/220 KV 500 MVA ICT 1 AT GORAKHPUR(UP)	UPPTCL	D	For replacement of 70KN Disc Insulator by 120 KN Disc Insulator in 220 KV Main Bus-II & Jack Bus	03/Feb/2022	10:00	03/Feb/2022	15:00	Supply Not affected	PLANNED	Approved	03-Feb-22	10:00	03-Feb-22	15:00	State electrical inspector approval required
	RQ81209	191		ORMER	1 AT DEEDWANA(MTS)	RRVPN L,ATSL	D	For annual preventive maintenance purpose	21/Feb/2022		21/Feb/2022			PLANNED	Approved	21-Feb-22	08:00	21-Feb-22	18:00	
755	RQ80830	OCC_ 191	sldcps_sd	ORMER	400/220 KV 315 MVA ICT 2 AT NAKODAR(PS G)		D	Periodic Maintenance	18/Feb/2022	09:00	18/Feb/2022	17:00		PLANNED	Approved	18-Feb-22	09:00	18-Feb-22	17:00	
756	RQ80829	OCC_ 191	sldcps_sd	ORMER	400/220 KV 315 MVA ICT 1 AT NAKODAR(PS G)		D	Periodic Maintenance	17/Feb/2022	09:00	17/Feb/2022	17:00		PLANNED	Approved	17-Feb-22	09:00	17-Feb-22	17:00	
757	RQ80828	OCC_ 191	sldcps_sd	ORMER	400/220 KV 315 MVA ICT 2 AT NAKODAR(PS G)		D	Periodic Maintenance	09/Feb/2022	09:00	09/Feb/2022	17:00		PLANNED	Approved	09-Feb-22	09:00	09-Feb-22	17:00	

758	RQ80826	OCC_ 191	sldcps_sd	ORMER	400/220 KV 500 MVA ICT 3 AT MAKHU(PS)		Nut bolt tightening and cleaning of Bay 420 CT,CB,isolators and CB and cleaning of BMK and C&R Panel and the terminal tightening of CT JB and CB MB	08/Feb/2022	09:00	08/Feb/2022	17:00	ſ	PLANNED	Approved	08-Feb-22	09:00	08-Feb-22	17:00	
759	RQ80827	OCC_ 191	sldcps_sd	ORMER	400/220 KV 500 MVA ICT 2 AT DHURI(PS)		Complete body cleaning & Tightening of transformer bush. Tightening of links of Marshalling box of Transformer	08/Feb/2022	09:00	08/Feb/2022	17:00	- (PLANNED	Approved	08-Feb-22	09:00	08-Feb-22	17:00	
760	RQ80825	OCC_ 191	sldcps_sd	ORMER	400/220 KV 500 MVA ICT 1 AT DHURI(PS)		Maintenance of ICT Bushing Clamps, 220 kV Output Bus bar , Transformer Cleaning	07/Feb/2022	09:00	07/Feb/2022	17:00	- 1	PLANNED	Approved	07-Feb-22	09:00	07-Feb-22	17:00	
761	RQ80824	OCC_ 191	sldcps_sd	ORMER	400/220 KV 500 MVA ICT 1 AT DHURI(PS)	D	403 89A, 402 89B isolator	04/Feb/2022	09:00	04/Feb/2022	17:00	- [PLANNED	Approved	04-Feb-22	09:00	04-Feb-22	17:00	
762	RQ80823	OCC_ 191	sldcps_sd	TRANSF ORMER	400/220 KV 500 MVA ICT 1 AT DHURI(PS)		Maintenance of 403 89L, LA (HV), LA (IV), Body Cleaning of ICT	03/Feb/2022	09:00	03/Feb/2022	17:00	- [PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	17:00	
763	RQ80822	OCC_ 191	sldcps_sd	TRANSF ORMER	400/220 KV 315 MVA ICT 2 AT MAKHU(PS)	D		03/Feb/2022	09:00	03/Feb/2022	17:00	1	PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	17:00	
764	RQ80820	OCC_ 191	sldcps_sd	ORMER	400/220 KV 315 MVA ICT 1 AT NAKODAR(PS G)	D	Periodic Maintenance	02/Feb/2022	09:00	02/Feb/2022	17:00		PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	17:00	

765	RQ80821	OCC_ 191	sldcps_sd		400/220 KV 500 MVA ICT 3 AT DHURI(PS)		D	Protection Testing	02/Feb/2022	09:00	02/Feb/2022	17:00	-	PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	17:00	
766	RQ80819	OCC_ 191	sldcps_sd	ORMER	400/220 KV 315 MVA ICT 1 AT MAKHU(PS)			Cleaning and Recording of IR Values of Bay 214(IV Side) CT's and CB, cleaning of CTR Panel and Terminal tightening of ICT-1 MB	01/Feb/2022	09:00	01/Feb/2022	17:00		PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	17:00	
767	RQ81365	OCC_ 191	indigrid_sd	ORMER	400/220 KV 500 MVA ICT 2 AT SOHNA ROAD (GPTL)	GPTL	D	Annual preventive maintenance	11/Feb/2022	08:00	11/Feb/2022	22:00	AMP Works	PLANNED	Approved	11-Feb-22	08:00	11-Feb-22	22:00	
768	RQ81364	OCC_ 191	indigrid_sd		400/220 KV 500 MVA ICT 2 AT KADARPUR (GPTL)	GPTL	D	Annual preventive maintenance	08/Feb/2022	08:00	08/Feb/2022	20:00	AMP Works	PLANNED	Approved	08-Feb-22	08:00	08-Feb-22	20:00	
769	RQ81138	OCC_ 191	ntpcos_sd		400/11 KV 80 MVA ST 5 AT RIHAND(NT)	NTPC		Bi-annual maintenance of Transformer ans associated bay equipments	01/Feb/2022	08:00	05/Feb/2022	18:00	Shutdown being taken during overhauling of Rihand Unit-5	PLANNED	Approved	01-Feb-22	08:00	05-Feb-22	18:00	
770	RQ81375	OCC_ 191	cpcc3_sd	ORMER	220/132 KV 200 MVA ICT 3 AT RAEBAREILLY(PG)	POWER GRID	D	For topping up of Oil and replacement of Canopy	02/Feb/2022	10:00	02/Feb/2022	14:00		PLANNED	Approved	02-Feb-22	10:00	02-Feb-22	14:00	
771	RQ81472	OCC_ 191	bbmb_sd	TRANS MISSIO N LINE	220 KV BALLABHGAR H(BB)- BADARPUR(N T) (BB) CKT-1	ВВМВ	С	For Automation of Sub-staton.	28/Feb/2022	08:00	02/Mar/2022	18:00		PLANNED	Approved	28-Feb-22	08:00	02-Mar-22	18:00	
772	RQ81467	OCC_ 191	bbmb_sd	TRANS MISSIO	220 KV PONG(BB)- DASUYA(PS) (BBMB) CKT-2	ВВМВ	D	Permit required for insetring the CTs in protection ckt during commissioning of bus bar protection at PPH Talwara	26/Feb/2022	08:00	26/Feb/2022	18:00		PLANNED	Approved	26-Feb-22	08:00	26-Feb-22	18:00	

773	RQ81219	OCC_ 191	cpcc1_sd	TRANS MISSIO	DADRI (BB)	ввмв	Stringing of 400 kV D/C Mahendragarh- Bhiwani TL at Loc.41A/0-42/0	25/Feb/2022	08:00	26/Feb/2022	18:00	PLANNED	Approved	25-Feb-22	08:00	26-Feb-22	18:00	subject to Haryana and BBMB consent
774	RQ81218	OCC_ 191	cpcc1_sd	TRANS MISSIO	220 KV BHIWANI- CHARKHI DADRI (BB) CKT-3	ВВМВ	Stringing of 400 kV D/C Mahendragarh- Bhiwani TL at Loc.41A/0-42/0	25/Feb/2022	08:00	26/Feb/2022	18:00	PLANNED	Approved	25-Feb-22	08:00	26-Feb-22	18:00	subject to Haryana and BBMB consent
775	RQ81216	OCC_ 191	cpcc1_sd	TRANS MISSIO	220 KV BHIWANI- CHARKHI DADRI (BB) CKT-1	ввмв	Stringing of 400 kV D/C Mahendragarh- Bhiwani TL at Loc.41A/0-42/0	25/Feb/2022	08:00	26/Feb/2022	18:00	PLANNED	Approved	25-Feb-22	08:00	26-Feb-22	18:00	subject to Haryana and BBMB consent
776	RQ81217	OCC_ 191	cpcc1_sd	MISSIO	220 KV BHIWANI- CHARKHI DADRI (BB) CKT-2	ввмв	Stringing of 400 kV D/C Mahendragarh- Bhiwani TL at Loc.41A/0-42/0	25/Feb/2022	08:00	26/Feb/2022	18:00	PLANNED	Approved	25-Feb-22	08:00	26-Feb-22	18:00	subject to Haryana and BBMB consent
777	RQ81466	OCC_ 191	bbmb_sd	MISSIO	(BBMB) CKT-1	ВВМВ	Permit required for insetring the CTs in protection ckt during commissioning of bus bar protection at PPH Talwara	25/Feb/2022	08:00	25/Feb/2022	18:00	PLANNED	Approved	25-Feb-22	08:00	25-Feb-22	18:00	
778	RQ81306	OCC_ 191	sldcrs_sd	TRANS MISSIO	(BB) CKT-1	ввмв	For bay maintenance & Tree Trimming under the Line requiring Shutdown	25/Feb/2022	08:00	25/Feb/2022	18:00	PLANNED	Approved	25-Feb-22	08:00	25-Feb-22	18:00	
779	RQ81468	OCC_ 191	bbmb_sd	MISSIO	220 KV JALANDHAR- PONG (BB) CKT-2	ВВМВ	Permit required for insetring the CTs in protection ckt during commissioning of bus bar protection at PPH Talwara	24/Feb/2022	08:00	24/Feb/2022	18:00	PLANNED	Approved	24-Feb-22	08:00	24-Feb-22	18:00	

780	RQ81473	OCC_ 191	bbmb_sd	MISSIO N LINE	220 KV BALLABHGAR H(BB)- BADARPUR(N T) (BB) CKT-2	ввмв	С	For Automation of Sub-staton.	24/Feb/2022	08:00	26/Feb/2022	18:00	PLANNED	Approved	24-Feb-22	08:00	26-Feb-22	18:00	
781	RQ81474	OCC_ 191	bbmb_sd	MISSIO	220 KV BALLABHGAR H-SAMAYPUR (BB) CKT-3	ВВМВ	С	For Automation of Sub-staton.	24/Feb/2022	08:00	26/Feb/2022	18:00	PLANNED	Approved	24-Feb-22	08:00	26-Feb-22	18:00	
782	RQ81471	OCC_ 191	bbmb_sd	MISSIO	220 KV GANGUWAL- JAGADHARI (BB) CKT-1	ввмв	D	Quarterly mtc	23/Feb/2022	08:00	23/Feb/2022	18:00	PLANNED	Approved	23-Feb-22	08:00	23-Feb-22	18:00	
783	RQ81463	OCC_ 191	bbmb_sd			ВВМВ	D	Permit required for insetring the CTs in protection ckt during commissioning of bus bar protection at PPH Talwara	23/Feb/2022	08:00	23/Feb/2022	18:00	PLANNED	Approved	23-Feb-22	08:00	23-Feb-22	18:00	
784	RQ81462	OCC_ 191	bbmb_sd	MISSIO	220 KV BHAKRA_L- GANGUWAL (BB) CKT-2	ввмв	D	Annual mtc	21/Feb/2022	08:00	22/Feb/2022	18:00	PLANNED	Approved	21-Feb-22	08:00	22-Feb-22	18:00	
785	RQ81484	OCC_ 191	bbmb_sd	MISSIO	220 KV GANGUWAL- JAMALPUR (BB) CKT-2	ввмв	С	For Replacement of 245kV line Bus- 2 Isolator No. 250 with new one.	21/Feb/2022	08:00	24/Feb/2022	18:00	PLANNED	Approved	21-Feb-22	08:00	24-Feb-22	18:00	CEA CLEARANE REQUIRED
786	RQ81469	OCC_ 191	bbmb_sd	MISSIO	220 KV BALLABHGAR H-SAMAYPUR (BB) CKT-1	ввмв	С	For Automation of Sub-staton.	21/Feb/2022	08:00	23/Feb/2022	18:00	PLANNED	Approved	21-Feb-22	08:00	23-Feb-22	18:00	
787	RQ81478	OCC_ 191	bbmb_sd	MISSIO	BALLABHGAR H-SAMAYPUR (BB) CKT-2	ВВМВ	С	For Automation of Sub-staton.	17/Feb/2022	08:00	20/Feb/2022	18:00	PLANNED	Approved	17-Feb-22	08:00	20-Feb-22	18:00	

788	RQ81477	OCC_ 191	bbmb_sd	MISSIO	220 KV BALLABHGAR H-CHARKHI DADRI (BB) CKT-1	ВВМВ	С	For Automation of Sub-staton.	17/Feb/2022	08:00	20/Feb/2022	18:00	PLANNED	Approved	17-Feb-22	08:00	20-Feb-22	18:00	
789	RQ81310	OCC_ 191	sldcrs_sd	TRANS MISSIO N LINE	220 KV CHARKHI DADRI(BB)- KHETRI(RS) (BB) CKT-1	ввмв	D	For maintenance Work & tree trimming	14/Feb/2022	08:00	14/Feb/2022	18:00	PLANNED	Approved	14-Feb-22	08:00	14-Feb-22	18:00	
790	RQ81483	OCC_ 191	bbmb_sd	TRANS MISSIO	220 KV GANGUWAL- JAMALPUR (BB) CKT-1	ввмв		For Replacement of 245kV line Bus- 2 Isolator No. 244 with new one.	14/Feb/2022	08:00	17/Feb/2022	18:00	PLANNED	Approved	14-Feb-22	08:00	17-Feb-22	18:00	CEA CLEARANE REQUIRED
791	RQ81461	OCC_ 191	bbmb_sd	TRANS MISSIO	220 KV DELHI RR(BB)- NARELA(DV) (BBMB) CKT-2		D	Maitenance during foggy season.	09/Feb/2022	08:00	09/Feb/2022	18:00	PLANNED	Approved	09-Feb-22	08:00	09-Feb-22	18:00	
792	RQ81486	OCC_ 191	bbmb_sd	TRANS MISSIO N LINE	220 KV JAMALPUR(B B)- SANGRUR(PS) (BB) CKT-2	ВВМВ		For Replacement of 245kV line Bus- 2 Isolator No. 204 with new one.	07/Feb/2022	08:00	10/Feb/2022	18:00	PLANNED	Approved	07-Feb-22	08:00	10-Feb-22	18:00	CEA CLEARANE REQUIRED
793	RQ81311	OCC_ 191	sldcrs_sd	MISSIO N LINE	220 KV CHARKHI DADRI(BB)- KHETRI(RS) (BB) CKT-2	ввмв	С	For overhauling of its CB at dadri end	07/Feb/2022	08:00	11/Feb/2022	18:00	PLANNED	Approved	07-Feb-22	08:00	11-Feb-22	18:00	
794	RQ81460	OCC_ 191	bbmb_sd	TRANS MISSIO	220 KV BHAKRA_R- JAMALPUR (BB) CKT-1	ввмв		Annual mtc. To attend hot point on 220 KV Bhakra- Jamalpur Ckt-I	07/Feb/2022	08:00	08/Feb/2022	18:00	PLANNED	Approved	07-Feb-22	08:00	08-Feb-22	18:00	
795	RQ81459	OCC_ 191	bbmb_sd	TRANS MISSIO	220 KV BHAKRA_L- GANGUWAL (BB) CKT-1	ввмв	D	Annual mtc	07/Feb/2022	08:00	08/Feb/2022	18:00	PLANNED	Approved	07-Feb-22	08:00	08-Feb-22	18:00	

796	RQ81458	OCC_ 191	bbmb_sd	MISSIO	220 KV BHAKRA_R- GANGUWAL (BB) CKT-1	ВВМВ	D	Annual mtc	04/Feb/2022	08:00	05/Feb/2022	18:00	PLANNE	Approved	04-Feb-22	08:00	05-Feb-22	18:00	
797	RQ81457	OCC_ 191	bbmb_sd	MISSIO	220 KV BHAKRA_R- JAMALPUR (BB) CKT-2	ввмв	D	Annual mtc	04/Feb/2022	08:00	05/Feb/2022	18:00	PLANNE	Approved	04-Feb-22	08:00	05-Feb-22	18:00	
798	RQ81485	OCC_ 191	bbmb_sd	MISSIO N LINE	220 KV JAMALPUR(B B)- SANGRUR(PS) (BB) CKT-1	ВВМВ		For Replacement of 245kV line Bus- 2 Isolator No. 208 with new one.	02/Feb/2022	08:00	05/Feb/2022	18:00	PLANNE	Approved	02-Feb-22	08:00	05-Feb-22		CEA CLEARANE REQUIRED
799	RQ81455	OCC_ 191	bbmb_sd	MISSIO	220 KV DELHI RR(BB)- NARELA(DV) (BBMB) CKT-1		D	Maitenance during foggy season.	02/Feb/2022	08:00	02/Feb/2022	18:00	PLANNEI	Approved	02-Feb-22	08:00	02-Feb-22	18:00	
800	RQ81482	OCC_ 191	bbmb_sd	MISSIO N LINE	220 KV CHARKHI DADRI- SAMAYPUR (BB) CKT-1	ВВМВ	С	For Automation of Sub-staton.	02/Feb/2022	08:00	05/Feb/2022	18:00	PLANNE	Approved	02-Feb-22	08:00	05-Feb-22	18:00	
801	RQ81454	OCC_ 191	bbmb_sd	MISSIO	220 KV BHAKRA_R- GANGUWAL (BB) CKT-2	ввмв	D	Annual mtc.	01/Feb/2022	08:00	02/Feb/2022	18:00	PLANNEI	Approved	01-Feb-22	08:00	02-Feb-22	18:00	
802	RQ81019	OCC_ 191	stuup_sd	MISSIO N LINE	SULTANPUR(UPPTCL	D	For Routine bay maintenance	26/Feb/2022	10:00	26/Feb/2022	18:00	PLANNEI	Approved	26-Feb-22	10:00	26-Feb-22	18:00	
803	RQ81124	OCC_ 191	cpcc3_sd	MISSIO N LINE	MAINPURI(P	UPPTCL	D	AMP work	18/Feb/2022	09:00	18/Feb/2022	18:00	PLANNEI	Approved	18-Feb-22	09:00	18-Feb-22	18:00	

804	RQ81123	OCC_ 191	cpcc3_sd	MISSIO N LINE	220 KV MAINPURI(P G)- NEEBKARORI(UP) (UP) CKT- 1	UPPTCL	D	AMP work	17/Feb/2022	09:00	17/Feb/2022	18:00		PLANNED	Approved	17-Feb-22	09:00	17-Feb-22	18:00	
805	RQ80997	OCC_ 191	sldcdv_sd	MISSIO N LINE	220 KV GAZIPUR(DTL)- SHAHIBABAD(UP) (UP) CKT-	UPPTCL	D	Tan Delta, testing of Equipments as per PMS at 220kV Sub Station Gazipur, DTL	16/Feb/2022	13:30	16/Feb/2022	17:30		PLANNED	Approved	16-Feb-22	13:30	16-Feb-22	17:30	
806	RQ80998	OCC_ 191	sldcdv_sd	MISSIO N LINE	220 KV GAZIPUR(DTL)-NOIDA SEC62(UP) (UP) CKT-1	UPPTCL	D	Tan Delta, testing of Equipments as per PMS at 220kV Sub Station Gazipur, DTL	16/Feb/2022	09:30	16/Feb/2022	13:30		PLANNED	Approved	16-Feb-22	09:30	16-Feb-22	13:30	
807	RQ80785	OCC_ 191	stuup_sd	MISSIO	220 KV NAPP(NP)- SIMBHOLI(UP) (UP) CKT-1	UPPTCL	D	For general maintenance work.	14/Feb/2022	10:30	15/Feb/2022	18:00	There will be no any supply interruption due to this shut down	PLANNED	Approved	14-Feb-22	10:30	15-Feb-22	18:00	
808	RQ80783	OCC_ 191	stuup_sd	MISSIO	220 KV NARA(UP)- ROORKEE(UK) (UP) CKT-1	UPPTCL	D	For Jumper tightening and lopping chopping of trees	10/Feb/2022	10:00	11/Feb/2022	18:00		PLANNED	Approved	10-Feb-22	10:00	11-Feb-22	18:00	
809	RQ80660	OCC_ 191	stuup_sd	MISSIO N LINE	220 KV PANTNAGAR(UK)- BAREILLY(UP) (UP) CKT-1	UPPTCL	С	for replacing C& R panel	07/Feb/2022	10:00	08/Feb/2022	19:00		PLANNED	Rejected					deferred to next OCC
810	RQ81095	OCC_ 191	cpcc3_sd	MISSIO	220 KV AGRA(PG)- SHAMSHABA D(UP) (UP) CKT-1	UPPTCL	D	AMP work	05/Feb/2022	08:00	05/Feb/2022	18:00		PLANNED	Approved	05-Feb-22	08:00	05-Feb-22	18:00	
811	RQ81307	OCC_ 191	sldcrs_sd		DAUSA(RS) (PG) CKT-1	POWER GRID	D	Quarterly maintenance work at both end	25/Feb/2022	09:00	25/Feb/2022	15:00		PLANNED	Approved	25-Feb-22	09:00	25-Feb-22	15:00	

812	RQ81309	OCC_ 191	sldcrs_sd	TRANS MISSIO	220 KV ANTA(NT)- LALSOTE(RS) (PG) CKT-1	POWER GRID	D	Quarterly Maintenance	25/Feb/2022	08:00	25/Feb/2022	18:00		PLANNED	Approved	25-Feb-22	08:00	25-Feb-22	18:00	
813	RQ81378	OCC_ 191	cpcc3_sd	TRANS MISSIO N LINE	220 KV ALLAHABAD(PG)- JHUSI(UP) (PG) CKT-1	POWER GRID		A/R INTO NON AUTO MODE FOR MEASUREMENT OF PID AT LOC 56- 57-58	25/Feb/2022	08:00	25/Feb/2022	18:00		PLANNED	Approved	25-Feb-22	08:00	25-Feb-22	18:00	
814	RQ81303	OCC_ 191	sldcrs_sd	TRANS MISSIO N LINE	220 KV SAWAIMADH OPUR(RS)- DAUSA(RS) (PG) CKT-1	POWER GRID		Quarterly maintenance work	24/Feb/2022	09:30	24/Feb/2022	14:30		PLANNED	Approved	24-Feb-22	09:30	24-Feb-22	14:30	
815	RQ81111	OCC_ 191	antagas_sd	TRANS MISSIO	220 KV ANTA(NT)- BHILWARA(R S) (PG) CKT-2	POWER GRID	С	AMP of Bay and line equipment (CTs, CVTs & LAs etc)	24/Feb/2022	08:00	26/Feb/2022	18:00	Line shutdown required	PLANNED	Approved	24-Feb-22	08:00	26-Feb-22	18:00	
816	RQ81041	OCC_ 191	cpcc3_sd	TRANS MISSIO N LINE	220 KV TANAKPUR(N H)- CBGANJ(UP) (PG) CKT-1	POWER GRID	D	AMP WORK	22/Feb/2022	09:00	22/Feb/2022	18:00		PLANNED	Approved	22-Feb-22	09:00	22-Feb-22	18:00	
817	RQ81464	OCC_ 191	bbmb_sd	TRANS MISSIO	220 KV JESSORE(HP)- PONG(BB) (PG) CKT-1	POWER GRID		Permit required for insetring the CTs in protection ckt during commissioning of bus bar protection at PPH Talwara	22/Feb/2022	08:00	22/Feb/2022	18:00		PLANNED	Approved	22-Feb-22	08:00	22-Feb-22	18:00	
818	RQ81110	OCC_ 191	antagas_sd	TRANS MISSIO	220 KV ANTA(NT)- LALSOTE(RS) (PG) CKT-1	POWER GRID	С	AMP of Bay and line equipment (CTs, CVTs & LAs etc)	21/Feb/2022	08:00	23/Feb/2022	18:00	Line shutdown required	PLANNED	Approved	21-Feb-22	08:00	23-Feb-22	18:00	

819	RQ81465	OCC_ 191	bbmb_sd	MISSIO	220 KV BAIRASIUL(N H)-PONG(BB) (PG) CKT-1	POWER GRID	D	Permit required for insetring the CTs in protection ckt during commissioning of bus bar protection at PPH Talwara	21/Feb/2022	08:00	21/Feb/2022	18:00		PLANNED	Approved	21-Feb-22	08:00	21-Feb-22	18:00	
820	RQ81125	OCC_ 191	cpcc3_sd	MISSIO N LINE	220 KV DHAULIGANG A(NH)- PITHORAGAR H(PG) (PG) CKT-1	POWER GRID	С	Shifting & final connection of lines at Jauljibi, Pithoragarh & Bareilly SS.	20/Feb/2022	08:00	27/Feb/2022	18:00		PLANNED	Approved	20-Feb-22	08:00	27-Feb-22	18:00	CEA safety CLEARANE REQUIRED/FTC REQUIREMENT.one ckt at a time
	RQ81126	191		MISSIO N LINE CIRCUIT	BAREILLY(UP) (PG) CKT-1	POWER GRID	С	Shifting & final connection of lines at Jauljibi, Pithoragarh & Bareilly SS.	20/Feb/2022	08:00	27/Feb/2022	18:00		PLANNED	Approved	20-Feb-22	08:00	27-Feb-22	18:00	CEA safety CLEARANE REQUIRED/FTC REQUIREMENT.one ckt at a time
822	RQ81127	OCC_ 191	cpcc3_sd	TRANS MISSIO N LINE	220 KV PITHORAGAR H(PG)- BAREILLY(UP) (PG) CKT-1	POWER GRID	С	Shifting & final connection of lines at Jauljibi, Pithoragarh & Bareilly SS.	20/Feb/2022	08:00	27/Feb/2022	18:00		PLANNED	Approved	20-Feb-22	08:00	27-Feb-22	18:00	CEA safety CLEARANE REQUIRED/FTC REQUIREMENT.one ckt at a time
	RQ81580	191		MISSIO N LINE CIRCUIT	220 KV HAMIRPUR(P G)- HAMIRPUR(H P) (PG) CKT-2		D	For AMP works and Pneumatic CB Drive overhauling at HPSEB Hamirpur (Mattansidh) end with non-auto reclose mode on 220kV Hamirpur- Hamirpur ckt-2 during shut down period.	18/Feb/2022		18/Feb/2022		Kindly approve	PLANNED	Approved	18-Feb-22	08:00	18-Feb-22	20:00	
824	RQ81040	OCC_ 191	cpcc3_sd	TRANS MISSIO N LINE	220 KV SITARGANJ(P G)- CBGANJ(UP) (PG) CKT-1	POWER GRID	D	AMP work	17/Feb/2022	10:00	17/Feb/2022	18:00		PLANNED	Approved	17-Feb-22	10:00	17-Feb-22	18:00	
825	RQ81481	OCC_ 191	bbmb_sd	AC TRANS MISSIO N LINE CIRCUIT	220 KV JESSORE(HP)- PONG(BB) (PG) CKT-1	POWER GRID	С	For replacement of 220 KV TBC bypass isolator of the said ckt.	17/Feb/2022	08:00	19/Feb/2022	18:00		PLANNED	Approved	17-Feb-22	08:00	19-Feb-22	18:00	CEA safety CLEARANE REQUIRED

826	RQ81579	OCC_ 191	cpcc2_sd	MISSIO N LINE	220 KV HAMIRPUR(P G)- HAMIRPUR(H P) (PG) CKT-1	POWER GRID	D	For AMP works and Pneumatic CB Drive overhauling at HPSEB Hamirpur (Mattansidh) end with non-auto reclose mode on 220kV Hamirpur- Hamirpur ckt-2 during shut down period.	17/Feb/2022	08:00	17/Feb/2022	20:00	Kindly approve	PLANNED	Approved	17-Feb-22	08:00	17-Feb-22	20:00	
827	RQ81520	OCC_ 191	nhpccc_sd	TRANS MISSIO N LINE	220 KV BAIRASIUL(N H)- JESSORE(HP) (PG) CKT-1	POWER GRID	С	Annual Maintenance works and Illumination works	17/Feb/2022	08:00	18/Feb/2022	18:00		PLANNED	Approved	17-Feb-22	08:00	18-Feb-22	18:00	
828	RQ81180	OCC_ 191	cpcc1_sd	MISSIO N LINE	220 KV SAWAIMADH OPUR(RS)- DAUSA(RS) (PG) CKT-1	POWER GRID	С	For NHAI Diversion Work	16/Feb/2022	08:00	25/Feb/2022	18:00		PLANNED	Approved	16-Feb-22	08:00	25-Feb-22		Require CEA clearance before charging/ANNEXUR E B-7 UNDERTAKING
829	RQ81181	OCC_ 191	cpcc1_sd	MISSIO	220 KV LALSOTE(RS)- DAUSA(RS) (PG) CKT-1	POWER GRID	С	For NHAI Diversion Work	16/Feb/2022	08:00	25/Feb/2022	18:00		PLANNED	Approved	16-Feb-22	08:00	25-Feb-22		Require CEA clearance before charging/ANNEXUR E B-7 UNDERTAKING
830	RQ81075	OCC_ 191	cpcc3_sd	MISSIO	220 KV KANPUR(PG)- UNCHAHAR(NT) (PG) CKT- 3	POWER GRID	D	For CT oil sampling	15/Feb/2022	09:00	15/Feb/2022	12:00		PLANNED	Approved	15-Feb-22	09:00	15-Feb-22	12:00	
831	RQ81377	OCC_ 191	cpcc3_sd	MISSIO N LINE	220 KV ALLAHABAD(PG)- JHUSI(UP) (PG) CKT-1	POWER GRID	D	For Replacement of Insulator at Loc no 56	15/Feb/2022	08:00	15/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	08:00	15-Feb-22		CEA safety CLEARANE REQUIRED
832	RQ81521	OCC_ 191	nhpccc_sd	TRANS MISSIO	H)-PONG(BB) (PG) CKT-1	POWER GRID	С	Annual Maintenance works and Illumination works	15/Feb/2022	08:00	16/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	08:00	16-Feb-22	18:00	

833	RQ81651	OCC_ 191	cpcc2_sd		220 KV KISHENPUR(P G)-SARNA(PS) (PG) CKT-2	POWER GRID	D	For AMP Works & Peak rectification works at Loc No. 3 & 24.	14/Feb/2022	09:00	14/Feb/2022	18:00	Kindly approve	PLANNED	Approved	14-Feb-22	09:00	14-Feb-22	18:00	
834	RQ81642	OCC_ 191	cpcc2_sd	MISSIO	220 KV KISHENPUR(P G)-SARNA(PS) (PG) CKT-1	POWER GRID		For AMP Works & Peak rectification works at Loc No. 3 & 24.	14/Feb/2022	09:00	14/Feb/2022	18:00	Kindly approve	PLANNED	Approved	14-Feb-22	09:00	14-Feb-22	18:00	
835	RQ81475	OCC_ 191	bbmb_sd	MISSIO N LINE	220 KV FARIDABAD SEC-58 (HV)- SAMAYPUR(B B) (PG) CKT-2	POWER GRID	С	For Automation of Sub-staton.	07/Feb/2022	08:00	10/Feb/2022	18:00		PLANNED	Approved	07-Feb-22	08:00	10-Feb-22	18:00	
836	RQ81566	OCC_ 191	cpcc2_sd	MISSIO	220 KV SARNA(PS)- DASUYA(PS) (PG) CKT-2	POWER GRID	D	For AMP works.	02/Feb/2022	10:00	02/Feb/2022	18:00	Kindly approve	PLANNED	Approved	02-Feb-22	10:00	02-Feb-22	18:00	
837	RQ81480	OCC_ 191	bbmb_sd	MISSIO	220 KV BAIRASIUL(N H)-PONG(BB)	POWER GRID		For replacement of 220 KV TBC bypass isolator of the said ckt.	02/Feb/2022	08:00	04/Feb/2022	18:00		PLANNED	Approved	02-Feb-22	08:00	04-Feb-22	18:00	CEA safety CLEARANE REQUIRED
				N LINE CIRCUIT	(PG) CKT-1			CKI.												
838	RQ81302	OCC_ 191	sldcrs_sd	AC TRANS MISSIO	220 KV AGRA(PG)- SIKANDRA(UP) (PG) CKT-1	POWER GRID,R RVPNL	D	For maintenance of line	25/Feb/2022	08:00	25/Feb/2022	18:00		PLANNED	Approved	25-Feb-22	08:00	25-Feb-22	18:00	
	RQ81302	191		AC TRANS MISSIO N LINE CIRCUIT AC TRANS MISSIO	220 KV AGRA(PG)- SIKANDRA(UP) (PG) CKT-1 220 KV AGRA(PG)- BHARATPUR(RS) (PG) CKT-	GRID,R RVPNL POWER GRID,R		For maintenance	25/Feb/2022 24/Feb/2022		25/Feb/2022 24/Feb/2022			PLANNED	Approved Approved	25-Feb-22 24-Feb-22	08:00	25-Feb-22 24-Feb-22	18:00	

841	RQ81668	OCC_ 191	cpcc2_sd	MISSIO	220 KV JAGRAON(PS)- LUDHIANA(P G) (PSTCL) CKT-1	PSTCL	D	For AMP works.	22/Feb/2022	09:00	22/Feb/2022	17:00	Kindly approve	PLANNED	Approved	22-Feb-22	09:00	22-Feb-22	17:00	
842	RQ81682	OCC_ 191	cpcc2_sd	MISSIO N LINE	220 KV MOGA(PG)- MEHAL- KALAN(PS) (PSTCL) CKT-2	PSTCL		For correction of Isolator orientation to prevent phase-to-phase flashover.	15/Feb/2022	08:00	15/Feb/2022	18:00	Kindly approve	PLANNED	Approved	15-Feb-22	08:00	15-Feb-22	18:00	
843	RQ81692	OCC_ 191	cpcc2_sd	MISSIO	220 KV PATIALA(PG)- RAJPURA(PS) (PSTCL) CKT-1	PSTCL	D	For Line Bay AMP Works at Patiala SS.	14/Feb/2022	09:00	14/Feb/2022	18:00	Kindly approve	PLANNED	Approved	14-Feb-22	09:00	14-Feb-22	18:00	
844	RQ81681	OCC_ 191	cpcc2_sd	MISSIO N LINE	220 KV MOGA(PG)- MEHAL- KALAN(PS) (PSTCL) CKT-1	PSTCL	D	For correction of Isolator orientation to prevent phase-to- phase flashover.	12/Feb/2022	08:00	12/Feb/2022	18:00	Kindly approve	PLANNED	Approved	12-Feb-22	08:00	12-Feb-22	18:00	
845	RQ81456	OCC_ 191	bbmb_sd	MISSIO N LINE	BHAKRA_R(B	PSTCL		Annual mtc. and to attend hot point on 220 KV Bhakra- Mahilpur Ckt-I	04/Feb/2022	08:00	05/Feb/2022	18:00		PLANNED	Approved	04-Feb-22	08:00	05-Feb-22	18:00	
846	RQ81594	OCC_ 191	cpcc2_sd	MISSIO N LINE	220 KV JALANDHAR(PG)- KANJAL(PS) (PSTCL) CKT-1	PSTCL		For safe working condition during BB Stabilty testing for upcoming 02 no.s 220kV 25 MVAR Bus Reactor Extension work at Jalandhar due to high induction.	03/Feb/2022	09:00	03/Feb/2022	19:00	Kindly approve	PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	19:00	
847	RQ81665	OCC_ 191	cpcc2_sd	MISSIO N LINE	LUDHIANA(P	PSTCL	D	For AMP works.	01/Feb/2022	09:00	01/Feb/2022	17:00	Kindly approve	PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	17:00	

848	RQ81453	OCC_ 191	bbmb_sd	MISSIO N LINE	BHAKRA_R(B	PSTCL	D	Annual mtc.	01/Feb/2022	08:00	02/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	02-Feb-22	18:00	
849	RQ81321	OCC_ 191	sldcrs_sd	MISSIO	ANTA(NT)- SAKATPURA(RS) (RS) CKT-	RRVPN L	С	Quartly maintenance work and Testing of Equipment	24/Feb/2022	08:00	25/Feb/2022	18:00		PLANNED	Approved	24-Feb-22	08:00	25-Feb-22	18:00	
850	RQ81172	OCC_ 191	cpcc1_sd	MISSIO	BHINMAL(PG)- SANCHORE(R S) (RS) CKT-1	RRVPN L	D	For AMP of Line Bay	22/Feb/2022	10:00	22/Feb/2022	13:00		PLANNED	Approved	22-Feb-22	10:00	22-Feb-22	13:00	
851	RQ81323	OCC_ 191	sldcrs_sd	MISSIO	220 KV RAPS_A(NP)- SAKATPURA(RS) (RS) CKT-2	RRVPN L	С	Quartly maintenance work and Testing of Equipment	17/Feb/2022	08:00	18/Feb/2022	18:00		PLANNED	Approved	17-Feb-22	08:00	18-Feb-22	18:00	
852	RQ81236	OCC_ 191	cpcc1_sd	MISSIO N LINE	220 KV JAIPUR SOUTH(PG)- GONER(RS) (RS) CKT-1	RRVPN L	D	AMP WORK	15/Feb/2022	09:00	15/Feb/2022	18:00		PLANNED	Approved	15-Feb-22	09:00	15-Feb-22	18:00	
853	RQ80772	OCC_ 191	rappc_sd	MISSIO	220 KV DEBARI(RS)- RAPS_A(NP) (RS) CKT-1	RRVPN L	С	For the removal of old electyromegnetic protection relay for the circuit as micom main-I and Main-II protection relay are in service.	14/Feb/2022	08:00	17/Feb/2022	18:00	old relay removal	PLANNED	Approved	14-Feb-22	08:00	17-Feb-22	18:00	
854	RQ81318	OCC_ 191	sldcrs_sd	MISSIO	220 KV RAPS_B(NP)- SAKATPURA(RS) (RS) CKT- 1	RRVPN L	С	Quartly maintenance work and Testing of Equipment	09/Feb/2022	08:00	10/Feb/2022	18:00		PLANNED	Approved	09-Feb-22	08:00	10-Feb-22	18:00	
855	RQ81235	OCC_ 191	cpcc1_sd	MISSIO	220 KV BHIWADI(PG)- BHIWADI(RS) (RS) CKT-2	RRVPN L	D	Relay retrofitting of Main 1 (From SEL to SIEMENS)	05/Feb/2022	08:00	05/Feb/2022	18:00		PLANNED	Approved	05-Feb-22	08:00	05-Feb-22	18:00	

856	RQ81234	OCC_ 191	cpcc1_sd	TRANS MISSIO	BHIWADI(PG)- BHIWADI(RS) (RS) CKT-1	RRVPN L		Relay retrofitting of Main 1 (From SEL to SIEMENS)	04/Feb/2022	08:00	04/Feb/2022	18:00		PLANNED	Approved	04-Feb-22	08:00	04-Feb-22	18:00	
857	RQ81322	OCC_ 191	sldcrs_sd	TRANS MISSIO	RAPS_A(NP)- SAKATPURA(RS) (RS) CKT-1	RRVPN L	С	Quartly maintenance work and Testing of Equipment	03/Feb/2022	08:00	04/Feb/2022	18:00		PLANNED	Approved	03-Feb-22	08:00	04-Feb-22	18:00	
858	RQ81452	OCC_ 191	cpcc1_sd	TRANS MISSIO N LINE	220 KV MOHANA(HV)- SONIPAT(PG) (HVPNL) CKT- 1	HVPNL	D	FOR AMP WORK	22/Feb/2022	09:00	22/Feb/2022	18:00		PLANNED	Approved	22-Feb-22	09:00	22-Feb-22	18:00	
859	RQ81449	OCC_ 191	cpcc1_sd	TRANS MISSIO	MANESAR(PG)-MAU(HV) (HVPNL) CKT-	HVPNL	D	Replacement of disconnector drive mechanism in Q2	10/Feb/2022	09:00	10/Feb/2022	18:00	Since last two OCC the S/D was approved but denied by HVPNL, It is urgent	PLANNED	Approved	10-Feb-22	09:00	10-Feb-22	18:00	
860	RQ81556	OCC_ 191	cpcc2_sd	TRANS MISSIO N LINE	ABDULLAPUR	HVPNL	D	For line bay AMP works at Abdullapur SS.	08/Feb/2022	09:00	08/Feb/2022	18:00	Kindly approve	PLANNED	Approved	08-Feb-22	09:00	08-Feb-22	18:00	
861	RQ81227	OCC_ 191	cpcc1_sd	TRANS MISSIO N LINE	GURGAON(P	HVPNL	D	AMP WORK	04/Feb/2022	09:00	04/Feb/2022	18:00		PLANNED	Approved	04-Feb-22	09:00	04-Feb-22	18:00	
862	RQ81576	OCC_ 191	cpcc2_sd	TRANS MISSIO N LINE	FATEHABAD(HVPNL	D	For line bay AMP works at Fatehabad SS.	02/Feb/2022	10:00	02/Feb/2022	17:00	Kindly approve	PLANNED	Approved	02-Feb-22	10:00	02-Feb-22	17:00	

863 RQ812	OCC_ 191	cpcc1_sd	TRANS MISSIO N LINE	GURGAON(P	HVPNL	D	AMP WORK	02/Feb/2022	09:00	02/Feb/2022 18:0		PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	18:00	
864 RQ816	596 OCC_ 191	cpcc2_sd	MISSIO	220 KV MADANPUR- PINJORE (HV) CKT-1	HVPNL		Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022 18:0	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	
865 RQ816	0CC_ 191	cpcc2_sd	MISSIO	220 KV MADANPUR- PINJORE (HV) CKT-2	HVPNL		Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022 18:0	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	
866 RQ816	0CC_ 191	cpcc2_sd	TRANS MISSIO	220 KV PINJORE(HV)- BADDI(HP) (HV) CKT-1	HVPNL		Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022 18:0	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	
867 RQ816	598 OCC_ 191	cpcc2_sd	MISSIO	220 KV KUNIHAR(HP)· PINJORE(HV) (HV) CKT-1	HVPNL		Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022 18:0	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	

868	ROS0588	locc I	adhydro_s	۸۲	220 KV	ADHPL	D	Preventive	21/Feb/2022	10.00	23/Feb/2022	16:30	Shutdown	PLANNED	Approved	21-Feb-22	10:00	23-Feb-22	16:30	
000			d		PHOZAL(HP)-	ADITIL		maintenance work	21/100/2022	10.00	23/100/2022	10.50	required on	LAININED	Approved	2110022	10.00	25 1 CD 22	10.50	
		131	u		NALLAGARH(of the 220kV					daily basis							
				N LINE	PG) (ADHPL)															
								Transmission Line					from 10:00							
				CIRCUIT	CKT-1			which includes					to 16:30 hrs.							
								tightening of					Power of							
								tower jumpers,					ADHPL and							
								checking and					Phozal							
								rectification of					HPPTCL will							
								vibration dampers,					be							
								arcing horns,					evacuated							
								tightening of					through 220							
								tower body					KV AD							
								bolt/nuts,					HYDRO(AD)-							
								inspection &					PHOZAL(HP)							
								cleaning of					(ADHPL)							
													1, ,							
								insulator strings,					CKT-1 and							
								clearance of tower					220 KV AD							
								beds, lopping of					HYDRO(AD)-							
								trees etc. in the					NALLAGARH							
								Line corridors and					(PG)							
								rectification of					(ADHPL)							
								loose sags if any.					CKT-1.							
869			adhydro_s		220 KV	ADHPL	D	Preventive	16/Feb/2022	10:00	19/Feb/2022	16:30	Shutdown	PLANNED	Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			adhydro_s d		220 KV PHOZAL(HP)-	ADHPL	D	Preventive maintenance work	16/Feb/2022	10:00	19/Feb/2022	16:30	Shutdown required on	PLANNED	Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869				TRANS		ADHPL			16/Feb/2022	10:00	19/Feb/2022	16:30	1	PLANNED	Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO	PHOZAL(HP)- NALLAGARH(ADHPL		maintenance work	16/Feb/2022	10:00	19/Feb/2022	16:30	required on	PLANNED	Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00	PLANNED	Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs.	PLANNED	Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of	PLANNED	Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers,	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and	PLANNED	Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal	PLANNED	Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will	PLANNED	Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of vibration dampers,	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will be	PLANNED	Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of vibration dampers, arcing horns,	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will be evacuated		Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of vibration dampers, arcing horns, tightening of	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will be evacuated through 220		Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of vibration dampers, arcing horns, tightening of tower body	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will be evacuated through 220 KV AD		Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of vibration dampers, arcing horns, tightening of tower body bolt/nuts,	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will be evacuated through 220 KV AD HYDRO(AD)-		Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of vibration dampers, arcing horns, tightening of tower body bolt/nuts, inspection &	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will be evacuated through 220 KV AD HYDRO(AD)- PHOZAL(HP)		Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of vibration dampers, arcing horns, tightening of tower body bolt/nuts, inspection & cleaning of	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will be evacuated through 220 KV AD HYDRO(AD)- PHOZAL(HP) (ADHPL)		Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of vibration dampers, arcing horns, tightening of tower body bolt/nuts, inspection & cleaning of insulator strings,	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will be evacuated through 220 KV AD HYDRO(AD)- PHOZAL(HP) (ADHPL) CKT-1 and		Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of vibration dampers, arcing horns, tightening of tower body bolt/nuts, inspection & cleaning of insulator strings, clearance of tower	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will be evacuated through 220 KV AD HYDRO(AD)- PHOZAL(HP) (ADHPL) CKT-1 and 220 KV AD		Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of vibration dampers, arcing horns, tightening of tower body bolt/nuts, inspection & cleaning of insulator strings, clearance of tower beds, lopping of	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will be evacuated through 220 KV AD HYDRO(AD)- PHOZAL(HP) (ADHPL) CKT-1 and 220 KV AD HYDRO(AD)-		Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of vibration dampers, arcing horns, tightening of tower body bolt/nuts, inspection & cleaning of insulator strings, clearance of tower	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will be evacuated through 220 KV AD HYDRO(AD)- PHOZAL(HP) (ADHPL) CKT-1 and 220 KV AD HYDRO(AD)- NALLAGARH		Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of vibration dampers, arcing horns, tightening of tower body bolt/nuts, inspection & cleaning of insulator strings, clearance of tower beds, lopping of	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will be evacuated through 220 KV AD HYDRO(AD)- PHOZAL(HP) (ADHPL) CKT-1 and 220 KV AD HYDRO(AD)-		Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of vibration dampers, arcing horns, tightening of tower body bolt/nuts, inspection & cleaning of insulator strings, clearance of tower beds, lopping of trees etc. in the	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will be evacuated through 220 KV AD HYDRO(AD)- PHOZAL(HP) (ADHPL) CKT-1 and 220 KV AD HYDRO(AD)- NALLAGARH		Approved	16-Feb-22	10:00	19-Feb-22	16:30	
869			d	TRANS MISSIO N LINE	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		maintenance work of the 220kV Transmission Line which includes tightening of tower jumpers, checking and rectification of vibration dampers, arcing horns, tightening of tower body bolt/nuts, inspection & cleaning of insulator strings, clearance of tower beds, lopping of trees etc. in the Line corridors and	16/Feb/2022	10:00	19/Feb/2022	16:30	required on daily basis from 10:00 to 16:30 hrs. Power of ADHPL and Phozal HPPTCL will be evacuated through 220 KV AD HYDRO(AD)-PHOZAL(HP) (ADHPL) CKT-1 and 220 KV AD HYDRO(AD)-NALLAGARH (PG)		Approved	16-Feb-22	10:00	19-Feb-22	16:30	

87	70 R	Q81644	OCC_ 191	cpcc2_sd	TRANS MISSIO	HYDRO(AD)- PHOZAL(HP) (ADHPL) CKT-	ADHPL	Non-auto mode required for OPGW installation works under ULDC scheme.	16/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	16-Feb-22	07:00	28-Feb-22	18:00	
87	71 R		OCC_ 191	adhydro_s d	TRANS MISSIO	HYDRO(AD)- NALLAGARH(PG) (ADHPL)	ADHPL	Re-routing of 220 KV ADHPL D/C line necessitated due to four laning of the road by NHAI.	01/Feb/2022	09:00	15/Feb/2022		Complete shutdown of the ADHPL 220 kV D/C Line i.e. 220 kV AD HYDRO(AD)-NALLAGARH (PG) (ADHPL) CKT-1, 220 KV AD HYDRO(AD)-PHOZAL(HP) (ADHPL) CKT-1, & 220 KV PHOZAL(HP)-NALLAGARH (PG) (ADHPL) CKT-1 required for the period from 1st February, 2022 to	PLANNED	Conditionally Approved	01-Feb-22	09:00	15-Feb-22		subject to hpsidc consent.CEA clearance required

872	RQ80586	OCC_ 191	adhydro_s d	TRANS MISSIO	PHOZAL(HP)- NALLAGARH(PG) (ADHPL)	ADHPL		Re-routing of 220 KV ADHPL D/C line necessitated due to four laning of the road by NHAI.	01/Feb/2022	09:00	15/Feb/2022		Complete shutdown of the ADHPL 220 kV D/C Line i.e. 220 kV AD HYDRO(AD)-NALLAGARH (PG) (ADHPL) CKT 1, 220 kV AD HYDRO(AD)-PHOZAL(HP) (ADHPL) CKT-1, & 220 kV PHOZAL(HP) NALLAGARH (PG) (ADHPL) CKT-1 required for the period from 1st February,		Conditionally Approved	01-Feb-22	09:00	15-Feb-22	18:00	subject to hpsIdc consent.CEA clearance required
873	RQ81500		sldchp_sd	AC	220 KV AD	ADHPL	С	Rerouting of	01/Feb/2022	09:00	15/Feb/2022	18:00	2022 to	PLANNED	Conditionally	01-Feb-22	09:00	15-Feb-22	18:00	subject to hpsldc
		191		MISSIO	HYDRO(AD)- NALLAGARH(PG) (ADHPL) CKT-1			220kV ADHPL- Nalagarh Line for four laining project of National Highway							Approved					consent.CEA clearance required

874 RQ80585 OCC_ladhydro_s AC	C Re-routing of 220	01/Feb/2022 09:00 1	15/Feb/2022 18:00	Complete PLANNED	Conditionally 01-Fe	eb-22 09:00	15-Feb-22 18:00	subject to hpsldc
191 d TRANS HYDRO(AD)-	KV ADHPL D/C line			shutdown of	Approved			consent.CEA
MISSIO PHOZAL(HP)	necessitated due			the ADHPL				clearance required
N LINE (ADHPL) CKT-	to four laning of			220 kV D/C				
CIRCUIT 1	the road by NHAI.			Line i.e. 220				
				KV AD				
				HYDRO(AD)-				
				NALLAGARH				
				(PG)				
				(ADHPL) CKT				
				1, 220 KV AD				
				AD HYDRO(AD)-				
				PHOZAL(HP)				
				(ADHPL)				
				CKT-1, &				
				220 KV				
				PHOZAL(HP)-				
				NALLAGARH				
				(PG)				
				(ADHPL)				
				CKT-1				
				required for				
				the period				
				from 1st				
				February,				
				2022 to				
875 RQ81641 OCC_cpcc2_sd AC 220 KV AD ADHPL		01/Feb/2022 07:00 2		Kindly PLANNED	Approved 01-Fe	eb-22 07:00	28-Feb-22 18:00	
191 TRANS HYDRO(AD)-	required for			approve.				
MISSIO NALLAGARH(N LINE PG) (ADHPL)	OPGW installation works under ULDO							
CIRCUIT (CKT-1	scheme.							
CIRCUIT CK1-1	Scrienie.							
876 RQ81670 OCC cpcc2 sd AC 220 KV AD ADHPL	D SD required for	01/Feb/2022 07:00 1	15/Feb/2022 18:00	Kindly PLANNED	Approved 01-Fe	eb-22 07:00	15-Feb-22 18:00	
191 TRANS HYDRO(AD)-	removal of	' ' ' '		approve.	,,,			
MISSIO NALLAGARH(Aviation Globules							
N LINE PG) (ADHPL)	for OPGW							
CIRCUIT CKT-1	installation works							
	under ULDC							
	scheme.							
877 RQ81709 OCC_cpcc2_sd AC 220 KV AD ADHPL		01/Feb/2022 07:00 1		Kindly PLANNED	Approved 01-Fe	eb-22 07:00	15-Feb-22 18:00	
TRANS HYDRO(AD)-	required for			approve				
MISSIO PHOZAL(HP) N LINE (ADHPL) CKT-	OPGW installation works under ULDO							
CIRCUIT 1	scheme.							
	Jonethe.							

878	RQ81645	OCC_ 191	cpcc2_sd	AC TRANS MISSIO N LINE CIRCUIT	220 KV PHOZAL(HP)- NALLAGARH(PG) (ADHPL) CKT-1	ADHPL	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	
879	RQ81672	OCC_ 191	cpcc2_sd		220 KV PHOZAL(HP)- NALLAGARH(PG) (ADHPL) CKT-1	ADHPL	D	SD required for removal of Aviation Globules for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	15/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	15-Feb-22	18:00	
880	RQ81671	OCC_ 191	cpcc2_sd	MISSIO	220 KV AD HYDRO(AD)- PHOZAL(HP) (ADHPL) CKT- 1	ADHPL	D	SD required for removal of Aviation Globules for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	15/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	15-Feb-22	18:00	
881	RQ80784	OCC_ 191	stuup_sd	MISSIO	220 KV MEERUT(PG)- SIMBHOLI(UP) (PG) CKT-1		D	For general maintenance work.	16/Feb/2022	10:30	19/Feb/2022	18:00	There will be no any supply interruption due to this shut down	PLANNED	Approved	16-Feb-22	10:30	19-Feb-22	18:00	
882	RQ81476	OCC_ 191	bbmb_sd	MISSIO N LINE	220 KV FARIDABAD SEC-58 (HV)- SAMAYPUR(B B) (HVPNL) CKT-1	POWER GRID,H VPNL	С	For Automation of Sub-staton.	11/Feb/2022	08:00	13/Feb/2022	18:00		PLANNED	Approved	11-Feb-22	08:00	13-Feb-22	18:00	
883	RQ81151	OCC_ 191	sldcdv_sd	N LINE	220 KV MANDOLA(P G)-SOUTH WAZIRABAD(DV) (DTL) CKT	DTL	С	Commissioning of BCPU/MU under PSDF scheme	09/Feb/2022	09:30	10/Feb/2022 2	21:30		PLANNED	Approved	09-Feb-22	09:30	10-Feb-22	21:30	
884	RQ81150	OCC_ 191	sldcdv_sd	N LINE	220 KV MANDOLA(P G)-SOUTH WAZIRABAD(DV) (DTL) CKT 3	DTL	С	Commissioning of BCPU/MU under PSDF scheme	07/Feb/2022	09:30	08/Feb/2022 2	21:30		PLANNED	Approved	07-Feb-22	09:30	08-Feb-22	21:30	
885	RQ80999	OCC_ 191	sldcdv_sd	MISSIO N LINE	220 KV MANDOLA(P G)- GOPALPUR(D TL) (DTL) CKT- 2	DTL	С	For replacment and upgradiing of outlived line isolator with new	05/Feb/2022	10:00	06/Feb/2022	17:00		PLANNED	Approved	05-Feb-22	10:00	06-Feb-22	17:00	CEA CLEARANE REQUIRED

886	RQ81506	OCC_ 191	cpcc1_sd	TRANS MISSIO N LINE	220 KV MAHARANIB AGH(PG)- LODHIROAD(DV) (DTL) CKT- 2	DTL	D	AMP Purpose	05/Feb/2022	09:00	05/Feb/2022	18:00	PL	LANNED	Approved	05-Feb-22	09:00	05-Feb-22	18:00	
887	RQ81116	OCC_ 191	sldcdv_sd	TRANS MISSIO N LINE	220 KV MANDOLA(P G)- NARELA(DV) (DTL) CKT-2	DTL	D	commissioning of BCPU/MU under PSDF scheme.	03/Feb/2022	10:00	04/Feb/2022	22:00	PL	LANNED	Approved	03-Feb-22	10:00	04-Feb-22	22:00	
888	RQ81149	OCC_ 191	sldcdv_sd	TRANS MISSIO N LINE	220 KV MANDOLA(P G)-SOUTH WAZIRABAD(DV) (DTL) CKT- 2	DTL	С	Commissioning of BCPU/MU under PSDF scheme	03/Feb/2022	09:30	04/Feb/2022	21:30	PL	LANNED	Approved	03-Feb-22	09:30	04-Feb-22	21:30	
889	RQ81115	OCC_ 191	sldcdv_sd	TRANS MISSIO N LINE	MANDOLA(P	DTL	D	commissioning of BCPU/MU under PSDF scheme.	01/Feb/2022	10:00	02/Feb/2022	22:00	PL	LANNED	Approved	01-Feb-22	10:00	02-Feb-22	22:00	
890	RQ81148	OCC_ 191	sldcdv_sd	TRANS MISSIO N LINE	220 KV MANDOLA(P G)-SOUTH WAZIRABAD(DV) (DTL) CKT- 1	DTL		Commissioning of BCPU/MU under PSDF scheme	01/Feb/2022	09:30	02/Feb/2022	21:30	PL	LANNED	Approved	01-Feb-22	09:30	02-Feb-22	21:30	
891	RQ81418	OCC_ 191	cpcc1_sd	TRANS MISSIO N LINE CIRCUIT	220 KV FATEHGARH_ II(PG)-AHEJ3L PSS HB_FGRAH_P G (AHEJ3L) (AHEJ3L) CKT- 1	AHEJ3L	D	FOR AMP WORK	02/Feb/2022	17:00	02/Feb/2022	23:00	PL	LANNED	Approved	02-Feb-22	17:00	02-Feb-22	23:00	
892	RQ81417	OCC_ 191	cpcc1_sd	TRANS MISSIO N LINE CIRCUIT	FATEHGARH_ II(PG)-AHEJOL	AHEJOL	D	FOR AMP WORK	02/Feb/2022	17:00	02/Feb/2022	23:00	PL	LANNED	Approved	02-Feb-22	17:00	02-Feb-22	23:00	

893	RQ81416	OCC_ 191	cpcc1_sd	MISSIO N LINE CIRCUIT	220 KV FATEHGARH_ II(PG)-AHEJOL PSS HB_FGRAH_P G (AHEJOL) (AHEJOL) CKT- 1		D	FOR AMP WORK	01/Feb/2022	17:00	01/Feb/2022	23:00		PLANNED	Approved	01-Feb-22	17:00	01-Feb-22	23:00	
894	RQ81419	OCC_ 191	cpcc1_sd	MISSIO N LINE	220 KV FATEHGARH_ II(PG)-AHEJ2L PSS HB_FGRAH_P G (AHEJ2L) (AHEJ2L) CKT- 1	AHEJ2L	D	FOR AMP WORK	01/Feb/2022	17:00	01/Feb/2022	23:00		PLANNED	Approved	01-Feb-22	17:00	01-Feb-22	23:00	
		191	sldchp_sd	TRANS MISSIO N LINE CIRCUIT		HPSEB		Annual Testing of substation and installation of new OPGW hardware fitting at 4 tower locations	01/Feb/2022		03/Feb/2022		Actual Date and Time of requisite Shutdown is from 27.01.2022 (10:00) to 29.01.2022 (17:00).		Approved	01-Feb-22	10:00	03-Feb-22	17:00	
896	RQ81700	OCC_ 191	cpcc2_sd	MISSIO N LINE	220 KV NALLAGARH(PG)- KISHAN(CHD) (CHD) CKT-2	CHAND IGARH SEB	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	
897	RQ81699	OCC_ 191	cpcc2_sd	MISSIO N LINE	220 KV NALLAGARH(PG)- KISHAN(CHD) (CHD) CKT-1	CHAND IGARH SEB	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	
898	RQ81636	OCC_ 191	cpcc2_sd	MISSIO N LINE	220 KV CHAMERA_3(NH)- BUDHIL(LB) (LB) CKT-1	GREEN KO BUDHIL	D	Non-auto mode required for OPGW installation works under ULDC scheme.	01/Feb/2022	07:00	28/Feb/2022	18:00	Kindly approve.	PLANNED	Approved	01-Feb-22	07:00	28-Feb-22	18:00	
899	RQ81405	OCC_ 191	cpcc1_sd	BUS	220KV BUS 1 AT MANDOLA(P G)	POWER GRID	D	For Busbar Bay unit retrofitment	28/Feb/2022	09:30	28/Feb/2022	18:30		PLANNED	Approved	28-Feb-22	09:30	28-Feb-22	18:30	
900	RQ81035	OCC_ 191	cpcc3_sd		220KV BUS 2 AT SHAHJAHANP UR(PG)	GRID	D	AMP Works	25/Feb/2022	10:00	25/Feb/2022	18:00		PLANNED	Approved	25-Feb-22	10:00	25-Feb-22	18:00	

901	RQ81034	OCC_ 191	cpcc3_sd	BUS	220KV BUS 1 AT SHAHJAHANP UR(PG)	GRID	D	AMP Works	24/Feb/2022	10:00	24/Feb/2022	18:00		PLANNED	Approved	24-Feb-22	10:00	24-Feb-22	18:00	
	RQ81407	191	cpcc1_sd	BUS	220KV BUS 3 AT MANDOLA(P G)	GRID	D	For Busbar Bay unit retrofitment	22/Feb/2022		22/Feb/2022			PLANNED	Approved	22-Feb-22	09:30	22-Feb-22	18:30	
	RQ81406	191	cpcc1_sd	BUS	220KV BUS 2 AT MANDOLA(P G)	GRID	D	For Busbar Bay unit retrofitment	21/Feb/2022		21/Feb/2022			PLANNED	Approved	21-Feb-22	09:30	21-Feb-22	18:30	
904	RQ81408	OCC_ 191	cpcc1_sd	BUS	220KV BUS 4 AT MANDOLA(P G)	GRID	D	For Busbar Bay unit retrofitment	20/Feb/2022	09:30	20/Feb/2022	18:30		PLANNED	Approved	20-Feb-22	09:30	20-Feb-22	18:30	
905	RQ81451	OCC_ 191	cpcc1_sd	BUS	220KV BUS 2 AT KOTPUTLI(PG)	GRID	D	FOR AMP WORK	18/Feb/2022	09:00	18/Feb/2022	18:00		PLANNED	Approved	18-Feb-22	09:00	18-Feb-22	18:00	
906	RQ81609	OCC_ 191	cpcc2_sd	BUS	220KV BUS 2 AT KAITHAL(PG)	POWER GRID	D	For AMP works.	17/Feb/2022	09:00	17/Feb/2022	17:30	Kindly approve	PLANNED	Approved	17-Feb-22	09:00	17-Feb-22	17:30	
907	RQ81663	OCC_ 191	cpcc2_sd	BUS	220KV BUS 2 AT LUDHIANA(P G)	POWER GRID	D	For AMP works.	16/Feb/2022	09:00	16/Feb/2022	17:00	Kindly approve	PLANNED	Approved	16-Feb-22	09:00	16-Feb-22	17:00	
908	RQ81450	OCC_ 191	cpcc1_sd	BUS	220KV BUS 1 AT KOTPUTLI(PG	GRID	D	FOR AMP WORK	16/Feb/2022	09:00	16/Feb/2022	18:00		PLANNED	Approved	16-Feb-22	09:00	16-Feb-22	18:00	
909	RQ81687	OCC_ 191	cpcc2_sd	BUS	220KV BUS 2 AT PANCHKULA(PG)	POWER GRID	D	For AMP works.	16/Feb/2022	09:00	16/Feb/2022	17:00	Kindly approve	PLANNED	Approved	16-Feb-22	09:00	16-Feb-22	17:00	
910	RQ81686	OCC_ 191	cpcc2_sd	BUS	220KV BUS 1 AT PANCHKULA(PG)	POWER GRID	D	For AMP works.	15/Feb/2022	09:00	15/Feb/2022	17:00	Kindly approve	PLANNED	Approved	15-Feb-22	09:00	15-Feb-22	17:00	
911	RQ81608	OCC_ 191	cpcc2_sd	BUS	220KV BUS 1 AT KAITHAL(PG)	POWER GRID	D	For AMP works.	15/Feb/2022	09:00	15/Feb/2022	17:30	Kindly approve	PLANNED	Approved	15-Feb-22	09:00	15-Feb-22	17:30	
912	RQ81662	OCC_ 191	cpcc2_sd	BUS	220KV BUS 1 AT LUDHIANA(P G)	POWER GRID	D	For AMP works.	14/Feb/2022	09:00	14/Feb/2022	17:00	Kindly approve	PLANNED	Approved	14-Feb-22	09:00	14-Feb-22	17:00	

913	RQ81625	OCC_ 191	cpcc2_sd	BUS	220KV BUS 2 AT KISHENPUR(P G)	POWER GRID	D	For Jumper connection Erection of Support Structure, BPI, BB extension work/ BB Stability works for upcoming 01 No. 220KV 25 MVAR Reactor bay in Bay No 212.	11/Feb/2022	09:00	12/Feb/2022	18:00	Kindly approve	PLANNED	Approved	11-Feb-22	09:00	12-Feb-22	18:00	
914	RQ81691	OCC_ 191	cpcc2_sd	BUS	220KV BUS 2 AT PATIALA(PG)	POWER GRID	D	For AMP works.	11/Feb/2022	09:00	11/Feb/2022	18:00	Kindly approve	PLANNED	Approved	11-Feb-22	09:00	11-Feb-22	18:00	
915	RQ81367	OCC_ 191	cpcc1_sd	BUS	220KV BUS 2 AT SONIPAT(PG)	POWER GRID	D	Construction works for Integarartion of new 220 Line Bay(213 and 214) with Bus-2, Bus-2 stability and Bus Bar Testing.	11/Feb/2022	08:00	13/Feb/2022	18:00		PLANNED	Approved	11-Feb-22	08:00	13-Feb-22	18:00	
916	RQ81017	OCC_ 191	cpcc3_sd	BUS	220KV BUS 2 AT RAEBAREILLY(PG)	GRID	D	AMP Works	10/Feb/2022	10:00	10/Feb/2022	18:00		PLANNED	Approved	10-Feb-22	10:00	10-Feb-22	18:00	
917	RQ81278	OCC_ 191	cpcc1_sd	BUS	220KV BUS 2 AT JAIPUR SOUTH(PG)	POWER GRID	D	AMP OF BUS	10/Feb/2022	09:00	10/Feb/2022	18:00		PLANNED	Approved	10-Feb-22	09:00	10-Feb-22	18:00	
918	RQ81274	OCC_ 191	cpcc1_sd	BUS	220KV BUS 2 AT MANESAR(PG)	GRID	D	Replacement of disconnector drive mechanism in Q2	10/Feb/2022	09:00	10/Feb/2022	18:00		PLANNED	Approved	10-Feb-22	09:00	10-Feb-22	18:00	
919	RQ81690	OCC_ 191	cpcc2_sd	BUS	220KV BUS 1 AT PATIALA(PG)	POWER GRID	D	For AMP works.	10/Feb/2022	09:00	10/Feb/2022	18:00	Kindly approve	PLANNED	Approved	10-Feb-22	09:00	10-Feb-22	18:00	
		191	cpcc3_sd	BUS	220KV BUS 1 AT RAEBAREILLY(PG)	GRID	D	AMP Works	09/Feb/2022		09/Feb/2022			PLANNED	Approved	09-Feb-22	10:00	09-Feb-22	18:00	
921	RQ81277	OCC_ 191	cpcc1_sd	BUS	220KV BUS 1 AT JAIPUR SOUTH(PG)	POWER GRID	D	AMP OF BUS	08/Feb/2022	09:00	08/Feb/2022	18:00		PLANNED	Approved	08-Feb-22	09:00	08-Feb-22	18:00	

922	RQ81624	OCC_ 191	cpcc2_sd	BUS	220KV BUS 1 AT KISHENPUR(P G)	POWER GRID		For Jumper connection Erection of Support Structure, BPI, BB extension work/ BB Stability works for upcoming 01 No. 220KV 25 MVAR Reactor bay in Bay No 212.	08/Feb/2022	09:00	09/Feb/2022	18:00	Kindly approve	PLANNED	Approved	08-Feb-22	09:00	09-Feb-22	18:00	
923	RQ81674	OCC_ 191	cpcc2_sd	BUS	220KV BUS 2 AT MOGA(PG)	POWER GRID		For correction of Isolator orientation to prevent phase-to-phase flashover.	08/Feb/2022	08:00	10/Feb/2022	18:00	Kindly approve	PLANNED	Approved	08-Feb-22	08:00	10-Feb-22	18:00	
924	RQ81366	OCC_ 191	cpcc1_sd	BUS	220KV BUS 1 AT SONIPAT(PG)	POWER GRID		Construction works for Integarartion of new 220 Line Bay(213 and 214) with Bus-1, Bus-1 stability and Bus Bar Testing.	08/Feb/2022	08:00	10/Feb/2022	18:00		PLANNED	Approved	08-Feb-22	08:00	10-Feb-22	18:00	
925	RQ81379	OCC_ 191	cpcc3_sd	BUS	220KV BUS 2 AT ALLAHABAD(PG)	POWER GRID	D	AMP work	07/Feb/2022	09:00	07/Feb/2022	18:00		PLANNED	Approved	07-Feb-22	09:00	07-Feb-22	18:00	
926	RQ81362	OCC_ 191	cpcc1_sd	BUS	220KV BUS 3 AT SAHARANPUR (PG)	GRID	D	AMP WORK	07/Feb/2022	08:00	08/Feb/2022	18:00		PLANNED	Approved	07-Feb-22	08:00	08-Feb-22	18:00	
927	RQ81589	OCC_ 191	cpcc2_sd	BUS	220KV BUS 2 AT JALANDHAR(PG)	POWER GRID		For Erection of Support Structure, BPI, BB extension work/BB Stability works for upcoming 02 no.s of 220kV 25 MVAR Bus Reactor Extension work.	04/Feb/2022	09:00	04/Feb/2022	19:00	Kindly approve	PLANNED	Approved	04-Feb-22	09:00	04-Feb-22	19:00	

928	RQ81578	OCC_ 191	cpcc2_sd	BUS	220KV BUS 1 AT HAMIRPUR(P G)	POWER GRID		For SF6 Top-up in GIS GC01 Compartment of Bay 204 (ICT-1). We will require shutdown of Bay 204 (ICT-I) and 220 kV Bus-I for the said top-up simultaneously	03/Feb/2022	11:00	03/Feb/2022	12:00	Kindly approve	PLANNED	Approved	03-Feb-22	11:00	03-Feb-22	12:00	
929	RQ81588	OCC_ 191	cpcc2_sd	BUS	220KV BUS 1 AT JALANDHAR(PG)	POWER GRID		For Erection of Support Structure, BPI, BB extension work/BB Stability works for upcoming 02 no.s of 220kV 25 MVAR Bus Reactor Extension work.	03/Feb/2022	09:00	03/Feb/2022	19:00	Kindly approve	PLANNED	Approved	03-Feb-22	09:00	03-Feb-22	19:00	
930	RQ81420	OCC_ 191	cpcc1_sd	BUS	220 KV FATEHGARH_ II(PG) - BUS 4	POWER GRID	D	for AMP works	02/Feb/2022	17:00	02/Feb/2022	23:00	220 KV Bus Bar-2B	PLANNED	Approved	02-Feb-22	17:00	02-Feb-22	23:00	
931	RQ81422	OCC_ 191	cpcc1_sd	BUS	220 KV FATEHGARH_ II(PG) - BUS 2	POWER GRID	D	FOR AMP WORK	02/Feb/2022	17:00	02/Feb/2022	23:00	220 KV Bus Bar-2A	PLANNED	Approved	02-Feb-22	17:00	02-Feb-22	23:00	
932	RQ81586	OCC_ 191	cpcc2_sd	BUS	220KV BUS 2 AT JALANDHAR(PG)	POWER GRID		For Erection of Support Structure, BPI, BB extension work/BB Stability works for upcoming 02 no.s of 220kV 25 MVAR Bus Reactor Extension work.	02/Feb/2022	09:00	02/Feb/2022	19:00	Kindly approve	PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	19:00	
933	RQ81425	OCC_ 191	cpcc1_sd	BUS	220 KV FATEHGARH_ II(PG) - BUS 3	POWER GRID	D	FOR AMP WORK	01/Feb/2022	17:00	01/Feb/2022	23:00	220 KV Bus Bar-1B	PLANNED	Approved	01-Feb-22	17:00	01-Feb-22	23:00	
934	RQ81421	OCC_ 191	cpcc1_sd	BUS	220 KV FATEHGARH_ II(PG) - BUS 1	POWER GRID	D	FOR AMP WORK	01/Feb/2022	17:00	01/Feb/2022	23:00	220 KV Bus Bar-1A	PLANNED	Approved	01-Feb-22	17:00	01-Feb-22	23:00	

935	RQ81585	OCC_ 191	cpcc2_sd	BUS	220KV BUS 1 AT JALANDHAR(PG)	POWER GRID	D	For Erection of Support Structure, BPI, BB extension work/BB Stability works for upcoming 02 no.s of 220kV 25 MVAR Bus Reactor Extension work.	01/Feb/2022	09:00	01/Feb/2022	19:00	Kindly approve	PLANNED	Approved	01-Feb-22	09:00	01-Feb-22	19:00	
936	RQ81490	OCC_ 191	bbmb_sd	BUS	220KV BUS 4 AT SAMAYPUR(B B)	ВВМВ	С	For Automation of Sub-staton.	28/Feb/2022	08:00	02/Mar/2022	18:00		PLANNED	Approved	28-Feb-22	08:00	02-Mar-22	18:00	
937		OCC_ 191	indigrid_sd	BUS		GPTL	D	Annual preventive maintenance	28/Feb/2022	08:00	28/Feb/2022	20:00	AMP Work	PLANNED	Approved	28-Feb-22	08:00	28-Feb-22	20:00	
938		OCC_ 191	indigrid_sd	BUS	KADARPUR (GPTL) - BUS 1	GPTL	D	Annual preventive maintenance	26/Feb/2022	08:00	26/Feb/2022	20:00	AMP Work	PLANNED	Approved	26-Feb-22	08:00	26-Feb-22	20:00	
939	RQ81117	OCC_ 191	antagas_sd	BUS	220KV BUS 1 AT ANTA(NT)	NTPC	D	Checking of Station Main Bus-1 Isolator of 220 KV ANTA(NT)- BHILWARA(RS) (PG) CKT-2 Bay	26/Feb/2022	08:00	26/Feb/2022	18:00	Main Bus1 shutdown required	PLANNED	Approved	26-Feb-22	08:00	26-Feb-22	18:00	
940	RQ81114	OCC_ 191	antagas_sd	BUS	220KV BUS 2 AT ANTA(NT)	NTPC	С	Checking of Station Main Bus-2 Isolator of 220 KV ANTA(NT)- BHILWARA(RS) (PG) CKT-2 Bay & Annual Maintenence work on Circuit Bkr of Bhilwara-2 Bay	24/Feb/2022	08:00	25/Feb/2022	18:00	Main Bus-2 shutdown required	PLANNED	Approved	24-Feb-22	08:00	25-Feb-22	18:00	
941	RQ81113	OCC_ 191	antagas_sd	BUS	220KV BUS 1 AT ANTA(NT)	NTPC	D	Checking of Station Main Bus-1 Isolator of 220 KV ANTA(NT)- LALSOTE(RS) (PG) CKT-1 Bay	23/Feb/2022	08:00	23/Feb/2022	18:00	Main Bus -1 shutdown required	PLANNED	Approved	23-Feb-22	08:00	23-Feb-22	18:00	

942	RQ81112	OCC_ 191	antagas_sd	BUS	220KV BUS 2 AT ANTA(NT)	NTPC	С	Checking of Station Main Bus-2 Isolator of 220 KV ANTA(NT)- LALSOTE(RS) (PG) CKT-1 Bay & Annual Maintenence work on Circuit Bkr of Lalsot Bay	21/Feb/2022	08:00	22/Feb/2022	18:00	Bus-2 shutdown required	PLANNED	Approved	21-Feb-22	08:00	22-Feb-22	18:00	
943	RQ80665	OCC_ 191	dadrigas_s d	BUS	220 KV DADRIGAS(NT) - BUS 2	NTPC	D	Annual Shutdown	03/Feb/2022	08:00	04/Feb/2022	18:00		PLANNED	Approved	03-Feb-22	08:00	04-Feb-22	18:00	
944	RQ80664	OCC_ 191	dadrigas_s d	BUS	220 KV DADRIGAS(NT) - BUS 1	NTPC	D	Annual Shutdown	01/Feb/2022	08:00	02/Feb/2022	18:00		PLANNED	Approved	01-Feb-22	08:00	02-Feb-22	18:00	
945	RQ81523	OCC_ 191	nhpccc_sd	BUS	220KV BUS 2 AT BAIRASIUL(N H)	NHPC	С	Maintenance & Illumination works	11/Feb/2022	08:00	14/Feb/2022	18:00		PLANNED	Approved	11-Feb-22	08:00	14-Feb-22	18:00	
946	RQ81522	OCC_ 191	nhpccc_sd	BUS	220KV BUS 1 AT BAIRASIUL(N H)	NHPC	С	Maintenance & Illumination works	07/Feb/2022	08:00	10/Feb/2022	18:00		PLANNED	Approved	07-Feb-22	08:00	10-Feb-22	18:00	
947	RQ80787	OCC_ 191	stuup_sd	BUS	220KV BUS 1 AT SIMBHOLI(UP)	UPPTCL	D	Main bus isolator maintenance and tighteing work	10/Feb/2022	12:00	12/Feb/2022	14:00	There will be supply interruption due to this shut down	PLANNED	Approved	10-Feb-22	12:00	12-Feb-22	14:00	
948	RQ81487	OCC_ 191	bbmb_sd	BUS	220 KV NARELA(DV) - BUS 2	DTL	С	To change the isolators under PSDF scheme	03/Feb/2022	08:00	04/Feb/2022	18:00		PLANNED	Approved	03-Feb-22	08:00	04-Feb-22	18:00	
949	RQ81291	OCC_ 191	cpcc1_sd		25 MVAR BUS REACTOR NO 1 AT 220 KV JIND(PG)		D	Oil sampelling from CTs for DGA testing of newly commissioned CTs.	02/Feb/2022	09:00	02/Feb/2022	18:00		PLANNED	Approved	02-Feb-22	09:00	02-Feb-22	18:00	

		191	bbmb_sd	ВАУ	SECTIONALIZ ER BAY - 220KV BUS 2 AT SAMAYPUR(B B) (BBMB) AND 220KV BUS 4 AT SAMAYPUR(B B) AT 220 KV SAMAYPUR(B B) (BBMB)	ВВМВ	For Automation of Sub-staton.	28/Feb/2022		02/Mar/2022			PLANNED	Approved	28-Feb-22	08:00	02-Mar-22	18:00	
951	RQ81491	OCC_ 191	bbmb_sd		203 BUS COUPLER BAY - 220KV BUS 1 AT SAMAYPUR(B B) (BBMB) AND 220KV BUS 2 AT SAMAYPUR(B B) AT 220 KV SAMAYPUR(B B) (BBMB)	ВВМВ	For Automation of Sub-staton.	14/Feb/2022	08:00	16/Feb/2022	18:00		PLANNED	Approved	14-Feb-22	08:00	16-Feb-22	18:00	
		191	indigrid_sd		BAY - 220 KV KADARPUR (GPTL) - BUS 1 (GPTL) AT KADARPUR(G PTL)	GPTL	Annual preventive maintenance			28/Feb/2022			PLANNED	Approved	28-Feb-22	08:00	28-Feb-22	20:00	
		191	indigrid_sd		BAY - 220 KV KADARPUR (GPTL) - BUS 1 (GPTL) AT KADARPUR(G PTL)	GPTL	Annual preventive maintenance	28/Feb/2022		28/Feb/2022		AMP Work	PLANNED	Approved	28-Feb-22	08:00	28-Feb-22	20:00	
954	RQ81391	OCC_ 191	indigrid_sd	ВАУ	202 MAIN BAY - 220 KV KADARPUR (GPTL) - BUS 1 (GPTL) AT KADARPUR(G PTL)	GPTL	Annual preventive maintenance	28/Feb/2022	08:00	28/Feb/2022	20:00	AMP work	PLANNED	Approved	28-Feb-22	08:00	28-Feb-22	20:00	

955	RQ81393	occ_ 191	indigrid_sc	ВАУ	209 MAIN BAY - 220 KV KADARPUR (GPTL) - BUS 1 (GPTL) AT KADARPUR(G PTL)	GPTL	D	Annual preventive maintenance	28/Feb/2022	08:00	28/Feb/2022	20:00	AMP Work	PLANNED	Approved	28-Feb-22	08:00	28-Feb-22	20:00	
956	RQ81382	OCC_ 191	indigrid_sc	BAY	204 MAIN BAY - 220 KV KADARPUR (GPTL) - BUS 1 (GPTL) AT KADARPUR(G PTL)	GPTL	D	Annual preventive maintenance	26/Feb/2022	08:00	26/Feb/2022	20:00	AMP Work	PLANNED	Approved	26-Feb-22	08:00	26-Feb-22	20:00	
957	RQ81383	OCC_ 191	indigrid_sc	BAY	201 MAIN BAY - 220 KV KADARPUR (GPTL) - BUS 1 (GPTL) AT KADARPUR(G PTL)	GPTL	D	Annual preventive maintenance	26/Feb/2022	08:00	26/Feb/2022	20:00	AMP work	PLANNED	Approved	26-Feb-22	08:00	26-Feb-22	20:00	
		191	indigrid_sd		BAY - 220 KV KADARPUR (GPTL) - BUS 1 (GPTL) AT KADARPUR(G PTL)	GPTL	D	Annual preventive maintenance	26/Feb/2022		26/Feb/2022		AMP Work	PLANNED	Approved	26-Feb-22	08:00	26-Feb-22	20:00	
959	RQ81384	OCC_ 191	indigrid_sc	BAY	210 MAIN BAY - 220 KV KADARPUR (GPTL) - BUS 1 (GPTL) AT KADARPUR(G PTL)	GPTL	D	Annual preventive maintenance	26/Feb/2022		26/Feb/2022	20:00	AMP Work	PLANNED	Approved	26-Feb-22	08:00	26-Feb-22	20:00	
		191	indigrid_sc		211 MAIN BAY - 220 KV KADARPUR (GPTL) - BUS 1 (GPTL) AT KADARPUR(G PTL)	GPTL	D	Annual preventive maintenance			24/Feb/2022		AMP Work	PLANNED	Approved	24-Feb-22	08:00	24-Feb-22	20:00	
961	RQ81374	OCC_ 191	indigrid_sc	BAY	210 MAIN BAY - 220 KV KADARPUR (GPTL) - BUS 1 (GPTL) AT KADARPUR(G	GPTL	D	Annual preventive maintenance	22/Feb/2022	08:00	22/Feb/2022	20:00	AMP Work	PLANNED	Approved	22-Feb-22	08:00	22-Feb-22	20:00	

962	RQ81373	OCC_ 191	indigrid_sd	ВАУ	209 MAIN BAY - 220 KV KADARPUR (GPTL) - BUS 1 (GPTL) AT KADARPUR(G PTL)	GPTL	D	Annual preventive maintenance	21/Feb/2022	08:00	21/Feb/2022	20:00	AMP Work	PLANNED	Approved	21-Feb-22	08:00	21-Feb-22	20:00	
963	RQ81372	OCC_ 191	indigrid_sd		208 MAIN BAY - 220 KV KADARPUR (GPTL) - BUS 1 (GPTL) AT KADARPUR(G PTL)	GPTL	D	Annual preventive maintenance	18/Feb/2022	08:00	18/Feb/2022	20:00	AMP Work	PLANNED	Approved	18-Feb-22	08:00	18-Feb-22	20:00	
		191	cpcc1_sd	BAY	BAY - 400/220 KV 315 MVA ICT 2 AT MEERUT(PG)	POWER GRID	С	CB Pole Overhauling	26/Feb/2022		01/Mar/2022			PLANNED	Approved	26-Feb-22	08:00	01-Mar-22	18:00	
965	RQ81536	OCC_ 191	cpcc1_sd		203 MAIN BAY - 220 KV MANDOLA(P G)- GOPALPUR(D TL) (DTL) CKT- 2 (POWERGRID	POWER GRID	С	REPLACEMENT OF OLD CB BY NEW CGL BREAKER	23/Feb/2022	08:00	28/Feb/2022	18:00		PLANNED	Approved	23-Feb-22	08:00	28-Feb-22	18:00	CEA safety CLEARANE REQUIRED
966	RQ81538	OCC_ 191	cpcc1_sd	BAY		POWER GRID	С	CB Pole Overhauling	22/Feb/2022	08:00	25/Feb/2022	18:00		PLANNED	Approved	22-Feb-22	08:00	25-Feb-22	18:00	
967	RQ81428	OCC_ 191	cpcc1_sd	ВАУ	I I	POWER GRID	С	Retroffing of MAIN BAY Breaker of ANTA-RAPPC Line main bay,	02/Feb/2022	10:00	10/Feb/2022	18:00	Till then ANTA-RAPP C line at NTPC End shall remain charge through Transfer BUS	PLANNED	Approved	02-Feb-22	10:00	10-Feb-22	18:00	

968	RQ80667	OCC_ 191	dadrigas_s d	ВАУ	202 BUS COUPLER BAY - 220 KV DADRIGAS(NT) - BUS 1 AND 220 KV DADRIGAS(N		D	Annual Shutdown	07/Feb/2022	08:00	08/Feb/2022	18:00		PLANNED	Approved	07-Feb-22	08:00	08-Feb-22	18:00	
					T) - BUS 2 AT 220 KV DADRIGAS(N T)															
	RQ81026	191		FSC	FSC(40%) OF 400 KV BALIA- SOHAWAL (PG) CKT-1 AT SOHAWAL(PG)	GRID		AMP Works	17/Feb/2022		17/Feb/2022	18:00		PLANNED	Approved	17-Feb-22	10:00	17-Feb-22	18:00	
970	RQ81028	OCC_ 191	cpcc3_sd	1		POWER GRID		RETRO FITMENT OF CIRCUIT BREAKER UNDER ADD CAP AT VINDHYACHAL S/S.Approved under CERC Order number 543/TT/2014 dtd. 20.09.2016	10/Feb/2022	10:00	09/Mar/2022	18:00	Power flow in Dual Block operation will be limited to 350MW in absence of any base filter i.e. BZZ11, BZZ21	PLANNED	Approved	10-Feb-22	10:00	09-Mar-22		Any restriction on Power Order. If there is may be availed after Rihad Dadri Bipole outage.

						Outage	es propo	sed in	other RPCs requiring NRPC approval			
SI No	outages proposed in	Name of Requesting Agency	Name of Elements	From		То		Basis	Reason	Remarks (If Any)	S/d Status	NRPC Remarks
1	WRPC	MP_SLDC	220KV-MALANPUR-MP-AURIYA	4/Feb/22	9:00	4/Feb/22	17:00	D	FOR LINE MAINTENANCE WORK		approved	subject to NTPC consent
2	WRPC	MP_SLDC	220KV-MALANPUR-MP-AURIYA	14/Feb/22	9:00	14/Feb/22	17:00	D	FOR BAY EQUIPMENT MAINTENANCE AND TESTING WORK		approved	subject to NTPC consent
3	WRPC	MP_SLDC	220KV-MEHGAON-MP-AURIYA	8/Feb/22	9:00	8/Feb/22	17:00	D	FOR LINE MAINTENANCE WORK		approved	subject to NTPC consent
4	WRPC	MP_SLDC	220KV-MEHGAON-MP-AURIYA	21/Feb/22	9:00	21/Feb/22	17:00	D	220KV MAIN BUS SHUTDOWN FOR FIRE WEDGE CONNECTOR INSTALLATION WORK AT 220KV S/S MEHGAON & PRE MONSOON MAINTANENECE WORK		approved	subject to NTPC consent
5	WRPC	MP_SLDC	220KV-MEHGAON-MP-AURIYA	22/Feb/22	9:00	22/Feb/22	17:00	D	220KV MAIN BUS SHUTDOWN FOR FIRE WEDGE CONNECTOR INSTALLATION WORK AT 220KV S/S MEHGAON & PRE MONSOON MAINTANENECE WORK		approved	subject to NTPC consent
6	WRPC	MP_SLDC	220KV-BHANPURA-MP-NIPANIYA	22/Feb/22	8:00	22/Feb/22	18:00	D	FOR LINE MAINTENANCE WORK	NR drawal restriction required up to 150 MW(max)	approved	NR drawal restriction required up to 150 MW(max). Subject to rajastan consent.
7	WRPC	MP_SLDC	220KV-SUWASARA-MP-NIPANIYA	17/Feb/22	8:00	17/Feb/22	18:00	D	FOR LINE MAINTENANCE WORK	NR drawal restriction required up to 150 MW(max)	approved	NR drawal restriction required up to 150 MW(max). Subject to rajastan consent.
8	WRPC	MP_SLDC	220KV-BHANPURA-MP-RANPUR	9/Feb/22	8:00	9/Feb/22	18:00	D	FOR LINE MAINTENANCE WORK	NR drawal restriction required up to 150 MW(max)	approved	Subject to rajasthan consent.
9	WRPC	MP_SLDC	220KV-BHANPURA-MP-MODAK	24/Feb/22	8:00	24/Feb/22	18:00	D	FOR LINE MAINTENANCE WORK	NR drawal restriction required up to 150 MW(max)	approved	Subject to rajasthan consent.
10	WRPC	MP_SLDC	132KV-SABALGARH-SHEOPUR + TAP TO KANDHAR	1/Feb/22	9:00	10/Feb/22	17:00	D	AUTO MODE TO NON-AUTO MODE FOR STRINGING OF OPGW		approved	

		Out	age Planning o	of Transm	ission Element	s of APRL	Kawai during	the period of February - 2022				
			From		То		Basis		Type			
S. No.	kV	Line/Bay	Date	Time	Date	Time		Reason	Construct ion/Routi ne	Remark	Shutdown Status	NRPC Remarks
1	400KV	414 Tie bay of Kawai - Chhabra line # 3 at Kawai SCTPS.	08.02.2022	9:00	08.02.2022	19:00	Daily	Annual maintenance and testing of bay equipment's (CT,Breaker & Isolator).	R	400 KV Kawai - Chhabra Line # 3 shall be available through Main bay 413.	approved	
2	400kV	410 Main bay of Station transformer # 2 at Kawai SCTPS.	10.02.2022	9:00	10.02.2022	19:00	Daily	Annual maintenance and testing of bay equipment's. (CT & Breaker)	R	Station transformer # 2 shall be available through tie bay 411.	approved	
3	400kV	401 Main bay of Bus reactor#1 at Kawai SCTPS.	14.02.2022	9:00	15.02.2022	19:00	Continuous	Circuit Breaker Overhauling	R	Bus reactor # 1 shall be available through Tie bay 402.	approved	
4		403 Main bay of Kawai - Anta line#1 at Kawai SCTPS.	16.02.2022	9:00	17.02.2022	19:00	Continuous	Circuit Breaker Overhauling	R	400 KV Kawai - Anta Line # 1 shall be available through Tie bay 402.	approved	
5	400kV	413 Main bay of Kawai - Chhabra Line#3 at Kawai SCTPS.	18.02.2022	9:00	19.02.2022	19:00	Continuous	Circuit Breaker Overhauling	R	400 KV Kawai - Chhabra Line # 3 shall be available through Tie bay 414.	approved	
6	400kV	400 KV Bus # 1 at Kawai SCTPS.	23.02.2022	9:00	24.02.2022	19:00	Continuous	Annual maintenance of 400 KV Bus connecting isolators.	R	400 KV Bus # 2 shall be available.	approved	subject to rajasthan consent. May be given on daily basis
7	400kV	400KV BUS 1 AT DEEDWANA(MTS)	7/Feb/22	9:00	7/Feb/22	18:00	Daily	For annual preventive maintenance purpose	R		approved	
8	400kV	400KV BUS 2 AT DEEDWANA(MTS)	8/Feb/22	9:00	8/Feb/22	18:00	Daily	For annual preventive maintenance purpose	R		approved	
9	400kV	220kV Bus-1 at Didwana SS	9/Feb/22	9:00	9/Feb/22	18:00	Daily	For annual preventive maintenance purpose	R		approved	
10	400kV	220kV Bus-2 at Didwana SS	10/Feb/22	9:00	10/Feb/22	18:00	Daily	For annual preventive maintenance purpose	R		approved	
11	400kV	400/220 KV 315 MVA ICT 1 AT DEEDWANA(MTS)	21/Feb/22	9:00	21/Feb/22	18:00	Daily	For annual preventive maintenance purpose	R		approved	
12	400kV	220/132 KV 100 MVA ICT 3 AT DEEDWANA(MTSCL)	24/Feb/22	9:00	24/Feb/22	18:00	Daily	For annual preventive maintenance purpose	R		approved	
13	400kV	400 KV ALWAR(ATIL)-HINDAUN(RS) (ATIL) CKT-1	15/Feb/22	8:00	15/Feb/22	18:00	Daily	Shutdown required for Annual maintenance of transmission Line.	R		approved	
14	400kV	400 KV BIKANER(RS)-DEEDWANA(MTS) (RS) CKT-1	21/Feb/22	8:00	21/Feb/22	18:00	Daily	Shutdown required for Annual maintenance of transmission Line.	R		approved	
15	400kV	400 KV SURATGARH SCTPS(RVUN)- BIKANER(RS) (RS) CKT-1	28/Feb/22	8:00	28/Feb/22	18:00	Daily	Shutdown required for Annual maintenance of transmission Line.	R		approved	
16	400kV	400 KV SURATGARH SCTPS(RVUN)- BIKANER(RS) (RS) CKT-2	28/Feb/22	8:00	28/Feb/22	18:00		AR to be kept OFF for safety purpose during 400 kV SSCTPS-Bikaner (ATRL) CKT-1.	R		approved	

		Scheo	luled Outage Pr	oposal for Feb	2022 - NRPC	System]	
S.No	. Voltage	Line/Equipment Names as per NRLDC Nomenculture	From Date	From Time	To Date	To Time	Basis	Reason	Agency	Shutdown Status	NRPC Remarks
1	400KV	400 KV MAHINDERGARH(APL)-DHANODA(HV) (ATIL) CKT-1	1/Feb/22	8:00	15/Feb/22	18:00	Continous	Continous shutdown required for completion of all erection activities of New 12 ohm Series Reactor for 400 KV MAHINDERGARH(APL)-DHANODA(HV) (ATIL) CKT-1.	ATIL-ADANI	approved	ATC Curtailment of 200-250 MW.
2	400KV	400 KV MAHINDERGARH(APL)-DHANODA(HV) (ATIL) CKT-2	16/Feb/22	8:00	28/Feb/22	18:00	Continous	Continous shutdown required for completion of all erection activities of New 12 ohm Series Reactor for 400 KV MAHINDERGARH(APL)-DHANODA(HV) (ATIL) CKT-2.		approved	ATC Curtailment of 200-250 MW.

,

Proposed Shutdown for the Month of January, 2022

Not Found in Portal

	Detail	of transmission element Name	Category to which	Da	ite	Timir	ngs				
S.No.	Voltage level	Name	transmission element belong (A/B/C)	From	То	From	То	Purpose	Daily/Continous bais	Shutdown Status	NRPC Remarks
1	I Δ()() k\/	50 MVAR Shunt Reactor (VP Line) Muzaffarnagar	А	12.02.2022	12.02.2022	10:00	14:00	For Tan Delta testing	Daily	approved	
2	400 kV	PGCIL 400 KV DC TWIN MOOSE SASARAM- ALLAHABAD LINE (CIRCUIT II)	А	10.02.2022	11.02.2022	9:00	17:00	OVERHEAD CROSSING OF UNDERCONSTRUCTION 400 KV DC TWIN MOOSE VARANASI (PGCIL)-JAUNPUR LINE BETWEEN LOCATION NO 29 & 30	Daily		Subjected to ERPC approval

						FORM	/IAT I(A): REQUEST F		SION ELEMENT OUTAGE TO RPC						
INDE	NTING AGENCY	DC.	CIL, CPCC (NR-III)	Lucknow	EOD T	HE MONTH	Jan'2	(SHUTDOW	NS)	DA	re	DD:MM:YYY	v		
INDE		PG	CIL, CPCC (NR-III)		DETAILS	HE MONTH	Jan 2	1	-	DA		OSED DATE AND TIME	T	1	
c N	NAME OF REQUESTING	VOLT			LIAILO		INTER/INTER	DAILY/	REASON	FRO		TO		Shutdown Status	NRPC Remarks
5.N.	AGENCY	LEVEL (KV)	FROM S/S	TO S/S	OWNER	CKT ID	INTER/ INTRA REGIONAL	CONTINUOUS		DATE	TIME	DATE	TIME	Status	Remarks
1	PGCIL	400 KV	Allahabad (PG)	Sasaram (PG)	POWER GRID	1	INTER	DAILY	For Replacement of Insulator at Loc no 553	10.02.2022	8:00	10.02.2021	18:00	approved	Subjected to ERPC approval
/DLAN	NED SHUT DOWN	10)				FORMAT I(B): R	EQUEST FOR BUS,BA	Y,ICTs,FACTS,FSC	s,SVCs etc OUTAGE TO RPC		1		1	1	
(PLAN	INDENTING AGE		PGCIL, CPCC (NR- III), LUCKNOW	FOR THE	MONTH of J	anuary`22			DATE	DD:MM	:YYYY]
			EQUIPMEN	T DETAILS					PROPOSED DATE AND TIME						
	NAME OF	VOLT	NAME OF		INTER/	DAILY/			FROM	TC)	Remarks	Shutdown Status	NRPC Remarks	
S.N	REQUESTING AGENCY	LEVEL (KV)	ELEMENTS (ICT, B/R, SVC, Bays, etc)	OWNER	INTRA REGION	CONTINUOUS	Reason	DATE	TIME	DATE	TIME		Status		
1	POWERGRID	400KV	B2Z21 Filter at HVDC Vindhyachal BTB	POWERGRID	INTRA	CONTINUOUS	Retrofitment of CB under ADD-CAP at Vindhyachal S/S under CERC Order No.543//TT/2014	10-Feb-22	8:00	9-Mar-22	18:00	350 MW in absence of any base filter.	approved		
2	POWERGRID	400KV	W1.W3.Q1 ICT-1 Main Bay at Agra W1.W3.Q1 ICT-1 &	POWERGRID	INTRA	DAILY	AMP of CBs and CTs	23.02.2022	9:00	23.02.2022	17:30		approved		
3	POWERGRID	400KV	ICT-2 Tie Bay at	POWERGRID	INTRA	DAILY	AMP of CBs and CTs	26.02.2022	9:00	26.02.2022	17:30		approved		
4	POWERGRID	400KV	Agra 400KV BUS SECTIONALIZER (WCB-1) at Agra	POWERGRID	INTRA	DAILY	AMP of CBs and CTs	08.02.2022	9:00	08.02.2022	17:30		approved		
5	POWERGRID	400KV	400KV BUS SECTIONALIZER (WCB-2) at Agra	POWERGRID	INTRA	DAILY	AMP of CBs and CTs	09.02.2022	9:00	09.02.2022	17:30		approved		

POWERGRID NORTHERN REGION-II

SUBJECT	:- Addition	al SD REQUEST FOR TRANSMISSI	ON ELEME	NTS for 191st (OCC MEETING						
		tails of Transmission Element	Category	,		RATION		Dailed			
S.N.	Voltage level (KV)	NAME OF THE ELEMENT AND SUBSTATION	of element	FR DATE	OM TIME	DATE	TIME	Daily/ Continuous	Reason	Shutdown Status	NRPC Remarks
1	220KV	25 MVar 220kV Bus Reactor at Amritsar S/s.	А	14.02.2022	10:00 HRS	14.02.2022	12:00 HRS	DAILY	FOR CT oil sampling after first charging.	approved	
2	220 KV	220 KV Bus -1 at Kala Amb	С	08.02.2022	09.00 Hrs	08.02.2022	17.00 Hrs	Daily	For AMP works.	approved	
3	220KV	220 KV Bus -2 at Kala Amb	С	09.02.2022	09.00 Hrs	09.02.2022	17.00 Hrs	Daily	For AMP works.	approved	
4	400 KV	424 Bay (Moga-1 Line Main Bay) at Kishenpur	А	18.02.2022	9:00 Hrs	18.02.2022	18:00 Hrs	Daily	For BB extension work/ BB Stability works for upcoming 01 No. 400KV 125 MVAR Reactor bay in Bay No 427.	approved	
5	132 KV	Mahanpur-Kathua Line	В	23.02.2022	10:00 Hrs	23.02.2022	0.625 Hrs	Daily	For AMP works.	approved	subject to JK consent in real time
6	132 KV	Mahanpur-Sewa-II Line	В	25.02.2022	10:00 Hrs	25.02.2022	0.625 Hrs	Daily	For AMP works.	approved	subject to JK consent in real time
7	132 KV	132 KV Mahanpur - Kathua Transmission Line.	В	17.02.2022	10:00 hrs	17.02.2022	15:00 hrs	Daily	For repair of Conductor between Tower No 110 & 111.	approved	subject to JK consent in real time
8	132 KV	132 KV Sewa - Kathua Transmission Line.	В	17.02.2022	10:00 hrs	17.02.2022	15:00 hrs	Daily	For working in 132 KV Mahanpur - Kathua Transmission Line. Other circuit A/R Relay required in Non Auto mode.		subject to JK consent in real time
9	132 KV	132 KV D/C Sewa-II Hiranagar Transmission Line Ckt-I	В	17.02.2022	10:00 hrs	17.02.2022	15:00 hrs	Daily	This line passes under the 132 KV Mahanpur Kathua TL. S/D required for safety purpose for repair of Conductor between Tower No 110 & 111 of 132 KV Mahanpur - Kathua T/L.	approved	subject to JK and sewa-II consent in real time
10	132 KV	132 KV D/C Sewa-II Hiranagar Transmission Line Ckt-II	В	17.02.2022	10:00 hrs	17.02.2022	15:00 hrs	Daily	This line passes under the 132 KV Mahanpur Kathua TL. S/D required for safety purpose for repair of Conductor between Tower No 110 & 111 of 132 KV Mahanpur - Kathua T/L.	approved	subject to JK and sewa-II consent in real time
11	765 KV	BIKANER TO MOGA CKT I & II	А	20.02.2022	08:00 hrs	22.02.2022	18:00 hrs	Continuous	For rectification of tower peak at Loc No. 986 & 988 and replacement of 23 Nos. polymer insulators (12 Nos. on ckt-1 and 11Nos. on ckt- 2).	approved	subject to availability of all other line at bhadla-II and bikaner
12	220KV	220KV BBMB Jagadhari- Kurukshetra S/C Transmission Line, (220kv BBMB KHERA , Jagadhari SubStation, Yamunanagar,Haryana)		01.02.2022	10:00 hrs	01.02.2022	18:00 hrs	On Requested date	For Stringing of conductors of 220KV Abdullapur-Jagadhari Transmission line(DFCCIL Project) between span location no. 16 & 17 of 220KV S/C Jagadhari- Kurukshetra BBMB line		subject to haryana and BBMB consent
13	220KV	220KV , YTPP-Abdullapur D/C Transmission Line 400/220kv Abdullapur S/S		10.02.2022	10:00 hrs	10.02.2021	18:00 hrs	On Requested date	For Stringing of conductors of 220KV Abdullapur-Jagadhari Transmission line(DFCCIL Project) between span location no. 86 & 87 of 220KV D/C YTPP-Abdullapur Transmission line		subject to haryana and BBMB consent

LIST OF ADDITONAL SHUTDOWNS PROPOSED FOR APPROVAL IN OCC-185 MEETING (PLANNED SHUTDOWNS)

FROM: Sr.DGM-CPCC, New Delhi DATE:- 11/01/22

TO: Copy: SE(OPN), NRPC, N DELHI Sr.GM (SO-1), NRLDC

Following S/D are required during the month of JAN/FEB, 2022 for 191th OCC. Kindly accord your approval so that site mobilisation may be arranged accordingly.

S.No.					DURA	TION						NRPC
	ELEMENTS	OWNER	MODE	FRO	И	то		PURPOSE	Remarks	NLDC/ RLDC	Shutdown	Remarks
				DATE	TIME	DATE	TIME			Remarks	Status	
	Contruction Related Additional Shutdown											
1	765 BUS-I at FATEHGARH_2		Daily	20.01.2022	1600 hrs	22.01.2022	2330 hrs	For Protection testing and Bus Bar extension of 765/400 KV ICT-4 HV Side.	765/400KV ICT-1 shall also be under shutdown as 765KV Dia with BUS-2 is under construction.		approved	
2	765KV BUS-II at FATEHGARH_2		Daily	23.01.2022	1600 hrs	25.01.2022	2330 hrs	For protection testing of 765KV Fatehgarh_2- Bhadla D/C line	765 BHADLA_2 CKT-I shall also be under shutdown as 765KV Dia with BUS- 1 shall be commissioned with ICT-4		approved	
3	400KV BUS-I at FATEHGARH_2		Daily	27.01.2022	1600 hrs	28.01.2022	2330 hrs	For protection testing and Bus Bar extension of 765/400 KV ICT-4 LV Side.	765/400KV ICT-1 shall also be under shutdown as 400KV Tie Bay(414) is under commisioning stage.		approved	
	765KV/400kV Lines											
1	765kV Phagi-Bhiwani Ckt-II		Daily	22.02.2022	09:00Hrs	22.02.2022	1800 Hrs	For AMP of Line Equipment and LR at Bhiwani end	along with line Reactor and other ckt will be in non auto mode.	May be allowed	approved	NR import curtailment 400MW
3	400KV D/C Fatehagarh-II to Fatehagrh-I		Daily	20.01.2022	1430Hrs	22.01.2022		For tapping arrangement work(jumper connection work) from AP 22 - 2/0 to Adani Line (LOOP IN) old section for charging of New 765 KV D/C FATEHGARH-2- BHADLA lines and for human safety due to heavy induction on the same tower.			approved	
4	400KV D/C Fatehagarh-II to Fatehagrh-II		Daily	23.01.2022	1430Hrs	25.01.2022		For tapping arrangement work(jumper connection work) from AP 22 - 2/0 to Adami Line (LOOP IN) old section for charging of New 765 KV D/C FATEHCARH-2- BHADLA lines and for human safety due to heavy induction on the same tower.			approved	
5	400KV ROORKI-KASHIPUR-1		Cont	27.01.2022	0900Hrs	10.02.2022	1800 Hrs	Shifting of line on ERS due to tower loc.169 endangered due to change in river course.			approved	subject to d-3 consent
6	400KV ROORKI-KASHIPUR-2		Cont	27.01.2022	0900Hrs	10.02.2022		Shifting of line on ERS due to tower loc.169 endangered due to change in river course.			approved	subject to d-3 consent
7	400KV HISAR(pg)-BBMB BHIWANI LINE		Daily	01.02.2022	0900Hrs	01.02.2022	1800 Hrs	AMP WORKS			approved	
8	400KV HISAR-BHIWANI LINE-3		Daily	02.02.2022	0900Hrs	02.02.2022	1800 Hrs	AMP WORKS			approved	
9	400KV HISAR- MOGA LINE-3		Daily	03.02.2022	0900Hrs	03.02.2022	1800 Hrs	AMP WORKS			approved	
10	220KV HISAR- HISAR I/A LINE-1		Daily	04.02.2022	0900Hrs	04.02.2022	1800 Hrs	AMP WORKS			approved	subject to haryana consent
11	220KV HISAR- SANGWAN LINE-1		Daily	05.02.2022	0900Hrs	05.02.2022	1800 Hrs	AMP WORKS			approved	subject to haryana consent
12	220KV HISAR SANGWAN LINE-2		Daily	07.02.2022	0900Hrs	07.02.2022	1800 Hrs	AMP WORKS			approved	subject to haryana consent
	400/220KV Bus/Reactor											
1	125 MVAR BUS REACTOR at Mandola		Daily	02.02.2022	0900Hrs	02.02.2022	1800 Hrs	CSD FINE TUNNING AND CT OIL SAMPLING			rejected	deferred to next

			I	1 1			T	ı	T	
2	125MVAR BUS REACTOR-3 AT HISAR	DAILY	08.02.2022	0900Hrs	08.02.2022	1800 Hrs	CSD FINE TUNING		rejected	deferred to next
	400/220KV Bus									
1	400kV BUS-1 at Bhinmal	DAILY	03.02.2022	9:00:00 AM	03.02.2022	18:00	AMP WORKS		approved	
2	400kV BUS-2 at Bhinmal	DAILY	04.02.2022	9:00:00 AM	04.02.2022	18:00	AMP WORKS		approved	
3	220kV BUS-1 at Bhinmal	DAILY	23.02.2022	9:00:00 AM	23.02.2022	18:00	AMP WORKS		approved	
4	220kV BUS-2 at Bhinmal	DAILY	24.02.2022	9:00:00 AM	24.02.2022	18:00	AMP WORKS		approved	
5	220kV Transfer Bus at Bhinmal	DAILY	25.02.2022	9:00:00 AM	25.02.2022	18:00	AMP WORKS		approved	
6	220kV BUS-1 at Hisar	DAILY	10.02.2022	9:00:00 AM	10.02.2022	18:00	AMP WORKS		approved	
7	220kV BUS-2 at Hisar	DAILY	12.02.2022	9:00:00 AM	12.02.2022	18:00	AMP WORKS		approved	
8	220kV Transfer Bus at Hisar	DAILY	13.02.2022	9:00:00 AM	13.02.2022	18:00	AMP WORKS		approved	
	400/220kV Bays									
1	401 Main Bay of 400 KV Kankroli Line at 400 KV RVPNL, Jodhpur SS	Daily	09.02.2022	9:00:00 AM	09.02.2022	18:00	AMP work at 400 KV RVPNL Jodhpur SS	AMP work at 400 KV RVPNL Jodhpur SS	approved	
2	MAIN BAY 203(ICT-3 IV SIDE) AT DTL BAWANA	Cont.	23.02.2022	9:00:00 AM	28.02.2022	1830	CB Overhauling work.		approved	
3	400kV Mahendergarh-IV Main 424 Bay at Bhiwani	Cont.	05.02.2022	9:00:00 AM	25.02.2022	18:00	For commissioing of Series Reactor and Dia Upgeadation from 2000A to 3000A for Bus splitting scheme SS34(Line Yet to be commissionend)		approved	subject to ftc/CEA clearance
4	400kV Mahendergarh-IV Tie 423 Bay at Bhiwani	Cont.	05.02.2022	9:00:00 AM	25.02.2022	18:00	For commissioing of Series Reactor and Dia Upgeadation from 2000A to 3000A for Bus splitting scheme SS34(Line Yet to be commissionend)		approved	subject to ftc/CEA clearance
5	400 kV Bus reactor R2&R3 Main Bay (40952)	Cont.	07.02.2022	9:00:00 AM	08.02.2022	18:00	CSD Installation and commissioning		approved	
6	220 kV RAPP-B (NP) -Chittorgarh # Ckt -2 - Main bay chanderia end /RRVPNL SS(RS) END	Cont.	07.02.2022	09-00hrs	12.02.2022	18-00hrs	Replacement / retofitting of main bay Circuit breaker , Line remain service through transfer bus circuit breaker at Chanderia /RRVPNL end.AUTORECLOSE WILL BE OUT OF SERVICE DURING LINE IN SERVICE WITH Transfer bus .		approved	CEA clearance required
7	220 kV RAPP-B (NP)-Chittorgarh # Ckt -1 - Main bay 220 KV Chanderia end /RRVPNL SS (RS)END	Cont.	14.02.2022	09-00hrs	19.02.2022	18-00hrs	Replacement / retofitting of main bay Circuit breaker , Line remain service through transfer bus circuit breaker at Chanderia /RRVPNL end.AUTORECLOSE WILL BE OUT OF SERVICE DURING LINE IN SERVICE WITH Transfer bus .		approved	CEA clearance required
8	220 kV RAPP-B (NP) -Debari MAIN BAY 220 KV DEBARI-RRVPNL (RS)END	Cont.	21.02.2022	09-00hrs	26.02.2022	18-00hrs	Replacement / retofitting of main bay Circuit breaker , Line remain service through transfer bus circuit breaker at Debari end /RRVPNL end. ,		approved	CEA clearance required

FORMAT 1(A): REQUEST FOR TRANSMISSION ELEMENT OUTAGE TO RPC (PLANNED SHUTDOWNS)

	IND	ENTING AGEN		AM/CPCC(NR-I)		Feb-20	22	DATE		27/12	2/2021				
S/D requested Group		NAME OF		LINE DETAILS	S		DAILY/		PROP	OSED D.	ATE AND TI	ME			
(including	SN	REQUESTING	VOLT			INTER/ INTRA		REASONS	FROM	4	то		REMARKS	Shutdown Status	NRPC Remarks
TL/SS/Cons/Others)	5	AGENCY	LEVEL (KV)	LINE DETAILS	OWNER	REGIONAL	OUS	KEASONS	DATE	TIME	DATE	TIME			
Fatehgarh-2 Substation		POWERGRID	765	765 kV D/C Fatehgarh-2 to Fatehgarh-1 CKT#1 [Loop IN] Charged at 400KV	POWERGRID	Intra Regional	DAILY	For Installation of Bird Diverters	25.01.2022	16:00	30.01.2022	23:00	Other Ckt will be in non-auto	approved	
Fatehgarh-2 Substation		POWERGRID	765	765 kV D/C Fatehgarh-2 to Fatehgarh-1 CKT#2 [Loop IN] Charged at 400KV	POWERGRID	Intra Regional	DAILY	For Installation of Bird Diverters	31.01.2022	16:00	05.02.2022	23:00	Other Ckt will be in non-auto	approved	
Fatehgarh-2 Substation		POWERGRID	765	765kV Fatehgarh-2-Bhadla-2-Ckt-I	TBCB	Intra Regional	DAILY	For Installation of Bird Diverters	06.02.2022	16:00	12.02.2022	23:00	Other Ckt will be in non-auto	approved	
Fatehgarh-2 Substation		POWERGRID	765	765kV Fatehgarh-2-Bhadla-2-Ckt-II	TBCB	Intra Regional	DAILY	For Installation of Bird Diverters	13.02.2022	16:00	19.02.2022	23:00	Other Ckt will be in non-auto	approved	
Fatehgarh-2 Substation		POWERGRID	765	765kV Fatehgarh-2-Bhadla-2-Ckt-I	TBCB	Intra Regional	DAILY	For Installation of Bird Diverters	19.02.2022	16:00	22.02.2022	23:00	Other Ckt will be in non-auto	approved	
Fatehgarh-2 Substation		POWERGRID	765	765kV Fatehgarh-2-Bhadla-2-Ckt-II	TBCB	Intra Regional	DAILY	For Installation of Bird Diverters	23.02.2022	16:00	26.02.2022	23:00	Other Ckt will be in non-auto	approved	

Sub: NTPC Koldam new over haul schedule for Jan 2022 OCC Approval.

NTPC has submitted that as intimated by Station approved over haul of Koldam during Dec 2020 OCC Could not be availed during Jan 2022 due to spread of COVID-19,

The revised dated for ovehauling of KOLDAM HPS as submitted buy NTPC are as below:-

Annual Inspection Plan of Koldam HPS for FY 2021-22

Unit		From	То	Days
	3	31-Jan-22	4-Feb-22	5
	4	8-Feb-22	12-Feb-22	5
	1	17-Feb-22	21-Feb-22	5
	2	25-Feb-22	1-Mar-22	5

Shutdown Status

approved

NRPC Remarks

Shutdown Request by NTPC:

Unchahar St-2 U#1-210 mw planned shut down for over haul have been approved in 190th OCC from 27.01.2022 for 40 days as requested.

During last few days Unchahar St-2 U#2-210 mw Unit Turbine axial shift having increasing trend, Therefore Unchahar St-2 U#2-210 mw will be taken under s/d for over haul (in place of Unchahar St-2 U#1). This will be 40 days s/d starting 27.01.2022.

Shutdown Status approved NRPC Remarks subject to UP consent

Format I(A): Request for transmission element outage by Indenting agency to RPC																
Indenting Agency			NHPC LTD.	For the Month		Jan-22	Date									
				ails	•				Proposed Date and Time							
SI. No.	Name of the Requesting Agency	Voltage Level (kV)	From substation	To substation	Owner	Ckt ID	Inter-Regional / Intra- Regional	Daily/ Continous	Reason	From Date	From Time	To Date	To Time	Remarks	Shutdown Status	NRPC Remarks
1	Dulhasti, NHPC LIMITED	400 kV	Dulhasti	Kishenpur	PGCIL	Dulhasti-Kishenpur 400 kV Line-1	Inter regional	Daily	Maintenance works	22-Jan-2022	9:00	22-Jan-2022	17:00	During shutdown of line, the Bus Coupler shall also be checked for its smooth operation.		

Daily Basis

Daily Basis

Daily Basis

Implementation of

SCADA system at CPS-I

Implementation of

SCADA system at CPS-I

Implementation of SCADA system at CPS-I 7-Feb-2022

9-Feb-2022

11-Feb-2022

9:00

9:00

8-Feb-2022

10-Feb-2022

12-Feb-2022

18:00

18:00

Implementation of

CPS-I

Implementation of

CPS-I

Implementation of

SCADA system at approved

SCADA system at approved

SCADA system at approved CPS-I

Chamera-I -

Jalandhar 400 kV

Line-1

Chamera-I -

Jalandhar 400 kV

Line-2

Chamera-I -

Line

PGCIL Chamera-II 400 kV

Inter regional

Inter regional

Inter regional

PGCIL

PGCIL

Jalandhar

Jalandhar

Chamera-II

Chamera PS I, NHPC

LIMITED

Chamera PS I, NHPC

LIMITED

Chamera PS I, NHPC LIMITED 400 kV

400 kV

400 kV

Chamera-I

Chamera-I

Chamera-I

2

3


4

Sr. No.	Transmission Line Name	Daily/Continuous	Reason	Requested from Date and Time	Requested to Date and Time	S/d Status	NRPC Remarks
1	NAPP-SAMBHAL 220 kV Line	С	CVT replacement for Phase-B	18.01.2022 & 0800 hrs	18.01.2022 & 2100 hrs	approved	subject to UP consent
2	NAPP-SIMBHOLI 220 kV Line	С	CVT replacement for Phase-Y and B	21.01.2022 & 0800 hrs	22.01.2022 & 2100 hrs	approved	subject to UP consent
3	NAPP-KHURJA 220 kV Line	С	CVT replacement for Phase-Ph-R, Y and B	27.01.2022 & 0800 hrs	28.01.2022 & 2100 hrs	approved	subject to UP consent
4	NAPP-DEBAI 220 kV Line	С	CVT replacement for Phase-Ph-R and Y	01.02.2022 & 0800 hrs	02.02.2022 & 2100 hrs	approved	subject to UP consent
5	NAPP-ATRAUALI 220 kV Line	С	CVT replacement for Phase-Ph-R and B	08.02.2022 & 0800 hrs	09.02.2022 & 2100 hrs	approved	subject to UP consent

Subject: Shutdown of the ADHPL Line for rerouting work-Intimation to HPPTCL and rerouting diagrame

ADHPL Dedicated Transmission System have applied for a complete shut down for 15 days starting from 01.02.2022 to 15.02.2022. They have intimated the HPPTCL (STU of HP) to inform its customers who are using the line and issue the required NOC. The shutdown is required for the rerouting of the line for four laining project of National Highway in the State of HP.

Route Alignment Lay Out Plan



Shutdown Status
approved
NRPC Remarks
subject to hpsldc consent and CEA clerance

Shutdown Request by PSTCL

PSTCL has requested to allow the auto-reclosure disable of **400KV Talwandi Sabo-Dhuri D/C from 01/02/2022 to 28/02/2022** from 0800 hours to 1800 hours on daily basis, for Supply, Erection, Testing and Commissioning of OPGW along with its Terminal Equipment on 132kV/220 kV/400 kV Transmission Lines & Substation of PSTCL Systems by M/s. Sterlite Power.

Shutdown Status
approved
NRPC Remarks
s/d for auto reclosure in non auto mode