Sr No	Reference Number	OCC Number	Name of Requesting	Element Type	Element Name	Owner	Propos Daily/ Continous	red Outage Program of 208th OC Reason	C meeting of N Requested From Date	Requested From Time	Requested To	Requested To Time	Requester Remarks	Request Type	Shutdown Status	NLDC/RLDC Comments
	RQ135840		Agency napp_sd	GENERATING	220 MW NAPS -		С	BSD OF NAPS UNIT-2	10/Jul/2023		07/Sep/2023			PLANNED	Requested	commency
2	RQ136647	OCC_208	cpcc3_sd	UNIT HVDC LINE CIRCUIT	UNIT 2 800 KV HVDC KURUKSHETRA- CHAMPA (PG) CKT- 1	NPCIL POWERGRID	D	Power line crossing of under construction loop out ckt of LILO of 765 KV Ghatampur- Hapur Line at Rampur S/S	28/Jul/2023	08:00	28/Jul/2023	18:00		PLANNED	Requested	
	RQ136649			HVDC LINE CIRCUIT	800 KV HVDC KURUKSHETRA- CHAMPA (PG) CKT- 3	POWERGRID	D	Power line crossing of under construction loop out ckt of LILO of 765 KV Ghatampur- Hapur Line at Rampur S/S	28/Jul/2023		28/Jul/2023				Requested	
	RQ136648			HVDC LINE CIRCUIT	800 KV HVDC KURUKSHETRA- CHAMPA (PG) CKT- 2	POWERGRID	D D	Power line crossing of under construction loop out ckt of LILO of 765 KV Ghatampur- Hapur Line at Rampur S/S	28/Jul/2023		28/Jul/2023 28/Jul/2023				Requested	
				CIRCUIT	KURUKSHETRA- CHAMPA (PG) CKT- 4	POWERGRID		Power line crossing of under construction loop out ckt of LILO of 765 KV Ghatampur- Hapur Line at Rampur S/S							Requested	
	RQ136156 RQ136157			HVDC LINE CIRCUIT	800 KV HVDC KURUKSHETRA- CHAMPA (PG) CKT- 2 800 KV HVDC	POWERGRID	С	Diversion for UPEIDA project Diversion for UPEIDA project	15/Jul/2023 15/Jul/2023		30/Jul/2023 30/Jul/2023				Requested Requested	
	RQ136158			HVDC LINE	KURUKSHETRA- CHAMPA (PG) CKT- 3 800 KV HVDC KURUKSHETRA-	POWERGRID	C	Diversion for UPEIDA project	15/Jul/2023	08:00	30/Jul/2023	20:00			Requested	
9	RQ136155	OCC_208	cpcc1_sd	HVDC LINE CIRCUIT	CHAMPA (PG) CKT- 4 800 KV HVDC KURUKSHETRA- CHAMPA (PG) CKT-	POWERGRID	С	Diversion for UPEIDA project	15/Jul/2023	08:00	30/Jul/2023	20:00		PLANNED	Requested	
10	RQ136140	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)- GWALIOR(PG) (PG) CKT-2	POWERGRID	D	For rectification of shutdown nature defect.DIA TO BE KEPT OPEN AT BOTH ENDS.	31/Jul/2023	08:00	31/Jul/2023	18:00	S/D requested by WR-II	PLANNED	Requested	
	RQ136139			AC TRANSMISSION LINE CIRCUIT	765 KV PHAGI(RS)- GWALIOR(PG) (PG) CKT-1	POWERGRID	D	For rectification of shutdown nature defect.DIA TO BE KEPT OPEN AT BOTH ENDS.	28/Jul/2023		28/Jul/2023		S/D requested by WR-II		Requested	
	RQ136813 RQ136812			AC TRANSMISSION LINE CIRCUIT	765 KV AGRA- GWALIOR (PG) CKT- 1 765 KV AGRA-	POWERGRID	D D	For rectification of shutdown nature defect. Dia to be kept open at both ends. by WR2 For rectification of shutdown	24/Jul/2023 21/Jul/2023		24/Jul/2023 21/Jul/2023				Requested Requested	
14	RQ136846	OCC_208	cpcc3_sd	TRANSMISSION LINE CIRCUIT AC TRANSMISSION	GWALIOR (PG) CKT- 2 765 KV ORAI- JABALPUR (PG) CKT-	POWERGRID	D	nature defect. Dia to be kept open at both ends by WR2 Implementation & testing for PRD revised scheme	20/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
15	RQ136845	OCC_208	cpcc3_sd	LINE CIRCUIT AC TRANSMISSION LINE CIRCUIT	2 765 KV ORAI- JABALPUR (PG) CKT- 1	POWERGRID	D	Implementation & testing for PRD revised scheme	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
16	RQ136810	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI- GWALIOR (PG) CKT- 1	POWERGRID	D	For AMP work of Line Reactor and Line terminal equipment and rectification of shutdown nature defect and Line Reactor AMP works. Dia to be kept open at both ends. A/R OFF on 765kV Orai - Satna Ckt 1	12/Jul/2023	08:00	12/Jul/2023	18:00		PLANNED	Requested	
	RQ136148 RQ136145			AC TRANSMISSION LINE CIRCUIT	765 KV CHITTORGARH- BANASKANTHA (PG) CKT-2 765 KV	POWERGRID	D D	To configure Line Reactor Tripping on Single phase fault as per CC approval Attending Shutdown nature	11/Jul/2023		11/Jul/2023		other ckt will be in non auto mode. other ckt will be in		Requested Requested	
				TRANSMISSION LINE CIRCUIT	CHITTORGARH- BANASKANTHA (PG) CKT-2	POWERGRID		defects i.e. CC ring Spacers, Hardware Loose Nutbolts cutter pins, VD, etc.					non auto mode.			
	RQ136147 RQ136146			AC TRANSMISSION LINE CIRCUIT	765 KV CHITTORGARH- BANASKANTHA (PG) CKT-1 765 KV PHAGI(RS)-	POWERGRID	D C	To configure Line Reactor Tripping on Single phase fault as per CC approval NHAI Diversion Work	10/Jul/2023		10/Jul/2023 25/Jul/2023		other ckt will be in non auto mode.		Requested Requested	
	RQ136144			TRANSMISSION LINE CIRCUIT AC TRANSMISSION LINE CIRCUIT	GWALIOR(PG) (PG) CKT-1 765 KV CHITTORGARH- BANASKANTHA	POWERGRID	D	Attending Shutdown nature defects i.e. CC ring Spacers, Hardware Loose Nutbolts	10/Jul/2023		10/Jul/2023		other ckt will be in non auto mode.		Requested	
22	RQ136809	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	(PG) CKT-1 765 KV ORAI- GWALIOR (PG) CKT- 1	POWERGRID	D	cutter pins, VD, etc. A/R IN NON AUTO MODE IS REQUIRED FOR FACILITATING WORK IN 765 KV SATNA- GWALIOR CKT # 2	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
23	RQ136808	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-SATNA (PG) CKT-1		D	A/R IN NON AUTO MODE IS REQUIRED FOR FACILITATING WORK IN 765 KV SATNA- GWALIOR CKT # 2	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
	RQ136827			AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI- GAYA (PG) CKT-2	POWERGRID	D	S/D for OPGW installation Work under Strengthening of OPGW Network in ER Project.Old/damaged earthwire & line crossing by ER1	05/Jul/2023		07/Jul/2023		olong with 1/2 c/-		Requested	
	RQ136136			AC TRANSMISSION LINE CIRCUIT	765 KV CHITTORGARH- BANASKANTHA (PG) CKT-2	POWERGRID	D	Switching of spare reactor with B Phase LR AT BANASKANTHA END. Due date (03.09.2023)	04/Jul/2023		04/Jul/2023		along with L/R . S/D requested by WR-II			
	RQ136802 RQ136836			AC TRANSMISSION LINE CIRCUIT	765 KV ORAI-SATNA (PG) CKT-1 765 KV BALIA-GAYA	POWERGRID	D D	For Switching of Spare with Y- Ph (For taking Y-Ph in Service) at Satna end by WR2 REPLACEMENT OF FLASHED	03/Jul/2023 01/Jul/2023		03/Jul/2023 01/Jul/2023				Requested Requested	
21		JCC_208	-specs_su	TRANSMISSION LINE CIRCUIT	(PG) CKT-1	POWERGRID	, ,	INSULATOR BY ER1	0±/3UI/2UZ3	36.00	01/Jul/2023	20.00		LAMMED	nequested	

_																
28	RQ136828	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI- GAYA (PG) CKT-2	POWERGRID	D	A/R non auto mode for OPGW installation Work under Strengthening of OPGW Network in ER Project by ER1	01/Jul/2023	08:00	31/Jul/2023	18:00		PLANNED	Requested	
29	RQ136797	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV ORAI- JABALPUR (PG) CKT- 1	POWERGRID	D	A/R IN NON AUTO MODE REQUIRED AT BOTH ENDS.For OPGW stringing under live line	01/Jul/2023	08:00	31/Jul/2023	18:00		PLANNED	Requested	
30	RQ136635	OCC_208	apl_sd	HVDC LINE CIRCUIT	500 KV HVDC MAHINDERGARH(A PL)-ADANI MUNDRA(APL)	POWERGRID	D	condition. OPGW REPLACEMENT WORK (Replacement of old earthwire with OPGW). No outage is required. Work will be carried	01/Jul/2023	06:00	31/Jul/2023	19:30	No outage Required	PLANNED	Requested	
31	RQ136858	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	(ATIL) CKT-2 400 KV SINGRAULI(NT)- VINDHYACHAL(PG)	POWERGRID	D	out online. For installation of IPS section from TBC isolator to line HCB isolator in at NTPC under ADD-	28/Jul/2023	08:00	28/Jul/2023	18:00		PLANNED	Requested	
32	RQ136149	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	(PG) CKT-1 400 KV KANKROLI- ZERDA (PG) CKT-1	POWERGRID	D	Attending Shutdown nature defects i.e Reversed Grading Ring, Cotter pins, Hardware fitting pins etc.	24/Jul/2023	08:00	28/Jul/2023	18:00	Line shutdown is required .Auto reclose relay of Bhinmal-Kankroli	PLANNED	Requested	
33	RQ136138	OCC 208	cpcc1 sd	AC	400 KV KANKROLI-	POWERGRID	D	REF Relay Retrofitting work at	22/Jul/2023	09:00	22/Jul/2023	18:00	line(Ckt# 2) to be kept into non auto mode. S/D requested by	PLANNED	Requested	
	RQ136151			TRANSMISSION LINE CIRCUIT AC	ZERDA (PG) CKT-1 400 KV BHINMAL-	POWERGRID		Kansari end .DIA TO BE KEPT OPEN AT BOTH ENDS.					WR-II			
34	KQ136151	OCC_208	cpcc1_sa	TRANSMISSION LINE CIRCUIT	ZERDA (PG) CKT-1		D	Attending Shutdown nature defects i.e Reversed Grading Ring, Cotter pins, Hardware fitting pins etc.	20/Jul/2023	08:00	22/Jul/2023	18:00	Line shutdown is required .Auto reclose relay of zerda-Kankroli line(Ckt# 1) to be kept into non auto	PLANNED	Requested	
35	RQ136137	OCC_208	cpcc1_sd	AC TRANSMISSION	400 KV BHINMAL- ZERDA (PG) CKT-1	POWERGRID	D	REF Relay Retrofitting work at Kansari end .DIA TO BE KEPT	20/Jul/2023	08:00	20/Jul/2023	18:00	mode. S/D requested by WR-II	PLANNED	Requested	
36	RQ136856	OCC_208	cpcc3_sd	LINE CIRCUIT AC	400 KV	POWERGRID	С	OPEN AT BOTH ENDS. Retrofitment of line bay	19/Jul/2023	08:00	21/Jul/2023	18:00	Concurrent outage	PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	SINGRAUL(NT)- VINDHYACHAL(PG) (PG) CKT-1			isolator(HCB) & TBC pantograph isolators under ADD-CAP					of TBC Bus is required for Retrofitment of 417 Bay TBC isolator after dismantling at SSTPS-NTPC. Singrauli & dismantling of IPS from TBC isolator to Line HCB Bus section. After Work completion line will be charged on TBC			
37	RQ136834	OCC_208	cpcc3_sd	AC TRANSMISSION	400 KV BALIA- BIHARSHARIFF (PG)	POWERGRID	D	FOR OVERHAULLING OF CB PIR (FIXING OF CB PIR AFTER O/H)	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
				LINE CIRCUIT	CKT-2	POWERGRID		by ER1. A/R OFF on Ckt 1								
38	RQ136832	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA- BIHARSHARIFF (PG) CKT-2	POWERGRID	D	FOR OVERHAULLING OF CB PIR (DISMANTLING OF CB PIR FOR O/H PURPOSE) and TL work by ER1. A/R OFF on CKT 1	17/Jul/2023	08:00	17/Jul/2023	18:00		PLANNED	Requested	
	RQ136833			AC TRANSMISSION LINE CIRCUIT	400 KV BALIA- BIHARSHARIFF (PG) CKT-1	POWERGRID	D	FOR OVERHAULLING OF CB PIR (FIXING OF CB PIR AFTER O/H) and TL work by ER1. A/R OFF on Ckt 2	07/Jul/2023		07/Jul/2023	18:00		PLANNED	Requested	
40	RQ136807	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RIHAND(NT): VINDHYACHALPOO L(PG) (PG) CKT-2	POWERGRID	D	Firmware upgradation work in P444 Relay(Main 1) of 400KV- VINDHYACHAL(PS)-RIHAND-2	07/Jul/2023	08:00	07/Jul/2023	18:00		PLANNED	Requested	
41	RQ136804	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RIHAND(NT)- VINDHYACHALPOO L(PG) (PG) CKT-2		D	Line AMP works & Terminal Equipment AMP at Vindhyachal PS Dia to be Kept open at both ends. A/R OFF on Ckt 1.	07/Jul/2023	08:00	07/Jul/2023	18:00		PLANNED	Requested	
42	RQ136831	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA- BIHARSHARIFF (PG) CKT-1	POWERGRID	D	FOR LBB RELAY RETROFITTING, FOR OVERHAULLING OF CB PIR (DISMATLING OF CB PIR FOR O/H PURPOSE) and TL work by ER1. A/R OFF on Ckt 2	06/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
43	RQ136822	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV VARANASI- BIHARSHARIFF (PG) CKT-1	POWERGRID	D	S/D required for OPGW installation Work under Strengthening of OPGW Network in ER Project.Due to line diamond crossing with 400KV BIHARSHARIF (PG)- PUSAULI(PG) LINE by ER1	05/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
44	RQ136823	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV VARANASI- BIHARSHARIFF (PG) CKT-2	POWERGRID	D	S/D required for OPGW installation Work under Strengthening of OPGW Network in ER Project.Due to line diamond crossing with 400KV BIHARSHARIF (PG)- PUSAULI(PG) LINE by ER1	05/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
	RQ136806			AC TRANSMISSION LINE CIRCUIT	400 KV RIHAND(NT)- VINDHYACHALPOO L(PG) (PG) CKT-1	POWERGRID	D	Firmware upgradation work in P444 Relay(Main 1) of 400KV- VINDHYACHAL(PS)-RIHAND-1	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
46	RQ136803	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RIHAND(NT)- VINDHYACHALPOO L(PG) (PG) CKT-1	POWERGRID	D	Line AMP works & Terminal Equipment AMP at Vindhyachal PS Dia to be Kept open at both ends. A/R OFF on Ckt 2.	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
47	RQ136824	OCC_208	cpcc3_sd	AC TRANSMISSION	400 KV BALIA- PATNA (PG) CKT-1		С	DIVERSION OF LINE DUE TO RVNL RAIL CONSTRUCTION by	01/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
48	RQ136825	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA- PATNA (PG) CKT-2	POWERGRID POWERGRID	С	ER1 DIVERSION OF LINE DUE TO RVNL RAIL CONSTRUCTION by ER1	01/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
49	RQ136830	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA(PG)- NAUBATPUR (BS) (PG) CKT-1		D	A/R NON Auto mode for OPGW erection work under Strengthening of OPGW Network in ER Project for	01/Jul/2023	08:00	31/Jul/2023	18:00		PLANNED	Requested	
						POWERGRID		balance work in UP Portion								

50 R	Q136651	OCC_208	cpcc3_sd	HVDC LINE CIRCUIT	500 KV HVDC RIHAND-DADRI (PG) CKT-1		D	Power line crossing of under construction loop out ckt of LILO of 765 KV Ghatampur- Hapur Line at Rampur S/S	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
51 R0	Q136652	OCC_208	cpcc3_sd	HVDC LINE CIRCUIT	500 KV HVDC RIHAND-DADRI (PG) CKT-2		D	Power line crossing of under construction loop out ckt of LILO of 765 KV Ghatampur- Hapur Line at Rampur S/S	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
52 R0	Q136165	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- BHADLA_2 (PG) CKT-2	POWERGRID	D	Attending Shutdown nature defects i.e. CC ring Spacers, Hardware Loose Nutbolts cutter pins, VD, etc.	28/Jul/2023	15:00	29/Jul/2023	23:00	To attend shutdown nature defects. Other ckt will be in Non auto mode.	PLANNED	Requested	
53 R	Q136164	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- BHADLA_2 (PG) CKT-1	POWERGRID	D	Attending Shutdown nature defects i.e. CC ring Spacers, Hardware Loose Nutbolts cutter pins, VD, etc.	26/Jul/2023	15:00	27/Jul/2023	23:00	To attend shutdown nature defects. Other ckt will be in Non auto mode.	PLANNED	Requested	
54 R	Q136666	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI- FATEHPUR (PG) CKT 1	POWERGRID	D	Replacement of broken CC Ring & AMP work	23/Jul/2023	08:00	23/Jul/2023	18:00		PLANNED	Requested	
55 R	Q136172	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- CHITTORGARH (PG) CKT-2	POWERGRID	D	Attending Shutdown nature defects i.e. CC ring Spacers, Hardware Loose Nutbolts cutter pins, VD, etc.	21/Jul/2023	08:00	21/Jul/2023	18:00	other ckt will be in non auto mode.	PLANNED	Requested	
56 R	Q136168	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- CHITTORGARH (PG) CKT-2	POWERGRID	D	To configure Line Reactor Tripping on Single phase fault as per CC approval	21/Jul/2023	08:00	21/Jul/2023	18:00	along with Line Reactor at Chittorgarh SS & other ckt will be in non auto mode.	PLANNED	Requested	
57 R	Q136015	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BIKANER- MOGA (PG) CKT-1	POWERGRID	D	S/D REQUIRED FOR RECTIFICATION OF SD NATURE DEFECTS	21/Jul/2023	08:00	21/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
		OCC_208		AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- BHADLA_2 (PG) CKT-2	POWERGRID	D	Overhead crossing by u/c of 765kV Bhadla 2-Sikar 2 TLC (Part-2) at AP 58-59	21/Jul/2023		22/Jul/2023				Requested	
		OCC_208		AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- BHADLA_2 (PG) CKT-1	POWERGRID	D	Overhead crossing by u/c of 765kV Bhadla 2-Sikar 2 TLC (Part-2) at AP 58-59	21/Jul/2023		22/Jul/2023				Requested	
60 R	Q136171	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- CHITTORGARH (PG) CKT-1	POWERGRID	D	Attending Shutdown nature defects i.e. CC ring Spacers, Hardware Loose Nutbolts cutter pins, VD, etc.	20/Jul/2023	08:00	20/Jul/2023	18:00	other ckt will be in non auto mode.	PLANNED	Requested	
61 R	Q136167	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- CHITTORGARH (PG) CKT-1	POWERGRID	D	To configure Line Reactor Tripping on Single phase fault as per CC approval	20/Jul/2023	08:00	20/Jul/2023	18:00	along with Line Reactor at Chittorgarh SS & other ckt will be in non auto mode.	PLANNED	Requested	
62 R	Q136166	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA- BIKANER (PG) CKT- 2	POWERGRID	D	For AMP of Line Equipment's	12/Jul/2023	17:00	12/Jul/2023	23:00		PLANNED	Requested	
63 R	Q136266	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- BHADLA_2 (PG) CKT-2	POWERGRID	D	For AMP work of reactor bay and reactor	10/Jul/2023	15:00	11/Jul/2023	23:00	Along with Line Reactor at Ajmer end	PLANNED	Requested	
64 R	Q136702	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA- JHATIKARA (PG) CKT-1	POWERGRID	D	For rectification of S/D nature defects.	10/Jul/2023	08:00	11/Jul/2023	18:00		PLANNED	Requested	
65 R	Q136265	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER- BHADLA_2 (PG) CKT-1	POWERGRID	D	For AMP work of reactor bay and reactor	08/Jul/2023	15:00	09/Jul/2023	23:00	Along with Line Reactor at Ajmer end	PLANNED	Requested	
66 R	Q136701	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV GR.NOIDA_2(UPC)- ALIGARH(PG) (PG)		D	For rectification of S/D nature defects.	08/Jul/2023	08:00	08/Jul/2023	18:00		PLANNED	Requested	
67 R	Q136150	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	CKT-1 765 KV MOGA- BHIWANI (PG) CKT- 1	POWERGRID	D	Attending Shutdown nature defects i.e Reversed Grading Ring, Cotter pins, Hardware	07/Jul/2023	08:00	08/Jul/2023	18:00	S/D nature defect liquidation	PLANNED	Requested	
68 R	Q136700	OCC_208	cpcc3_sd	AC TRANSMISSION	765 KV AGRA- ALIGARH (PG) CKT-	POWERGRID	D	fitting pins etc. For rectification of S/D nature defects.	05/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
69 R	Q136697	OCC_208	cpcc3_sd	LINE CIRCUIT AC TRANSMISSION	765 KV BALIA- LUCKNOW_2 (PG)	POWERGRID	D	For replacement of broken insulator disc at loc 696 & 844	05/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
70 R	Q136869	OCC_208	cpcc3_sd	LINE CIRCUIT AC TRANSMISSION LINE CIRCUIT	CKT-1 765 KV BAREILLY_2- LUCKNOW_2 (PG) CKT-1	POWERGRID	D	To attend S/D nature defect in Line	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
71 R	Q136665	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV VARANASI- BALIA (PG) CKT-1	POWERGRID	D	AMP WORK	03/Jul/2023	08:00	03/Jul/2023	18:00		PLANNED	Requested	
72 R	Q136758	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BAREILLY_2- LUCKNOW_2 (PG) CKT-1	POWERGRID	D	Line reactor replacement work at Bareilly S/S under ADD-CAP	03/Jul/2023	08:00	03/Jul/2023	18:00	Line will be charged without Line Reactor as old reactor to be replaced with new one under DD-CAP	PLANNED	Requested	
73 R	Q136688	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV KANPUR_GIS- ALIGARH (PG) CKT- 1	POWERGRID	D	Commissioning/construction of OPGW link and tapping of OPGW link for repeater station under reliable communication scheme	03/Jul/2023	08:00	03/Jul/2023	18:00	Simultaneous S/D of 400 KV Kanpur- Ballabhgarh-1 is also required	PLANNED	Requested	
74 R	Q136159	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV KOTESHWAR- MEERUT (PG) CKT-2		D	Auto Reclose off is required for OPGW INSTALLATION works under Northern Region Optical fibre Strengthening Scheme (NROSS)	01/Jul/2023	08:00	31/Jul/2023	18:00		PLANNED	Requested	
75 R	Q136687	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	765 KV KANPUR_GIS- ALIGARH (PG) CKT- 1	POWERGRID	D	A/R into non-auto mode for OPGW stringing work.	01/Jul/2023	08:00	31/Jul/2023	18:00		PLANNED	Requested	
76 R	Q136141	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AGRA- JHATIKARA (PG) CKT-1	POWERGRID	D	**For formation of Diamond arrangement of Earthwire with Existing line to overhead Crossing of 765 KV D/C (Hexa) Sikar-Aligarh Transmission line(Under Construction)	01/Jul/2023	08:00	03/Jul/2023	18:00	S/D required from date 16.06.2023 to 18.06.2023 on daily basis	PLANNED	Requested	
77 R	Q136174	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(PG)- BHADLA(PG) (FBTL)	POWERGRID,	D	For AMP, Relay testing works, Line equipment AMP Works	27/Jul/2023	17:00	27/Jul/2023	23:59		PLANNED	Requested	
					CKT-2	FBTL			23/Jul/2023							

79	RQ136161	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(PG)- BHADLA(PG) (FBTL) CKT-2	POWERGRID, FBTL	D	For ladder logic and interlock checking for spare reactor commissioning	20/Jul/2023	17:00	26/Jul/2023			PLANNED	Requested	
80	RQ136160	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV FATEHGARH_II(PG)- BHADLA(PG) (FBTL) CKT-1	POWERGRID, FBTL	D	For ladder logic and interlock checking for spare reactor commissioning	13/Jul/2023	17:00	19/Jul/2023	23:00		PLANNED	Requested	
81	RQ136170	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER(PG)- PHAGI(RS) (PAPTL) CKT-2	PAPTL	D	Attending Shutdown nature defects i.e. CC ring Spacers, Hardware Loose Nutbolts cutter pins, VD, etc.	25/Jul/2023	08:00	25/Jul/2023	18:00	other ckt will be in non auto mode.	PLANNED	Requested	
82	RQ136169	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV AJMER(PG)- PHAGI(RS) (PAPTL) CKT-1		D	Attending Shutdown nature defects i.e. CC ring Spacers, Hardware Loose Nutbolts cutter pins, VD, etc.	24/Jul/2023	08:00	24/Jul/2023	18:00	other ckt will be in non auto mode.	PLANNED	Requested	
83	RQ135950	OCC_208	stuup_sd	AC TRANSMISSION	765 KV OBRA_C_TPS-	PAPTL	С	HEIGHT RAISING OF 765KV OBRA C-UNNAO LINE (JHUSI-	23/Jul/2023	08:00	12/Aug/2023	18:00		PLANNED	Requested	
84	RQ136101	OCC_208	stuup_sd	AC	UNNAO (UP) 765 KV AGRA	UPPTCL	D	UNNAO SECTION) * 80MVAr Spare Line Reactor	04/Jul/2023	08:00	04/Jul/2023	12:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	FATEHBAD(UP)- LALITPUR(LPG) (UP) CKT-2	UPPTCL		will be charge as Line Reactor- II R Phase at 765kV Substation Fatehabad Agra. Spare Phase Line R								
85	RQ135819	OCC_208	stuup_sd	AC TRANSMISSION	765 KV ANPARA_C(LAN)-		С	* height raising of 765 kv Anpara C Unnao line Due to	01/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
				LINE CIRCUIT	UNNAO(UP) (UP) CKT-1	UPPTCL		proposed Ganga EXP.way. * 1.A/R tesing of Main Bay-4 protection relays Tie Bay-5 BCU SCADA problem by M/S GE TD Engineer of 765 kV Un								
86 1	RQ136176	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)- FATEHGARH_II(PG) (PFTL) CKT-2	PFTL	D	For AMP, Relay testing works, Line equipment AMP Works	22/Jul/2023	17:00	22/Jul/2023	23:59		PLANNED	Requested	
87	RQ136175	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	765 KV BHADLA_2 (PG)- FATEHGARH_II(PG)		D	For AMP, Relay testing works, Line equipment AMP Works	21/Jul/2023	17:00	21/Jul/2023	23:59		PLANNED	Requested	
88	RQ136163	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	(PFTL) CKT-1 765 KV BHADLA_2 (PG)- FATEHGARH_II(PG)	PFTL	D	For ladder logic and interlock checking for spare reactor commissioning	07/Jul/2023	17:00	12/Jul/2023	23:00		PLANNED	Requested	
89 1	RQ136162	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	(PFTL) CKT-2 765 KV BHADLA_2 (PG)- FATEHGARH_II(PG)	PFTL	D	For ladder logic and interlock checking for spare reactor commissioning	02/Jul/2023	17:00	06/Jul/2023	23:00		PLANNED	Requested	
90 1	RQ136617	OCC_208	sldcrs_sd	AC TRANSMISSION	(PFTL) CKT-1 765 KV ANTA- PHAGI (RS) CKT-2		D	Quarterly Maintenance work alongwith 3x80MVAr Reactor	12/Jul/2023	08:00	12/Jul/2023	18:00		PLANNED	Requested	
91 (RQ136230	OCC_208	cpcc1_sd	BUS	765 KV BHADLA_2 (PG) - BUS 2	RRVPNL	D	Bank at Phagi BAY EXTENSION WORKS	19/Jul/2023	17:00	20/Jul/2023	23:00	DURING 765 KV BUS- 2 SHUT DOWN, 765/400 KV ICT-3 SHALL BECOME OUT AS ICT-3 IS CHARGED THROUGH BUS-2	PLANNED	Requested	
92 1	RQ136229	OCC 208	cpcc1 sd	BUS	765 KV BHADLA_2	POWERGRID	D	BAY EXTENSION WORKS	17/Jul/2023	17:00	18/Jul/2023	23:00	ONLY	PLANNED	Requested	
93	RQ136227	OCC_208	cpcc1_sd	BUS	(PG) - BUS 1 765 KV FATEHGARH_II(PG) - BUS 1	POWERGRID	D	Jumpering and bay extension work by M/s TATA for TBCB package SS-01, SS-63 A1 & B1,	15/Jul/2023	17:00	28/Jul/2023	23:00		PLANNED	Requested	
					B03 1	POWERGRID		commissioning works of Bus bar integration work of bay extensions								
	RQ136631			BUS	765KV BUS 1 AT ALIGARH(PG)	POWERGRID	С	For termination of the cable related to the 765 kV Aligarh- Sikar-II Line 1/2 and 765 kV BUS BAR-1 protection Satbility Testing (Construction)	10/Jul/2023		11/Jul/2023				Requested	
95 1	RQ136228	OCC_208	cpcc1_sd	BUS	765 KV FATEHGARH_II(PG) - BUS 2	POWERGRID	D	Jumpering and bay extension work by M/s TATA for TBCB package SS-01, SS-63 A1 & B1, commissioning works of Bus bar integration work of bay extensions	01/Jul/2023	17:00	14/Jul/2023	23:00		PLANNED	Requested	
96	RQ136746	OCC_208	sldcrs_sd	BUS	765KV BUS 1 AT PHAGI(RS)	RRVPNL	D	For Attending alignment of Isolator 703-89AA	05/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
97	RQ136235	OCC_208	cpcc1_sd	BR/BSR/MSC/M SR	240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	Ladder logic commissioning with spare reactor logic scheme checking	20/Jul/2023	17:00	24/Jul/2023	23:00		PLANNED	Requested	
98	RQ136629	OCC_208	cpcc3_sd	BR/BSR/MSC/M SR	330 MVAR BUS REACTOR NO 1 AT 765KV VARANASI(PG)	POWERGRID	D	SPARE ROTATION,OTI-WTI SCHEME MODIFICATION & PRV SCHEME MODIFICATION	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
99	RQ136236	OCC_208	cpcc1_sd	BR/BSR/MSC/M SR		. GWENGRID	D	Ladder logic commissioning with spare reactor logic scheme checking	15/Jul/2023	17:00	19/Jul/2023	23:00		PLANNED	Requested	
	RQ136234			BR/BSR/MSC/M SR	240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	For final testing of CSD Relay of 765KV Bus Reactor	08/Jul/2023		12/Jul/2023		fine tuning and final commissioning of CSD relay 4-5 On load operations of each 240MVAr Reactors shall be performed during shutdown		Requested	
101	RQ136233	UCC_208	rcpcc1_sd	BR/BSR/MSC/M SR	240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	For final testing of CSD Relay of 765KV Bus Reactor	07/Jul/2023	1.7:00	10/Jul/2023	123:00	Please note that for fine tuning and final commissioning of CSD relay 4-5 On load operations of each 240MVAr Reactors shall be performed during shutdown	PLANNED	Requested	

				,					,							
102	RQ136870	OCC_208	cpcc3_sd	BR/BSR/MSC/M SR	REACTOR NO 2 AT		D	AMP, Replacement of CFT, Implementation & testing for	06/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
					765 KV ORAI(PG)			OTI & WTI Alarm & Trip								
								revised scheme, Implementation & testing for								
								PRD revised scheme, SF6								
								quality check of gas compartments, and Spare								
103	RQ135870	OCC 208	stuun sd	BR/BSR/MSC/M	240 MVAP BUS	POWERGRID	D	switching in Bus Reactor-2 * For routine Maintenance and	17/Jul/2023	00:00	17/Jul/2023	18:00		DIANNED	Requested	
103	NQ133070	000_200	stuup_su	SR SR	REACTOR NO 1 AT		b	Testing of Relays and reactor	17/301/2023	03.00	17/301/2023	18.00		LAININED	Requested	
					765KV AGRA FATEHBAD(UP)	UPPTCL		unit at 765kV Substation Fatehabad Agra								
104	RQ136231	OCC_208	cpcc1_sd		240 MVAR BUS		D	For internal inspection &	11/Jul/2023	09:00	12/Jul/2023	18:00		PLANNED	Requested	
				SR	REACTOR NO 2 AT 765 KV KHETRI			attending oil leakage								
105	RQ136232	000 200		BR/BSR/MSC/M	(PKTSL) 240 MVAR BUS	PKTSL	D	For internal inspection &	09/Jul/2023	00.00	10/Jul/2023	10.00		DIANINED	Requested	
103	NQ130232	OCC_208	cpcc1_su	SR SR	REACTOR NO 1 AT		ь	attending oil leakage	09/301/2023	05.00	10/101/2023	18.00		PLANNED	Requesteu	
					765 KV KHETRI (PKTSL)	PKTSL										
106	RQ136771	OCC_208	sldcrs_sd		240 MVAR BUS	T KTSE	D	For taken R-Phase into Circuit	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
				SR	REACTOR NO 2 AT 765 KV PHAGI(RS)	PAPTL		in place of spare reactor								
107	RQ136259	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON		D	Ladder logic commissioning with spare reactor logic	26/Jul/2023	17:00	28/Jul/2023	23:00		PLANNED	Requested	
					765 KV BHADLA_2			scheme checking								
					(PG)- FATEHGARH_II(PG)											
					(PFTL) CKT-1											
					@FATEHGARH_II(P	PFTL										
108	RQ136260	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR		D	Ladder logic commissioning	13/Jul/2023	17:00	15/Jul/2023	23:00		PLANNED	Requested	
					SWITCHABLE LR ON 765 KV BHADLA_2 -			with spare reactor logic scheme checking								
					FATEHGARH_II (PG) CKT-2											
					@FATEHGARH_II(P											
					G)	PFTL										
109	RQ136264	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR		D	FOR AMP WORKS	06/Jul/2023	17:00	08/Jul/2023	23:00		PLANNED	Requested	
					SWITCHABLE LR ON 765 KV BHADLA_2 -											
					FATEHGARH_II (PG)											
					CKT-2 @FATEHGARH_II(P											
					G)	PFTL										
110	RQ136256	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR	PFIL	D	For final testing of CSD Relay	06/Jul/2023	17:00	11/Jul/2023	23:00	Please note that for	PLANNED	Requested	
					SWITCHABLE LR ON 765 KV BHADLA_2 -			of 765KV Line Reactor					fine tuning and final commissioning of			
					FATEHGARH_II (PG)								CSD relay 4-5 On			
					CKT-2 @FATEHGARH_II(P								load operations of each 240MVAr			
					G)								Reactors shall be			
													performed during shutdown			
		000 000			240.4.0.4.0	PFTL		500 4440 11100115	05/11/2022	47.00	07/1 1/2022	22.00				
1111	RQ136263	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON		D	FOR AMP WORKS	05/Jul/2023	17:00	07/Jul/2023	23:00		PLANNED	Requested	
					765 KV BHADLA_2 (PG)-											
					FATEHGARH_II(PG)											
					(PFTL) CKT-1 @FATEHGARH_II(P											
Ш					G)	PFTL										
112	RQ136255	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON		D	For final testing of CSD Relay of 765KV Line Reactor	05/Jul/2023	17:00	10/Jul/2023	23:00	Please note that for fine tuning and final	PLANNED	Requested	
					765 KV BHADLA_2 (PG)-								commissioning of CSD relay 4-5 On			
					FATEHGARH_II(PG)								load operations of			
					(PFTL) CKT-1 @FATEHGARH II(P								each 240MVAr Reactors shall be			
					G)								performed during			
						PFTL							shutdown			
113	RQ136238	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR		D	FOR AMP WORKS	24/Jul/2023	17:00	24/Jul/2023	23:00		PLANNED	Requested	
					SWITCHABLE LR ON 765 KV BIKANER-											
					BHADLA_2 (PG)											
					CKT-1 @BHADLA_2 (PG)											
114	RQ136237	OCC 208	cncc1 sd	LINE REACTOR	240 MVAR	POWERGRID	D	FOR AMP WORKS	23/Jul/2023	17:00	23/Jul/2023	23:00		PLANNED	Requested	
114		500_200			SWITCHABLE LR ON		,	- Conto	23,341,2023	-7.00	25/301/2025	25.00			questeu	
					765 KV BIKANER- BHADLA_2 (PG)											
					CKT-2 @BHADLA_2											
					(PG)	POWERGRID										
115	RQ136258	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON		D	Ladder logic commissioning with spare reactor logic	23/Jul/2023	17:00	25/Jul/2023	23:00		PLANNED	Requested	
					765 KV			scheme checking								
					FATEHGARH_II- BHADLA (PG) CKT-2											
					@FATEHGARH_II(P											
					G)	POWERGRID										
116	RQ136240	OCC_208	cpcc1_sd	LINE REACTOR	330 MVAR		D	FOR AMP WORKS	22/Jul/2023	17:00	22/Jul/2023	23:00		PLANNED	Requested	
					SWITCHABLE LR ON 765 KV AJMER-											
					BHADLA_2 (PG) CKT-1 @BHADLA_2											
					(PG)	POWERGRID										
117	RQ136239	OCC_208	cpcc1_sd	LINE REACTOR	330 MVAR SWITCHABLE LR ON		D	FOR AMP WORKS	21/Jul/2023	17:00	21/Jul/2023	23:00		PLANNED	Requested	
					765 KV AJMER-											
					BHADLA_2 (PG) CKT-2 @BHADLA_2											
110	00126256	000 200		LINE DE COMO	(PG)	POWERGRID		To confirm the Confirmation Con	24/1:1/20	00.00	24/1 1/20	10.00		DIAMINES	D : :	
118	RQ136250	UCC_208	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON		D	To configure Line Reactor Tripping on Single phase fault	21/Jul/2023	08:00	21/Jul/2023	18:00		PLANNED	Requested	
					765 KV AJMER-			as per CC approval								
					CHITTORGARH (PG) CKT-1											
					@CHITTORGARH(P	POWERGRID										
					101	I. OWENGKID		L					1			

119	RQ136257	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II(PG)- BHADLA(PG) (FBTL) CKT-1		D	Ladder logic commissioning with spare reactor logic scheme checking	20/Jul/2023	17:00	22/Jul/2023	23:00		PLANNED	Requested	
120	RQ136249	OCC_208	cpcc1_sd	LINE REACTOR	@FATEHGARH_II(P G) 240 MVAR SWITCHABLE LR ON 765 KV AJMER- CHITTORGARH (PG)	POWERGRID	D	To configure Line Reactor Tripping on Single phase fault as per CC approval	20/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
					CKT-2 @CHITTORGARH(P	POWERGRID										
121	RQ136242	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON	POWERGRID	D	FOR AMP WORK	12/Jul/2023	17:00	12/Jul/2023	22:00		PLANNED	Requested	
					765 KV BHADLA- BIKANER (PG) CKT- 1 @BHADLA(PG)	POWERGRID										
122	RQ136247	OCC_208	cpcc1_sd	LINE REACTOR	330 MVAR SWITCHABLE LR ON 765 KV BIKANER- MOGA (PG) CKT-2 @BIKANER(PG)	POWERGRID	D	For AMP of the Reactor & its bay	12/Jul/2023	17:00	12/Jul/2023	23:00		PLANNED	Requested	
123	RQ136241	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA- BIKANER (PG) CKT- 2 @BHADLA(PG)	POWERGRID	D	FOR AMP WORK	11/Jul/2023	17:00	11/Jul/2023	22:00		PLANNED	Requested	
124	RQ136248	OCC_208	cpcc1_sd	LINE REACTOR	330 MVAR SWITCHABLE LR ON 765 KV BIKANER- MOGA (PG) CKT-1 @BIKANER(PG)		D	For AMP of the Reactor & its bay	11/Jul/2023	17:00	11/Jul/2023	23:00		PLANNED	Requested	
125	RQ136252	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON	POWERGRID	D	To configure Line Reactor	11/Jul/2023	08:00	11/Jul/2023	18:00		PLANNED	Requested	
					765 KV CHITTORGARH- BANASKANTHA (PG) CKT-1 @CHITTORGARH(P			Tripping on Single phase fault as per CC approval								
126	RQ136246	OCC_208	cpcc1_sd	LINE REACTOR	G) 330 MVAR	POWERGRID	D	For AMP of the Reactor & its	10/Jul/2023	17:00	10/Jul/2023	23:00		PLANNED	Requested	
					SWITCHABLE LR ON 765 KV BIKANER- BHADLA_2 (PG) CKT-1 @BIKANER(PG)			bay								
127	RQ136251	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV CHITTORGARH- BANASKANTHA	POWERGRID	D	To configure Line Reactor Tripping on Single phase fault as per CC approval	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
					(PG) CKT-2 @CHITTORGARH(P											
128	RQ136805	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR NON- SWITCHABLE LR ON	POWERGRID	D	FOR REACTOR/BAY AMP WORKS	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
					MEERUT-BHIWANI (PG) CKT-1 @BHIWANI(PG)	POWERGRID										
129	RQ136245	OCC_208	cpcc1_sd	LINE REACTOR	330 MVAR SWITCHABLE LR ON 765 KV BIKANER- BHADLA_2 (PG) CKT-2 @BIKANER(PG)	POWERGRID	D	For AMP of the Reactor & its bay	09/Jul/2023	17:00	09/Jul/2023	23:00		PLANNED	Requested	
130	RQ136243	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON	POWERGRID	D	For AMP of the Reactor & its bay	08/Jul/2023	17:00	08/Jul/2023	23:00		PLANNED	Requested	
					765 KV BHADLA- BIKANER (PG) CKT- 2 @BIKANER(PG)	POWERGRID										
131	RQ136244	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV BHADLA- BIKANER (PG) CKT- 1 @BIKANER(PG)		D	For AMP of the Reactor & its bay	07/Jul/2023	17:00	07/Jul/2023	23:00		PLANNED	Requested	
132	RQ136262	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR	POWERGRID	D	FOR AMP WORKS	04/Jul/2023	17:00	06/Jul/2023	22:00		PLANNED	Requested	
					SWITCHABLE LR ON 765 KV FATEHGARH_II- BHADLA (PG) CKT-2 @FATEHGARH_II(P G)	POWERGRID										
133	RQ136254	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II- BHADLA (PG) CKT-2 @FATEHGARH_II(P G)	TOWERGIND	D	For final testing of CSD Relay of 765KV Line Reactor	04/Jul/2023	17:00	08/Jul/2023	23:00	Please note that for fine tuning and final commissioning of CSD relay 4-5 On load operations of each 240MVAr Reactors shall be	PLANNED	Requested	
						POWERGRID							performed during shutdown	L		
134	RQ136261	OCC_208	cpcc1_sd	LINE REACTOR	240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II(PG)- BHADLA(PG) (FBTL) CKT-1		D	FOR AMP WORKS	03/Jul/2023	17:00	05/Jul/2023	23:00		PLANNED	Requested	
135	RQ136253	OCC_208	cpcc1_sd	LINE REACTOR	@FATEHGARH_II(P G) 240 MVAR SWITCHABLE LR ON 765 KV FATEHGARH_II(PG)- BHADLA(PG) (FBTL) CKT-1 @FATEHGARH_II(P G)	POWERGRID	D	For final testing of CSD Relay of 765KV Line Reactor	03/Jul/2023	17:00	06/Jul/2023	23:00	Please note that for fine tuning and final commissioning of CSD relay 4-5 On load operations of each 240MVAr Reactors shall be performed during shutdown	PLANNED	Requested	

126	DO126102	000 300	cncc1 cd	DAV	701 MAIN BAY -			CCD Eine tuning works at	30/Jul/2023	17:00	30/Jul/2023	23:00	DIANNED	Doguartad	
136	RQ136182	OCC_208	cpcc1_sa	BAY	765 KV AJMER- BHADLA_2 (PG) CKT-2		D	CSD Fine tuning works at Bhadla-2	30/Jul/2023	17:00	30/Jul/2023	23:00	PLANNED	Requested	
					(POWERGRID)	POWERGRID	_		//		/: //				
137	RQ136199	OCC_208	cpcci_sa	ВАУ	720 TIE BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(PG) (POWERGRID) AND 765 KV BHADLA_2 (PG)- FATEHGARH_II(PG) (PFTL) CKT-1 AT 765 KV		D	For Bay AMP works	29/Jul/2023	17:00	30/Jul/2023	23:00	PLANNED	Requested	
138	RQ136181	OCC_208	cpcc1_sd	BAY	FATEHGARH_II(PG) (POWERGRID) 704 MAIN BAY - 765 KV AJMER-	POWERGRID		CSD Fine tuning works at Bhadla-2	29/Jul/2023	17:00	29/Jul/2023	23:00	PLANNED	Requested	
					BHADLA_2 (PG) CKT-1 (POWERGRID)	POWERGRID									
139	RQ136184	OCC_208	cpcc1_sd	BAY	719 MAIN BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(PG) (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID		For DGA oil testing of bay 765kV CT	28/Jul/2023	17:00	28/Jul/2023	23:00	PLANNED	Requested	
140	RQ136685	OCC_208	cpcc3_sd	BAY	707 MAIN BAY -	TOWERGIND	D	AMP works	28/Jul/2023	08:00	28/Jul/2023	18:00	PLANNED	Requested	
					765 KV AGRA- FATEHPUR (PG) CKT- 1 AND 765KV BUS 1 AT AGRA(PG)	POWERGRID									
141	RQ136198	OCC_208	cpcc1_sd	BAY	719 MAIN BAY - 765/400 KV 1500		D	For Bay AMP works	27/Jul/2023	17:00	28/Jul/2023	23:00	PLANNED	Requested	
					MVA ICT 4 AT FATEHGARH_II(PG) (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID									
142	RQ136183	OCC_208	cpcc1_sd	BAY	720 TIE BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(PG) (POWERGRID) AND 765 KV BHADLA_2 (PG)- FATEHGARH_II(PG)		D	For DGA oil testing of bay 765kV CT	27/Jul/2023	17:00	27/Jul/2023	23:00	PLANNED	Requested	
					(PFTL) CKT-1 AT 765 KV FATEHGARH_II(PG)	POWERGRID									
143	RQ136197	OCC_208	cpcc1_sd	BAY	(POWERGRID) 715 MAIN BAY -	POWERGRID	D	For Bay AMP works	25/Jul/2023	17:00	26/Jul/2023	23:00	PLANNED	Requested	
					240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(PG) (POWERGRID)	POWERGRID									
144	RQ136196	OCC_208	cpcc1_sd	BAY	718 MAIN BAY - 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-2 (POWERGRID)	POWERGRID	D	For Bay AMP works	23/Jul/2023	17:00	24/Jul/2023	23:00	PLANNED	Requested	
145	RQ136201	OCC_208	cpcc1_sd	BAY	719 MAIN BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(PG) (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWENGIND	D	For erection works of SS-63 A1, B1 & TBCB bay extension.	23/Jul/2023	17:00	30/Jul/2023	23:00	PLANNED	Requested	
146	RQ136195	000 200		BAY	721 MAIN BAY -	POWERGRID	D	For Bay AMP works	21/Jul/2023	17.00	22/Jul/2023	22.00	DIANNED	Requested	
140	KQ130133	OCC_208	cpcci_su	DAT	765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-1 (POWERGRID)	POWERGRID		FUI BAY AIVIF WUIKS	21/30/2023	17.00	22/Jul/2023	23.00	FLANNED	nequesteu	
147	RQ136200	OCC_208	cpcc1_sd	BAY	720 TIE BAY - 765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(PG) (POWERGRID) AND 765 KV BHADLA_2 (PG)- FATEHGARH_II(PG) (PFTL) CKT-1 AT 765 KV		D	For erection works of SS-63 A1, B1 & TBCB bay extension.	21/Jul/2023	17:00	27/Jul/2023	23:00	PLANNED	Requested	
					FATEHGARH_II(PG)	POWERGRID									
148	RQ136450	OCC_208	cpcc3_sd	BAY	TOZ TIE BAY - 765/400 KV 1500 MVA ICT 1 AT FATEHPUR(PG) (POWERGRID) AND 765 KV VARANASI- FATEHPUR (PG) CKT: 1 AT 765 KV FATEHPUR(PG) (POWERGRID)		D	AMP works	20/Jul/2023	08:00	20/Jul/2023	18:00	PLANNED	Requested	
149	RQ136194	OCC_208	cpcc1_sd	BAY	716 MAIN BAY - 765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(PG)		D	For Bay AMP works	19/Jul/2023	17:00	20/Jul/2023	23:00	PLANNED	Requested	
150	RQ136193	OCC_208	cpcc1_sd	ВАУ	(POWERGRID) 717 TIE BAY - 765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(PG) (POWERGRID) AND 765 KV BHADLA_2 - FATEHGARH_II (PG) (CKT-2 AT 765 KV FATEHGARH_II(PG) (POWERGRID)	POWERGRID	D	For Bay AMP works	17/Jul/2023	17:00	18/Jul/2023	23:00	PLANNED	Requested	

151	RQ136634	OCC_208	cpcc3_sd	BAY	817 TIE BAY - 765/400 KV 1500 MVA ICT 2 AT ALIGARH(PG) (POWERGRID) AND FUTURE AT 765 KV		C	765 kV Sikar Line Protection Commissioning Testing and Line Recator LBB Testing	16/Jul/2023	08:00	17/Jul/2023	18:00	PLANNED	Requested	
					ALIGARH(PG) (POWERGRID)	DOMEDONIO									
152	RQ136633	OCC_208	cpcc3_sd	BAY	816 MAIN BAY - 765KV BUS 1 AT ALIGARH(PG) AND FUTURE AT 765 KV ALIGARH(PG)	POWERGRID POWERGRID	С	765 kV Sikar Line Protection Commissioning Testing and Line Recator LBB Testing	16/Jul/2023	08:00	17/Jul/2023	18:00	PLANNED	Requested	
153	RQ136192	OCC_208	cpcc1_sd	BAY	710 MAIN BAY - 765/400 KV 1500 MVA ICT 1 AT FATEHGARH_II(PG) (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	For Bay AMP works	15/Jul/2023	17:00	16/Jul/2023	23:00	PLANNED	Requested	
154	RQ136191	OCC_208	cpcc1_sd	BAY	713 MAIN BAY - 765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(PG) (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID	D	For Bay AMP works	13/Jul/2023	17:00	14/Jul/2023	23:00	PLANNED	Requested	
155	RQ136478	OCC_208	cpcc3_sd	BAY	813 MAIN BAY - 765KV BUS 1 AT ALIGARH(PG) AND FUTURE AT 765 KV ALIGARH(PG)	POWERGRID	С	765 kV Sikar Line Protection Commissioning Testing and Line Recator LBB Testing	13/Jul/2023	08:00	14/Jul/2023	18:00	PLANNED	Requested	
156	RQ136479	OCC_208	cpcc3_sd	BAY	814 TIE BAY - 765/400 KV 1500 MVA ICT 1 AT ALIGARH(PG) AND FUTURE AT 765 KV ALIGARH(PG)	POWERGRID	С	765 kV Sikar Line Protection Commissioning Testing and Line Reactor LBB Testing	13/Jul/2023	08:00	14/Jul/2023	18:00	PLANNED	Requested	
157	RQ136190	OCC_208	cpcc1_sd	BAY	714 TIE BAY - 765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(PG) (POWERGRID) AND 240 MVAR BUS REACTOR NO 1 AT 765 KV FATEHGARH_II(PG) AT 765 KV FATEHGARH_II(PG) (POWERGRID)	POWERGRID	D	For Bay AMP works	11/Jul/2023	17:00	12/Jul/2023	23:00	PLANNED	Requested	
158	RQ136447	OCC_208	cpcc3_sd	BAY	706 MAIN BAY - 240 MVAR BUS REACTOR NO 2 AT	POWERGRID	D	AMP works	11/Jul/2023	08:00	11/Jul/2023	18:00	PLANNED	Requested	
159	RQ136202	OCC_208	cpcc1_sd	ВАУ	721 MAIN BAY - 765 KV BHADLA_2 - FATEHGARH_II (PG) CKT-1 (POWERGRID)	POWERGRID	D	For erection works of SS-63 A1, B1 & TBCB bay extension.	10/Jul/2023	17:00	17/Jul/2023	23:00	PLANNED	Requested	
160	RQ136189	OCC_208	cpcc1_sd	BAY	707 MAIN BAY - 240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(PG) (POWERGRID) AT 765 KV FATEHGARH_II(PG)	TOWERGING	D	For Bay AMP works	09/Jul/2023	17:00	10/Jul/2023	23:00	PLANNED	Requested	
161	RQ136188	OCC_208	cpcc1_sd	BAY	712 MAIN BAY - 765 KV FATEHGARH_II- BHADLA (PG) CKT-1 (POWERGRID) AT 765 KV FATEHGARH_II(PG)	POWERGRID POWERGRID	D	For Bay AMP works	07/Jul/2023	17:00	08/Jul/2023	23:00	PLANNED	Requested	
162	RQ136180	OCC_208	cpcc1_sd	BAY	708 TIE BAY - 765KV JHATIKARA- BHIWANI (PG) CKT- 1 AND 765/400KV 1500 MVA ICT 1 AT JHATIKARA(PG)		D	FOR AMP WORK	06/Jul/2023	08:00	07/Jul/2023	18:00	PLANNED	Requested	
	RQ136187			BAY	711 TIE BAY - 765 KV FATEHGARH_II- BHADLA (PG) CKT-1 (POWERGRID) AND 765/400 KV 1500 MVA ICT 1 AT FATEHGARH_II(PG) AT 765 KV FATEHGARH_II(PG) (POWERGRID)	POWERGRID	D	For Bay AMP works	05/Jul/2023		06/Jul/2023		PLANNED	Requested	
164	RQ136461	OCC_208	cpcc3_sd	BAY	710 MAIN BAY - 765KV AGRA- FATEHPUR (PG) CKT- 2 AT FATEHPUR(PG)		D	AMP works	05/Jul/2023	08:00	05/Jul/2023	18:00	PLANNED	Requested	
	RQ136470			ВАУ	705 TIE BAY - 765/400 KV 1500 MVA ICT 2 AT LUCKNOW_2(PG) (POWERGRID) AND FUTURE AT 765 KV LUCKNOW_2(PG) (POWERGRID)	POWERGRID	D	AMP works	05/Jul/2023		05/Jul/2023			Requested	
166	RQ136179	OCC_208	cpcc1_sd	BAY	718 MAIN BAY - 765/400KV 1500 MVA ICT 4 AT JHATIKARA(PG)	POWERGRID	D	FOR AMP WORK	04/Jul/2023	08:00	05/Jul/2023	18:00	PLANNED	Requested	

167	RQ136476	OCC_208	cpcc3_sd	BAY	816 MAIN BAY - 765KV BUS 1 AT ALIGARH(PG) AND FUTURE AT 765 KV		С	For termination of the cable related to the 765 kV Aligarh- Sikar-II Line 2 (Construction)	04/Jul/2023	08:00	05/Jul/2023	18:00	PLANNED	Requested	
					ALIGARH(PG)	POWERGRID									
168	RQ136477	OCC_208	cpcc3_sd	ВАУ	817 TIE BAY - 765/400 KV 1500 MVA ICT 2 AT ALIGARH(PG) (POWERGRID) AND		С	For termination of the cable related to the 765 kV Aligarh- Sikar-II Line 2 (Construction)	04/Jul/2023	08:00	05/Jul/2023	18:00	PLANNED	Requested	
169	RQ136186	OCC 208	cpcc1 sd	BAY	FUTURE AT 765 KV ALIGARH(PG) (POWERGRID) 709 MAIN BAY -	POWERGRID	D	For Bay AMP works	03/Jul/2023	17:00	04/Jul/2023	23:00	PLANNED	Requested	
					765 KV FATEHGARH_II- BHADLA (PG) CKT-2 (POWERGRID) AT 765 KV		_				- 7, - 7,				
					FATEHGARH_II(PG)	POWERGRID									
170	RQ136446	OCC_208	cpcc3_sd	BAY	710 MAIN BAY - 765KV VARANASI- BALIA (PG) CKT-1		D	AMP works	03/Jul/2023	08:00	03/Jul/2023	18:00	PLANNED	Requested	
171	RQ136462	OCC_208	cpcc3_sd	BAY	AT BALIA(PG) 706 MAIN BAY - 765/400KV 1500	POWERGRID	D	AMP works	03/Jul/2023	08:00	03/Jul/2023	18:00	PLANNED	Requested	
172	RQ136185	OCC_208	cpcc1_sd	BAY	MVA ICT 1 AT FATEHPUR(PG) 708 TIE BAY - 765 KV FATEHGARH_II-	POWERGRID	D	For Bay AMP works	01/Jul/2023	17:00	02/Jul/2023	23:00	PLANNED	Requested	
					BHADLA (PG) CKT-2 (POWERGRID) AND 240 MVAR BUS REACTOR NO 2 AT 765 KV FATEHGARH_II(PG) AT 765 KV FATEHGARH_II(PG) (POWERGRID)	POWERGRID									
173	RQ136474	OCC_208	cpcc3_sd	BAY	813 MAIN BAY - 765KV BUS 1 AT ALIGARH(PG) AND FUTURE AT 765 KV ALIGARH(PG)	POWERGRID	С	For termination of the cable related to the 765 kV Aligarh- Sikar-II Line 1 (Construction)	01/Jul/2023	08:00	02/Jul/2023	18:00	PLANNED	Requested	
174	RQ136475	OCC_208	cpcc3_sd	BAY	814 TIE BAY -	23	С	For termination of the cable	01/Jul/2023	08:00	02/Jul/2023	18:00	PLANNED	Requested	
					765/400 KV 1500 MVA ICT 1 AT ALIGARH(PG) AND FUTURE AT 765 KV ALIGARH(PG)	DOMEDONIO		related to the 765 kV Aligarh- Sikar-II Line 1 (Construction)							
175	RQ136121	OCC_208	stuup_sd	BAY	709 MAIN BAY - 240 MVAR BUS	POWERGRID	D	For annual maintenance & Testing work (There is no load	12/Jul/2023	08:00	12/Jul/2023	14:00	PLANNED	Requested	
					REACTOR NO 1 AT 765 KV GR.NOIDA_2(UPC)	UPPTCL		interruption as load will be feed by Tie bay)							
176	RQ136119	OCC_208	stuup_sd	BAY	702 TIE BAY - 765		D	For annual maintenance &	11/Jul/2023	08:00	11/Jul/2023	14:00	PLANNED	Requested	
					GR.NOIDA_2(UPC)- ALIGARH(PG) (PG) CKT-1 AND 765/400 KV 1500 MVA ICT 1 AT GR.NOIDA_2(UPC) AT 765 KV GR.NOIDA_2(UPC)	UPPTCL		Testing work (There is no load interruption as load will be feed by Main bay)							
	RQ136118			BAY	701 MAIN BAY - 765/400 KV 1500 MVA ICT 1 AT GR.NOIDA_2(UPC)	UPPTCL	D	For annual maintenance & Testing work (There is no load interruption as load will be feed by Tie bay)	10/Jul/2023		10/Jul/2023			Requested	
178	RQ136178	OCC_208	cpcc1_sd	BAY	710 MAIN BAY - 765 KV KHETRI (PKTSL)- JHATIKARA(PG) (PG) CKT-2 (PKTSL) AT JHATIKARA(PG)	PKTSL	D	FOR AMP WORK	11/Jul/2023	08:00	12/Jul/2023	18:00	PLANNED	Requested	
179	RQ136177	OCC_208	cpcc1_sd	BAY	713 MAIN BAY - 765 KV KHETRI (PKTSL)- JHATIKARA(PG) (PG) CKT-1 (PKTSL)		D	FOR AMP WORK	06/Jul/2023	08:00	07/Jul/2023	18:00	PLANNED	Requested	
180	RQ136213	OCC_208	cpcc1_sd	TRANSFORMER	AT JHATIKARA(PG) 765/400 KV 1500 MVA ICT 1 AT FATEHGARH_II(PG)	PKTSL	D	FOR AMP WORK	25/Jul/2023	17:00	27/Jul/2023	23:00	PLANNED	Requested	
181	RQ136212	OCC_208	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT FATEHGARH_II(PG)	POWERGRID	D	FOR AMP WORK	22/Jul/2023	17:00	24/Jul/2023	23:00	PLANNED	Requested	
182	RQ136214	OCC_208	cpcc1_sd	TRANSFORMER	765/400 KV 1500	POWERGRID	D	FOR AMP WORK	18/Jul/2023	17:00	20/Jul/2023	23:00	PLANNED	Requested	
192	RQ136730	OCC 306	cucc ₃ e ₄	TRANSFORMER	MVA ICT 4 AT FATEHGARH_II(PG) 765/400 KV 1500	POWERGRID	D	AMP WORK ,	17/Jul/2023	08:00	18/Jul/2023	18-00	ΡΙ ΔΝΙΝΙΈΡ	Requested	
					MVA ICT 2 AT KANPUR_GIS(PG)	POWERGRID		IMPLEMENTATION OF 9TH AND 10TH PCC GUIDELINES & Spare Rotation							
	RQ136224				765/400 KV 1500 MVA ICT 3 AT BHADLA_2 (PG)	POWERGRID	D	CSD fine tuning Works	16/Jul/2023		16/Jul/2023			Requested	
185	RQ136223	OCC_208	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT		D	FOR AMP WORK	15/Jul/2023	17:00	15/Jul/2023	23:00	PLANNED	Requested	
186	RQ136211	OCC_208	cpcc1_sd	TRANSFORMER	BHADLA_2 (PG) 765/400 KV 1500 MVA ICT 3 AT FATEHGARH_II(PG)	POWERGRID	D	FOR AMP WORK	15/Jul/2023	17:00	17/Jul/2023	23:00	PLANNED	Requested	
187	RQ136210	OCC_208	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 4 AT FATEHGARH_II(PG)	POWERGRID	D	Commissioning of ICT with Spare ICT Bank & CSD Fine tuning works	15/Jul/2023	17:00	24/Jul/2023	23:00	PLANNED	Requested	
			<u> </u>	1		POWERGRID		l							

400	0.425722			TD 111050D1 15D	755 (400 10 (4000			h	45/1 1/2022	00.00	45/1 1/2022	40.00		la	
188	RQ136732	OCC_208	cpcc3_sd	TRANSFORMER	765/400 KV 1000 MVA ICT 2 AT ORAI(PG)	POWERGRID	D	Implementation & testing for PRD and OSR revised scheme	15/Jul/2023	08:00	15/Jul/2023	18:00	PLANNED	Requested	
189	RQ136222	OCC_208	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT		D	FOR AMP WORK	14/Jul/2023	17:00	14/Jul/2023	23:00	PLANNED	Requested	
190	RQ136205	OCC_208	cpcc1_sd	TRANSFORMER	BHADLA_2 (PG) 765/400 KV 1500	POWERGRID	D	For providing insulation on	13/Jul/2023	08:00	13/Jul/2023	18:00	PLANNED	Requested	
					MVA ICT 1 AT CHITTORGARH(PG)	POWERGRID		Tertiery connector and conductor							
191	RQ136215	OCC_208	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 4 AT	TOWERGRID	D	For LBB testing of LV side Tie bay 429 for commissioning	12/Jul/2023	17:00	20/Jul/2023	23:00	PLANNED	Requested	
					FATEHGARH_II(PG)	POWERGRID		works of STATCOM Main bay 430							
192	RQ136729	OCC_208	cpcc3_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT		D	AMP WORK, IMPLEMENTATION OF 9TH	12/Jul/2023	08:00	13/Jul/2023	18:00	PLANNED	Requested	
193	RQ136206	OCC_208	cpcc1_sd	TRANSFORMER	765/400 KV 1500	POWERGRID	D	AND 10TH PCC GUIDELINES For providing insulation on	12/Jul/2023	08:00	12/Jul/2023	18:00	PLANNED	Requested	
					MVA ICT 2 AT CHITTORGARH(PG)			Tertiery connector and conductor							
194	RQ136731	OCC_208	cpcc3_sd	TRANSFORMER	765/400 KV 1000 MVA ICT 1 AT	POWERGRID	D	Implementation & testing for PRD and OSR revised scheme	11/Jul/2023	08:00	11/Jul/2023	18:00	PLANNED	Requested	
195	RQ136207	OCC 208	cncc1 sd	TRANSFORMER	ORAI(PG) 765/400 KV 1500	POWERGRID	D	Commissioning of ICT with	10/Jul/2023	17:00	18/Jul/2023	23:00	PLANNED	Requested	
133	NQ130207	000_200	cpcc1_su	TRAISI ORWER	MVA ICT 3 AT FATEHGARH_II(PG)			Spare ICT Bank & CSD Fine tuning works	10/301/2023	17.00	10/301/2023	25.00	PEANNED	Requested	
196	RQ136216	OCC_208	cpcc1_sd	TRANSFORMER	765/400 KV 1500	POWERGRID	D	For Erection works of SS-63 A1	07/Jul/2023	17:00	11/Jul/2023	23:00	PLANNED	Requested	
					MVA ICT 4 AT FATEHGARH_II(PG)			package 765 kV ICT-5 B phase unit							
197	RQ136220	OCC_208	cpcc1_sd	TRANSFORMER	765/400 KV 800	POWERGRID	D	CSD commissioning and fine	07/Jul/2023	08:00	07/Jul/2023	18:00	PLANNED	Requested	
400		000 000		T0.11/05001450	MVA ICT 4 AT KOTESHWAR(PG)	POWERGRID		tuning Works	05/11/2022	47.00	05/1 1/2022	22.00			
198	RQ136203	JULC_208	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT BIKANER(PG)	POWERGRID	D	SPARE ICT SWITCHING WITH ICT1 B-PHASE	06/Jul/2023	17:00	06/Jul/2023	25:00	PLANNED	Requested	
199	RQ136221	OCC_208	cpcc1_sd	TRANSFORMER	765/400 KV 800 MVA ICT 3 AT	. SWENGRID	D	CSD commissioning and fine tuning Works	06/Jul/2023	08:00	06/Jul/2023	18:00	PLANNED	Requested	
200	RQ136208	OCC_208	cpcc1_sd	TRANSFORMER	KOTESHWAR(PG) 765/400 KV 1500	POWERGRID	D	Commissioning of ICT with	05/Jul/2023	17:00	12/Jul/2023	23:00	PLANNED	Requested	
					MVA ICT 2 AT FATEHGARH_II(PG)			Spare ICT Bank & CSD Fine tuning works							
201	RQ136219	OCC_208	cpcc1_sd	TRANSFORMER	765/400 KV 800	POWERGRID	D	CSD commissioning and fine	05/Jul/2023	08:00	05/Jul/2023	18:00	PLANNED	Requested	
202	RQ136204	OCC 200	cncc1 sd	TRANSFORMER	MVA ICT 2 AT KOTESHWAR(PG) 765/400 KV 1500	POWERGRID	D	tuning Works	04/Jul/2023	17:00	04/Jul/2023	23·00	ΡΙ ΔΝΙΝΙΕΙ	Requested	
202		JCC_208	cpcc1_su	MANOPORIVIER	MVA ICT 3 AT BIKANER(PG)	POWERGRID		CSD Fine tuning & Spare ICT Switching	0-yJul/2023	17.00	J=1,1U1,2U23	23.00	LAINNED	nequested	
203	RQ136787	OCC_208	cpcc1_sd	TRANSFORMER	765/400 KV 1000 MVA ICT 3 AT		D	FOR REACTOR/BAY AMP WORKS	04/Jul/2023	09:00	04/Jul/2023	18:00	PLANNED	Requested	
204	RQ136218	OCC_208	cpcc1_sd	TRANSFORMER	765/400 KV 800	POWERGRID	D	CSD commissioning and fine	04/Jul/2023	08:00	04/Jul/2023	18:00	PLANNED	Requested	
					MVA ICT 1 AT KOTESHWAR(PG)	POWERGRID		tuning Works							
205	RQ136472	OCC_208	cpcc3_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT ALIGARH(PG)		С	For termination of the cable related to the 765 kV Aligarh- Sikar-II Line 2 (Construction)	04/Jul/2023	08:00	05/Jul/2023	18:00	PLANNED	Requested	
206	RQ136209	OCC 208	cncc1 sd	TRANSFORMER	765/400 KV 1500	POWERGRID	D	Commissioning of ICT with	01/Jul/2023	17:00	06/Jul/2023	23:00	PLANNED	Requested	
					MVA ICT 1 AT FATEHGARH_II(PG)			Spare ICT Bank & CSD Fine tuning works	.,.,					.,	
207	RQ136473	OCC_208	cpcc3_sd	TRANSFORMER	765/400 KV 1500	POWERGRID	С	For termination of the cable	01/Jul/2023	08:00	02/Jul/2023	18:00	PLANNED	Requested	
					MVA ICT 1 AT ALIGARH(PG)	POWERGRID		related to the 765 kV Aligarh- Sikar-II Line1 (Construction)							
208	RQ136217	OCC_208	cpcc1_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 1 AT	POWERGRID	D	For internal inspection & attending oil leakage	13/Jul/2023	09:00	14/Jul/2023	18:00	PLANNED	Requested	
209	RQ136728	OCC_208	sldcrs_sd	TRANSFORMER	KHETRI (PKTSL) 765/400 KV 1500	PKTSL	D	For proper alignment of LV	08/Jul/2023	08:00	08/Jul/2023	18:00	PLANNED	Requested	
					MVA ICT 3 AT PHAGI(RS)	RRVPNL		side HCB isolators through M/s TBEA						·	
210	RQ135869	OCC_208	stuup_sd	TRANSFORMER	765/400 KV 1500 MVA ICT 2 AT AGRA		D	* For Charging of 500MVA ICT- II R Phase unit at 765kV	03/Jul/2023	10:00	03/Jul/2023	17:00	PLANNED	Requested	
					FATEHBAD(UP)	LIDDEC		Substation Fatehabad Agra. At present Spare Phase unit is							
211	RQ136100	OCC_208	stuup_sd	AC TRANSMISSION	400 KV AGRA(PG)- AGRA	UPPTCL	D	charged as R * JUMPER TIGHTENING DEFECTIVE POLYMER/JUMPER	31/Jul/2023	10:00	31/Jul/2023	17:00	PLANNED	Requested	
				LINE CIRCUIT	FATEHBAD(UP) (PG) CKT-1	POWERGRID, UPPTCL		REPLACEMENT WORK							
212	RQ135953	OCC_208	stuup_sd	AC TRANSMISSION	400 KV LUCKNOW_1(PG)-		D	* For Upgradation of Bus-Bar Protection Panel from	26/Jul/2023	09:00	26/Jul/2023	18:00	PLANNED	Requested	
				LINE CIRCUIT	LUCKNOW(UP) (PG) CKT-1			Electromechanical type to Numerical Type (Connection							
24.2	BO125555	000 225	etuur . '	AC	400 KV AGRA(UP)-	POWERGRID, UPPTCL		of CT Bus-Bar Prot	25/1:1/225	10:00	27/Jul/2023	17:00	DI ANIN'S	Dog:	
213	RQ136095	ULC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	AGRA FATEHBAD(UP) (PG)	POWERGRID	D	* Jumper Tightening Defective Polymer/Jumper Changing	25/Jul/2023	10:00	z//Jul/2023	17:00	PLANNED	Requested	
214	RQ135843	OCC 208	stuup sd	AC	CKT-2 400 KV	UPPTCL	D	* For Routine Bay	14/Jul/2023	10:00	14/Jul/2023	18:00	PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	SULTANPUR(UP)- LUCKNOW_1(PG)	POWERGRID,	-	Maintenance at 400KV S/S Sultanpur	, , 2023		,,			.,	
215	RQ136091	OCC_208	stuup_sd	AC	(PG) CKT-1 400 KV DADRI(NT)-	UPPTCL	D	* High Temp. Point will be	09/Jul/2023	10:00	09/Jul/2023	14:00	PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	GR.NOIDA(UPC) (PG) CKT-1			attended at R phase Wave trap clamp of 400 kV Dadri							
24.5	00125022	000 225	etuur . '	AC	400 KV	POWERGRID, UPPTCL	-	Bay. This work will be attended for healthine	00/1:1/225	08:00	09/1-1/202-	10.00	DI ANIN'S	Dog:	
∠16	RQ135833	JULC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MORADABAD(UP)- RAMPUR_PRSTL		D	Power line crossing work for under construction of Loop Out CKT of LILO of 765kV	08/Jul/2023	U8:UU	08/Jul/2023	18:00	PLANNED	Requested	
					(UP) (PG)	POWERGRID,		GHatampur-Hapur line at 765/400/220kV GIS SS Rampur							
217	RQ136641	OCC_208	cpcc3_sd	AC	400 KV	UPPTCL	D	Power line crossing of under	08/Jul/2023	08:00	08/Jul/2023	18:00	PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	MORADABAD(UP)- RAMPUR_PRSTL			construction loop out ckt of LILO of 765 KV Ghatampur-							
24.	004255	000 5		A.C.	(UP) (PG)	POWERGRID, UPPTCL	_	Hapur Line at Rampur S/S	20/11/22	00.00	20/1-1/	10.00	DI 45-15-		
218	RQ135955	UCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV UNNAO- LUCKNOW (UP) CKT		D	* For Upgradation of Bus-Bar Protection Panel from Electromechanical type to	29/Jul/2023	09:00	29/Jul/2023	18:00	PLANNED	Requested	
				CINCOIT	-			Numerical Type (Connection of CT Bus-Bar Prot							
						UPPTCL									

219	RQ136102	OCC_208	stuup sd	AC	400 KV AGRA	1 '	D								
				TRANSMISSION LINE CIRCUIT	FATEHBAD- MATHURA (UP) CKT-		D	* 400 KV Manth(Mathura)- Fatehabad Line-1 shutdown for Jumper Tightening, Nest Removal, Polymer Cleaning and other works.	26/Jul/2023	10:00	29/Jul/2023	20:00	PLANNED	Requested	
220	RQ135916	OCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV GR.NOIDA_2(UPC)- GR.NOIDA(UPC) (UP) CKT-1	UPPTCL	D	* Tree trimmring will be carried out in line cooridoor during this shutdown period.	25/Jul/2023	10:00	25/Jul/2023	17:00	PLANNED	Requested	
221	RQ136662	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SAMBHAL_PRSTL - BADAUNE (UP) CKT- 2		D	Power line crossing of under construction loop out ckt of LILO of 765 KV Ghatampur- Hapur Line at Rampur S/S	25/Jul/2023	08:00	25/Jul/2023	18:00	PLANNED	Requested	
222	RQ136661	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SAMBHAL_PRSTL - BADAUNE (UP) CKT-	UPPTCL	D	Power line crossing of under construction loop out ckt of LILO of 765 KV Ghatampur- Hapur Line at Rampur S/S	25/Jul/2023	08:00	25/Jul/2023	18:00	PLANNED	Requested	
223	RQ135837	OCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SAMBHAL_PRSTL - BADAUNE (UP) CKT-	UPPTCL	D	Power line crossing work for under construction of Loop Out CKT of LILO of 765kV	25/Jul/2023	08:00	25/Jul/2023	18:00	PLANNED	Requested	
224	RQ135836	OCC_208	stuup_sd	AC	2 400 KV	UPPTCL	D	GHatampur-Hapur line at 765/400/220kV GIS SS Rampur Power line crossing work for	25/Jul/2023	08:00	25/Jul/2023	18:00	PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	SAMBHAL_PRSTL - BADAUNE (UP) CKT- 1	UPPTCL		under construction of Loop Out CKT of LILO of 765kV GHatampur-Hapur line at 765/400/220kV GIS SS Rampur							
225	RQ136653	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SAMBHAL_PRSTL - RAMPUR_PRSTL (UP) CKT-1		D	Power line crossing of under construction loop out ckt of LILO of 765 KV Ghatampur- Hapur Line at Rampur S/S	22/Jul/2023	08:00	22/Jul/2023	18:00	PLANNED	Requested	
226	RQ136654	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SAMBHAL_PRSTL - RAMPUR_PRSTL (UP) CKT-2	UPPTCL	D	Power line crossing of under construction loop out ckt of LILO of 765 KV Ghatampur- Hapur Line at Rampur S/S	22/Jul/2023	08:00	22/Jul/2023	18:00	PLANNED	Requested	
227	RQ135834	OCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SAMBHAL_PRSTL - RAMPUR_PRSTL (UP) CKT-1	UPPTCL	D	Power line crossing work for under construction of Loop Out CKT of LILO of 765kV GHatampur-Hapur line at	22/Jul/2023	08:00	22/Jul/2023	18:00	PLANNED	Requested	
228	RQ135835	OCC_208	stuup_sd	AC TRANSMISSION	400 KV SAMBHAL_PRSTL -	UPPTCL	D	765/400/220kV GIS SS Rampur Power line crossing work for under construction of Loop	22/Jul/2023	08:00	22/Jul/2023	18:00	PLANNED	Requested	
				LINE CIRCUIT	RAMPUR_PRSTL (UP) CKT-2	UPPTCL		Out CKT of LILO of 765kV GHatampur-Hapur line at 765/400/220kV GIS SS Rampur							
	RQ136096 RQ135904			AC TRANSMISSION LINE CIRCUIT	400 KV AGRA FATEHBAD- MATHURA (UP) CKT- 2 400 KV ANPARA-	UPPTCL	D C	* JUMPER TIGHTENING DEFECTIVE POLYMER/JUMPER REPLACEMENT WORK * DIVERSION OF 1.005 KM.	20/Jul/2023 20/Jul/2023		22/Jul/2023 31/Jul/2023			Requested Requested	
230	NQ133904	OCC_208	stuup_su	TRANSMISSION LINE CIRCUIT	SARNATH (UP) CKT-	UPPTCL	C	400KV ANPARA-SARNATH (L3) SARNATH-AZAMGARH D/C LINE BETWEEN TOWER NO. 19 TO 22 DUE TO INFR	20/30// 2023	08.00	51/Jui/2025	18.00	FLANNED	nequesteu	
	RQ136104			AC TRANSMISSION LINE CIRCUIT	400 KV BANDA- ORAI (UP) CKT-2	UPPTCL	D	* For attending oil leakage of 400 kv R-phase CT of main bay -406(400 kv orai-banda ckt-2)	19/Jul/2023		19/Jul/2023			Requested	
	RQ135831			AC TRANSMISSION LINE CIRCUIT	400 KV SHAHJAHANPUR(P G)-ROSA(UPC) (UP) CKT-1 400 KV ORAI-	UPPTCL	D D	in order to carry out annual maintenance of line equipment's and cleaning of BPI * SHUTDOWN APPLIED FOR	18/Jul/2023		18/Jul/2023 31/Jul/2023			Requested Requested	
255	RQ135923	000_200	stuup_su		MAINPURI (UP) CKT-	UPPTCL	D	REPLACEMENT OF DISC INSULATORS BY POLYMER INSULATORS AT SUSPENSION TOWERS, JUMPER TIGHTENING AND OTHE	10/30// 2023	08.00	51/Jul/2025	16.00	PLANNED	nequesteu	
	RQ135844 RQ136094			AC TRANSMISSION LINE CIRCUIT AC	400 KV OBRA_B- SULTANPUR (UP) CKT-1 400 KV AGRA-AGRA	UPPTCL	D D	* For Routine Bay Maintenance at 400KV S/S Sultanpur * JUMPER TIGHTENING	17/Jul/2023 17/Jul/2023		17/Jul/2023 19/Jul/2023			Requested Requested	
	RQ135860			TRANSMISSION LINE CIRCUIT	FATEHBAD (UP) CKT 1 400 KV AZAMGARH-	UPPTCL	C	DEFECTIVE POLYMER/JUMPER REPLACEMENT WORK * Relay Retrofitting	13/Jul/2023		18/Jul/2023			Requested	
	RQ135841			TRANSMISSION LINE CIRCUIT	MAU (UP) CKT-1 400 KV TANDA(NT)-	UPPTCL	D	Commissioning of 50MVAR Line Reactor. on 400kV Azamgarh Mau Line * For Routine Bay	12/Jul/2023		12/Jul/2023			Requested	
	RQ135888			TRANSMISSION LINE CIRCUIT	SULTANPUR(UP) (UP) CKT-1 400 KV ALIGARH-	UPPTCL	D	Maintenance and testing at 400KV S/S Sultanpur Annual Testing and Preventive	11/Jul/2023		11/Jul/2023			Requested	
	RQ135832			TRANSMISSION LINE CIRCUIT AC TRANSMISSION	MAINPURI (UP) CKT- 1 400 KV SHAHJAHANPUR(P	UPPTCL	D	Maintenance of Line bay. in order to carry out annual maintenance of line	11/Jul/2023		11/Jul/2023			Requested	
240	RQ135927	OCC_208	stuup_sd	AC TRANSMISSION	G)-ROSA(UPC) (UP) CKT-2 400 KV MURADNAGAR_2-	UPPTCL	D	equipment's and cleaning of BPI * 400 KV Manth(Mathura)- Muradnagar new Line	11/Jul/2023	10:00	14/Jul/2023	20:00	PLANNED	Requested	
2/1	RQ135925	UCC 300	stuum ed	LINE CIRCUIT	MATHURA (UP) CKT-	UPPTCL	D	Shutdown for Jumper Tightening, Bird Nest Removal, Insulator Cleaning and other	10/Jul/2023	08-00	14/Jul/2023	18:00	DIANNER	Dequested	
	RQ135925			TRANSMISSION LINE CIRCUIT	400 KV BANDA- REWA ROAD (UP) CKT-2	UPPTCL	C	* For Jumper tightening and Line maintenance work of 400 KV Banda-Rewaroad 2 line (under ETD Banda) * PLCC commissioning, 400kV	10/Jul/2023		14/Jul/2023 31/Jul/2023			Requested Requested	
				TRANSMISSION LINE CIRCUIT	AZAMGARH (UP)	UPPTCL		Reactor Isolating, MoAN Reactor Isolation Commissioning of SOMVAR line reactor of 400kv Azamgarh-Sa. *DIVERSION OF 1.005 KM. 400kV ANPARA-SARNATH (13) SARNATH-4ZAMGARH D/C LINE BETWEEN TOWER NO. 19 TO 22 DUE TO INFR	, , , , , , , , , , , , , , , , , , ,		1301/2425				

243	RQ136103	OCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PANKI- ALIGARH (UP) CKT- 1	UPPTCL	D	* Shutdown Taken for Maintenance work/Jumper Tightening of 400KV Panki Aligarh Line	05/Jul/2023	10:00	05/Jul/2023	18:00		PLANNED	Requested	
244	RQ135894	OCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ORAI- PARICHA (UP) CKT- 2	UPPTCL	D	Interconnection of Existing Bus- I with New Extended Bus-2	05/Jul/2023	08:00	05/Jul/2023	18:00	For above work we need shutdown of 400 KV Bus-1 & Bus- 2, LINE-2 shutdown will be required as it is just near to Existing Support Towers	PLANNED	Requested	
245	RQ135912	OCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MUZAFFARNAGAR- ATAUR (UP) CKT-1	UPPTCL	D	* REMOVING BIRD NESTS, JUMPER TIGHTENING, LOOPING- CHOPINGS OF TRESS, AND OTHER MR WORKS .	03/Jul/2023	09:00	06/Jul/2023	17:00		PLANNED	Requested	
246	RQ135893	OCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ORAI- PARICHA (UP) CKT- 2	UPPTCL	D	Interconnection of Existing Bus- I with New Extended Bus-1	03/Jul/2023	08:00	03/Jul/2023	18:00	Safety clearance from Electrical safety department is still awaited.		Requested	
247	RQ135924	OCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BANDA- REWA ROAD (UP) CKT-1	UPPTCL	D	* For Jumper tightening and line maintenance work of 400 KV Banda-Rewaroad 1 line (under ETD Banda)	03/Jul/2023	08:00	07/Jul/2023	18:00		PLANNED	Requested	
248	RQ135951	OCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY- UNNAO (UP) CKT-1	UPPTCL	D	* Preventive mainteance ,testing of Bay and Taking in ckt new 63 MVAR line reactor	03/Jul/2023	08:00	03/Jul/2023	18:00		PLANNED	Requested	
249	RQ135922	OCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ORAI- MAINPURI (UP) CKT- 1	UPPTCL	D	* SHUTDOWN APPLIED FOR REPLACEMENT OF DISC INSULATORS BY POLYMER INSULATORS AT SUSPENSTION TOWERS, JUMPER TIGHTENING AND OTHE	02/Jul/2023	08:00	17/Jul/2023	18:00		PLANNED	Requested	
250	RQ135926	OCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV UNNAO- PANKI (UP) CKT-1	UPPTCL	С	* Hight raising work of 400KV Panki Unaao Line due to NHAI,Mandhana (Kanpur Nagar)	01/Jul/2023	09:00	15/Jul/2023	18:00		PLANNED	Requested	
	RQ135952			AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY- UNNAO (UP) CKT-2	UPPTCL	D	* to out line reactor from ckt for reactor replacement work and preventive maintenace, Testing of Bay	01/Jul/2023	08:00	01/Jul/2023	18:00		PLANNED	Requested	
	RQ136840 RQ136841			AC TRANSMISSION LINE CIRCUIT AC	400 KV BAREILLY- UNNAO (UP) CKT-1 400 KV BAREILLY-	UPPTCL	С	For de-stringing of HVDC AGRA- BNC line(Dismantalled portion) For de-stringing of HVDC AGRA-	01/Jul/2023 01/Jul/2023		03/Jul/2023 03/Jul/2023				Requested Requested	
	RQ136552			TRANSMISSION LINE CIRCUIT AC	UNNAO (UP) CKT-2 400 KV CLP	UPPTCL	D	BNC line(Dismantalled portion To verify BI, BOM & Dismantalled portion	28/Jul/2023		28/Jul/2023				Requested	
255	RQ136567	OCC_208	sldchr_sd	TRANSMISSION LINE CIRCUIT	JHAJJAR(CLP)- DHANODA(HV) (HVPNL) CKT-1 400 KV	HVPNL	D	protection signals in SAS. For replacement of DPR Main-	17/Jul/2023	09:00	17/Jul/2023	17:00		PLANNED	Requested	
256	RQ136553	OCC_208	sldchr_sd	TRANSMISSION LINE CIRCUIT	GURGAON(PG)- DAULATABAD(HV) (HV) CKT-1 400 KV CLP	HVPNL	D	2 Relay To verify BI, BOM & DOM & D	12/Jul/2023	09:00	12/Jul/2023	18:00		PLANNED	Requested	
	RQ136568			TRANSMISSION LINE CIRCUIT	JHAJJAR(CLP)- DHANODA(HV) (HVPNL) CKT-2 400 KV	HVPNL	D	protection signals in SAS. For replacement of DPR Main-	10/Jul/2023		10/Jul/2023				Requested	
				TRANSMISSION LINE CIRCUIT	JHAJJAR(APCL)- DAULATABAD(HV) (HV) CKT-1	HVPNL		2							Requested	
	RQ136566 RQ135826			AC TRANSMISSION LINE CIRCUIT AC	400 KV DHANODA- DAULATABAD (HV) CKT-2 400 KV CLP	HVPNL	D D	For half yearly mtc CB SF6 Gas analysis & BCU	05/Jul/2023 04/Jul/2023		05/Jul/2023 04/Jul/2023				Requested	
260	RQ135825	OCC_208	sldchr_sd	TRANSMISSION LINE CIRCUIT	JHAJJAR(CLP)- DHANODA(HV) (HVPNL) CKT-2 400 KV CLP	HVPNL	D	replacement work CB SF6 Gas analysis & BCU	03/Jul/2023	09:00	03/Jul/2023	18:00		PLANNED	Requested	
261	RQ136565	OCC 208	sldchr sd	TRANSMISSION LINE CIRCUIT	JHAJJAR(CLP)- DHANODA(HV) (HVPNL) CKT-1 400 KV DHANODA-	HVPNL	D	replacement work For half yearly mtc &	03/Jul/2023	09:00	03/Jul/2023	17:00		PLANNED	Requested	
262	RQ136684	OCC_208	cpcc3_sd	TRANSMISSION LINE CIRCUIT AC TRANSMISSION	DAULATABAD (HV) CKT-1 400 KV ALLAHABAD- FATEHPUR (PG) CKT-		D	replacement of DPR Main-2 AMP WORK	28/Jul/2023	08:00	28/Jul/2023	18:00		PLANNED	Requested	
263	RQ136318	OCC_208	cpcc1_sd	AC TRANSMISSION	400 KV DADRI(NT)- KAITHAL(PG) (PG)	POWERGRID	D	DEFECT RECTIFICATION WORK	28/Jul/2023	08:00	28/Jul/2023	18:00	Line maintenance	PLANNED	Requested	
264	RQ136681	OCC_208	cpcc3_sd	LINE CIRCUIT AC TRANSMISSION LINE CIRCUIT	CKT-1 400 KV SARNATH(UP)- VARANASI(PG) (PG)	POWERGRID	D	Installation of pilot insulators at D type towers	27/Jul/2023	08:00	27/Jul/2023	18:00	-	PLANNED	Requested	
265	RQ136154	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	CKT-2 400 KV KURUKSHETRA- JIND (PG) CKT-2	POWERGRID	С	For current injection point for Bus-3 for Busbar Relay Testing after HV test of ICT-3 bays.	27/Jul/2023	08:00	28/Jul/2023	20:00		PLANNED	Requested	
266	RQ136598	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA(RS)- BHADLA(PG) (PG) CKT-2	POWERGRID	D	Quarterly/ Half Yearly/ Yearly Maintenance work at 400KV GSS, Bhadla	26/Jul/2023	16:00	26/Jul/2023	23:00		PLANNED	Requested	
	RQ136105			AC TRANSMISSION LINE CIRCUIT	400 KV ORAI(PG)- ORAI(UP) (PG) CKT- 2	POWERGRID POWERGRID	D	* For routine protection testing maintenance work of bay.	26/Jul/2023		26/Jul/2023				Requested	
268	RQ136844	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR_GIS- LUCKNOW_2 (PG) CKT-2	POWERGRID	D	AMP WORK	26/Jul/2023	08:00	26/Jul/2023	18:00		PLANNED	Requested	
269	RQ136668	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SARNATH(UP)- VARANASI(PG) (PG) CKT-1	POWERGRID	D	Installation of pilot insulators at D type towers	26/Jul/2023	08:00	26/Jul/2023	18:00		PLANNED	Requested	
	RQ136014			AC TRANSMISSION LINE CIRCUIT	400 KV MOGA- BHIWANI (PG)	POWERGRID	D	S/D REQUIRED FOR RECTIFICATION OF SD NATURE DEFECTS LAS INTEGRATION AND	26/Jul/2023		26/Jul/2023		Kindly Approve UNDER SHUTDOWN		Requested	
			singrauli_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)- RIHAND(NT) (PG) CKT-1	POWERGRID	С	SAS INTEGRATION AND TESTING	26/Jul/2023		28/Jul/2023		UNDER SHUTDOWN		·	
272	RQ136597	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA(RS)- BHADLA(PG) (PG) CKT-1	POWERGRID	D	Quarterly/ Half Yearly/ Yearly Maintenance work at 400KV GSS, Bhadla	25/Jul/2023	16:00	25/Jul/2023	23:00		PLANNED	Requested	

273	RQ135956	OCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUCKNOW(UP)- BAREILLY(PG) (PG) CKT-1	POWERGRID	D	* For Upgradation of Bus-Bar Protection Panel from Electromechanical type to Numerical Type (Connection of CT Bus-Bar Prot	25/Jul/2023	09:00	25/Jul/2023	18:00		PLANNED	Requested	
274	RQ136326	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SHREE CEMENT(SCL)- KOTA(PG) (PG) CKT- 1	POWERGRID	D	Line and bay AMP work	25/Jul/2023	08:00	25/Jul/2023	18:00	During shutdown, AR to be kept off, of 400 kV Kota-Merta line	PLANNED	Requested	
275	RQ135954	OCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)- LUCKNOW(UP) (PG) CKT-1	POWERGRID	D	* For Upgradation of Bus-Bar Protection Panel from Electromechanical type to Numerical Type (Connection of CT Bus-Bar Prot	24/Jul/2023	09:00	24/Jul/2023	18:00		PLANNED	Requested	
276	RQ136843	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR_GIS- LUCKNOW_2 (PG) CKT-1	POWERGRID	D	AMP WORK	24/Jul/2023	08:00	24/Jul/2023	18:00		PLANNED	Requested	
277	RQ136821	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA-SIKAR (PG) CKT-2	POWERGRID	D	AMP WORK	22/Jul/2023	08:00	22/Jul/2023	18:00		PLANNED	Requested	
278	RQ136037	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- NEWWANPOH (PG) CKT-3	POWERGRID	D	Shutdown required for rectification work of tower no. 185.	22/Jul/2023	08:00	22/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
279	RQ136038	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- NEWWANPOH (PG) CKT-4	POWERGRID	D	Shutdown required for rectification work of tower no. 185.	22/Jul/2023	08:00	22/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
280	RQ136011	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MOGA- JALANDHAR (PG) CKT-2	POWERGRID	D	Relay testing and line equipment AMP work	21/Jul/2023	09:00	21/Jul/2023	17:30	Kindly Approve	PLANNED	Requested	
281	RQ136036	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- NEWWANPOH (PG) CKT-4	POWERGRID	D	Shutdown required for rectification work of tower no. 272.	20/Jul/2023	09:00	20/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
282	RQ136035	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- NEWWANPOH (PG) CKT-3	POWERGRID	D	Shutdown required for rectification work of tower no. 272.	20/Jul/2023	09:00	20/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
283	RQ136010	OCC_208	cpcc2_sd	AC TRANSMISSION	400 KV MOGA- JALANDHAR (PG)		D	Relay testing and line equipment AMP work	20/Jul/2023	09:00	20/Jul/2023	17:30	Kindly Approve	PLANNED	Requested	
284	RQ136820	OCC_208	cpcc3_sd	AC TRANSMISSION	CKT-1 400 KV AGRA-SIKAR (PG) CKT-1	POWERGRID	D	AMP WORK	20/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
285	RQ136335	OCC_208	cpcc1_sd	AC TRANSMISSION	400 KV MAINPURI- BALLABHGARH (PG)	POWERGRID	D	to attend SD nature defects	20/Jul/2023	08:00	20/Jul/2023	18:00	Line maintenance work	PLANNED	Requested	
286	RQ136341	OCC_208	cpcc1_sd	AC TRANSMISSION	CKT-2 400 KV MEERUT- MANDOLA (PG) CKT-	POWERGRID	С	Tower erection, Conductor stringing, Destringing and	20/Jul/2023	08:00	05/Aug/2023	18:00		PLANNED	Requested	
						POWERGRID		Development of six - lane access controlled in Uttar Pradesh portion of Delhi – Saharanpur Highway from Delhi/UP Border to EPE Junction (Ch. 14.750 to Ch. 31.600) in the State of Uttar Pradesh on EPC mode under Economic Corridor in Phase-I of Bharatmala Pariyojana.	20/1/0000	20.00	0.4. (000	40.00				
287	RQ136340	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MEERUT- MANDOLA (PG) CKT- 1	POWERGRID	С	Tower erection, Conductor stringing, Destringing and Tower Dismantling work under Development of six - lane access controlled in Uttar Pradesh portion of Delhi – Saharanpur Highway from Delhi/UP Border to EPE Junction (Ch.14.750 to Ch. 31.600) in the State of Uttar Pradesh on EPC mode under Economic Corridor in Phase-I economic Corridor in Phase-I economic Corridor in Phase-I of Bharatmala Pariyojana.	20/Jul/2023	08:00	05/Aug/2023	18:00		PLANNED	Requested	
288	RQ136043	OCC_208	cpcc2_sd	AC TRANSMISSION	400 KV JALANDHAR- HAMIRPUR (PG)	TOWEROMB	D	Shut down is required on alternate day basis for	19/Jul/2023	09:00	22/Jul/2023	18:00	head, Kindly	PLANNED	Requested	
				LINE CIRCUIT	CKT-1			replacement of Deccan make polymer insulators in line crossings with non auto mode of 400kv Banala-Amritsar/ Hamirpur Jalandhar TL					Approve			
289	RQ136312	OCC_208	cpcc1_sd	AC	400 KV SHREE	POWERGRID	D	To attend shutdown nature	19/Jul/2023	08:00	19/Jul/2023	18:00	During Shutdown ,	PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	CEMENT(SCL)- MERTA(RS) (PG) CKT-1	POWERGRID		defects					A/R to be kept off of 400 KV Kota-Merta line from both ends as safety measures			
290	RQ136350	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BASSI- BHIWADI (PG) CKT-	POWERGRID	D	For attending of SD nature defects	19/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
291	RQ136327	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTA(PG)- MERTA(RS) (PG) CKT-1		D	Line and bay AMP work	19/Jul/2023	08:00	19/Jul/2023	18:00	During shutdown, AR to be kept off, of 400 kV Kota-Shree Cement (Beawar)	PLANNED	Requested	
292	RQ135974	OCC_208	cpcc2_sd	AC TRANSMISSION	400 KV KISHENPUR- SAMBA (PG) CKT-2	POWERGRID	D	For AMP work of line	18/Jul/2023	09:00	18/Jul/2023	18:00	line Kindly Approve	PLANNED	Requested	
293	RQ136849	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)- RIHAND(NT) (PG)	POWERGRID	D	AMP WORK	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
294	RQ136310	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	CKT-1 400 KV SHREE CEMENT(SCL)- KOTA(PG) (PG) CKT- 1	POWERGRID	D	To attend shutdown nature defects	18/Jul/2023	08:00	18/Jul/2023	18:00	During Shutdown , A/R to be kept off of 400 KV Kota-Merta line from both ends as safety measures	PLANNED	Requested	
295	RQ136334	OCC_208	cpcc1_sd	AC TRANSMISSION	400 KV MAINPURI- BALLABHGARH (PG)	POWERGRID	D	to attend SD nature defects	18/Jul/2023	08:00	18/Jul/2023	18:00	Line maintenance work	PLANNED	Requested	
296	RQ136276	OCC_208	cpcc1_sd	AC TRANSMISSION	CKT-1 400 KV RAPS_C(NP)- KANKROLI(PG) (PG)	POWERGRID	D	SHUTDOWN NATURE DEFECT RECTIFICATION	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
				LINE CIRCUIT	CKT-1	POWERGRID										

297	RQ136818	OCC_208	cpcc3_sd	AC TRANSMISSION	400 KV AGRA(PG)- AGRA(UP) (PG) CKT-		D	Jumper replacement work at Loc 22	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
298	RQ136054	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- NEWWANPOH (PG) CKT-1	POWERGRID	D	Jumper tightening of vulnerable towers in Pirpanjal Section	17/Jul/2023	09:00	17/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
299	RQ135973	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- SAMBA (PG) CKT-1	POWERGRID	D	For AMP work of line	17/Jul/2023	09:00	17/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
300	RQ136848	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)- FATEHPUR(PG) (PG) CKT-1	POWERGRID	D	For installation of backup impedence relay for Line reactor at Singrauli end	17/Jul/2023	09:00	17/Jul/2023	15:00		PLANNED	Requested	
301	RQ136762	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AURAIYA(NT)- AGRA(PG) (PG) CKT-	POWERGRID	D	For rectification of S/D nature defects.	17/Jul/2023	08:00	17/Jul/2023	18:00		PLANNED	Requested	
302	RQ136300	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHINMAL- KANKROLI (PG) CKT- 1	POWERGRID	D	Attending Shutdown nature defects i.e Reversed Grading Ring, Cotter pins, Hardware fitting pins etc.	17/Jul/2023	08:00	21/Jul/2023	18:00	Zerda-Kankroli line(Ckt# 1)to be kept into non auto mode.	PLANNED	Requested	
303	RQ136304	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHINMAL- KANKROLI (PG) CKT- 1	POWERGRID	D	Attending Shutdown nature defects i.e Reversed Grading Ring, Cotter pins, Hardware fitting pins etc.	17/Jul/2023	08:00	20/Jul/2023	18:00	Zerda-Kankroli line(Ckt# 1)to be kept into non auto mode.	PLANNED	Requested	
304	RQ136311	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTA(PG)- MERTA(RS) (PG) CKT-1	POWERGRID	D	To attend shutdown nature defects	17/Jul/2023	08:00	17/Jul/2023	18:00	During Shutdown , A/R to be kept off of both 400 KV Kota- Shreecement & 400 KV Shreecement- Merta line from both ends as safety measures	PLANNED	Requested	
305	RQ136835	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR- AGRA (PG) CKT-1	POWERGRID	С	For line isolator 415 89-L and reactor isolator 415-89-R replacement under ADD-CAP	17/Jul/2023	08:00	23/Jul/2023	18:00	After isolator replacement line will be charged through tie bay only as main bay will be under 5/0 for 415 89 and 41589A isolator replacement under ADD-CAP	PLANNED	Requested	
306	RQ136280	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHITTORGARH(RS)- KANKROLI(PG) (PG) CKT-1	POWERGRID	D	SHUTDOWN NATURE DEFECT RECTIFICATION	17/Jul/2023	08:00	17/Jul/2023	18:00		PLANNED	Requested	
	RQ136153			AC TRANSMISSION LINE CIRCUIT	400 KV KAITHAL- HISSAR (PG) CKT-2	POWERGRID	D	RECTIFICATION OF SHUT- DOWN NATURE DEFECTS. UNDER 2ND PHASE OF MAKING MODEL LINES	17/Jul/2023		22/Jul/2023		other ckt will be in non auto mode.		Requested	
308	RQ136351	OCC_208	cpcc1_sd	AC TRANSMISSION	400 KV BHIWADI- HISSAR (PG) CKT-1		С	For NCRTC diversion work	16/Jul/2023	08:00	31/Jul/2023	18:00		PLANNED	Requested	
309	RQ136349	OCC_208	cpcc1_sd	AC TRANSMISSION	400 KV KOTPUTLI- BHIWADI (PG) CKT-	POWERGRID	С	For NCRTC diversion work	16/Jul/2023	08:00	31/Jul/2023	18:00		PLANNED	Requested	
310	RQ136041	OCC_208	cpcc2_sd	LINE CIRCUIT AC	1 400 KV HAMIRPUR-	POWERGRID	D	Shut down is required on	15/Jul/2023	09:00	18/Jul/2023	18:00	Under construction	PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	PARBATI POOLING BANALA (PG) CKT-1	POWERGRID		alternate day basis for replacement of Deccan make polymer insulators in line crossings with non auto mode of 400kv Banala-Amritsar/ Hamirpur Jalandhar TL					head, Kindly Approve			
311	RQ136042	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMRITSAR- PARBATI POOLING BANALA (PG) CKT-1	POWERGRID	D	Shutdown is required for re- installation of avaiation Globules after OPGW works with non auto mode of 400kv Banala-Hamirpur/ Hamirpur Jalandhar TI	15/Jul/2023	09:00	25/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
312	RQ136605	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SHREE CEMENT(SCL)- MERTA(RS) (PG) CKT-1	POWERGRID	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	15/Jul/2023	08:00	15/Jul/2023	18:00		PLANNED	Requested	
	RQ136275			AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_C(NP)- CHITTORGARH(RS) (PG) CKT-1	POWERGRID	D	SHUTDOWN NATURE DEFECT RECTIFICATION	15/Jul/2023	08:00	15/Jul/2023	18:00	Line maintenance work.		Requested	
	RQ136637			AC TRANSMISSION LINE CIRCUIT	400 KV DULHASTI(NH)- KISHENPUR(PG) (PG) CKT-1	POWERGRID	С	Shutdown required for rectification work of tower no. 210.	15/Jul/2023		20/Jul/2023		Kindly Approve		Requested	
315	RQ136610	OCC_208	sldcrs_sd	AC TRANSMISSION	400 KV KOTA(PG)- MERTA(RS) (PG)	POWERGRID	D	For Quarterly/Half Yearly maintenance work	14/Jul/2023	08:00	14/Jul/2023	18:00		PLANNED	Requested	
316	RQ136269	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	CKT-1 400 KV RAPS_D(NP)- KOTA(PG) (PG) CKT- 2	POWERGRID	D	Additonal glass disc insertion work	14/Jul/2023	08:00	14/Jul/2023	18:00	During shutdown, AR to be kept off, of 400 kV RAPP D- Jaipur line	PLANNED	Requested	
317	RQ136817	OCC_208	cpcc3_sd	AC TRANSMISSION	400 KV AGRA- BALLABHGARH (PG)		D	For jumper replacement work at Loc 63	14/Jul/2023	08:00	14/Jul/2023	18:00		PLANNED	Requested	
318	RQ136034	OCC_208	cpcc2_sd	LINE CIRCUIT AC TRANSMISSION LINE CIRCUIT	CKT-1 400 KV KISHENPUR- NEWWANPOH (PG) CKT-3	POWERGRID	D	Shutdown along with non auto mode of ckt 4 is required for rectification of damaged cross- arm at Ckt-3 of tower no. 288.	13/Jul/2023	09:00	17/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
319	RQ136816	OCC_208	cpcc3_sd	AC TRANSMISSION	400 KV KANPUR- AGRA (PG) CKT-1		D	For rectification of S/D nature defects.	13/Jul/2023	08:00	13/Jul/2023	18:00		PLANNED	Requested	
320	RQ136143	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA- JAIPUR SOUTH (PG) CKT-2	POWERGRID	D	Attending Shutdown nature defects i.e. CC ring Spacers, Hardware Loose Nutbolts cutter pins, VD, etc.	13/Jul/2023	08:00	13/Jul/2023	18:00	S/D nature defect liquidation	PLANNED	Requested	
321	RQ136301	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHITTORGARH(RS)- KANKROLI(PG) (PG)	POWERGRID	D	To Attend Loose G Ring and other Shutdown nature defects	13/Jul/2023	08:00	13/Jul/2023	18:00	400 KV RAPPC- KANKROLI CK-II o be kept in non Auto	PLANNED	Requested	
322	RQ136336	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	CKT-1 400 KV BALLABHGARH(PG)- NAWADA(HV) (PG) CKT-1	POWERGRID	D	SD nature defects observed by cross checking team eg GR loose ,GR reversed ,cotter nut loose	13/Jul/2023	08:00	13/Jul/2023	18:00	mode	PLANNED	Requested	
323	RQ136270	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_D(NP)- JAIPUR SOUTH(PG) (PG) CKT-1	POWERGRID	D	Additonal glass disc insertion work	13/Jul/2023	08:00	13/Jul/2023	18:00	During shutdown, AR to be kept off, of 400 kV RAPP D-Kota and 400 kV Kota - Jaipur line	PLANNED	Requested	
				1	1	. STERONID		1			1		pospui inic			

324	RQ136013	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MOGA- HISSAR (PG) CKT-3	POWERGRID	D	Relay testing, OTI/WTI & PRV logic modification of L/R and line equipment AMP work	12/Jul/2023	09:00	12/Jul/2023	17:30	Kindly Approve	PLANNED	Requested	
325	RQ136761	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AURAIYA(NT)- AGRA(PG) (PG) CKT-		D	For rectification of S/D nature defects.	12/Jul/2023	08:00	12/Jul/2023	18:00		PLANNED	Requested	
326	RQ136142	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA- JAIPUR SOUTH (PG) CKT-1	POWERGRID	D	Attending Shutdown nature defects i.e. CC ring Spacers, Hardware Loose Nutbolts cutter pins, VD, etc.	12/Jul/2023	08:00	12/Jul/2023	18:00	S/D nature defect liquidation	PLANNED	Requested	
327	RQ136277	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_C(NP)- KANKROLI(PG) (PG) CKT-1	POWERGRID	D	To Attend Loose G Ring and other Shutdown nature defects	11/Jul/2023	08:00	11/Jul/2023	18:00	400 KV Chittor - KANKROLI CK-I to be kept in non Auto	PLANNED	Requested	
328	RQ136012	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MOGA- HISSAR (PG) CKT-2	POWERGRID	D	Relay testing, OTI/WTI & PRV logic modification of L/R and line equipment AMP work	11/Jul/2023	08:00	11/Jul/2023	18:00	mode Kindly Approve	PLANNED	Requested	
329	RQ136337	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALLABHGARH- MAHARANIBAGH (PG) CKT-1	POWERGRID	D	Flash-over insulator replacement @ T83 and other SD nature defect observed by cross checking team	11/Jul/2023	08:00	11/Jul/2023	18:00		PLANNED	Requested	
330	RQ136017	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KURUKSHETRA- JALANDHAR (PG) CKT-1	POWERGRID	D	Auto recloser Non Auto Mode required to attend Earthwire fittings tightening	10/Jul/2023	09:00	15/Jul/2023	18:00	Non shutdown activity.Kindly Approve	PLANNED	Requested	
331	RQ136016	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KURUKSHETRA(PG)- NAKODAR(PSG)		D	Auto recloser Non Auto Mode required to attend Earthwire fittings tightening	10/Jul/2023	09:00	15/Jul/2023	18:00	Non shutdown activity.Kindly Approve	PLANNED	Requested	
332	RQ136699	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	(PG) CKT-1 400 KV GORAKHPUR(PG)- BASTI(UP) (PG) CKT-	POWERGRID	D	AMP WORK	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
333	RQ136842	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ALLAHABAD- KANPUR_GIS (PG) CKT-2	POWERGRID	D	AMP WORK	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
334	RQ136284	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWADI- HISSAR (PG) CKT-1	POWERGRID	D	For AMP work of Line equipment's	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
335	RQ136314	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HAPUR(UP)- MORADABAD(UP) (PG) CKT-1	FOWERGRID	С	NHAI DIVERSION WORK 171- 174	10/Jul/2023	08:00	25/Jul/2023	18:00	During outage both side jumper shall be open at working area. rest of the line shall be charged from both side to prevent theft.	PLANNED	Requested	
336	RQ136152	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KAITHAL- HISSAR (PG) CKT-1	POWERGRID	D	RECTIFICATION OF SHUT- DOWN NATURE DEFECTS. UNDER 2ND PHASE OF	10/Jul/2023	08:00	15/Jul/2023	18:00	other ckt will be in non auto mode.	PLANNED	Requested	
337	RQ136710	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY_2(PG)- KASHIPUR(UK) (PG)	POWERGRID	D	MAKING MODEL LINES For rectification of S/D nature defects.	09/Jul/2023	08:00	11/Jul/2023	18:00		PLANNED	Requested	
338	RQ136283	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KOTPUTLI- BHIWADI (PG) CKT- 1	POWERGRID	D	For AMP work of Line equipment's	09/Jul/2023	08:00	09/Jul/2023	18:00		PLANNED	Requested	
	RQ136839			AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR- BALLABHGARH (PG) CKT-3	POWERGRID	D	AMP WORK	08/Jul/2023		08/Jul/2023				Requested	
			singrauli_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)- LUCKNOW(UP) (PG) CKT-1	POWERGRID	С	REACTOR ISOLTOR REPLACEMNT	08/Jul/2023	08:00	11/Jul/2023	18:00	UNDER SHUTDOWN	PLANNED	kequestea	
	RQ136022 RQ135919			AC TRANSMISSION LINE CIRCUIT AC	400 KV LUDHIANA- PATIALA (PG) CKT-2 400 KV	POWERGRID	D D	For AMP work Replacement of PG clamp to C-	07/Jul/2023 07/Jul/2023		07/Jul/2023 08/Jul/2023		Kindly Approve		Requested Requested	
				TRANSMISSION LINE CIRCUIT	BHIWANI(PG)- KABULPUR(HV) (PG)	POWERGRID		wedge clamp at tapping point of LILO 400kV Kabulpur.								
343	RQ136306	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEEPALPUR(JHKT)- BAWANA(DV) (PG) CKT-1	POWERGRID	D	Modification of terminal connector for attending the repeated hotspot of line isolator	07/Jul/2023	08:00	07/Jul/2023	18:00		PLANNED	Requested	
344	RQ136760	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AGRA- JAIPUR SOUTH (PG) CKT-2	POWERGRID	D	AMP of Line Reactor and other maintenance work	07/Jul/2023	08:00	07/Jul/2023	18:00		PLANNED	Requested	
345	RQ136829	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHPUR(PG)- PANKI(UP) (PG) CKT 2		D	To connect jumper of 406 89-A isolator after isolator under ADD-CAP	07/Jul/2023	08:00	07/Jul/2023	18:00	S/D of 400 KV Bus- 1at Panki is also required for alignment after	PLANNED	Requested	
346	RQ136021	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV LUDHIANA- PATIALA (PG) CKT-1	POWERGRID	D	For AMP work	06/Jul/2023	09:00	06/Jul/2023		rectification Kindly Approve	PLANNED	Requested	
	RQ135967 RQ136709			AC TRANSMISSION LINE CIRCUIT AC	400 KV BAGHPAT- KAITHAL (PG) CKT-2		D D	FOR AMP WORKS OF LINE EQUIPMENTS For rectification of S/D nature	06/Jul/2023		06/Jul/2023		Kindly Approve		Requested	
				TRANSMISSION LINE CIRCUIT	400 KV BAREILLY_2(PG)- KASHIPUR(UK) (PG) CKT-1	POWERGRID		For rectification of S/D nature defects.	06/Jul/2023		08/Jul/2023			PLANNED	Requested	
	RQ136638			AC TRANSMISSION LINE CIRCUIT	400 KV DULHASTI(NH)- KISHENPUR(PG) (PG) CKT-2	POWERGRID	D	Shutdown required for rectification work of tower no. 166 and 195.	06/Jul/2023		08/Jul/2023		Kindly Approve	PLANNED	Requested	
350	RQ136325	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_C(NP)- KANKROLI(PG) (PG) CKT-1		D	Additional glass disc insertion work	06/Jul/2023	08:00	06/Jul/2023	18:00	During shutdown, AR to be kept off, of 400 kV RAPP C- Kankroli line	PLANNED	Requested	
	RQ136049			AC TRANSMISSION LINE CIRCUIT	400 KV URI_2(NH)- WAGOORA(PG) (PG) CKT-1	POWERGRID	D	SD required to attend shutdown nature defects	05/Jul/2023		06/Jul/2023		Kindly Approve		Requested	
352	RQ136039	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- NEWWANPOH (PG) CKT-3	POWERGRID	D	Shutdown required for rectification work of tower no. 185.	05/Jul/2023	08:00	05/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
353	RQ136040	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- NEWWANPOH (PG) CKT-4	POWERGRID	D	Shutdown required for rectification work of tower no. 185.	05/Jul/2023	08:00	05/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	

	Q136316	OCC_208				POWERGRID							open at working area. rest of the line shall be charged from both side to prevent theft.			
356 R			cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)- MANDOLA(PG) (PG) CKT-2	POWERGRID	С	NHAI DIVERSION WORK 122- 123	05/Jul/2023	08:00	17/Jul/2023	18:00	During outage both side jumper shall be open at working area. rest of the line shall be charged from both side to prevent theft.	PLANNED	Requested	
	Q136642	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- NEWWANPOH (PG) CKT-3		D	AR non auto mode required for rectification work of tower no. 185.	05/Jul/2023	08:00	05/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
357 R	Q136643	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KISHENPUR- NEWWANPOH (PG) CKT-4	POWERGRID	D	AR non auto mode required for rectification work of tower no. 185.	05/Jul/2023	08:00	05/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
358 R	Q136324	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV RAPS_C(NP)- CHITTORGARH(RS) (PG) CKT-1	POWERGRID	D	Additonal glass disc insertion work	05/Jul/2023	08:00	05/Jul/2023	18:00	During shutdown, AR to be kept off, of 400 kV RAPP C-	PLANNED	Requested	
359 R	Q135966	OCC_208	cpcc2_sd	AC TRANSMISSION	400 KV BAGHPAT- KAITHAL (PG) CKT-1		D	FOR AMP WORKS OF LINE EQUIPMENTS	04/Jul/2023	09:00	04/Jul/2023	18:00	Kankroli line Kindly Approve	PLANNED	Requested	
360 R	Q135920	OCC_208	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAHADURGARH(PG)-KABULPUR(HV) (PG) CKT-1	POWERGRID	D	Replacement of PG clamp to C- wedge clamp at tapping point of LILO 400kV Kabulpur.	04/Jul/2023	08:30	05/Jul/2023	17:00		PLANNED	Requested	
		OCC_208		AC TRANSMISSION LINE CIRCUIT	400 KV DADRI(NT)- PANIPAT(BB) (PG) CKT-1	POWERGRID	D	DEFECT RECTIFICATION WORK	04/Jul/2023		04/Jul/2023		Line maintenance work	PLANNED	Requested	
362 R	Q136305	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV DEEPALPUR(JHKT)- BAWANA(DV) (PG) CKT-1	POWERGRID	D	Modification of terminal connector for attending the repeated hotspot of line isolator	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
363 R	Q136847	OCC_208	cpcc3_sd	AC TRANSMISSION	400 KV ORAI(PG)- ORAI(UP) (PG) CKT-		D	Installation of counter weight at Location No.110 and for	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
364 R	Q136864	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	2 400 KV RIHAND(NT)- ALLAHABAD(PG) (PG) CKT-2	POWERGRID	D	AMP work Line and Line Reactor AMP Work	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
365 R	Q136798	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHIWANI- HISSAR (PG) CKT-2	POWERGRID	D	For 400 kV Hisar-Bhiwani-4 & 400 kV Hisar-Bhiwani-2 Bypass arrangement	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
366 R	Q136801	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAHINDERGARH(A PL)-BHIWANI(PG) (PG) CKT-4		D	For 400 kV Hisar-Bhiwani-3 & 400 kV Hisar-Bhiwani-3 Bypass arrangement	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
367 R	Q136279	OCC_208	cpcc1_sd	AC TRANSMISSION	400 KV BHINMAL- KANKROLI (PG) CKT-	POWERGRID	D	For AMP work of Line equipments and non	03/Jul/2023	08:00	03/Jul/2023	18:00		PLANNED	Requested	
368 R	Q136826	OCC_208	cpcc3_sd	AC TRANSMISSION	1 400 KV FATEHPUR(PG)-	POWERGRID	D	switchable Line reactor Isolator replacement at Panki under ADD-CAP	03/Jul/2023	08:00	03/Jul/2023	18:00	S/D of 400 KV Bus- 1at Panki is also	PLANNED	Requested	
				LINE CIRCUIT	PANKI(UP) (PG) CKT- 2	POWERGRID							required for alignment after rectification			
369 R	Q136419	OCC_208	singrauli_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SINGRAULI(NT)- LUCKNOW(UP) (PG) CKT-1	POWERGRID	С	LINE ISOLATOR REPLACEMENT	03/Jul/2023	08:00	06/Jul/2023	18:00	UNDER SHUTDOWN	PLANNED	Requested	
370 R	Q136686	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANPUR- BALLABHGARH (PG) CKT-1	POWERGRID	D	Construction/commissioning of OPGW link and Tapping of OPGW for repeater station under reliable communication scheme.	03/Jul/2023	08:00	03/Jul/2023	18:00		PLANNED	Requested	
371 R	Q136344	OCC_208	cpcc1_sd	AC TRANSMISSION	400 KV BASSI(PG)- HEERAPURA(RS)		D	For Line Side Equipments Overhauling work at Both	03/Jul/2023	08:00	03/Jul/2023	18:00		PLANNED	Requested	
372 R	Q136020	OCC_208	cpcc2_sd	LINE CIRCUIT AC TRANSMISSION	(PG) CKT-1 400 KV AMRITSAR- JALANDHAR (PG)	POWERGRID	D	For AMP work of line	02/Jul/2023	08:00	02/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
373 R	Q135985	OCC_208	cpcc2_sd	LINE CIRCUIT AC TRANSMISSION LINE CIRCUIT	CKT-2 400 KV KISHENPUR- MOGA (PG) CKT-1	POWERGRID	С	For Stringing work on Gantry Tower over Line Equipments and Bus Reactor-3 in Dulhasti- 3 (New) Line Bay.	01/Jul/2023	09:00	10/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
374 R	Q136838	OCC_208	cpcc3_sd	AC TRANSMISSION	400 KV KANPUR- BALLABHGARH (PG)	POWERGRID	D	AMP WORK	01/Jul/2023	08:00	01/Jul/2023	18:00		PLANNED	Requested	
375 R	Q135964	OCC_208	cpcc2_sd	LINE CIRCUIT AC TRANSMISSION LINE CIRCUIT	CKT-2 400 KV DULHASTI(NH)- KISHENPUR(PG) (PG) CKT-2	POWERGRID	D	Shutdown is required to carryout stringing on circuit 2*400KV Dulhast Kishenpur-II is a Double circuit Line but stringing is done on one circuit only. Award has been placed for stringing on Circuit 2. under evacuation of Power from Pakaldul HEP in Chenab Valley HEPs.	01/Jul/2023	08:00	31/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
376 R	Q136278	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANKROLI(PG)- JODHPUR(RS) (PG)	POWERGRID POWERGRID	С	For reconductoring works with Twin HTLS	01/Jul/2023	08:00	31/Jul/2023	18:00		PLANNED	Requested	
377 R	Q135965	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	CKT-1 400 KV DULHASTI(NH)- KISHENPUR(PG)		D	Non auto mode is required to carryout stringing on circuit 2	01/Jul/2023	08:00	31/Jul/2023	18:00	head, Kindly Approve Non auto	PLANNED	Requested	
378 R	Q136309	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	(PG) CKT-2 400 KV BHIWADI- HISSAR (PG) CKT-1	POWERGRID	D	RETROFITMENT OF LINE BAY CVT 'S ALONG WITH CVT JB AT HISAR END AND AMP OF LINE TERMINAL EQUIPMENTS	01/Jul/2023	08:00	01/Jul/2023	22:00	mode	PLANNED	Requested	
379 R	Q136640	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY(PG)- MORADABAD(UP) (PG) CKT-1	POWERGRID	D	Actual S/D required on 26.06.23 for power line crossing of under construction loop out ckt of LILO of 765 KV Ghatampur-Hapur Line at Rampur S/S.	01/Jul/2023	08:00	01/Jul/2023	18:00		PLANNED	Requested	

380	RQ136707	OCC 208	cncc2 sd	AC	400 KV CHAMBA-		D	AR NON - AUTO MODE	01/Jul/2023	08:00	31/Jul/2023	18:00	Under construction	PI ANNED	Requested	
300	nq150707	000_200	cpccz_su	TRANSMISSION LINE CIRCUIT	JALANDHAR (PG) CKT-1	POWERGRID		required for OPGW installation	01/30// 2023	00.00	31/34// 2023	10.00	head, Kindly Approve		nequested	
381	RQ136708	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHAMBA- JALANDHAR (PG) CKT-2	POWERGRID	D	AR NON - AUTO MODE required for OPGW installation	01/Jul/2023	08:00	31/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
382	RQ136865	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BALIA- SOHAWAL (PG) CKT- 1	POWERGRID	D	For Measurement of FSC-I R- Ph LA IR Value due to rise in THRC Value. Actual S/D	01/Jul/2023	08:00	01/Jul/2023	18:00	Арргоче	PLANNED	Requested	
383	RQ136867	OCC 208	cpcc3 sd	AC	400 KV	POWERGRID	D	required on 23.06.2023 For Fixing safety Plate in R-Ph	01/Jul/2023	08:00	01/Jul/2023	18:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	LUCKNOW_1- SHAHJAHANPUR		-	Wave Trap (As per observation of Regional SIR Audit) and	,,		,,				,	
					(PG) CKT-2	POWERGRID		AMP of Line Equipment								
384	RQ136799	OCC_208	cpcc1_sd	AC TRANSMISSION	400 KV BHIWANI- HISSAR (PG) CKT-3		D	For 400 kV Hisar-Bhiwani-4 & 400 kV Hisar-Bhiwani-2 Bypass	01/Jul/2023	08:00	01/Jul/2023	18:00		PLANNED	Requested	
385	RQ136800	OCC_208	cpcc1_sd	AC CIRCUIT	400 KV	POWERGRID	D	arrangement For 400 kV Hisar-Bhiwani-3 &	01/Jul/2023	08:00	01/Jul/2023	18:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	MAHINDERGARH(A PL)-BHIWANI(PG)			400 kV Hisar-Bhiwani-3 Bypass arrangement								
296	RQ135941	OCC 208	eldere ed	AC	(PG) CKT-3 400 KV PHAGI-	POWERGRID	D	Half Yearly maintenance work	28/Jul/2023	08:00	28/Jul/2023	19:00		DIANNED	Requested	
300	110133341	000_200	Jacis_su	TRANSMISSION LINE CIRCUIT	AJMER (RS) CKT-2	RRVPNL		of associated equipments	20/30// 2023	00.00	20/34//2023	10.00			nequested	
387	RQ136330	OCC_208	cpcc1_sd	AC TRANSMISSION	400 KV BIKANER(RS)-		D	Overhead crossing by u/c of 765kV Bhadla 2-Sikar 2 TLC	28/Jul/2023	08:00	29/Jul/2023	18:00		PLANNED	Requested	
				LINE CIRCUIT	DEEDWANA(MTS) (RS) CKT-1	RRVPNL		(Part-2) at AP 81-82								
388	RQ135940	OCC_208	sldcrs_sd	AC TRANSMISSION	400 KV PHAGI- AJMER (RS) CKT-1	20145	D	Half Yearly maintenance work of associated equipments	27/Jul/2023	08:00	27/Jul/2023	18:00		PLANNED	Requested	
389	RQ136320	OCC_208	cpcc1_sd	AC	400 KV	RRVPNL	D	PRV MODIFICATION WORK	22/Jul/2023	08:00	22/Jul/2023	18:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	BIKANER(RS)- SIKAR(PG) (RS) CKT- 2	RRVPNL										
390	RQ136319	OCC_208	cpcc1_sd	AC TRANSMISSION	400 KV BIKANER(RS)-	IVL	D	PRV MODIFICATION WORK	21/Jul/2023	08:00	21/Jul/2023	18:00		PLANNED	Requested	
L				LINE CIRCUIT	SIKAR(PG) (RS) CKT- 1	RRVPNL										
391	RQ135961	OCC_208	sldcrs_sd	AC TRANSMISSION	400 KV ANTA(RS)- KAWAI SCTPS(APR)		D	HALF YEARLY MAINTENANCE	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
202	BO130007	000 200	cldore	LINE CIRCUIT	(RS) CKT-2	RRVPNL	С	Schedule of work to be done	17/lul/2022	08:00	21/1-1/2022	18:00		DIANNER	Requested	
392	RQ136607	JULU_208	siacis_sa	AC TRANSMISSION LINE CIRCUIT	400 KV SURATGARH(RVUN) RATANGARH(RS)		'	by M/S Man Structurals Ltd. :- 1. Erection work of D+6 Tower	17/Jul/2023	06:00	31/Jul/2023	18:00		FLANNED	nequestea	
					(RS) CKT-2			with location number 62. 2.Erection work of D+9 Tower								
								with location number 65. 3.Dismantle work of existing								
								towers with no. 62, 63, 64 and 65								
								Old conductor dismantle and clamping. 5. Complete								
								stringing work of six sections. 6. Work of jumpers of all								
								towers. 7. Complete stringing work of all towers								
								throughout.								
207	BO120000	000 200	older - '	AC.	400 KV	RRVPNL	-	For Quarterly (Ind.)	17/11/225-	08:00	17/11/202	10:00		DI ANIN'S	Pogus at 1	
393	RQ136609	JULC_208	siacrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HINDAUN(RS)- CHHABRA(RVUN)		D	For Quarterly/Half Yearly maintenance work	17/Jul/2023	U8:UU	17/Jul/2023	18:00		PLANNED	Requested	
394	RQ135945	OCC 208	sldcrs sd	AC	(RS) CKT-1 400 KV	RRVPNL	D	Planned maintenance	15/Jul/2023	08:00	15/Jul/2023	18:00		PLANNED	Requested	
			1_1-1-	TRANSMISSION LINE CIRCUIT	BARMER(RS)- RAJWEST(RW) (RS)				,		,,====					
395	RQ135942	OCC_208	sldcrs_sd	AC	CKT-1 400 KV	RRVPNL	D	Planned maintenance	14/Jul/2023	08:00	14/Jul/2023	18:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	RAJWEST(RW)- JODHPUR (RS) CKT-	RRVPNL										
396	RQ136331	OCC_208	cpcc1_sd	AC TRANSMISSION	400 KV BIKANER- MERTA (RS) CKT-1	INDALINE	D	Overhead crossing by u/c of 765kV Bhadla 2-Sikar 2 TLC	14/Jul/2023	08:00	15/Jul/2023	18:00		PLANNED	Requested	
397	RQ136616	OCC_ 208	sldcrs_sd	LINE CIRCUIT	400 KV	RRVPNL	С	(Part-2) at AP 51-52 1. Calibration of line metering	14/Jul/2023	08:00	15/Jul/2023	18:00		PLANNED	Requested	
			1_1=	TRANSMISSION LINE CIRCUIT	CHHABRA(RVUN)- KAWAI SCTPS(APR)			CT's and Energy meters. 2.Annual maintenance and	,		,,====					
L					(RS) CKT-1	RRVPNL		testing of Line/Bay equipments.								
398	RQ136600	OCC_208	sldcrs_sd	AC TRANSMISSION	400 KV BHADLA- RAMGARH (RS) CKT-		D	Quarterly/ Half Yearly/ Yearly Maintenance work at 400KV	13/Jul/2023	16:00	13/Jul/2023	23:00		PLANNED	Requested	
399	RQ135930	OCC_208	sldcrs_sd	AC TRANSMISSION	400 KV RAJWEST(RW)-	RRVPNL	D	GSS, Bhadla Planned maintenance at both	13/Jul/2023	08:00	13/Jul/2023	18:00		PLANNED	Requested	
				LINE CIRCUIT	KANKANI (RS) CKT-	RRVPNL		end								
400	RQ136599	OCC_208	sldcrs_sd	AC TRANSMISSION	400 KV BHADLA- RAMGARH (RS) CKT-		D	Quarterly/ Half Yearly/ Yearly Maintenance work at 400KV	12/Jul/2023	16:00	12/Jul/2023	23:00		PLANNED	Requested	
401	RQ135933	OCC_208	sldcrs_sd	AC	1 400 KV CHHABRA-	RRVPNL	С	GSS, Bhadla Annual maintenance for	12/Jul/2023	08:00	13/Jul/2023	18:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	CHHABRA SCTPS (RS) CKT-2			tightening of Bus equipments & Relay testing								
402	RQ135960	OCC_208	sldcrs_sd	AC	400 KV ANTA(RS)-	RRVPNL	D	HALF YEARLY MAINTENANCE	11/Jul/2023	08:00	11/Jul/2023	18:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	(RS) CKT-1	DD//DN/										
403	RQ136619	OCC_208	sldcrs_sd	AC TRANSMISSION	400 KV JODHPUR- KANKANI (RS) CKT-	RRVPNL	D	Preventive maintenance & Testing of bay and equipments	11/Jul/2023	08:00	11/Jul/2023	18:00		PLANNED	Requested	
404	RQ136601	OCC: 208	slders sd	LINE CIRCUIT	2 400 KV BHADLA-	RRVPNL	D	Quarterly/ Half Yearly/ Yearly	10/Jul/2023	16:00	11/Jul/2023	23:00		PLANNED	Requested	
704		500_200	uc.3_3U	TRANSMISSION LINE CIRCUIT	JODHPUR (RS) CKT-			Maintenance work at 400KV GSS, Bhadla & its 50MVAR Line	10, 101, 2023		±=/301/2023	_5.00		. SavidED	cquesteu	
405	RQ135963	OCC_208	sldcrs_sd	AC CINCOTT	400 KV ANTA-	RRVPNL	D	Reactor HALF YEARLY MAINTENANCE	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	KALISINDH (RS) CKT- 2	RRVPNL									·	
406	RQ136603	OCC_208	sldcrs_sd	AC TRANSMISSION	400 KV MERTA- KANKANI (RS) CKT-		D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS at both	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
407	RQ136596	OCC_208	sldcrs_sd	AC	1 400 KV	RRVPNL	С	Shutdown required for shifting	10/Jul/2023	08:00	17/Jul/2023	18:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	DEEDWANA(MTS)			of T/L works due to construction of Nataional								
1		1			(RS) CKT-1			Highway Amritsar-Jamnagar T/L under Bharatmala project								
						l	l	of PIU - Hanumangarh.						1		

408	RQ135932	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV CHHABRA- CHHABRA SCTPS (RS) CKT-1	RRVPNL	C	Annual maintenance for tightening of Bus equipments & Relay testing	10/Jul/2023	08:00	11/Jul/2023	18:00		PLANNED	Requested	
409	RQ136267	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AKAL- BARMER (RS) CKT-1		D	Overhead crossing I. e. Stringing work of 400kV D/C Ramgarh II (Fatehgarh-III) — Fatehgarh II transmission Line	08/Jul/2023	07:00	11/Jul/2023	19:00	Keeping in View of safety aspects and difficulty in power line crossing work in night hours is, in night hours theft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any damage to RRVPNL line, shutdown is required in day hours only.	PLANNED	Requested	
410	RQ136602	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA- MERTA (RS) CKT-1	RRVPNL	D	Quarterly/ Half Yearly/ Yearly Maintenance work at 400KV GSS, Bhadla & its 50MVAR Line	07/Jul/2023	16:00	08/Jul/2023	23:00		PLANNED	Requested	
411	RQ135962	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANTA- KALISINDH (RS) CKT- 1	RRVPNL	D	Reactor HALF YEARLY MAINTENANCE	07/Jul/2023	08:00	07/Jul/2023	18:00		PLANNED	Requested	
412	RQ136618	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV JODHPUR- KANKANI (RS) CKT- 1	RRVPNL	D	Preventive maintenance & Testing of bay and equipments	07/Jul/2023	08:00	07/Jul/2023	18:00		PLANNED	Requested	
413	RQ136608	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV HEERAPURA HINDAUN (RS) CKT- 1	RRVPNL	D	For Quarterly/Half Yearly maintenance work	06/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
414	RQ136615	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER- MERTA (RS) CKT-1		D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS & 50MVAR line Reactor-at Merta	06/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
415	RQ136614	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BIKANER- BHADLA (RS) CKT-1	RRVPNL	D	Quarterly/ Half Yearly/ Yearly Maintenance work at 400KV GSS, Bhadla & its 50MVAR Line	05/Jul/2023	16:00	06/Jul/2023	23:00		PLANNED	Requested	
416	RQ135959	OCC_208	sldcrs_sd		400 KV AJMER- BHILWARA (RS) CKT	RRVPNL	D	Reactor Routine Maintenance of Bay & Line	05/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
417	RQ136594	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV KANKANI- JAISALMER (RS) CKT	RRVPNL RRVPNL	D	Preventive maintenance & Testing of bay and equipments	05/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
418	RQ135935	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV ANTA- CHHABRA SCTPS (RS) CKT-2	RRVPNL	С	Annual maintenance for tightening of Bus equipments & Relay testing	05/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
419	RQ136611	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MERTA- HEERAPURA (RS) CKT-1	RRVPNL	D	For Quarterly/Half Yearly maintenance work	05/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
420	RQ136593	OCC_208	sldcrs_sd	AC	400 KV MERTA- RATANGARH (RS) CKT-1		D	Maintenance work of bay equipments , isolators and testing work of bay	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
421	RQ136604	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AKAL- KANKANI (RS) CKT-	RRVPNL	D	equipments. at both end Preventive maintenance & Testing of bay and equipments	03/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
422	RQ135934	OCC_208	sldcrs_sd	AC	400 KV ANTA- CHHABRA SCTPS (RS) CKT-1	RRVPNL	С	Annual maintenance for tightening of Bus equipments & Relay testing	03/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
423	RQ136606	OCC_208	slders_sd	AC TRANSMISSION LINE CIRCUIT	400 KV SURATGARH(RVUN) RATAMGARH(RS) (RS) CKT-1		c	Schedule of work to be done by M/S Man Structurals Ltd. :- 1. Frection work of D+6 Tower with location number 64. 2. Erection work of D+0 Tower with location number 64. 3. Erection work of D+0 Tower with location number 64. 3. Erection work of D+0 Tower with location number 62. 4. Dismantle work of existing towers with no. 62, 63, 64 and 65. 5. Old conductor dismantle and clamping. 6. Complete stringing work of jumpers of all towers. 7. Work of jumpers of all towers. 8. Complete stringing work of all towers throughout.	01/Jul/2023	08:00	16/Jul/2023	18:00		PLANNED	Requested	
424	RQ136656	OCC_208	cpcc3_sd	AC TRANSMISSION	400 KV BAREILLY- MEERUT (PG) CKT-2	RRVPNL	D	Power line crossing of under construction loop out ckt of	25/Jul/2023	08:00	25/Jul/2023	18:00		PLANNED	Requested	
425	012665	000 225	cncc3 - '	LINE CIRCUIT	400 KV DADE*****	POWERLINK, POWERGRID	-	LILO of 765 KV Ghatampur- Hapur Line at Rampur S/S	2E/II/222-	08:00	25/11/2057	10:00		DI ANIA/TO	Book	
425	RQ136655	UCC_208	cpccs_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY- MEERUT (PG) CKT-1	POWERLINK, POWERGRID	D	Power line crossing of under construction loop out ckt of LILO of 765 KV Ghatampur- Hapur Line at Rampur S/S	25/Jul/2023	08:00	25/Jul/2023	18:00		PLANNED	Requested	
	RQ135839			AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY- MEERUT (PG) CKT-2		D	Power line crossing work for under construction of Loop Out CKT of LILO of 765kV GHatampur-Hapur line at 765/400/220kV GIS SS Rampur	25/Jul/2023		25/Jul/2023				Requested	
	RQ135838			AC TRANSMISSION LINE CIRCUIT	400 KV BAREILLY- MEERUT (PG) CKT-1	POWERLINK, POWERGRID	D	Power line crossing work for under construction of Loop Out CKT of LILO of 765kV GHatampur-Hapur line at 765/400/220kV GIS SS Rampur	25/Jul/2023		25/Jul/2023				Requested	
	RQ136291			AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(PG)- FATEHGARH POOLING(FBTL) (FBTL) CKT-2 400 KV	POWERGRID, FBTL	D	For arching horn installation work in Line isolator/earth switch by agency M/s Linxon	20/Jul/2023 10/Jul/2023		21/Jul/2023 10/Jul/2023		Other Circuit in Non Auto Mode		Requested Requested	
				TRANSMISSION LINE CIRCUIT	BHADLA(PG)- BHADLA_2 (PG) (FBTL) CKT-2	POWERGRID, FBTL		equipment's								

430	RQ136281	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV BHADLA(PG)- BHADLA_2 (PG) (FBTL) CKT-1	POWERGRID,	D	For AMP work of Line equipment's	09/Jul/2023	17:00	09/Jul/2023	18:00		PLANNED	Requested	
431	RQ136290	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV FATEHGARH_II(PG)- FATEHGARH POOLING(FBTL)	POWERGRID,	D	For arching horn installation work in Line isolator/earth switch by agency M/s Linxon	08/Jul/2023	17:00	09/Jul/2023	23:00	Other Circuit in Non Auto Mode	PLANNED	Requested	
422	RQ136555	000 200	aldaha ad	46	(FBTL) CKT-1	FBTL		T	20/1-1/2022	00.00	20/11/2022	10.00		DIANNED	D	
			_	AC TRANSMISSION LINE CIRCUIT	400 KV NEEMRANA(PG)- DHANODA(HV) (GPTL) CKT-2	GPTL	D	To verify BI, BOM & DE protection signals in SAS.	20/Jul/2023	09:00	20/Jul/2023	18:00		PLANNED	Requested	
433	RQ136554	OCC_208	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV NEEMRANA(PG)- DHANODA(HV) (GPTL) CKT-1	GPTL	D	To verify BI, BOM & Department of the protection signals in SAS.	18/Jul/2023	09:00	18/Jul/2023	18:00		PLANNED	Requested	
434	RQ136053	OCC_208	cpcc2_sd	AC	400 KV	GI IL	D	Jumper tightening of	18/Jul/2023	09:00	18/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
425	RQ136556	000 200	oldobr od	TRANSMISSION LINE CIRCUIT	NEWWANPOH(PG)- BAGLIHAR(JK) (JKSPDCL) CKT-1 400 KV	POWERGRID,J KSPDCL	D	vulnerable towers in Pirpanjal Section	14/Jul/2023	00:00	14/Jul/2023	19:00		DIANNED	Requested	
433	NQ130330	000_208	siuciii_su	TRANSMISSION LINE CIRCUIT	MAHINDERGARH(A PL)-DHANODA(HV) (ATIL) CKT-1	ATIL	D	To verify BI, BOM & Dry protection signals in SAS.	14/30// 2025	05.00	14/30//2023	18.00		PLANNED	Requested	
436	RQ136557	OCC_208	sldchr_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MAHINDERGARH(A PL)-DHANODA(HV) (ATIL) CKT-2	ATIL	D	To verify BI, BOM & Dry protection signals in SAS.	10/Jul/2023	09:00	10/Jul/2023	18:00		PLANNED	Requested	
437	RQ136052	OCC_208	cpcc2_sd	AC TRANSMISSION	400 KV AMARGARH(NRSS	Alle	D	Jumper tightening of vulnerable tension towers	12/Jul/2023	09:00	12/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
				LINE CIRCUIT	XXIX)- WAGOORA(PG)	POWERGRID,										
		007			(NRSS XXIX) CKT-2	NRSS XXIX			44.00.00	00.07	40.50	40.0-	10. H. (
438	RQ136051	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV AMARGARH(NRSS XXIX)- WAGOORA(PG)	POWERGRID,	D	Jumper tightening of vulnerable tension towers	11/Jul/2023	U9:00	11/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
439	RQ136050	OCC 208	cpcc2 sd	AC	(NRSS XXIX) CKT-1 400 KV URI_1(NH)-	NRSS XXIX	D	Jumper tightening of	04/Jul/2023	09:00	04/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	AMARGARH(NRSS XXIX) (NRSS XXIX) CKT-1	POWERGRID, NRSS XXIX		vulnerable tension towers								
440	RQ136308	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MANDOLA(PG)- MAHARANIBAGH(P G) (DTL) CKT-1	POWERGRID,	D	Attending oil leakges from all ct of old wsi make ct of main bay 404 by DTL	09/Jul/2023	08:00	09/Jul/2023	14:30		PLANNED	Requested	
441	RQ136307	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	400 KV MANDOLA(PG)- MAHARANIBAGH(P G) (DTL) CKT-1		D	Attending oil leakges from all ct of old wsi make ct of main bay 404 by DTL	06/Jul/2023	08:00	06/Jul/2023	14:30		PLANNED	Requested	
442	RQ136595	OCC_208	sldcrs_sd	AC	400 KV	012	D	Quarterly/ Half Yearly/ Yearly	03/Jul/2023	16:00	04/Jul/2023	23:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	BIKANER(PG)- BHADLA(RS) (PG) CKT-1	POWERGRID, RRVPNL		Maintenance work at 400KV GSS, Bhadla & its 50 MVAR Line Reactor at Bhadla								
443	RQ136764	OCC_208	cpcc2_sd	AC TRANSMISSION	400 KV PATIALA(PG)-		D	Shutdown required along with AR non auto mode of 400kV	02/Jul/2023	08:00	02/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
				LINE CIRCUIT	PATRAN(PATR)			Patiala-Patran-I for								
					(PATRAN) CKT-2	POWERGRID, PATRAN		rectification of shutdown nature defects								
444	RQ136763	OCC_208	cpcc2_sd	AC TRANSMISSION	400 KV PATIALA(PG)-		D	Shutdown required along with AR non auto mode of 400kV	01/Jul/2023	08:00	01/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
				LINE CIRCUIT	PATRAN(PATR) (PATRAN) CKT-1	POWERGRID, PATRAN	_	Patiala-Patran-II for rectification of shutdown nature defects		00.0-	45.5.5	10.5-				
	RQ136582			AC TRANSMISSION LINE CIRCUIT	400 KV BHIWANI(BB)- RAJPURA(PS) (PG) CKT-1	POWERGRID, BBMB	С	Erection of towers, String & sagging of line between Tno.640-641 deposit work of NHAI	01/Jul/2023		15/Jul/2023				Requested	
446	RQ136033	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	400 KV PARBATI_3(NH)- PARBATI POOLING BANALA(PG) (PKTCL) CKT-1	PKTCL,POWE RGRID	D	AR NON - AUTO MODE required for OPGW installation works	01/Jul/2023	07:00	31/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
447	RQ136705	OCC_208	cpcc3_sd	BUS	400KV BUS 1 AT KANPUR(PG)		D	To open jumper of 415-89 isolator for isolator replacement under ADDCAP	31/Jul/2023	15:00	31/Jul/2023	18:00		PLANNED	Requested	
448	RQ136437	OCC_208	cpcc1_sd	BUS	400KV BUS 4 AT	POWERGRID	С	For connection of internal	29/Jul/2023	07:00	30/Jul/2023	20:00		PLANNED	Requested	
					KURUKSHETRA(PG)	POWERGRID		conductor of new ICT-3 GIS bay with Existing GIS Bus-4 & Busbar Relay Testing after HV test								
449	RQ136454	OCC_208	cpcc1_sd	BUS	400KV BUS 4 AT MANDOLA(PG)	POWERGRID	D	For new Busbar Protection testing	28/Jul/2023	08:00	28/Jul/2023	18:00		PLANNED	Requested	
	RQ136414			BUS	400KV BUS 2 AT BALLABHGARH(PG)	POWERGRID	D	S/D Required for Bus Bar protection testing work.	28/Jul/2023		28/Jul/2023			PLANNED	Requested	
451	RQ136703	OCC_208	cpcc3_sd	BUS	400KV BUS 1 AT KANPUR(PG)	POWERGRID	D	To open jumper of 415-89 isolator for isolator replacement under ADDCAP	27/Jul/2023	08:00	27/Jul/2023	11:00		PLANNED	Requested	
452	RQ136436	OCC_208	cpcc1_sd	BUS	400KV BUS 3 AT KURUKSHETRA(PG)	OWENGRID	С	For connection of internal conductor of new ICT-3 GIS bay with Existing GIS Bus-3 & Busbar Relay Testing after HV	27/Jul/2023	07:00	28/Jul/2023	20:00		PLANNED	Requested	
452	RQ136452	OCC 308	cncc1 sd	BUS	400KV BUS 2 AT	POWERGRID	D	test For new Busbar Protection	26/Jul/2023	08:00	26/Jul/2023	18:00		PLANNED	Requested	
	RQ136412			BUS	MANDOLA(PG) 400KV BUS 4 AT	POWERGRID	С	testing S/D Required for Bus Bar	26/Jul/2023 26/Jul/2023		28/Jul/2023 28/Jul/2023				Requested	
	-				BALLABHGARH(PG)	POWERGRID		protection retrofitment work.								
455	RQ136451	OCC_208	cpcc1_sd	BUS	400KV BUS 1 AT MANDOLA(PG)	POWERGRID	D	For new Busbar Protection testing	25/Jul/2023	08:00	25/Jul/2023	18:00		PLANNED	Requested	
456	RQ136453	OCC_208	cpcc1_sd	BUS	400KV BUS 3 AT	POWERGRID	D	For new Busbar Protection	23/Jul/2023	08:00	23/Jul/2023	18:00		PLANNED	Requested	
457	RQ136410	OCC_208	cpcc1_sd	BUS	MANDOLA(PG) 400KV BUS 2 AT BALLABHGARH(PG)	- OWENGKID	С	s/D Required for Bus Bar protection retrofitment work.	23/Jul/2023	08:00	25/Jul/2023	18:00		PLANNED	Requested	
458	RQ136486	OCC_208	cpcc1_sd	BUS	400 KV FATEHGARH-II(PG) -	POWERGRID	D	Construction works of Statcom- 1 and their commissioning	21/Jul/2023	17:00	28/Jul/2023	23:00		PLANNED	Requested	
459	RQ136494	OCC_208	cpcc1_sd	BUS	8US 2 400 KV	POWERGRID	D	works for bus bar testing. For erection work of bay	21/Jul/2023	17:00	28/Jul/2023	23:00		PLANNED	Requested	
					FATEHGARH-II(PG) - BUS 2	POWERGRID		extension of 400 kV Jackson line bays								

460	RQ136488	OCC_208	cpcc1_sd	BUS	400 KV FATEHGARH-II(PG) - BUS 4		D	construction related works of Phase II, STATCOM-2 erection works, Bus Bar, LBB Relay	20/Jul/2023	17:00	28/Jul/2023	23:00		PLANNED	Requested	
461	RQ136413	OCC_208	cpcc1_sd	BUS	400KV BUS 1 AT	POWERGRID	D	Testing for Ph-II Commissionming work S/D Required for Bus Bar	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
462	RQ136675	OCC 208	cncc3 cd	BUS	BALLABHGARH(PG)	POWERGRID	D	protection testing work. AMP works	17/Jul/2023	08:00	17/Jul/2023	19:00		DIANNED	Requested	
					BAREILLY_2(PG) - BUS 2	POWERGRID										
	RQ136408			BUS	400KV BUS 2 AT CHITTORGARH(PG)	POWERGRID	С	For Bay Extension work by BHEL under TBCB at Chittorgarh SS	17/Jul/2023		22/Jul/2023				Requested	
464	RQ136430	OCC_208	cpcc1_sd	BUS	400KV BUS 4 AT KURUKSHETRA(PG)	POWERGRID	С	For HV Test of GIS Extension bay of Bus-4	17/Jul/2023	07:00	18/Jul/2023	20:00		PLANNED	Requested	
465	RQ136411	OCC_208	cpcc1_sd	BUS	400KV BUS 3 AT BALLABHGARH(PG)	POWERGRID	С	S/D Required for Bus Bar protection retrofitment work.	16/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
466	RQ136429	OCC_208	cpcc1_sd	BUS	400KV BUS 3 AT KURUKSHETRA(PG)	POWERGRID	С	For HV Test of GIS Extension bay of Bus-3	15/Jul/2023	07:00	16/Jul/2023	20:00		PLANNED	Requested	
467	RQ136058	OCC_208	cpcc2_sd	BUS	400KV BUS 2 AT WAGOORA(PG)	POWERGRID	D	To provide sufficient clearance for Erection of IPS tubes of 403 Bay.	14/Jul/2023	09:00	14/Jul/2023	17:00	Kindly approve under construction activity	PLANNED	Requested	
468	RQ136442	OCC_208	cpcc3_sd	BUS	400KV BUS 2 AT	POWERGRID	D	AMP works	14/Jul/2023	08:00	14/Jul/2023	18:00	accepty	PLANNED	Requested	
469	RQ136441	OCC_208	cpcc3_sd	BUS	FATEHPUR(PG) 400KV BUS 1 AT	POWERGRID	D	AMP works	13/Jul/2023	08:00	13/Jul/2023	18:00		PLANNED	Requested	
470	RQ136674	OCC_208	cpcc3_sd	BUS	FATEHPUR(PG) 400 KV	POWERGRID	D	AMP works	13/Jul/2023	08:00	13/Jul/2023	18:00		PLANNED	Requested	
					BAREILLY_2(PG) - BUS 1	POWERGRID										
471	RQ136409	UCC_208	cpcc1_sd	BUS	400KV BUS 1 AT BALLABHGARH(PG)	DOM/EDCS:S	С	S/D Required for Bus Bar protection retrofitment work.	13/Jul/2023	U8:00	15/Jul/2023	18:00		PLANNED	Requested	
472	RQ136459	OCC_208	cpcc1_sd	BUS	400KV BUS 2 AT JHATIKARA(PG)	POWERGRID POWERGRID	С	ISOLATOR REPLACEMENT OF	13/Jul/2023	08:00	15/Jul/2023	18:00		PLANNED	Requested	
473	RQ136416	OCC_208	cpcc1_sd	BUS	400KV BUS 2 AT BAHADURGARH(PG		D	FOR AMP WORK	12/Jul/2023	08:00	12/Jul/2023	18:00		PLANNED	Requested	
474	RQ136493	OCC_208	cpcc1_sd	BUS	400 KV	POWERGRID	D	Construction works of	11/Jul/2023	17:00	20/Jul/2023	23:00		PLANNED	Requested	
					FATEHGARH-II(PG) - BUS 2			Fatehgarh-3 double ckt line and their commissioning works								
475	RQ136415	OCC_208	cpcc1_sd	BUS	400KV BUS 1 AT	POWERGRID	D	for bus bar testing. FOR AMP WORK	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
476	RQ136407	000 300		BUS	BAHADURGARH(PG) 400KV BUS 1 AT	POWERGRID		For Day Subsection would be	10/Jul/2023	00.00	15/Jul/2023	10.00		PLANNED	Danis and a	
470	KQ130407	OCC_208	cpcc1_su	B03	CHITTORGARH(PG)	POWERGRID	С	For Bay Extension work by BHEL under TBCB at Chittorgarh SS	10/301/2025	08.00	13/101/2023	10.00		PLANNED	Requested	
477	RQ136460	OCC_208	cpcc1_sd	BUS	400KV BUS 4 AT JHATIKARA(PG)	POWERGRID	С	ISOLATOR REPLACEMENT OF 415-89B	10/Jul/2023	08:00	12/Jul/2023	18:00		PLANNED	Requested	
478	RQ136485	OCC_208	cpcc1_sd	BUS	400 KV FATEHGARH-II(PG) -		D	Construction related works of Phase II, Busbar, LBB	08/Jul/2023	17:00	15/Jul/2023	23:00		PLANNED	Requested	
					BUS 1	POWERGRID		Testing,under Phase 2 commissioning works								
479	RQ136420	OCC_208	cpcc1_sd	BUS	400KV BUS 3 AT KURUKSHETRA(PG)		С	For Erection of interface module for connection of ICT- 3 main bay with existing Bus-4. After erection, internal conductor link will be removed and corona shield applied on	08/Jul/2023	07:00	14/Jul/2023	20:00		PLANNED	Requested	
						POWERGRID		both ends to isolate existing & new GIS. Internal conductor will be connected after HV test.								
480	RQ136698	OCC_208	cpcc3_sd	BUS	400KV BUS 2 AT KANPUR(PG)		D	'To Close jumper of 406-89 isolator after isolator	07/Jul/2023	15:00	07/Jul/2023	18:00		PLANNED	Requested	
404	DO126407	000 200		DUIC	400 KV	POWERGRID		replacement under ADDCAP	06/Jul/2023	17.00	12/11/2022	22-00		DIANNED	Danis and a	
481	RQ136487	OCC_208	cpcc1_sa	BUS	FATEHGARH-II(PG) - BUS 3		D	For erection of LV side Jack bus of 765/400 kV ICT-5 & ICT- 6, Busbar, LBB Testing of ICT-6 under Phase 2 commissioning	06/Jul/2023	17:00	13/Jul/2023	23:00		PLANNED	Requested	
482	RQ136403	OCC_208	cpcc1_sd	BUS	400KV BUS 2 AT	POWERGRID	D	works Bus bar Integration Work	06/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
483	RQ136400	OCC_208	cpcc1_sd	BUS	NEEMRANA(PG) 400 KV BHADLA_2	POWERGRID	D	BUS SECTIONALIZER	05/Jul/2023	17:00	08/Jul/2023	23:00		PLANNED	Requested	
484	RQ136677	OCC_208	cpcc3_sd	BUS	(PG) - BUS 2 400KV BUS 1 AT	POWERGRID	D	COMMISSIONING WORKS AMP works	05/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
485	RQ136689	OCC_208	cpcc3_sd	BUS	BAREILLY(PG) 400KV BUS 1 AT KANPUR(PG)	POWERGRID	D	to facilititate un-installation of Siemens CB and CT from bay-	05/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
486	RQ136402	OCC_208	cpcc1_sd	BUS	400KV BUS 1 AT	POWERGRID	D	424 Bus bar Integration Work	05/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
487	RQ136056	OCC_208	cpcc2_sd	BUS	NEEMRANA(PG) 400KV BUS 1 AT	POWERGRID	D	Bus-1 Droppers will be	04/Jul/2023	09:00	04/Jul/2023	17:00	Under construction	PLANNED	Requested	
					WAGOORA(PG)	POWERGRID		removed for Isolator retrofitting as the main CB is under retrofitting and ICT-2 is charged via TBC					head, Kindly Approve			
488	RQ136855	OCC_208	cpcc3_sd	BUS	400KV BUS 2 AT SHAHJAHANPUR(P		D	Changing the direction of grading ring in 400 KV Bus-2	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
489	RQ136057	OCC_208	cpcc2_sd	BUS	G) 400KV BUS 2 AT	POWERGRID	D	Insulator To provide sufficient clearance	03/Jul/2023	09:00	03/Jul/2023	18:00	Under construction	PLANNED	Requested	
					WAGOORA(PG)			for dismantling the IPS tubes for CB Retrofitting and					head, Kindly Approve			
								correspondingly Bus-2 Droppers will be removed for Isolator retrofitting.								
490	RQ136690	OCC_208	cpcc3_sd	BUS	400KV BUS 2 AT KANPUR(PG)	POWERGRID	D	'To open jumper of 406-89 isolator for isolator	03/Jul/2023	08:00	03/Jul/2023	11:00		PLANNED	Requested	
	DO1255-	000 277		DUIS	400107 5115 : :=	POWERGRID		replacement under ADDCAP	02/: 1/	00.00	02/11/22	10.00		DI 4***		
491	RQ136854	UCC_208	cpcc3_sd	BUS	400KV BUS 1 AT SHAHJAHANPUR(P	POWERGRID	D	Changing the direction of grading ring in 400 KV Bus-1 Insulator	03/Jul/2023	U8:00	03/Jul/2023	18:00		PLANNED	Requested	
492	RQ136399	OCC_208	cpcc1_sd	BUS	400 KV BHADLA_2 (PG) - BUS 1	POWERGRID	D	BUS SECTIONALIZER COMMISSIONING WORKS	01/Jul/2023	17:00	04/Jul/2023	23:00		PLANNED	Requested	
493	RQ136492	OCC_208	cpcc1_sd	BUS	400 KV FATEHGARH-II(PG) -		D	For erection work of bay extension of 400 kV Jackson	01/Jul/2023	17:00	10/Jul/2023	23:00		PLANNED	Requested	
					BUS 1	POWERGRID		line bays								

494	RQ136421	OCC_208	cpcc1_sd	BUS	400KV BUS 4 AT KURUKSHETRA(PG)		С	For Erection of interface module for connection of ICT-	01/Jul/2023	07:00	07/Jul/2023	20:00		PLANNED	Requested	
					KOKOKSHETKA(FG)			3 main bay with existing Bus-4.								
								After erection, internal								
								conductor link will be removed and corona shield applied on								
								both ends to isolate existing &								
								new GIS. Internal conductor								
								will be connected after HV test.								
						POWERGRID										
495	RQ136109	OCC_208	stuup_sd	BUS	400KV BUS 3 AT LUCKNOW(UP)		D	* Upgradation of Bus-Bar Protection Panel from	30/Jul/2023	09:00	30/Jul/2023	18:00		PLANNED	Requested	
					,			Electromechanical type to								
								Numerical Type (Connection								
						UPPTCL		of CT Bus-Bar Protecio								
496	RQ135910	OCC_208	stuup_sd	BUS	400KV BUS 2 AT		С	* For Upgradation of Bus-Bar	24/Jul/2023	09:00	31/Jul/2023	18:00		PLANNED	Requested	
					LUCKNOW(UP)			Protection Panel from Electromechanical type to								
								Numerical Type at 400 KV Sub-								
497	RQ135850	OCC 208	stuun sd	BUS	400KV BUS 2 AT	UPPTCL	С	* For replacement of	17/Jul/2023	08:00	21/Jul/2023	18:00		PLANNED	Requested	
					SULTANPUR(UP)			pantograph isolator of	,,		,,				.,	
						UPPTCL		315MVA ICT-IV at 400KV S/s Sultanpur								
498	RQ135849	OCC_208	stuup_sd	BUS	400KV BUS 1 AT		С	* For replacement of	12/Jul/2023	08:00	16/Jul/2023	18:00		PLANNED	Requested	
					SULTANPUR(UP)			pantograph isolator of 315MVA ICT-IV at 400KV S/s								
						UPPTCL		Sultanpur								
499	RQ135858	OCC_208	stuup_sd	BUS	400KV BUS 1 AT SARNATH(UP)		С	* For attending hot point and bay tightening work >X*	07/Jul/2023	09:00	08/Jul/2023	18:00		PLANNED	Requested	
					SOMMATIN(UP)			30.05.2023 15:54:28 INDIA								
500	00135007	000 000	etuur	DLIC	400KV/ BUIC 2 ***	UPPTCL		(11007349)	07/11/205	00:00	07/Jul/2023	10.00		DI ANIA:	Dog:	
300	RQ135907	JULU_208	stuup_sa	BUS	400KV BUS 2 AT BAREILLY(UP)	UPPTCL	D	* preventive mainteance	07/Jul/2023	00.00	U7/JUI/2023	10.00		PLANNED	Requested	
501	RQ135828	OCC_208	stuup_sd	BUS	400KV BUS		D	Interconnection of Existing Bus-	05/Jul/2023	08:00	05/Jul/2023	18:00	After getting	PLANNED	Requested	
					2PARICHA(UP)			I with New Extended Bus-2					clearance from Electrical safety			
													department,			
													Interconnection of Reactor Bay 400KV			
													Bus-1 and Bus-2 with			
													Existing Bus will be			
													required for charging the Bus Reactor			
502	RQ135906	OCC 306	stuun sa	BUS	400KV BUS 1 AT	UPPTCL	D	* preventive mainteance of	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
302		000_200	stuup_su	503	BAREILLY(UP)			bus and PGCIL CKT -I Isoltaors	04/30// 2023	00.00	0-1/301/2023	10.00			nequested	
503	RQ135859	OCC 208	stuun sd	BUS	400KV BUS 2 AT	UPPTCL	С	* For Repairing and	03/Jul/2023	00:00	04/Jul/2023	19:00		DI ANINED	Requested	
303	NQ133033	000_200	stuup_su	503	SARNATH(UP)			Strengthening of damaged	03/301/2023	03.00	04/301/2023	10.00		LANNED	Requested	
504	RQ135827	000 200		BUS	400KV BUS	UPPTCL	D	portion of 400KV Bus	03/Jul/2023	00.00	03/Jul/2023	10.00	Daniel and a second	DIANNED	Descripted	
504	KQ135827	OCC_208	stuup_sa	803	1PARICHA(UP)		"	Interconnection of Existing Bus- I with New Extended Bus-1	03/301/2023	08:00	03/101/2023	18:00	Bay construction work for 01 No. 125	PLANNED	Requested	
						UPPTCL							MVAR is almost			
505	RQ136712	OCC_208	cpcc3_sd	BUS	400KV BUS 1 AT	OFFICE	D	'For rectification of damaged	03/Jul/2023	08:00	03/Jul/2023	18:00	completed.	PLANNED	Requested	
					PANKI(UP)			isolator of R ph of 400kV								
		L	L	L		UPPTCL	L	Fatehpur (Kanpur)-Panki-2 line	<u>L</u>					L		
506	RQ135991	OCC_208	cpcc2_sd	BUS	400KV BUS 2 AT		С	Link Interconnection and Bus	29/Jul/2023	09:00	31/Jul/2023	18:00	Under construction	PLANNED	Requested	
					KALA AMB(PKTL)			Stability of Main Bus-2 (GIS Bay Ext. and 125MVAR BR					head, Kindly Approve			
				1	1	1	1			1			1		I	1
						DVATI		installation under Package SS-								
507	RQ135990	OCC_208	cpcc2_sd	BUS	400KV BUS 1 AT	PKATL	С	installation under Package SS- 67 in progress) Link Interconnection and Bus	26/Jul/2023	09:00	28/Jul/2023	18:00	Under construction	PLANNED	Requested	
507	RQ135990	OCC_208	cpcc2_sd	BUS	400KV BUS 1 AT KALA AMB(PKTL)	PKATL	С	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS	26/Jul/2023	09:00	28/Jul/2023	18:00	head, Kindly	PLANNED	Requested	
507	RQ135990	OCC_208	cpcc2_sd	BUS		PKATL	С	67 in progress) Link Interconnection and Bus	26/Jul/2023	09:00	28/Jul/2023	18:00		PLANNED	Requested	
					KALA AMB(PKTL)	PKATL		67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress)					head, Kindly Approve		·	
	RQ135990 RQ135989			BUS			С	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-	26/Jul/2023 24/Jul/2023		28/Jul/2023 25/Jul/2023		head, Kindly Approve		Requested Requested	
					KALA AMB(PKTL) 400KV BUS 2 AT	PKATL		67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-					head, Kindly Approve Under construction		·	
508	RQ135989	OCC_208	cpcc2_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL)		С	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress)	24/Jul/2023	09:00	25/Jul/2023	18:00	head, Kindly Approve Under construction head, Kindly Approve	PLANNED	Requested	
508		OCC_208	cpcc2_sd		KALA AMB(PKTL) 400KV BUS 2 AT	PKATL		67 in progress) Unk Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR Installation under Package S5- 67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR Installation under Package SS- 67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR		09:00		18:00	head, Kindly Approve Under construction head, Kindly Approve Under construction head, Kindly	PLANNED	·	
508	RQ135989	OCC_208	cpcc2_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT	PKATL	С	67 in progress) Unk Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-	24/Jul/2023	09:00	25/Jul/2023	18:00	head, Kindly Approve Under construction head, Kindly Approve Under construction	PLANNED	Requested	
508	RQ135989	OCC_208	cpcc2_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT	PKATL	С	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) Intercept of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress)	24/Jul/2023	09:00	25/Jul/2023	18:00	head, Kindly Approve Under construction head, Kindly Approve Under construction head, Kindly Approve	PLANNED	Requested	
508	RQ135989 RQ135988	OCC_208	cpcc2_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL)	PKATL	С	67 in progress) Unk Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) Installation of Interface Module (GIS Bay Ext. and Module (GIS Bay Ext. and	24/Jul/2023 22/Jul/2023	09:00	25/Jul/2023 23/Jul/2023	18:00	head, Kindly Approve Under construction head, Kindly	PLANNED	Requested Requested	
508	RQ135989 RQ135988	OCC_208	cpcc2_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT	PKATL	С	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) Intercept of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress)	24/Jul/2023 22/Jul/2023	09:00	25/Jul/2023 23/Jul/2023	18:00	head, Kindly Approve Under construction head, Kindly Approve Under construction head, Kindly Approve Under construction Under construction Under construction	PLANNED	Requested Requested	
508	RQ135989 RQ135988 RQ135987	OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd	BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL)	PKATL	C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR Installation under Package S5- 67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package S5- 67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5- 67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5- 67 in progress)	24/Jul/2023 22/Jul/2023 15/Jul/2023	09:00 09:00 09:00	25/Jul/2023 23/Jul/2023 18/Jul/2023	18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve Under construction head, Kindly Approve Under construction head, Kindly Approve Approve	PLANNED PLANNED PLANNED	Requested Requested Requested	
508	RQ135989 RQ135988	OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL)	PKATL PKATL	С	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface	24/Jul/2023 22/Jul/2023	09:00 09:00 09:00	25/Jul/2023 23/Jul/2023	18:00 18:00	head, Kindly Approve Under construction	PLANNED PLANNED	Requested Requested	
508	RQ135989 RQ135988 RQ135987	OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd	BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL)	PKATL PKATL	C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) Installation of interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) Installation of interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) Installation of interface Module (GIS Bay Ext. and 125MVAR BR installation STANDERS BR STANDERS SS- MODULE (GIS Bay Ext. and 125MVAR BR Installation in Interface Module (GIS Bay Ext. and 125MVAR BR Installation in Interface	24/Jul/2023 22/Jul/2023 15/Jul/2023	09:00 09:00 09:00	25/Jul/2023 23/Jul/2023 18/Jul/2023	18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve Under construction head, Kindly Approve Under construction head, Kindly Approve Approve	PLANNED PLANNED	Requested Requested Requested	
508	RQ135989 RQ135988 RQ135987	OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd	BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL)	PKATL PKATL PKATL	C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress)	24/Jul/2023 22/Jul/2023 15/Jul/2023	09:00 09:00 09:00	25/Jul/2023 23/Jul/2023 18/Jul/2023	18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve	PLANNED PLANNED	Requested Requested Requested	
508 509 510	RQ135989 RQ135988 RQ135987	OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd	BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL)	PKATL PKATL	C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) Installation of interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) Installation of interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) Installation of interface Module (GIS Bay Ext. and 125MVAR BR installation STANDERS BR STANDERS SS- MODULE (GIS Bay Ext. and 125MVAR BR Installation in Interface Module (GIS Bay Ext. and 125MVAR BR Installation in Interface	24/Jul/2023 22/Jul/2023 15/Jul/2023	09:00 09:00 09:00	25/Jul/2023 23/Jul/2023 18/Jul/2023	18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve	PLANNED PLANNED PLANNED	Requested Requested Requested	
508 509 510	RQ135989 RQ135988 RQ135987	OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd	BUS BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL)	PKATL PKATL PKATL	C C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5- 67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package S5- 67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5- 67 in progress) Installation under Package S5- 67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5- 67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5- 67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5- 67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after	24/Jul/2023 22/Jul/2023 15/Jul/2023	09:00 09:00 09:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023	18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve	PLANNED PLANNED PLANNED	Requested Requested Requested	
508 509 510 511	RQ135989 RQ135988 RQ135987 RQ135986	OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd	BUS BUS BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 4 AT SINGRAULI(INT)	PKATL PKATL PKATL	C C C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS- 67 in progress) Installation under Package SS- 67 in progress) Installation of interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023	09:00 09:00 09:00 09:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023	18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve	PLANNED PLANNED PLANNED PLANNED	Requested Requested Requested Requested Requested	
508 509 510 511	RQ135989 RQ135988 RQ135987	OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd	BUS BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 3 AT	PKATL PKATL PKATL PKATL	C C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar	24/Jul/2023 22/Jul/2023 15/Jul/2023	09:00 09:00 09:00 09:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023	18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve	PLANNED PLANNED PLANNED PLANNED	Requested Requested Requested	
508 509 510 511	RQ135989 RQ135988 RQ135987 RQ135986	OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd	BUS BUS BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 4 AT SINGRAULI(INT)	PKATL PKATL PKATL PKATL NTPC	C C C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR Installation under Package S5-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, STRAKTINGARPH	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023	09:00 09:00 09:00 09:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023	18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve	PLANNED PLANNED PLANNED PLANNED	Requested Requested Requested Requested Requested	
508 509 510 511 512	RQ135989 RQ135988 RQ135987 RQ135986 RQ136754	OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd	BUS BUS BUS BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 3 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL	C C C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Retrofitment of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023	09:00 09:00 09:00 09:00 09:00 08:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023	18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve	PLANNED PLANNED PLANNED PLANNED PLANNED	Requested Requested Requested Requested Requested Requested	
508 509 510 511 512	RQ135989 RQ135988 RQ135987 RQ135986	OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd	BUS BUS BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 3 AT	PKATL PKATL PKATL PKATL NTPC	C C C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR Installation under Package S5-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, STRAKTINGARPH	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023	09:00 09:00 09:00 09:00 09:00 08:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023	18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve	PLANNED PLANNED PLANNED PLANNED PLANNED	Requested Requested Requested Requested Requested	
508 509 510 511 512	RQ135989 RQ135988 RQ135987 RQ135986 RQ136754	OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd	BUS BUS BUS BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 1 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL NTPC	C C C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at S5TPS-NTPC, Shaktinagar Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at S5TPS-NTPC, Shaktinagar S/D of Transfer Bus for Retrofitment of 417 Bay TBC isolator after dismantling at STPS-NTPC, Shaktinagar	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023	09:00 09:00 09:00 09:00 09:00 08:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023	18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve	PLANNED PLANNED PLANNED PLANNED PLANNED	Requested Requested Requested Requested Requested Requested	
508 509 510 511 512	RQ135989 RQ135988 RQ135987 RQ135986 RQ136754	OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd	BUS BUS BUS BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 1 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL NTPC	C C C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR Installation under Package SS-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar SFLOOR Transfer Bus for Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023	09:00 09:00 09:00 09:00 09:00 08:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023	18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve	PLANNED PLANNED PLANNED PLANNED PLANNED	Requested Requested Requested Requested Requested Requested	
508 509 510 511 512	RQ135989 RQ135988 RQ135987 RQ135986 RQ136754	OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd	BUS BUS BUS BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 1 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL NTPC	C C C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR RR Installation under Package S5-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR RR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR RR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR RR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR RR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR RR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR RR installation under Package S5-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Sylo of Transfer Bus for Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Sylo of Transfer Bus for Retrofitment of 417 Bay TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023	09:00 09:00 09:00 09:00 09:00 08:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023	18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve	PLANNED PLANNED PLANNED PLANNED PLANNED	Requested Requested Requested Requested Requested Requested	
508 509 510 511 512 513	RQ135989 RQ135988 RQ135987 RQ135986 RQ136754 RQ136753	OCC_208 OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd	BUS BUS BUS BUS BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 2 AT T KALA AMB(PKTL) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL NTPC NTPC	C C C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at S5TPS-NTPC, Shaktinagar Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at S5TPS-NTPC, Shaktinagar SC/D of Transfer Bus for Retrofitment of 417 Bay TBC isolator after dismantling of 195 FNTPC, Shaktinagar SC/D of Transfer Bus for Retrofitment of 417 Bay TBC isolator after dismantling of 195 FNTPC, Shaktinagar & dismantling of 195 Fnom TBC Isolator to Line HCB BUS 4150LATOR	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023	09:00 09:00 09:00 09:00 09:00 08:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023	18:00 18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve	PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED	Requested Requested Requested Requested Requested Requested	
508 509 510 511 512 513	RQ135989 RQ135988 RQ135987 RQ136754 RQ136753 RQ136755	OCC_208 OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd cpcc3_sd cpcc3_sd singrauli_sd	BUS BUS BUS BUS BUS BUS BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 6 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL NTPC	C C C C C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR Installation under Package SS-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar & SSTPS-NTPC, Shaktinagar & dismantling of PS from TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar & dismantling of PS from TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar & dismantling of PS from TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar & dismantling of PS from TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar & dismantling of PS from TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar & dismantling of PS from TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar & dismantling of PS from TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar & dismantling of PS from TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar & dismantling of PS from TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar & dismantling of PS from TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar & dismantling of PS from TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar & dismantling of PS from TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar & dismantling at SSTPS-NTPC, Shaktinagar & dismantling at SSTPS-NT	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023 19/Jul/2023	09:00 09:00 09:00 09:00 08:00 08:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023 24/Jul/2023 20/Jul/2023	18:00 18:00 18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve Bus 4 SHUTDOWN REQUIRED	PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED	Requested Requested Requested Requested Requested Requested Requested Requested	
508 509 510 511 512 513 514	RQ135989 RQ135988 RQ135987 RQ135986 RQ136754 RQ136753 RQ136755 RQ136449	OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd cpcc3_sd cpcc3_sd singrauli_sd singrauli_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 1 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL NTPC NTPC		67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR Installation under Package S5-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation GIS Bay Ext. and 12	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023 23/Jul/2023 19/Jul/2023 17/Jul/2023	09:00 09:00 09:00 09:00 08:00 08:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023 24/Jul/2023 20/Jul/2023 16/Jul/2023	18:00 18:00 18:00 18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve	PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED	Requested Requested Requested Requested Requested Requested Requested Requested Requested	
508 509 510 511 512 513 514	RQ135989 RQ135988 RQ135987 RQ136754 RQ136753 RQ136755	OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd cpcc3_sd cpcc3_sd singrauli_sd singrauli_sd	BUS BUS BUS BUS BUS BUS BUS BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 2 AT T KALA AMB(PKTL) 400KV BUS 1 AT T KALA AMB(PKTL) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL PKATL NTPC NTPC NTPC	C C C C C	67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Sy/D of Transfer Bus for Retrofitment of 417 Bay Bus-3 STSTPS-NTPC, Shaktinagar Sy/D of Transfer Bus for Retrofitment of 417 Bay Bus-3 STSTPS-NTPC, Shaktinagar Bus STSTPS-NTPC, Shaktinagar Bus STSTPS-NTPC, Shaktinagar & Gismantling of 19F from TBC Isolator to Line HCB BUS 4 ISOLATOR REPALCEMNT BUS 3 ISOLATOR REPALCEMNT	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023 19/Jul/2023	09:00 09:00 09:00 09:00 08:00 08:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023 24/Jul/2023 20/Jul/2023	18:00 18:00 18:00 18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve Bush a Shutton Bush 4 Shutton Bush 4 Shutton Bush 5 Shutton Bush 6 Shutton Bush 7 Shutton Bush 7 Shutton Bush 7 Shutton Bush 8 Shutton Bush	PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED	Requested Requested Requested Requested Requested Requested Requested Requested	
508 509 510 511 512 513 514 516 517	RQ135989 RQ135988 RQ135987 RQ135986 RQ136754 RQ136755 RQ136748 RQ136449 RQ136448 RQ136748	OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd cpcc3_sd cpcc3_sd singrauli_sd singrauli_sd sidcrs_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL PKATL NTPC NTPC NTPC		67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR Installation under Package SS-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR BR Installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR BR Installation under Package SS-67 in progress) Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar & ISSTPS-NTPC, Shaktinagar &	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023 23/Jul/2023 17/Jul/2023 13/Jul/2023 25/Jul/2023	09:00 09:00 09:00 09:00 08:00 08:00 08:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023 24/Jul/2023 20/Jul/2023 25/Jul/2023	18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve Bush a Shutton Bush 4 Shutton Bush 4 Shutton Bush 5 Shutton Bush 6 Shutton Bush 7 Shutton Bush 7 Shutton Bush 7 Shutton Bush 8 Shutton Bush	PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED	Requested	
508 509 510 511 512 513 514 516 517	RQ135989 RQ135988 RQ135987 RQ135986 RQ136754 RQ136753 RQ136755 RQ136449	OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd cpcc3_sd cpcc3_sd singrauli_sd singrauli_sd sidcrs_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL PKATL NTPC NTPC NTPC NTPC NTPC		67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Sylo Transfer Bus for Retrofitment of 417 Bay TBC isolator after dismantling of IPS From TBC Isolator to Line HCB BUS 4 ISOLATOR REPALCEMENT Preventive maintenance & Testing of bay and equipments	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023 23/Jul/2023 19/Jul/2023 17/Jul/2023	09:00 09:00 09:00 09:00 08:00 08:00 08:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023 24/Jul/2023 20/Jul/2023 16/Jul/2023	18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve Bush a Shutton Bush 4 Shutton Bush 4 Shutton Bush 5 Shutton Bush 6 Shutton Bush 7 Shutton Bush 7 Shutton Bush 7 Shutton Bush 8 Shutton Bush	PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED	Requested Requested Requested Requested Requested Requested Requested Requested Requested	
508 509 510 511 512 513 514 515 516 517 518	RQ135989 RQ135988 RQ135987 RQ135986 RQ136754 RQ136753 RQ136755 RQ136449 RQ136448 RQ136748	OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd cpcc3_sd cpcc3_sd singrauli_sd singrauli_sd sldcrs_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL PKATL NTPC NTPC NTPC NTPC NTPC		67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar SC) of Transfer Bus for Retrofitment of 417 Bay TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar SC) of Transfer Bus for Retrofitment of 417 Bay TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar SC) of Transfer Bus for Retrofitment of 417 Bay TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar SC) of Transfer Bus for Retrofitment of 417 Bay TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar SC) and SMATTPC, Shaktinagar SC) and SMATTPC, Shaktinagar SC SMA	24/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023 23/Jul/2023 19/Jul/2023 17/Jul/2023 25/Jul/2023 24/Jul/2023	09:00 09:00 09:00 09:00 08:00 08:00 08:00 08:00 08:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023 24/Jul/2023 20/Jul/2023 25/Jul/2023 24/Jul/2023	18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve Bush a Shutton Bush 4 Shutton Bush 4 Shutton Bush 5 Shutton Bush 6 Shutton Bush 7 Shutton Bush 7 Shutton Bush 7 Shutton Bush 8 Shutton Bush	PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED	Requested	
508 509 510 511 512 513 514 515 516 517 518	RQ135989 RQ135988 RQ135987 RQ135986 RQ136754 RQ136755 RQ136748 RQ136449 RQ136448 RQ136748	OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd cpcc3_sd cpcc3_sd singrauli_sd singrauli_sd sldcrs_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 3 AT 510GRAULI(NT) 400KV BUS 4 AT 510GRAULI(NT) 400KV BUS 4 AT 510GRAULI(NT) 400KV BUS 3 AT 510GRAULI(NT) 400KV BUS 3 AT 510GRAULI(NT) 400KV BUS 4 AT 510GRAULI(NT) 400KV BUS 3 AT 510GRAULI(NT) 400KV BUS 4 AT 510GRAULI(NT) 400KV BUS 4 AT 510GRAULI(NT) 400KV BUS 5 AT 610KV BUS 9 AT	PKATL PKATL PKATL PKATL PKATL NTPC NTPC NTPC NTPC NTPC NTPC RRVPNL		67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR Installation under Package S5-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation GIS Bay Ext. and 125MVAR BR i	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023 23/Jul/2023 17/Jul/2023 17/Jul/2023 25/Jul/2023	09:00 09:00 09:00 09:00 08:00 08:00 08:00 08:00 08:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023 24/Jul/2023 20/Jul/2023 25/Jul/2023	18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve Bush a Shutton Bush 4 Shutton Bush 4 Shutton Bush 5 Shutton Bush 6 Shutton Bush 7 Shutton Bush 7 Shutton Bush 7 Shutton Bush 8 Shutton Bush	PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED PLANNED	Requested	
508 509 510 511 512 513 514 515 516 517 518	RQ135989 RQ135988 RQ135987 RQ135986 RQ136754 RQ136753 RQ136748 RQ136448 RQ136748 RQ136747 RQ136743	OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd cpcc3_sd cpcc3_sd singrauli_sd singrauli_sd sidcrs_sd sidcrs_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL PKATL NTPC NTPC NTPC NTPC NTPC NTPC RRVPNL		67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR Installation under Package S5-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR Installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Stylo Firmater Bus for Retrofitment of 417 Bay TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar Stylo Firmater Bus for Retrofitment of 417 Bay TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar Stylo Firmater Bus for Retrofitment of 417 Bay TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar Stylo Firmater Bus for Retrofitment of 417 Bay TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar Stylo Firmater Bus 3 ISOLATOR REPLACEMENT Preventive maintenance & Testing of bay and equipments Quarterly/ Half Yearly/ Yearly Maintenance work at 400kV GSS, Bhadila	24/Jul/2023 15/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023 19/Jul/2023 17/Jul/2023 25/Jul/2023 24/Jul/2023	09:00 09:00 09:00 09:00 09:00 08:00 08:00 08:00 08:00 08:00 16:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 24/Jul/2023 21/Jul/2023 25/Jul/2023 24/Jul/2023 24/Jul/2023	18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve Bush a Shutton Bush 4 Shutton Bush 4 Shutton Bush 5 Shutton Bush 6 Shutton Bush 7 Shutton Bush 7 Shutton Bush 7 Shutton Bush 8 Shutton Bush	PLANNED	Requested	
508 509 510 511 512 513 514 515 516 517 518	RQ135989 RQ135988 RQ135987 RQ135986 RQ136754 RQ136753 RQ136755 RQ136449 RQ136448 RQ136748	OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd cpcc3_sd cpcc3_sd singrauli_sd singrauli_sd sidcrs_sd sidcrs_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT) 40KV BUS 3 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL PKATL PKATL NTPC NTPC NTPC NTPC RRVPNL RRVPNL		67 in progress) Unk Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR Installation under Package SS-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar & SSTPS-NTPC, Shaktinaga	24/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023 23/Jul/2023 19/Jul/2023 17/Jul/2023 25/Jul/2023 24/Jul/2023	09:00 09:00 09:00 09:00 09:00 08:00 08:00 08:00 08:00 08:00 16:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023 24/Jul/2023 20/Jul/2023 25/Jul/2023 24/Jul/2023	18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00	head, Kindly Approve Under construction head, Kindly Approve Bush a Shutton Bush 4 Shutton Bush 4 Shutton Bush 5 Shutton Bush 6 Shutton Bush 7 Shutton Bush 7 Shutton Bush 7 Shutton Bush 8 Shutton Bush	PLANNED	Requested	
508 509 510 511 512 513 514 516 517 518 519 520	RQ135989 RQ135988 RQ135986 RQ136754 RQ136753 RQ136745 RQ136449 RQ136748 RQ136747 RQ136743 RQ136742	OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd cpcc3_sd cpcc3_sd singrauli_sd singrauli_sd sidcrs_sd sidcrs_sd sidcrs_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT) 40KV BUS 3 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL PKATL PKATL NTPC NTPC NTPC NTPC RRVPNL RRVPNL		67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR Installation under Package S5-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR Installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package S5-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Stylo Firmater Bus for Retrofitment of 417 Bay TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar Stylo Firmater Bus for Retrofitment of 417 Bay TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar Stylo Firmater Bus for Retrofitment of 417 Bay TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar Stylo Firmater Bus for Retrofitment of 417 Bay TBC isolator after dismantling at SSTPS-NTPC, Shaktinagar Stylo Firmater Bus 3 ISOLATOR REPLACEMENT Preventive maintenance & Testing of bay and equipments Quarterly/ Half Yearly/ Yearly Maintenance work at 400kV GSS, Bhadila	24/Jul/2023 22/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023 23/Jul/2023 17/Jul/2023 25/Jul/2023 22/Jul/2023 22/Jul/2023	09:00 09:00 09:00 09:00 08:00 08:00 08:00 08:00 08:00 16:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 27/Jul/2023 24/Jul/2023 25/Jul/2023 25/Jul/2023 22/Jul/2023 22/Jul/2023	18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 23:00	head, Kindly Approve Under construction head, Kindly Approve Bush a Shutton Bush 4 Shutton Bush 4 Shutton Bush 5 Shutton Bush 6 Shutton Bush 7 Shutton Bush 7 Shutton Bush 7 Shutton Bush 8 Shutton Bush	PLANNED	Requested	
508 509 510 511 512 513 514 516 517 518 519 520	RQ135989 RQ135988 RQ135987 RQ135986 RQ136754 RQ136753 RQ136748 RQ136448 RQ136748 RQ136747 RQ136743	OCC_208 OCC_208	cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc2_sd cpcc3_sd cpcc3_sd cpcc3_sd singrauli_sd singrauli_sd sidcrs_sd sidcrs_sd sidcrs_sd	BUS	KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 2 AT KALA AMB(PKTL) 400KV BUS 1 AT KALA AMB(PKTL) 400KV BUS 3 AT SINGRAULI(NT) 400KV BUS 4 AT SINGRAULI(NT) 400KV BUS 3 AT SINGRAULI(NT) 40KV BUS 3 AT SINGRAULI(NT)	PKATL PKATL PKATL PKATL PKATL PKATL NTPC NTPC NTPC NTPC RRVPNL RRVPNL RRVPNL		67 in progress) Link Interconnection and Bus Stability of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-2 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) HV Test of Main Bus-1 (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Installation of Interface Module (GIS Bay Ext. and 125MVAR BR installation under Package SS-67 in progress) Retrofitment of 417 Bay Bus-4 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Retrofitment of 417 Bay Bus-3 pantograph isolator after dismantling at SSTPS-NTPC, Shaktinagar Sylva Interface Mismantling of IPS From TBC isolator to Line HCB BUS 4 ISOLATOR REPALCEMMT Preventive maintenance & Testing of bay and equipments Preventive maintenance & Testing of bay and equipments Preventive maintenance & Testing of bay and equipments Preventive maintenance work at 400KV GSS, Bhadla Quarterly Half Yearly/ Yearly Maintenance work at 400KV GSS, Bhadla	24/Jul/2023 15/Jul/2023 15/Jul/2023 10/Jul/2023 26/Jul/2023 19/Jul/2023 17/Jul/2023 25/Jul/2023 24/Jul/2023	09:00 09:00 09:00 09:00 08:00 08:00 08:00 08:00 08:00 16:00	25/Jul/2023 23/Jul/2023 18/Jul/2023 14/Jul/2023 24/Jul/2023 21/Jul/2023 25/Jul/2023 24/Jul/2023 24/Jul/2023	18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 18:00 23:00	head, Kindly Approve Under construction head, Kindly Approve Bush a Shutton Bush 4 Shutton Bush 4 Shutton Bush 5 Shutton Bush 6 Shutton Bush 7 Shutton Bush 7 Shutton Bush 7 Shutton Bush 8 Shutton Bush	PLANNED PLANNED	Requested	

522	RQ136744	OCC_208	sldcrs_sd	BUS	400KV BUS 1 AT HINDAUN(RS)	RRVPNL	D	For Quarterly/Half Yearly maintenance work	13/Jul/2023	08:00	13/Jul/2023	18:00		PLANNED	Requested	
523	RQ136739	OCC_208	sldcrs_sd	BUS	400KV BUS 2 AT		D	QUARTERLY MAINT.WORK OF	12/Jul/2023	08:00	12/Jul/2023	18:00		PLANNED	Requested	
524	RQ136750	OCC_208	sldcrs sd	BUS	MERTA(RS) 400 KV CHHABRA	RRVPNL	С	BAY & EQUIPMENTS Annual maintenance for	12/Jul/2023	08:00	13/Jul/2023	18:00		PLANNED	Requested	
		_	_		SCTPS(RS) - BUS 2			tightening of Bus equipments								
						RRVPNL		& Relay testing								
525	RQ136738	OCC_208	sldcrs_sd	BUS	400KV BUS 1 AT MERTA(RS)	RRVPNL	D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	11/Jul/2023	08:00	11/Jul/2023	18:00		PLANNED	Requested	
526	RQ136749	OCC_208	sldcrs_sd	BUS	400 KV CHHABRA	KKVPINL	С	Annual maintenance for	10/Jul/2023	08:00	11/Jul/2023	18:00		PLANNED	Requested	
					SCTPS(RS) - BUS 1			tightening of Bus equipments								
						RRVPNL		& Relay testing								
527	RQ136740	OCC_208	sldcrs_sd	BUS	400KV BUS 1 AT BABAI(RS)		С	Jumpering work, Bus VT extension from existing system	06/Jul/2023	08:00	07/Jul/2023	18:00		PLANNED	Requested	
					DADAI(N3)			and Bus Bar testing (CU to PU)								
								by M/s NRSS for commissioning of 400 KV D/C								
						RRVPNL		Bhiwani line bays.								
528	RQ136741	OCC_208	sldcrs_sd	BUS	400KV BUS 2 AT BABAI(RS)		С	Jumpering work, Bus VT extension from existing system	04/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
								and Bus Bar testing (CU to PU)								
								by M/s NRSS for commissioning of 400 KV D/C								
500	00405045	000 000		D. I.C	100101 0115 1 17	RRVPNL		Bhiwani line bays.	45/11/2022	10.00	45/1 1/2022	45.00				
529	KQ135915	OCC_208	stuup_sa	BUS	400KV BUS 1 AT GR.NOIDA(UPC)		D	* Maintenance work will be carried out during this	16/Jul/2023	10:00	16/Jul/2023	16:00		PLANNED	Requested	
						UPPCL		shutdown period at 400 kV								
530	RQ136564	OCC_208	sldchr_sd	BUS	400KV BUS 2 AT	OFFCE	D	S/S Greater Noida. For replacement of Bay Unit	13/Jul/2023	09:00	13/Jul/2023	17:00		PLANNED	Requested	
					DAULATABAD(HV)			(Bay 403) & testing of Bus Bar Protection (SD will be availed								
								after purchasing Bay units and								
								matter has been taken with firm for this purpose)								
			ļ			HVPNL										
531	RQ136563	OCC_208	sldchr_sd	BUS	400KV BUS 1 AT DAULATABAD(HV)		D	For replacement of Bay Unit (Bay 418) & testing of Bus Bar	12/Jul/2023	09:00	12/Jul/2023	17:00		PLANNED	Requested	
								Protection (SD will be availed								
								after purchasing Bay units and matter has been taken with								
						Invot		firm for this purpose)								
532	RQ135830	OCC_208	stuup_sd	BUS	400 KV	HVPNL	D	For Annual maintenance of	05/Jul/2023	09:30	05/Jul/2023	18:30		PLANNED	Requested	
					BADAUNE(UP) -	OCRT		Bus elements & protection			. ,					
533	RQ135829	OCC_208	stuup_sd	BUS	BUS 2 400 KV	OCBTL	D	system For Annual maintenance of	03/Jul/2023	09:30	03/Jul/2023	18:30		PLANNED	Requested	
					BADAUNE(UP) - BUS 1	OCRTI		Bus elements & protection								
534	RQ136550	OCC_208	sldchr_sd	BUS	400KV BUS 2 AT	OCBTL	D	AMP of Bus Equipment	03/Jul/2023	08:00	03/Jul/2023	18:00		PLANNED	Requested	
					DEEPALPUR(JHKT)	KT-JHAJJAR		(Testing of 400KV Bus CVT & Bus isolator alignment)								
535	RQ136526	OCC_208	cpcc1_sd	LINE REACTOR	50 MVAR NON-	KITHAJAK	С	Overhauling work on 407LR	17/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
					SWITCHABLE LR ON			Breaker								
					AGRA-SIKAR (PG) CKT-2 @SIKAR(PG)											
526	RO126527	OCC_208	cncc1 sd	LINE REACTOR	50 MVAR NON-	POWERGRID	D	AMP work on reactor and	07/Jul/2023	08:00	07/Jul/2023	18:00		DIANNED	Requested	
330		200_200	-presi_su		SWITCHABLE LR ON		້	reactor bay	5., July 2023	20.00	o./Jui/2023	_0.00		. SaviveD	cquesteu	
					AGRA-SIKAR (PG) CKT-2 @SIKAR(PG)											
						POWERGRID										
537	RQ136525	OCC_208	cpcc1_sd	LINE REACTOR	50 MVAR NON- SWITCHABLE LR ON		С	Overhauling work on 410LR Breaker	03/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
					AGRA-SIKAR (PG)			Di canci								
					CKT-1 @SIKAR(PG)	POWERGRID										
538	RQ136523	OCC_208	cpcc1_sd	LINE REACTOR	50 MVAR NON-		D	FOR AMP WORK	02/Jul/2023	08:00	02/Jul/2023	18:00		PLANNED	Requested	
					SWITCHABLE LR ON BHIWADI-HISSAR											
					(PG) CKT-1	DOMEDONO										
539	RQ136108	OCC_208	stuup_sd	LINE REACTOR		POWERGRID	С	* to repalce this 50 MVAR line	01/Jul/2023	08:00	25/Jul/2023	18:00		PLANNED	Requested	
					SWITCHABLE LR ON BAREILLY-UNNAO			reactor with new 63 MVAR line reactor								
					(UP) CKT-1			inic reactor								
540	RO136500	OCC_208	cpcc1 sd	BR/BSR/MSC/M	@BAREILLY(UP) 125 MVAR BUS	UPPTCL	С	For current injection point for	29/Jul/2023	07:00	30/Jul/2023	20:00		PLANNED	Requested	
		2202		SR SR	REACTOR NO 1 AT			Bus-4 for Busbar Relay Testing	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		, 301, 2023				questeu	
					400KV KURUKSHETRA(PG)			after HV test of ICT-3 bays.								
Ш						POWERGRID										
541	RQ136499	OCC_208	cpcc1_sd	BR/BSR/MSC/M SR	125 MVAR BUS REACTOR NO 2 AT		D	FOR AMP WORK	24/Jul/2023	08:00	24/Jul/2023	18:00		PLANNED	Requested	
		00-			400 KV SIKAR(PG)	POWERGRID		500 4440 11:2-:-	407: .:	20.05	40.51	40.0-		DI 4:::		
542	KQ136496	OCC_208	cpcc1_sd	BR/BSR/MSC/M SR	50 MVAR BUS REACTOR NO 1 AT		D	FOR AMP WORK	18/Jul/2023	00:800	18/Jul/2023	18:00		PLANNED	Requested	
					400KV	DOW/52.5										
543	RQ136497	OCC_208	cpcc1 sd	BR/BSR/MSC/M	MANDOLA(PG) 125 MVAR BUS	POWERGRID	D	For CSD Fine tuning work	16/Jul/2023	08:00	16/Jul/2023	18:00		PLANNED	Requested	
				SR	REACTOR NO 2 AT						,					
					400 KV MANDOLA(PG)	POWERGRID										
544	RQ136501	OCC_208	cpcc1_sd	BR/BSR/MSC/M	80 MVAR BUS		D	FOR AMP WORK	15/Jul/2023	08:00	15/Jul/2023	18:00		PLANNED	Requested	
				SR	REACTOR NO 1 AT 400KV KOTA(PG)	POWERGRID										
545	RQ135984	OCC_208	cpcc2_sd	BR/BSR/MSC/M SR	125 MVAR BUS		C	For Stringing work on Gantry	01/Jul/2023	09:00	10/Jul/2023	18:00	Under construction	PLANNED	Requested	
				3K	REACTOR NO 3 AT 400 KV			Tower over Line Equipments and Bus Reactor-3 in Dulhasti-					head, Kindly Approve			
					KISHENPUR(PG)	POWERGRID		3 (New) Line Bay.								
546	RQ136770	OCC_208	sldcrs_sd	BR/BSR/MSC/M		. OWENGKID	D	Preventive maintenance &	27/Jul/2023	08:00	27/Jul/2023	18:00		PLANNED	Requested	
				SR	REACTOR NO 1 AT 400 KV			Testing of bay and equipments								
Ш					KANKANI(RS)	RRVPNL										
547	RQ136766	OCC_208	sldcrs_sd	BR/BSR/MSC/M SR	125 MVAR BUS REACTOR NO 1 AT		D	Quarterly/ Half Yearly/ Yearly Maintenance work at 400KV	24/Jul/2023	09:00	24/Jul/2023	14:00		PLANNED	Requested	
					400KV BHADLA(RS)			GSS, Bhadla								
548	RQ136769	OCC_208	sldcrs sd	BR/BSR/MSC/M	125 MVAR BUS	RRVPNL	D	For the measurement of Tan	13/Jul/2023	08:00	13/Jul/2023	18:00		PLANNED	Requested	
		2202		SR SR	REACTOR NO 1 AT			Delta Bushings.	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		,,, 2023				questeu	
					400KV PHAGI(RS)			Other maintenance work of Reactor.								
								3. Tightening of clamp								
549	RQ136767	OCC_208	sldcrs sd	BR/BSR/MSC/M	125 MVAR BUS	RRVPNL	D	connectors of equipments. For Quarterly/Half Yearly	12/Jul/2023	08:00	12/Jul/2023	16:00		PLANNED	Requested	
[]				SR SR	REACTOR NO 1 AT		-	maintenance work	,, 2023		,, 2023					
		L_	<u></u>		400KV HINDAUN(RS)	RRVPNL	<u></u>							<u></u>		
550	RQ136768	OCC_208	sldcrs_sd	BR/BSR/MSC/M	125 MVAR BUS		D	QUARTERLY MAINT.WORK	01/Jul/2023	08:00	01/Jul/2023	18:00		PLANNED	Requested	
				SR	REACTOR NO 1 AT 400KV MERTA(RS)	RRVPNL		OF BAY & EQUIPMENTS	<u>L_</u>					L		
L									_							

551	RQ136495	OCC_208	cpcc1_sd	BR/BSR/MSC/M SR	125 MVAR BUS REACTOR NO 1 AT		D	FOR AMP WORK	22/Jul/2023	17:00	23/Jul/2023	23:00		PLANNED	Requested	
				Sit	400 KV											
					FATEHGARH_II(PG)											
552	RQ136588	OCC_208	bbmb_sd	BR/BSR/MSC/M			D	Half yearly mtc	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
				SR	REACTOR NO 1 AT 400KV											
552	RQ135908	000 208	stuup sd	BR/BSR/MSC/M	BHIWANI(BB) 80 MVAR BUS	BBMB	D	* preventive maintenace work	04/Jul/2023	08:00	04/Jul/2023	19:00		DIANNED	Requested	
333	NQ133300	000_200	stuup_su	SR SR	REACTOR NO 1 AT			to free transfer bus for	04/301/2023	00.00	04/301/2023	18.00		LAININED	Requested	
					400KV BAREILLY(UP)	UPPTCL		Maintenace								
554	RQ135823	OCC_208	stuup_sd		80 MVAR BUS		D	For annual testing of Reactor	03/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
				SR	REACTOR NO 1 AT 400 KV											
					HARDUAGANJ (UP)	UPPTCL										
555	RQ136772	OCC_208	ntpcos_sd			OTTTEE	С	For Annual Maintenance of	04/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
				SR	REACTOR NO 2 AT 400 KV RIHAND(NT)			Reactor & Other Bay equipments								
EEG	RQ136519	000 200	enect ed	BAY	421 MAIN BAY -	NTPC	С	CB Mechanism Overhauling	27/Jul/2023	00:00	30/Jul/2023	19:00		DIANNED	Requested	
330	NQ130313	000_208	cpcc1_su	DAI	400 KV BASSI-SIKAR			work for All the three phases	27/301/2023	08.00	30/301/2023	18.00		PLANNED	Requested	
					(PG) CKT-2 AND 400KV BUS 2 AT											
553	00405540	000 000		241	BASSI(PG)	POWERGRID		0004	22/11/2022	00.00	25/11/2022	10.00				
557	RQ136518	OCC_208	cpcc1_sa	BAY	420 TIE BAY - 400 KV BASSI-SIKAR		С	CB Mechanism Overhauling work for All the three phases	23/Jul/2023	08:00	26/Jul/2023	18:00		PLANNED	Requested	
					(PG) CKT-2 AND 400 KV JAIPUR SOUTH-											
					BASSI (PG) CKT-2											
					AT BASSI(PG)	POWERGRID										
558	RQ136006	OCC_208	cpcc2_sd	BAY	414 TIE BAY - 50 MVAR BUS		С	Circuit Breaker SF6 Leakage to	22/Jul/2023	09:00	31/Jul/2023	17:30	Kindly Approve	PLANNED	Requested	
					REACTOR NO 1 AT			be attended.								
					400KV MOGA(PG) (POWERGRID) AND											
					400 KV KISHENPUR-											
					MOGA (PG) CKT-1 AT 400 KV											
					MOGA(PG)											
					(POWERGRID)	POWERGRID										
559	RQ136444	OCC_208	singrauli_sd	BAY	423 MAIN BAY - 400 KV		С	SAS INTEGRATION	21/Jul/2023	08:00	25/Jul/2023	18:00	LINE WILL BE CHARGED THROUGH	PLANNED	Requested	
					SINGRAULI(NT)-								TRANSFER BUS			
					RIHAND(NT) (PG) CKT-1 AT											
					SINGRAULI(NT)	POWERGRID										
560	RQ136517	OCC_208	cpcc1_sd	BAY	410 MAIN BAY - 400 KV BASSI-SIKAR		С	CB Mechanism Overhauling work for All the three phases	19/Jul/2023	08:00	22/Jul/2023	18:00		PLANNED	Requested	
					(PG) CKT-1 AND											
					400KV BUS 1 AT BASSI(PG)	POWERGRID										
561	RQ136587	OCC_208	bbmb_sd	BAY	X6 CB MAIN BAY - 400 KV		D	Half yearly mtc	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
					BHIWANI(BB)-											
					HISSAR(PG) (PG) CKT-1 AT											
					BHIWANI(BB)	POWERGRID										
562	RQ136515	OCC_208	cpcc1_sd	BAY	416 MAIN BAY - 400KV		С	For 400kV GIS CB rectification works	17/Jul/2023	08:00	22/Jul/2023	20:00		PLANNED	Requested	
					KURUKSHETRA(PG)-											
					NAKODAR(PSG) (PG) CKT-1 AT											
					KURUKSHETRA(PG)	POWERGRID										
563	RQ136005	OCC_208	cpcc2_sd	BAY	405 TIE BAY - 400	POWERGRID	С	Circuit Breaker SF6 Leakage to	12/Jul/2023	09:00	19/Jul/2023	17:30	Kindly Approve	PLANNED	Requested	
					KV MOGA- FATEHABAD (PG)			be attended.								
					CKT-1											
					(POWERGRID) AND 400/220 KV 500											
					MVA ICT 3 AT MOGA(PG) AT 400											
					KV MOGA(PG)											
564	RQ136757	OCC_208	cpcc3_sd	BAY	(POWERGRID) AWL5 TIE BAY - 400	POWERGRID	С	Pneumatic drive mechanish	12/Jul/2023	08:00	14/Jul/2023	18:00		PLANNED	Requested	
					KV SINGRAULI(NT)-			overhauling								
					VINDHYACHAL(PG) (PG) CKT-1											
					(POWERGRID) AND 400 KV											
					SINGRAULI(NT)-											
					VINDHYACHAL(PG) (PG) CKT-2 AT 400											
					KV											
					VINDHYACHAL(PG) (POWERGRID)											
Sec	RQ136514	000 300	cncc1 sd	BAY	417 TIE BAY -	POWERGRID	С	For 400kV GIS CB rectification	09/Jul/2023	08:00	16/Jul/2023	20.00		DIANNED	Requested	
363	nq150514	JULU_208	chcc1_sa	DAT	400KV			works	09/301/2023	08.00	10/101/2023	20.00		LANNED	nequested	
					ABDULLAPUR- KURUKSHETRA (PG)											
					CKT-1 AND 400KV											
					KURUKSHETRA(PG)- NAKODAR(PSG)											
					(PG) CKT-1 AT											
					KURUKSHETRA(PG)											
566	RQ136506	000 300	ence1 ed	BAY	429 TIE BAY -	POWERGRID	D	STATCOM erection works	08/Jul/2023	15:00	13/Jul/2023	23:00		DIANNER	Requested	
эрр	MU130300	JULU_208	chcc1_sq	DAT	400/220 KV 500		"	STATEOWI erection Works	00/301/2023	13.00	15/JUI/2023	25.00		PLANNED	mequestea	
					MVA ICT 4 AT FATEHGARH_II(PG)											
					(POWERGRID) AND											
					FUTURE AT 400 KV FATEHGARH_II(PG)											
					(POWERGRID)											
567	RQ136756	OCC_208	cpcc3_sd	BAY	AWL4 MAIN BAY -	POWERGRID	С	Pneumatic drive mechanish	08/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
			-		400 KV SINGRAULI(NT)-			overhauling								
					VINDHYACHAL(PG)											
					(PG) CKT-2 (POWERGRID) AT											
					400 KV											
					VINDHYACHAL(PG)	POWERGRID										
				•	•											

[]		I		T	T					I	T /: - /			I		
568	RQ136511	OCC_208	cpcc1_sa	BAY	420 TIE BAY - 400KV MEERUT-		D	ATTENDING OIL LEAKAGE FROM CT TERMINAL	07/Jul/2023	08:00	07/Jul/2023	18:00		PLANNED	Requested	
					MANDOLA (PG) CKT 2 AND 400KV											
					DADRI(NT)- MANDOLA(PG) (PG)											
					CKT-1 AT	POWERGRID										
569	RQ136512	OCC_208	cpcc1_sd	BAY	MANDOLA(PG) 426 TIE BAY -		С	ABB BREAKER OVERHAULLING	06/Jul/2023	08:00	12/Jul/2023	18:00		PLANNED	Requested	
					400KV MEERUT(PG) MANDOLA(PG) (PL)	1										
					CKT-4 AND FUTURE AT MANDOLA(PG)											
						POWERGRID										
570	RQ136107	OCC_208	stuup_sd	BAY	421 MAIN BAY -	FOWERGRID	D	* to mainteance of 400 KV BUS	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
					400KV BAREILLY- BAREILLY (PG) CKT-			I pantograph isoltaor , line will be chraged through transfer								
571	RQ136055	OCC 208	cpcc2 sd	BAY	1 AT BAREILLY(PG) 403 MAIN BAY -	POWERGRID	С	breaker CB retrofitting under ADD	03/Jul/2023	09:00	14/Jul/2023	18:00	Under construction	PLANNED	Requested	
					400/220KV 315 MVA ICT 2 AT			CAP.ICT-2 will remain charged via TBC					head, Kindly Approve		'	
572	RQ136004	000 200	ba Cases	BAY	WAGOORA(PG) 430 TIE BAY -	POWERGRID	С	GIS Circuit Breaker	03/Jul/2023	00:00	09/Jul/2023	17:20	Kindly Approve	DIANNED	Requested	
3,2	NQ130004	000_200	cpccz_su	DA1	765/400 KV 1500			Modification work by (OEM)	03/301/2023	03.00	03/341/2023	17.50	Kilidiy Approve	LANNED	Requested	
					MVA ICT 2 AT MOGA(PG)											
					(POWERGRID) AND FUTURE AT 400 KV											
					MOGA(PG) (POWERGRID)	POWERGRID										
573	RQ136513	OCC_208	cpcc1_sd	BAY	427 TIE BAY - 125 MVAR BUS		С	For 400kV GIS CB rectification works	01/Jul/2023	08:00	07/Jul/2023	20:00		PLANNED	Requested	
					REACTOR NO 1 AT											
					400KV KURUKSHETRA(PG)											
					AND 400KV ABDULLAPUR-											
		<u></u>	<u></u>		KURUKSHETRA (PG) CKT-2	POWERGRID										
574	RQ136784	OCC_208	sldcrs_sd	BAY	411-52T TIE BAY - 765/400 KV 1500		D	HALF YEARLY & QUARTERLY MAINTENANCE	24/Jul/2023	08:00	24/Jul/2023	18:00		PLANNED	Requested	
					MVA ICT 3 AT ANTA(RS) AND											
					FUTURE AT 400 KV											
575	RQ136783	OCC_208	sldcrs_sd	BAY	ANTA(RS) 411-52 D MAIN BAY	RRVPNL	D	HALF YEARLY & QUARTERLY	24/Jul/2023	08:00	24/Jul/2023	18:00		PLANNED	Requested	
					- 400KV BUS 2 AT ANTA(RS) AND			MAINTENANCE								
					FUTURE AT 400 KV ANTA(RS)	RRVPNL										
576	RQ136794	OCC_208	sldcrs_sd	BAY	40652B MAIN BAY - 400 KV MERTA-		D	QUARTERLY MAINT.WORK AND TESTING WORK OF BAY	22/Jul/2023	10:00	22/Jul/2023	13:00		PLANNED	Requested	
					HEERAPURA (RS) CKT-1 AT MERTA			& EQUIPMENTS								
£22	RQ136777	000 200	alders ad	BAY	401052D MAIN BAY	RRVPNL		HALF YEARLY MAINTENANCE	22/Jul/2023	00.00	22/Jul/2023	10.00		DIANNED	Danisatad	
3//	KQ130///	000_208	siucis_su	DAT	- 400KV PHAGI-		D	WORK OF ASSOCITED BAY	22/301/2023	08.00	22/301/2023	16.00		PLANNED	Requested	
					AJMER (RS) CKT-1 AT PHAGI(RS)			EQUIPMENTS								
578	RQ136792	OCC_208	sldcrs_sd	BAY	40652T TIE BAY -	RRVPNL	D	QUARTERLY MAINT.WORK	21/Jul/2023	13:00	21/Jul/2023	17:00		PLANNED	Requested	
					400 KV MERTA- HEERAPURA (RS)			AND TESTING WORK OF BAY & EQUIPMENTS								
					CKT-1 AND 125 MVAR BUS											
					REACTOR NO 1 AT 400KV MERTA(RS)											
					AT 400 KV MERTA(RS)	RRVPNL										
579	RQ136793	OCC_208	sldcrs_sd	BAY	40652A MAIN BAY - 125 MVAR BUS	THE STATE OF THE S	D	QUARTERLY MAINT.WORK AND TESTING WORK OF BAY	21/Jul/2023	10:00	21/Jul/2023	13:00		PLANNED	Requested	
					REACTOR NO 1 AT			& EQUIPMENTS								
580	RQ136778	OCC_208	sldcrs_sd	BAY	400KV MERTA(RS) 401052T TIE BAY -	RRVPNL	D	HALF YEARLY MAINTENANCE	21/Jul/2023	08:00	21/Jul/2023	18:00		PLANNED	Requested	
					765/400KV 1500 MVA ICT 2 AT			WORK OF ASSOCITED BAY EQUIPMENTS								
					PHAGI(RS) AND 400KV PHAGI-											
581	RQ136795	OCC_208	sldcrs_sd	BAY	AJMER (RS) CKT-1 40552B MAIN BAY -	RRVPNL	D	QUARTERLY MAINT.WORK	20/Jul/2023	10:00	20/Jul/2023	13:00		PLANNED	Requested	
					400 KV MERTA- RATANGARH (RS)			AND TESTING WORK OF BAY & EQUIPMENTS								
					CKT-1 AT MERTA	RRVPNL										
582	RQ136775	OCC_208	sldcrs_sd	BAY	40852D MAIN BAY - 400KV PHAGI-		D	QUARTERLY MAINTENANCE WORK OF MAIN BAY	20/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
					AJMER (RS) CKT-2 AT PHAGI(RS)	RRVPNL		EQUIPMENTS OF 400KV PHAGI- AJMER LINE-2								
583	RQ136790	OCC_208	sldcrs_sd	BAY	40552T TIE BAY -	- OVALINE	D	QUARTERLY MAINT.WORK	19/Jul/2023	13:00	19/Jul/2023	17:00		PLANNED	Requested	
					400 KV MERTA- RATANGARH (RS)			AND TESTING WORK OF BAY & EQUIPMENTS								
					CKT-1 AND 400/220 KV 315											
					MVA ICT 2 AT MERTA(RS) AT 400											
584	RQ136791	OCC 208	sldcrs sd	BAY	KV MERTA(RS) 40552A MAIN BAY -	RRVPNL	D	QUARTERLY MAINT.WORK	19/Jul/2023	10:00	19/Jul/2023	13:00		PLANNED	Requested	
					400/220 KV 315 MVA ICT 2 AT		-	AND TESTING WORK OF BAY & EQUIPMENTS	,, 2023		2,22,2023					
505	RQ136796	000 300	siders	BAY	MERTA(RS) 40452B MAIN BAY -	RRVPNL	D	QUARTERLY MAINT.WORK	18/Jul/2023	10:00	18/Jul/2023	12-00		DIAMMER	Requested	
205	NQ130/96	JULI 208	Janucis_Sd	DAT	400 KV BHADLA-		"	AND TESTING WORK OF BAY	10/Jul/2023	20.00	18/JUI/2023	15.00		CLANNED	nequested	
					MERTA (RS) CKT-1 (RRVPNL) AND			& EQUIPMENTS								
					400KV BUS 2 AT MERTA(RS) AT 400											
		L			KV MERTA(RS) (RRVPNL)	RRVPNL					<u></u>					
586	RQ136776	OCC_208	sldcrs_sd	BAY	40852C MAIN BAY - 400KV PHAGI-		D	HALF YEARLY MAINTENANCE WORK OF ASSOCITED BAY	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
					HEERAPURA (RS) CKT-1 AT PHAGI(RS)			EQUIPMENTS								
587	RQ136788	OCC 308	slders ed	BAY	40452T TIE BAY -	RRVPNL	D	QUARTERLY MAINT.WORK	17/Jul/2023	13:00	17/Jul/2023	17:00		PLANNED	Requested	
		2202	su	[400 KV BHADLA- MERTA (RS) CKT-1			AND TESTING WORK OF BAY & EQUIPMENTS	, , , , , 2023						questeu	
					AND 400/220 KV			& EQUITIVIENTS								
					315 MVA ICT 1 AT MERTA(RS) AT 400	DD1 45										
					KV MERTA(RS)	RRVPNL							1			l

588	RQ136789	OCC_208	sldcrs_sd	BAY	40452A MAIN BAY - 400/220 KV 315 MVA ICT 1 AT		D	QUARTERLY MAINT.WORK AND TESTING WORK OF BAY & EQUIPMENTS	17/Jul/2023	10:00	17/Jul/2023	13:00	PLANNED	Requested	
589	RQ136779	OCC_208	sldcrs_sd	BAY	MERTA(RS) 40752T TIE BAY - 765/400KV 1500 MVA ICT 1 AT PHAGI(RS) AND 400KV PHAGI- HEERAPURA (RS) CKT-2	RRVPNL	D	HALF YEARLY MAINTENANCE WORK OF ASSOCITED BAY EQUIPMENTS	17/Jul/2023	08:00	17/Jul/2023	18:00	PLANNED	Requested	
590	RQ136780	OCC_208	sldcrs_sd	BAY	40752C MAIN BAY - 765/400KV 1500 MVA ICT 1 AT PHAGI(RS)	RRVPNL	D	HALF YEARLY MAINTENANCE WORK OF ASSOCITED BAY EQUIPMENTS	14/Jul/2023	08:00	14/Jul/2023	18:00	PLANNED	Requested	
591	RQ136516	OCC_208	cpcc1_sd	BAY	4402 TIE BAY - 400KV BASSI(PG)- HEERAPURA(RS) (PG) CKT-1 AND 400KV HEERAPURA- HINDAUN (RS) CKT- 1 AT HEERAPURA(RS)		С	For New CBs Erection & Commisioning in All the three phases under Add Cap	13/Jul/2023	08:00	16/Jul/2023	18:00	PLANNED	Requested	
592	RQ136786	OCC_208	sldcrs_sd	BAY	414 TIE BAY - 400KV CHHABRA(RVUN)- KAWAI SCTPS(APR) (RS) CKT-1 AND FUTURE AT KAWAI SCTPS(APR)	APL	С	Circuit Breaker Overhauling	21/Jul/2023	08:00	23/Jul/2023	18:00	PLANNED	Requested	
593	RQ136127	OCC_208	stuup_sd	BAY	403 MAIN BAY - 765/400 KV 1500 MVA ICT 1 AT GR.NOIDA_2(UPC)	UPPTCL	D	For annual maintenance & Testing work (There is no load interruption as load will be feed by Tie bay)	18/Jul/2023	09:30	18/Jul/2023	13:30	PLANNED	Requested	
594	RQ136125	OCC_208	stuup_sd	BAY	402 TIE BAY - 765/400 KV 1500 MVA ICT 1 AT GR.NOIDA_2(UPC) AND 400/220 KV 315 MVA ICT 1 AT GR.NOIDA_2(UPC) AT 400 KV GR.NOIDA_2(UPC)	UPPTCL	D	For annual maintenance & Testing work (There is no load interruption as load will be feed by Main bay)	17/Jul/2023	13:30	17/Jul/2023	17:30	PLANNED	Requested	
595	RQ136123	OCC_208	stuup_sd	BAY	401 MAIN BAY - 400/220 KV 315 MVA ICT 1 AT GR.NOIDA_2(UPC)	UPPTCL	D	For annual maintenance & Testing work (There is no load interruption as load will be feed by Tie bay)	17/Jul/2023	08:00	17/Jul/2023	12:00	PLANNED	Requested	
596	RQ136106	OCC_208	stuup_sd	BAY	404 MAIN BAY - 400KV AGRA FATEHBAD-AGRA SOUTH (UP) CKT-1 AND SELECT AT AGRA SOUTH(UP)	UPPTCL	D	* FOR PLCC/DPC CKT TESTING AND OTHER MAINTENANCE WORK	11/Jul/2023	10:00	12/Jul/2023	18:00	PLANNED	Requested	
597	RQ136117	OCC_208	stuup_sd	BAY	404 MAIN BAY - 125 MVAR BUS REACTOR NO 1 AT 400KV SIKANDRABAD(UP)	UPPTCL	D	For annual maintenance & Testing work (There is no load interruption as load will be feed by Tie bay)	08/Jul/2023	13:30	08/Jul/2023	18:00	PLANNED	Requested	
598	RQ135895	OCC_208	stuup_sd	BAY	409 MAIN BAY - 400KV SARNATH- AZAMGARH (UP) CKT-1 AT SARNATH(UP)	UPPTCL	D	* for attending hot point & Bay tightening work 30.05.2023 15:58:52 INDIA (11007349).Complete Bay tightening	07/Jul/2023	14:30	07/Jul/2023	18:00	PLANNED	Requested	
599	RQ135897	OCC_208	stuup_sd	BAY	402 MAIN BAY - 400KV ANPARA_B(UPUN)- SARNATH(UP) (UP) CKT-1 AT SARNATH(UP)	UPPTCL	D	* for attending hot point & bus repairing work 30.05.2023 15:56:21 INDIA (11007349). Complete Bay tightening	07/Jul/2023	09:00	07/Jul/2023	14:00	PLANNED	Requested	
600	RQ136572	OCC_208	sldcup_sd	ВАУ	402 TIE BAY- 400/220 KV 500 MVA ICT 1 AT SIKANDRABAD(UP) (UPPTCL) AND 400 KV HARDUAGAN1 - SIKANDRABAD (UP) CKT-1 AT 400 KV SIKANDRABAD(UP) (UPPTCL)	UPPTCL	D	For annual maintenance & Testing work (There is no load interruption as load will be feed by Main bay)	06/Jul/2023	13:30	06/Jul/2023	18:00	PLANNED	Requested	
601	RQ136116	OCC_208	stuup_sd	BAY	412 MAIN BAY - 400 KV GR.NOIDA_2(UPC)- SIKANDRABAD (UP) CKT-1 AT SIKANDRABAD (UP)		D	For annual maintenance & Testing work (There is no load interruption as load will be feed by Tie bay)	06/Jul/2023	08:00	06/Jul/2023	12:00	PLANNED	Requested	
	RQ136115			ВАУ	411 TIE BAY - 400 KV GR.NOIDA_2(UPC)- SIKANDRABAD (UP) CKT-1 AND FUTURE AT 400 KV SIKANDRABAD(UP)		D	For annual maintenance & Testing work (There is no load interruption as load will be feed by Main bay)	05/Jul/2023		05/Jul/2023			Requested	
	RQ136114			ВАУ	408 TIE BAY - 400 KV GR.NOIDA_2(UPC)- SIKANDRABAD (UP) CKT-2 AND 400/220 KV 500 MVA ICT 2 AT SIKANDRABAD(UP) AT 400 KV SIKANDRABAD(UP)		D	For annual maintenance & Testing work (There is no load interruption as load will be feed by Main bay)	05/Jul/2023		05/Jul/2023			Requested	
604	RQ135896	OCC_208	stuup_sd	BAY	408 MAIN BAY - 400KV ANPARA_B(UPUN)- SARNATH(UP) (UP) CKT-2 AT SARNATH(UP)	UPPTCL	D	* For attending hot points and Bus repairing work 30.05.2023 15:47:40 INDIA (11007349). For repairing/strengthening of damaged bus and complete bay tightening.	03/Jul/2023	09:00	03/Jul/2023	18:00	PLANNED	Requested	

605	RQ136440	OCC_208	singrauli_sd	BAY	414 MAIN BAY - 400/132 KV 100 MVA ICT 2 AT		С	BUS 4 ISOLATOR REPLACEMENT	17/Jul/2023	08:00	20/Jul/2023	18:00	BAY WILL BE CHARGED THROUGH TRANSFER BUS	PLANNED	Requested	
606	RQ136435	OCC_208	singrauli_sd	BAY	SINGRAULI(NT) 414 MAIN BAY - 400/132 KV 100 MVA ICT 2 AT	NTPC	С	BUS 3 ISOLATOR REPALCEMNT	13/Jul/2023	08:00	16/Jul/2023	18:00	BAY WILL BE CHARGED THROUGH TRANSFER BUS	PLANNED	Requested	
607	RQ136785	OCC_208	sldcrs_sd	BAY	SINGRAULI(NT) 409 MAIN BAY - 63 MVAR BUS REACTOR NO 2 AT 400 KV KAWAI	NTPC	С	Circuit Breaker Overhauling	17/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
608	RQ135902	OCC_208	stuup_sd	BAY	SCTPS(APR) 405 TIE BAY - 400	APRL	D	For Annual maintenance of	08/Jul/2023	09:30	08/Jul/2023	18:30		PLANNED	Requested	
					KV BADAUNE- ROSA(UPC) (UP) CKT-1 (OCBTL) AND 400 KV BADAUNE(UP) - BUS 1 AT 400 KV BADAUNE(UP)			Bay & Spare Line-5 equipments								
609	RQ135900	OCC_208	stuup_sd	BAY	(OCBTL) 404 MAIN BAY - 400 KV BADAUNE(UP) -	OCBTL	D	For Annual maintenance of Bay & Spare Line-5 equipments	08/Jul/2023	09:30	08/Jul/2023	18:30		PLANNED	Requested	
610	RQ135901	OCC_208	stuup_sd	BAY	BUS 1 (OCBTL) 402 TIE BAY - 400 KV BADAUNE- ROSA(UPC) (UP) CKT-2 (OCBTL) AND 400 KV BADAUNE(UP) - BUS 1 AT 400 KV BADAUNE(UP) BADAUNE(UP)	OCBTL	D	For Annual maintenance of Bay & Spare Line-6 equipments	07/Jul/2023	09:30	07/Jul/2023	18:30		PLANNED	Requested	
611	RQ135899	OCC_208	stuup_sd	BAY	(OCBTL) 401 MAIN BAY -	OCBTL	D	For Annual maintenance of	07/Jul/2023	09:30	07/Jul/2023	18:30		PLANNED	Requested	
	RQ136381			TRANSFORMER	400 KV BADAUNE(UP) - BUS 1 (OCBTL) 400/220 KV 500	OCBTL	D	Bay & Spare Line-6 equipments FOR AMP WORK	29/Jul/2023		29/Jul/2023				Requested	
				MANAPORIVIER	MVA ICT 7 AT BHADLA_2 (PG)	POWERGRID								LAINNED	nequested	
613	RQ136383	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 6 AT BHADLA_2 (PG)	POWERGRID	D	FOR AMP WORK	28/Jul/2023	17:00	28/Jul/2023	23:00		PLANNED	Requested	
614	RQ136367	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 5 AT FATEHGARH_II(PG)	POWERGRID	D	LM erection Works	28/Jul/2023	17:00	30/Jul/2023	23:00		PLANNED	Requested	
615	RQ136382	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 5 AT		D	FOR AMP WORK	27/Jul/2023	17:00	27/Jul/2023	23:00		PLANNED	Requested	
616	RQ136379	OCC_208	cpcc1_sd	TRANSFORMER	BHADLA_2 (PG) 400/220 KV 315 MVA ICT 2 AT SONIPAT(PG)	POWERGRID	D	FOR AMP WORK	27/Jul/2023	08:00	27/Jul/2023	18:00		PLANNED	Requested	
617	RQ136384	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT		D	FOR AMP WORK	26/Jul/2023	17:00	26/Jul/2023	23:00		PLANNED	Requested	
618	RQ136380	OCC_208	cpcc1_sd	TRANSFORMER	BHADLA_2 (PG) 400/220 KV 315 MVA ICT 1 AT	POWERGRID	D	FOR AMP WORK	26/Jul/2023	08:00	26/Jul/2023	18:00		PLANNED	Requested	
619	RQ136734	OCC_208	cpcc3_sd	TRANSFORMER	SONIPAT(PG) 400/220 KV 500 MVA ICT 1 AT LUCKNOW_1(PG)	POWERGRID POWERGRID	D	AMP including compliance of 9th and 10th PCC meeting	26/Jul/2023	08:00	26/Jul/2023	18:00		PLANNED	Requested	
620	RQ136385	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT		D	FOR AMP WORK	25/Jul/2023	17:00	25/Jul/2023	23:00		PLANNED	Requested	
621	RQ136373	OCC_208	cpcc1_sd	TRANSFORMER	BHADLA_2 (PG) 400/220 KV 500 MVA ICT 3 AT FATEHGARH_II(PG)	POWERGRID	D	For testing and commissioning works with TBC Bay	23/Jul/2023	17:00	24/Jul/2023	23:00		PLANNED	Requested	
622	RQ136369	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT FATEHGARH_II(PG)	POWERGRID	D	For testing and commissioning works with TBC Bay	21/Jul/2023	17:00	22/Jul/2023	23:00		PLANNED	Requested	
623	RQ136375	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 5 AT FATEHGARH_II(PG)	POWERGRID	D	For erection works of 33 kV Auxiliary transformer of Statcom-1 and its	21/Jul/2023	17:00	27/Jul/2023	23:00		PLANNED	Requested	
624	RQ136468	OCC_208	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT	POWERGRID	D	commissioning PRD & OSR scheme modification work	21/Jul/2023	08:00	21/Jul/2023	18:00		PLANNED	Requested	
625	RQ136733	OCC_208	cpcc3_sd	TRANSFORMER	GORAKHPUR(PG) 400/220 KV 500	POWERGRID	D	AMP including compliance of	21/Jul/2023	08:00	21/Jul/2023	18:00		PLANNED	Requested	
626	RQ136362	OCC_208	cpcc1_sd	TRANSFORMER	MVA ICT 2 AT LUCKNOW_1(PG) 400/220 KV 500	POWERGRID	D	9th and 10th PCC meeting For replacement of LBB relay	20/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
					MVA ICT 4 AT BALLABHGARH(PG)	POWERGRID		of 220KV CB.								
627	RQ136368	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT FATEHGARH_II(PG)		D	For testing and commissioning works with TBC Bay	19/Jul/2023	17:00	20/Jul/2023	23:00		PLANNED	Requested	
628	RQ136361	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT BALLABHGARH(PG)	POWERGRID	D	For replacement of LBB relay of 220KV CB.	19/Jul/2023	08:00	19/Jul/2023	18:00		PLANNED	Requested	
629	RQ136852	OCC_208	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT SOHAWAL(PG)	POWERGRID	D	AMP works	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
630	RQ136363	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT BALLABHGARH(PG)		D	For replacement of LBB relay of 220KV CB.	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
631	RQ136360	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT BALLABHGARH(PG)	POWERGRID	D	For replacement of LBB relay of 220KV CB.	17/Jul/2023	08:00	17/Jul/2023	18:00		PLANNED	Requested	
632	RQ136357	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT BIKANER(PG)	POWERGRID POWERGRID	D	EARTHWIRE STRINGING WORK Above ICT1&2 JACK BUS	15/Jul/2023	17:00	15/Jul/2023	23:00		PLANNED	Requested	
633	RQ136356	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT		D	EARTHWIRE STRINGING WORK Above ICT1&2 JACK BUS	15/Jul/2023	17:00	15/Jul/2023	23:00		PLANNED	Requested	
634	RQ136371	OCC_208	cpcc1_sd	TRANSFORMER	BIKANER(PG) 400/220 KV 500 MVA ICT 7 AT FATEHGARH_II(PG)	POWERGRID	D	LBB testing and TBC testing of ICT-7 with TBC Bay and Tertiary Bay erection and	14/Jul/2023	17:00	19/Jul/2023	22:00		PLANNED	Requested	
635	RQ136467	OCC_208	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT	POWERGRID	D	commissioning works PRD & OSR scheme modification work	14/Jul/2023	08:00	14/Jul/2023	18:00		PLANNED	Requested	
			L	1	GORAKHPUR(PG)	POWERGRID	L		l						L	

636	RQ136850	OCC_208	cpcc3_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT		D	AMP works	13/Jul/2023	08:00	13/Jul/2023	18:00		PLANNED	Requested	
637	RQ136853	OCC_208	cpcc3_sd	TRANSFORMER	ALLAHABAD(PG) 400/220 KV 315 MVA ICT 1 AT	POWERGRID	D	AMP works	11/Jul/2023	08:00	11/Jul/2023	18:00		PLANNED	Requested	
638	RQ136851	OCC_208	cpcc3_sd	TRANSFORMER	SOHAWAL(PG) 400/220 KV 315 MVA ICT 1 AT	POWERGRID	D	AMP works	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
639	RQ136366	OCC_208	cpcc1_sd	TRANSFORMER	ALLAHABAD(PG) 400/220 KV 500 MVA ICT 2 AT KURUKSHETRA(PG)	POWERGRID	D	Outdoor GIB of ICT-3 will be installed in near vicinity of ICT-2 220kV SF6 to Air Bushing. For safety reasons, ICT-2 shutdown required for 220kV GIB erection works for ICT-3 commissioning .	10/Jul/2023	07:00	10/Jul/2023	20:00		PLANNED	Requested	
640	RQ136007	OCC_208	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 4 AT	POWERGRID	D	For AMP work	09/Jul/2023	08:00	09/Jul/2023	20:00	Kindly Approve	PLANNED	Requested	
641	RQ136628	OCC_208	cpcc3_sd	TRANSFORMER	MOGA(PG) 400/220 KV 315 MVA ICT 2 AT	POWERGRID	D	AMP works	08/Jul/2023	08:00	08/Jul/2023	18:00		PLANNED	Requested	
642	RQ136370	OCC_208	cpcc1_sd	TRANSFORMER	FATEHPUR(PG) 400/220 KV 500 MVA ICT 4 AT FATEHGARH_II(PG)	POWERGRID	D	LM erection Works	07/Jul/2023	17:00	16/Jul/2023	23:00		PLANNED	Requested	
643	RQ136359	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT SAHARANPUR(PG)	POWERGRID	D	FOR AMP WORK	07/Jul/2023	08:00	07/Jul/2023	18:00		PLANNED	Requested	
644	RQ136358	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT MANESAR(PG)	POWERGRID	D	FOR AMP WORK	06/Jul/2023	08:00	06/Jul/2023	18:00	500 MVA ICT-2 ALONG WITH 400 KV BAY 408 AND 220 KV BAY 207 AT GIS MANESAR SS	PLANNED	Requested	
645	RQ136374	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 8 AT FATEHGARH_II(PG)	POWERGRID	D	ICT-9 CSD Relay final tuning and other construction works	05/Jul/2023	17:00	08/Jul/2023	23:00		PLANNED	Requested	
646	RQ136376	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 7 AT FATEHGARH_II(PG)	POWERGRID	D	ICT-7 CSD Relay final tuning and other construction works	05/Jul/2023	17:00	10/Jul/2023	23:00		PLANNED	Requested	
647	RQ136355	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT TUGHLAKABAD(PG)	POWERGRID	D	FOR AMP WORK	05/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
648	RQ136364	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT BAHADURGARH(PG	POWERGRID	D	FOR AMP WORK	05/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
649	RQ136354	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 4 AT BHADLA(PG)	POWERGRID	D	FOR AMP WORK	03/Jul/2023	17:00	04/Jul/2023	23:00		PLANNED	Requested	
650	RQ136372	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 500 MVA ICT 9 AT FATEHGARH_II(PG)		D	For commissioning works of 400 kV ICT-6 under SS-63 package and ICT-9 CSD Relay final tuning, other	03/Jul/2023	17:00	09/Jul/2023	23:00	Bay 443 for commissioning check with ICT-6 LV	PLANNED	Requested	
651	RQ136365	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT BAHADURGARH(PG	POWERGRID	D	construction works FOR AMP WORK	03/Jul/2023	08:00	03/Jul/2023	18:00	Bay(BaY 231)	PLANNED	Requested	
652	RQ136378	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT BAWANA(DV)	POWERGRID	D	FOR AMP WORK	03/Jul/2023	08:00	03/Jul/2023	18:00		PLANNED	Requested	
653	RQ135992	OCC_208	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT KALA AMB(PKTL)	POWERGRID		GIB Erection of New Dia along with existing GIB of ICT-2. The clearance between existing GIB and new GIB is not permitting to work. Hence shutdown is proposed.	01/Jul/2023	09:00	15/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
654	RQ136377	OCC_208	cpcc1_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT BAWANA(DV)	POWERGRID	D	Attending Oil leakages from oltc	01/Jul/2023	08:00	02/Jul/2023	18:00		PLANNED	Requested	
655	RQ135865	OCC_208	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT LUCKNOW(UP)		D	* For Upgradation of Bus-Bar Protection Panel from Electromechanical type >X to Numerical Type (Connection of CT Bus-Bar Prot	28/Jul/2023	09:00	28/Jul/2023	18:00		PLANNED	Requested	
656	RQ135866	OCC_208	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 1 AT LUCKNOW(UP)	UPPTCL UPPTCL	D	* For Upgradation of Bus-Bar Protection Panel from Electromechanical type >X to Numerical Type (Connection of CT Bus-Bar Prot	27/Jul/2023	09:00	27/Jul/2023	18:00		PLANNED	Requested	
657	RQ135867	OCC_208	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT UNNAO(UP)		D	* Routine Protection Testing and Preventive Maintenance of Transformer and Bay equipment.	27/Jul/2023	09:00	27/Jul/2023	17:00		PLANNED	Requested	
658	RQ135868	OCC_208	stuup_sd	TRANSFORMER	MVA ICT 2 AT	UPPTCL	D	* Maintenance work will be carried out during this	21/Jul/2023	10:00	21/Jul/2023	16:00		PLANNED	Requested	
659	RQ135846	OCC_208	stuup_sd	TRANSFORMER	GR.NOIDA(UPC) 400/220 KV 315 MVA ICT 3 AT	UPPTCL	D	* For Routine Bay Maintenance and testing at	11/Jul/2023	10:00	11/Jul/2023	18:00		PLANNED	Requested	
660	RQ135873	OCC_208	stuup_sd	TRANSFORMER	SULTANPUR(UP) 400/220 KV 315 MVA ICT 2 AT BANDA(UP)	UPPTCL	D	400KV S/S Sultanpur * For work of 400 KV 220 KV Bay maintenance related to 315 MVA ICT-2 at 400 KV S/S	10/Jul/2023	10:00	11/Jul/2023	18:00		PLANNED	Requested	
661	RQ135855	OCC_208	stuup_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT SARNATH(UP)	UPPTCL	D	Banda. * For General Maintenance and attending hot points >X* 30.05.2023 16:00:35 INDIA (11007349)	08/Jul/2023	09:00	08/Jul/2023	18:00		PLANNED	Requested	
662	RQ135847	OCC_208	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT SULTANPUR(UP)	UPPTCL	D	* For Routine Bay Maintenance and testing at 400KV S/S Sultanpur	07/Jul/2023	10:00	07/Jul/2023	18:00		PLANNED	Requested	
663	RQ135872	OCC_208	stuup_sd	TRANSFORMER	400/220 KV 200 MVA ICT 2 AT AGRA SOUTH(UP)	UPPTCL	D	* Routine Testing and Maintenance Work.	07/Jul/2023	08:00	08/Jul/2023	18:00		PLANNED	Requested	
664	RQ135856	OCC_208	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 4 AT SARNATH(UP)	UPPTCL	D	* For General maintenance and bay tightening work >X* 30.05.2023 15:53:04 INDIA (11007349)	06/Jul/2023	09:00	06/Jul/2023	18:00		PLANNED	Requested	
665	RQ135861	OCC_208	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT BAREILLY(UP)	UPPTCL	D	* preventive maintenance	06/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	

ccc	00135054	000 200		TDANCEODAAED	400/220 KV 315	I	D	# F C Maintanna	05/101/2022	00.00	05/11/2022	10.00		DI ANINED	Daniel de la constant	
000	RQ135854	UCC_208	stuup_sa	TRANSFORMER	MVA ICT 3 AT	LIBETO	U	* For General Maintenance and Complete Bay Tightening	05/Jul/2023	09:00	05/Jul/2023	18:00		PLANNED	Requested	
667	RQ135862	OCC_208	stuup_sd	TRANSFORMER	SARNATH(UP) 400/220 KV 315 MVA ICT 2 AT	UPPTCL	D	* preventive maintenance	05/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
668	RQ135892	OCC_208	stuup_sd	TRANSFORMER	BAREILLY(UP) 400/220 KV 315 MVA ICT 2 AT	UPPTCL	С	Attending of Transformer Oil Leakage.	05/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
669	RQ135845	OCC 208	stuun sd	TRANSFORMER	ALIGARH(UP) 400/220 KV 240	UPPTCL	D	* For Routine Bay	04/Jul/2023	10:00	04/Jul/2023	18:00		PLANNED	Requested	
					MVA ICT 2 AT SULTANPUR(UP)	UPPTCL	_	Maintenance and testing at 400KV S/S Sultanpur	- 4.14		2 7127222				,	
670	RQ135857	OCC_208	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT	OTT TEE	D	* for general Maintenance and bay tightening >X* 30.05.2023	04/Jul/2023	09:00	04/Jul/2023	18:00		PLANNED	Requested	
					SARNATH(UP)	UPPTCL		15:50:40 INDIA (11007349)								
671	RQ135871	OCC_208	stuup_sd	TRANSFORMER	400/220 KV 200	OFFICE	D	* Routine Testing and	04/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
					MVA ICT 1 AT AGRA SOUTH(UP)	UPPTCL		Maintenance Work			(:					
672	RQ135848	OCC_208	stuup_sd	TRANSFORMER	400/220 KV 315 MVA ICT 4 AT		D	For overhauling ot circuit breaker on the 400 kV side	02/Jul/2023	10:00	03/Jul/2023	18:00		PLANNED	Requested	
673	RQ136560	OCC_208	sldchr_sd	TRANSFORMER	SULTANPUR(UP) 400/220 KV 315	UPPTCL	D	To verify BI, BOM & amp;	25/Jul/2023	09:00	25/Jul/2023	18:00		PLANNED	Requested	
					MVA ICT 2 AT DHANODA(HV)	HVPNL		protection signals in SAS.								
674	RQ136559	OCC_208	sldchr_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT		D	To verify BI, BOM & Drotection signals in SAS.	21/Jul/2023	09:00	21/Jul/2023	18:00		PLANNED	Requested	
675	RQ136711	OCC 208	sldchr sd	TRANSFORMER	DHANODA(HV) 400/220 KV 315	HVPNL	D	For testing of tan detla and	18/Jul/2023	10:00	18/Jul/2023	15:00		PLANNED	Requested	
					MVA ICT 3 AT NAWADA(HV)	HVPNL		bushing and winding	,,		,,				,	
676	RQ136561	OCC_208	sldchr_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT		D	To verify BI, BOM & amp;	06/Jul/2023	09:00	06/Jul/2023	18:00		PLANNED	Requested	
677	00126720	000 200	-144	TRANSFORMER	DHANODA(HV)	HVPNL		protection signals in SAS.	25/1-1/2022	00.00	25/1-1/2022	10.00		DIANNED	Danis at a d	
0/7	RQ136720	UCC_208	siacts_sd	TRANSFORMER	400/220 KV 315 MVA ICT 3 AT		D	Maintenance work of bay equipments , isolators and	25/Jul/2023	U8:UU	25/Jul/2023	18:00		PLANNED	Requested	
					RATANGARH(RS)	RRVPNL		testing work of bay equipments.								
678	RQ136716	OCC_208	sldcrs_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT		D	For Quarterly/Half Yearly maintenance work	21/Jul/2023	08:00	21/Jul/2023	18:00		PLANNED	Requested	
679	RQ136722	OCC_208	sldcrs_sd	TRANSFORMER	HINDAUN(RS) 400/220 KV 315	RRVPNL	D	Routine Bay Maintenance	20/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
					MVA ICT 2 AT BIKANER(RS)	RRVPNL		Work								
680	RQ136714	OCC_208	sldcrs_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT		D	For Quarterly/Half Yearly maintenance work	20/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
681	RQ136719	OCC 208	sldcrs sd	TRANSFORMER	HINDAUN(RS) 400/220 KV 500	RRVPNL	D	Quarterly/ Half Yearly/ Yearly	19/Jul/2023	16:00	20/Jul/2023	23:00		PLANNED	Requested	
					MVA ICT 1 AT BHADLA(RS)	RRVPNL		Maintenance work at 400KV GSS, Bhadla	.,,		,,,,				.,	
682	RQ136725	OCC_208	sldcrs_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT	MKVI NE	D	Preventive maintenance &	19/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
602	00126710	000 200	-144	TRANSFORMER	KANKANI(RS)	RRVPNL	D	Testing of bay and equipments	10/1-1/2022	00.00	40/11/2022	10.00		DIANNED	Danis at a d	
083	RQ136718	UCC_208	siders_sd	TRANSFORMER	400/220 KV 315 MVA ICT 2 AT		U	Maintenance work of bay equipments , isolators and	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
					RATANGARH(RS)	RRVPNL		testing work of bay equipments.								
684	RQ136715	OCC_208	sldcrs_sd	TRANSFORMER	400/220 KV 500 MVA ICT 2 AT		D	Quarterly/ Half Yearly/ Yearly Maintenance work at 400KV	17/Jul/2023	16:00	18/Jul/2023	23:00		PLANNED	Requested	
685	RQ136726	OCC_208	sldcrs_sd	TRANSFORMER	BHADLA(RS) 400/220 KV 500	RRVPNL	D	GSS, Bhadla Preventive maintenance &	17/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
					MVA ICT 2 AT KANKANI(RS)	RRVPNL		Testing of bay and equipments								
686	RQ136724	OCC_208	sldcrs_sd	TRANSFORMER	400/220 KV 500 MVA ICT 3 AT		D	Quarterly/ Half Yearly/ Yearly Maintenance work at 400KV	14/Jul/2023	16:00	15/Jul/2023	23:00		PLANNED	Requested	
687	RQ136721	OCC_208	sldcrs_sd	TRANSFORMER	BHADLA(RS) 400/220 KV 315	RRVPNL	D	GSS, Bhadla Routine Bay Maintenance	14/Jul/2023	08:00	14/Jul/2023	18:00		PLANNED	Requested	
					MVA ICT 1 AT BIKANER(RS)	RRVPNL		Work								
688	RQ136723	OCC_208	sldcrs_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT		D	QUARTERLY MAINT.WORK OF BAY & EQUIPMENTS	13/Jul/2023	08:00	13/Jul/2023	18:00		PLANNED	Requested	
689	RQ136717	OCC 208	sldcrs sd	TRANSFORMER	MERTA(RS) 400/220 KV 315	RRVPNL	D	Maintenance work of bay	06/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
					MVA ICT 1 AT RATANGARH(RS)			equipments , isolators and testing work of bay							.,	
600	RQ136727	000 200	clderc cd	TRANSFORMER	400/220 KV 500	RRVPNL	D	equipments. Routine Maintenance and	06/Jul/2023	08:00	06/Jul/2023	19:00		DIANNED	Requested	
030	NQ130727	OCC_200	314613_34	TRAINSI ORIVIER	MVA ICT 1 AT BHILWARA(RS)			Testing of 500 MVA 400/220/33 KV Transformer	00/30/2023	08.00	00/341/2023	18.00		PEANINED	nequesteu	
					BHILWARA(R3)	DDVDNII		No.1 and Bay (4152A) &								
691	RQ136713	OCC_208	sldcrs_sd	TRANSFORMER	400/220 KV 315	RRVPNL	D	Associated Equipments QUARTERLY MAINT.WORK OF	03/Jul/2023	08:00	03/Jul/2023	18:00		PLANNED	Requested	
		005 -			MVA ICT 2 AT MERTA(RS)	RRVPNL		BAY & EQUIPMENTS	40.00	00.05	45.5	10.5-	ne ll c			
692	RQ136048	OCC_208	cpcc2_sd	TRANSFORMER	400/220 KV 315 MVA ICT 1 AT		С	"Scheme modification works:- 1. Cable termination for	12/Jul/2023	09:00	13/Jul/2023	18:00	Kindly Approve alog with its 400KV and	PLANNED	Requested	
					DEHAR(BB)			scheme modification implementation work at CT					220KV bays			
								ends Relay ends and 86 Group relay ends. 2. 2 nos. of								
								Backup O/c & EF cable terminataion (Mechanical								
								protection of ICT will be brought in these 02 nos. relays								
								and Output command will be								
								extended to 86 group relay in POWER House), - Signal								
								testing and commissioning. 3. Bus Voltage extension for								
								Earth fault feature in Backup O/c & EF protection relay								
								through selection logic (isolator status wiring for								
								selected Bus Voltage). 4. Integration in SCADA and								
								testing of all signals in RHMI During the scheme								
								modification work AMP work for ICT will also be done."								
						POWERGRID, BBMB										
693	RQ135821	OCC_208	stuup_sd	TRANSFORMER		POINIR	D	For annual testing of	05/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
					MVA ICT 2 AT HARDUAGANJ (UP)			transformer								
694	RQ135822	OCC_208	stuup_sd	TRANSFORMER	400/220 KV 315	UPRVUNL	D	For annual testing of	03/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
					MVA ICT 1 AT HARDUAGANJ (UP)			transformer								
695	RQ136018	OCC_208	cpcc2_sd	TRANSFORMER	220/66 KV 50 MVA	UPRVUNL	D	For AMP work	10/Jul/2023	09:00	10/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
						POWERGRID										

606	RQ136426	OCC 208	cocc3 ed	TRANSFORMER	220/132 KV 100		D	AMP Works. Actual S/D	03/Jul/2023	ne-nn	03/Jul/2023	18:00		DIANNED	Requested	
050	AQ130420	OCC_208	cpccs_su	TRANSPORIVER	MVA ICT 2 AT SITARGANJ(PG)	POWERGRID		required on 29.06.2023	05/301/2025	08.00	05/301/2025	18.00		PLANNED	Requesteu	
697	RQ136425	OCC_208	cpcc3_sd	TRANSFORMER	220/132 KV 100 MVA ICT 3 AT SITARGANJ(PG)	POWERGRID	D	AMP Works. Actual S/D required on 26.06.2023	01/Jul/2023	08:00	01/Jul/2023	18:00		PLANNED	Requested	
698	RQ136130	OCC_208	napp_sd	AC TRANSMISSION LINE CIRCUIT	220 KV NAPP(NP)- SIMBHOLI(UP) (UP) CKT-1	UPPTCL	С	Insulator cleaning CT and CVT diagnostic and relay testing iob.	11/Aug/2023	08:00	12/Aug/2023	18:00	NAPS-2 BSD	PLANNED	Requested	
699	RQ136129	OCC_208	napp_sd	AC TRANSMISSION LINE CIRCUIT	220 KV NAPP(NP)- SAMBHAL(UP) (UP) CKT-1	UPPTCL	С	Insulator cleaning CT and CVT diagnostic and relay testing iob.	09/Aug/2023	08:00	10/Aug/2023	18:00	NAPS-2 BSD	PLANNED	Requested	
700	RQ136128	OCC_208	napp_sd	AC TRANSMISSION	220 KV NAPP(NP)- KHURJA(UP) (UP)	OFFICE	С	Khurja line jumper tightness, insulator cleaning CT and CVT	04/Aug/2023	08:00	07/Aug/2023	18:00	NAPS-2 BSD	PLANNED	Requested	
				LINE CIRCUIT	CKT-1	UPPTCL		diagnostic and relay testing job.								
701	RQ135842	OCC_208	stuup_sd	AC TRANSMISSION	220 KV SULTANPUR(UP)-	OFFICE	D	* For routine bay maintenance work at 220KV S/S Sultanpur.	28/Jul/2023	10:00	28/Jul/2023	18:00		PLANNED	Requested	
702	00135977	000 300	ntpcos_sd	LINE CIRCUIT	TANDA(NT) (UP) CKT-2 220 KV	UPPTCL	С	CT and bay equipment testing	28/Jul/2023	08:00	29/Jul/2023	19:00		DIANNED	Requested	
702	(Q133877	000_200	mtpcos_su	TRANSMISSION LINE CIRCUIT	UNCHAHAR(NT)- RAEBAREILLY(PG) (UP) CKT-2	UPPTCL		er and bay equipment testing	20/30// 2023	08.00	23/34//2023	18.00		PENINED	Requested	
703	RQ136683	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHPUR(PG)- SARH(UP) (UP) CKT-		D	AMP WORK	27/Jul/2023	08:00	27/Jul/2023	18:00		PLANNED	Requested	
704	RQ136682	OCC_208	cpcc3_sd	AC TRANSMISSION	220 KV FATEHPUR(PG)-	UPPTCL	D	AMP WORK	26/Jul/2023	08:00	26/Jul/2023	18:00		PLANNED	Requested	
				LINE CIRCUIT	SARH(UP) (UP) CKT-	UPPTCL										
705	RQ136287	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BAGHPAT(PG)- BAGHPAT(UP) (UP)		С	For rectification of PD defect in 220 kV Bus 1	04/Jul/2023	10:00	08/Jul/2023	20:00		PLANNED	Requested	
706	RQ136286	OCC_208	cpcc1_sd	AC TRANSMISSION	CKT-2 220 KV BAGHPAT(PG)-	UPPTCL	С	For rectification of PD defect in 220 kV Bus 1	04/Jul/2023	10:00	08/Jul/2023	20:00		PLANNED	Requested	
				LINE CIRCUIT	BAGHPAT(UP) (UP) CKT-1	UPPTCL										
707	RQ136285	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BAGHPAT(PG)- MODIPURAM_2 (UP) (UP) CKT-1	UPPTCL	С	For rectification of PD defect in 220 kV Bus 1	04/Jul/2023	10:00	08/Jul/2023	20:00		PLANNED	Requested	
708	RQ135863	OCC_208	stuup_sd	AC TRANSMISSION LINE CIRCUIT	220 KV PANTNAGAR(UK)- BAREILLY(UP) (UP)	UPPTCL	D	* For relay testing and routine maintenance	03/Jul/2023	09:00	03/Jul/2023	17:00		PLANNED	Requested	
709	RQ136868	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	CKT-1 220 KV AZIZPUR (UP)- SHAHJAHANPUR(P G) (UP) CKT-2	UPPTCL	D	AMP works	02/Jul/2023	08:00	02/Jul/2023	18:00		PLANNED	Requested	
710	RQ136866	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SOHAWAL(PG)- SOHAWAL(UP) (UP)	OFFICE	D	As a reference Bay for Bus bar testing of ICT-III 220KV Bay 204 with 220KV Bus-II. Actual	01/Jul/2023	08:00	01/Jul/2023	18:00		PLANNED	Requested	
711	RQ135939	OCC 208	slders sd	AC	220 KV	UPPTCL	D	S/D required on 22.06.2023 Quarterly maintenance work	28/Jul/2023	08:00	28/Jul/2023	18:00		PLANNED	Requested	
/11	(Q133333	000_200	siders_su	TRANSMISSION LINE CIRCUIT	SAWAIMADHOPUR(RS)-DAUSA(RS) (PG) CKT-1	POWERGRID		quarterly maintenance work	20/301/2023	06.00	26/34//2023	18.00		PENINED	nequesteu	
712	RQ135944	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)- LALSOTE(RS) (PG) CKT-1	POWERGRID	D	Quarterly maintenance and Installation of pilot string on (C,D type tower) on 220 KV Lalsot-Anta Line	28/Jul/2023	08:00	28/Jul/2023	18:00		PLANNED	Requested	
713	RQ135978	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)- SALAL(NH) (PG) CKT		D	Shifting of line from ERS to new tower at L-131	27/Jul/2023	09:00	29/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
714	RQ135943	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV LALSOTE(RS)- DAUSA(RS) (PG)	POWERGRID	D	Quarterly maintenance work	27/Jul/2023	08:00	27/Jul/2023	18:00		PLANNED	Requested	
715	RQ136339	OCC_208	cpcc1_sd	AC TRANSMISSION	CKT-1 220 KV FARIDABAD	POWERGRID	D	Earth wire rectification Tower No. 42 and 42A highway	26/Jul/2023	10:00	26/Jul/2023	14:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	SEC-58 (HV)- FARIDABAD(NT) (PG) CKT-2			No. 42 and 42A highway crossing by Ms PSH infra (to attend punch point)								
716	RQ136329	OCC_208	cpcc1_sd	AC TRANSMISSION	220 KV ANTA(NT)- SAWAIMADHOPUR(POWERGRID	D	AMP WORK	26/Jul/2023	08:00	26/Jul/2023	18:00		PLANNED	Requested	
717	RQ136046	OCC_208	cpcc2_sd	LINE CIRCUIT AC	RS) (PG) CKT-1 220 KV	POWERGRID	D	Shut down is required on	24/Jul/2023	09:00	27/Jul/2023	18:00	Under construction	PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	HAMIRPUR(PG)- HAMIRPUR(HP) (PG) CKT-1			alternate day basis for replacement of Deccan make polymer insulators in line crossings with non auto mode of other 220KV Hamirpur					head, Kindly Approve			
718	RQ136047	OCC_208	cpcc2_sd	AC TRANSMISSION	220 KV HAMIRPUR(PG)-	POWERGRID	D	Hamirpur Ckt-II Shut down is required on alternate day basis for	24/Jul/2023	09:00	27/Jul/2023	18:00	Under construction head, Kindly	PLANNED	Requested	
				LINE CIRCUIT	HAMIRPUR(PG)- HAMIRPUR(HP) (PG) CKT-2			alternate day basis for replacement of Deccan make polymer insulators in line crossings with non auto mode of other 220KV Hamirpur					Approve			
719	RQ135977	OCC_208	cpcc2_sd	AC	220 KV	POWERGRID	D	Hamirour Ckt-I Shifting of line from ERS to	24/Jul/2023	09:00	26/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	KISHENPUR(PG)- SALAL(NH) (PG) CKT- 1	POWERGRID		new tower at L-131								
720	RQ136059	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENGANGA(NH)- WAGOORA(PG) (PG) CKT-2	POWERGRID	D	Repair of damaged conductor in span no 289-290	23/Jul/2023	09:00	23/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
721	RQ136328	OCC_208	cpcc1_sd	AC TRANSMISSION	220 KV ANTA(NT)- BHILWARA(RS) (PG)		D	AMP WORK	22/Jul/2023	08:00	22/Jul/2023	18:00		PLANNED	Requested	
722	RQ135979	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)- UDHAMPUR(PDD)	POWERGRID	D	For AMP work of line	21/Jul/2023	09:00	21/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
723	RQ135980	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	(PG) CKT-1 220 KV KISHENPUR(PG)- UDHAMPUR(PDD)	POWERGRID	D	For AMP work of line	21/Jul/2023	09:00	21/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
724	RQ135976	OCC_208	cpcc2_sd	AC TRANSMISSION	(PG) CKT-2 220 KV KISHENPUR(PG)-	POWERGRID	D	For AMP work of line	20/Jul/2023	09:00	20/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
				LINE CIRCUIT	SARNA(PS) (PG) CKT-2	POWERGRID										

725	RQ135975	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV KISHENPUR(PG)- SARNA(PS) (PG) CKT-1	POWERGRID	D	For AMP work of line	19/Jul/2023	09:00	19/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
726	RQ136322	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_B(NP)- DEBARI(RS) (PG) CKT-1		D	AMP work line and bay equipment's.	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
727	RQ135997	OCC_208	cpcc2_sd	AC TRANSMISSION	220 KV CHAMERA_3(NH)-	POWERGRID	D	For rectifiaction of SIR Audit observations	16/Jul/2023	10:00	16/Jul/2023	15:00	Kindly Approve	PLANNED	Requested	
				LINE CIRCUIT	CHAMBA(PG) (PG) CKT-2	POWERGRID										
728	RQ136133	OCC_208	sldcjk_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SALAL(NH)- JAMMU(PDD) (PG) CKT-1	POWERGRID	D	Preventive Maintenance	16/Jul/2023	07:00	16/Jul/2023	12:00	20 - 50 MW load may be shifted and fed from the sister 220 KV grids subject to real time loading and availability of power from these grid s. Rest 200 MW load (approx.)shall be affected.	PLANNED	Requested	
729	RQ136134	OCC_208	sldcjk_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SALAL(NH)- JAMMU(PDD) (PG) CKT-2	POWERGRID	D	Preventive Maintenance	16/Jul/2023	07:00	16/Jul/2023	12:00	20-50 MW load may be shifted and fed from the sister 220 KV grids subject to real time loading and availability of power from these grid s. Rest 200 MW load (approx.)shall be affected.	PLANNED	Requested	
730	RQ135996	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHAMERA_3(NH)- CHAMBA(PG) (PG)		D	For rectifiaction of SIR Audit observations	15/Jul/2023	10:00	15/Jul/2023	15:00	Kindly Approve	PLANNED	Requested	
731	RQ136620	OCC_208	sldcup_sd	AC TRANSMISSION LINE CIRCUIT	CKT-1 220 KV AURAIYA(NT)- SIKANDRA(UP) (PG) CKT-2	POWERGRID	D	Stringing work of LILO Tower ,LILO of 220 KV AURAIYA(NT)- SIKANDRA(UP) (PG) CKT-2 at 220KV Saifai.	15/Jul/2023	10:00	16/Jul/2023	16:00		PLANNED	Requested	
732	RQ135938	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_B(NP)- DEBARI(RS) (PG) CKT-1		D	maintenance of line	14/Jul/2023	08:00	14/Jul/2023	18:00		PLANNED	Requested	
733	RQ136272	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_B(NP)- CHITTORGARH(RS) (PG) CKT-2	POWERGRID	D	SHUTDOWN NATURE DEFECT RECTIFICATION	14/Jul/2023	08:00	14/Jul/2023	18:00	Line maintenance work.	PLANNED	Requested	
734	RQ135972	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SAMBA(PG)- HIRANAGAR(PDD) (PG) CKT-1		D	For AMP work	13/Jul/2023	10:00	13/Jul/2023	16:00	Kindly Approve	PLANNED	Requested	
735	RQ136271	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_B(NP)- CHITTORGARH(RS) (PG) CKT-1	POWERGRID	D	SHUTDOWN NATURE DEFECT RECTIFICATION	13/Jul/2023	08:00	13/Jul/2023	18:00	Line maintenance work.	PLANNED	Requested	
736	RQ135981	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BAIRASIUL(NH)- PONG(BB) (PG) CKT-	POWERGRID	D	For AMP work at BBMB Pong	12/Jul/2023	10:00	12/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
737	RQ135958	OCC_208	sldcrs_sd	AC TRANSMISSION	220 KV ANTA(NT)- BHILWARA(RS) (PG)	POWERGRID	D	Routine Maintenance of Bay & Line	12/Jul/2023	08:00	12/Jul/2023	18:00		PLANNED	Requested	
738	RQ136323	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_C(NP)- ANTA(NT) (PG) CKT- 1		D	Retrofitting of LBB relay	12/Jul/2023	08:00	13/Jul/2023	18:00		PLANNED	Requested	
	RQ136273			AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_B(NP)- DEBARI(RS) (PG) CKT-1	POWERGRID	D	SHUTDOWN NATURE DEFECT RECTIFICATION	12/Jul/2023		12/Jul/2023		Line maintenance work.		Requested	
740	RQ135957	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)- BHILWARA(RS) (PG) CKT-1	POWERGRID	D	Routine Maintenance of Bay & Line	11/Jul/2023	08:00	11/Jul/2023	18:00		PLANNED	Requested	
741	RQ136321	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_B(NP)- CHITTORGARH(RS) (PG) CKT-1	POWERGRID	D	AMP work line and bay equipment's.	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
742	RQ136343	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HEERAPURA(RS)- I.G.NAGAR(RS) (PG) CKT-1	POWERGRID	С	For New CTs Erection & Commissioning in All the three phases under Add Cap	09/Jul/2023	08:00	12/Jul/2023	18:00		PLANNED	Requested	
743	RQ136302	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)- BHILWARA(RS) (PG) CKT-1	POWERGRID	D	For rectification of shutdown nature defects	07/Jul/2023	08:00	07/Jul/2023	18:00	other ckt will be in non auto mode.	PLANNED	Requested	
744	RQ136860	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV TANAKPUR(NH)- SITARGANJ(PG) (PG) CKT-1	POWERGRID	D	AMP WORK	06/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
	RQ136303			AC TRANSMISSION LINE CIRCUIT	220 KV ANTA(NT)- BHILWARA(RS) (PG) CKT-2	POWERGRID	D	For rectification of shutdown nature defects	06/Jul/2023		06/Jul/2023		other ckt will be in non auto mode.		Requested	
	RQ136044			AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(PG)- NEHRIAN(HP) (PG) CKT-1	POWERGRID	D	Shut down is required on alternate day basis for replacement of Deccan make polymer insulators in line crossings with non auto mode of other 220KV Jalandhar Nebrian Ckt-II	05/Jul/2023		08/Jul/2023		Under construction head, Kindly Approve		Requested	
	RQ136045			AC TRANSMISSION LINE CIRCUIT	220 KV JALANDHAR(PG)- NEHRIAN(HP) (PG) CKT-2	POWERGRID	D	Shut down is required on alternate day basis for replacement of Deccan make polymer insulators in line crossings with non auto mode of other 220KV Jalandhar Nehrian Ckt-I	05/Jul/2023		08/Jul/2023		Under construction head, Kindly Approve		Requested	
	RQ136706			AC TRANSMISSION LINE CIRCUIT	220 KV PITHORAGARH- JAULJIVI (PG) CKT- 2	POWERGRID	D	AMP WORK	05/Jul/2023		05/Jul/2023				Requested	
	RQ135931			AC TRANSMISSION LINE CIRCUIT	220 KV HEERAPURA(RS)- I.G.NAGAR(RS) (PG) CKT-1	POWERGRID	D	Quartererly maintenance and testing of Bay Equipment	05/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
750	RQ136859	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SITARGANJ(PG)- CBGANJ(UP) (PG) CKT-1	POWERGRID	D	AMP WORK	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
				•												

751	RQ136274	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RAPS_C(NP)- ANTA(NT) (PG) CKT- 1	POWERGRID	D	Auto Reclose off is required for OPGW INSTALLATION works under Northern Region Optical fibre Strengthening Scheme (NROSS)	01/Jul/2023	08:00	31/Jul/2023	18:00		PLANNED	Requested	
752	RQ136019	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV DASUYA(PS)- JALANDHAR(PG) (PG) CKT-1	POWERGRID	D	For AMP work of Line	01/Jul/2023	08:00	01/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
753	RQ135937	OCC_208	sldcrs_sd	AC TRANSMISSION			D	maintenance of line	28/Jul/2023	08:00	28/Jul/2023	18:00		PLANNED	Requested	
754	RQ135928	OCC_208	sldcrs_sd	AC TRANSMISSION	CKT-1 220 KV AGRA(PG)- BHARATPUR(RS)	POWERGRID,	D	maintenance of line and bay at 220KV GSS RVPN, Bharatpur	27/Jul/2023	08:00	27/Jul/2023	18:00		PLANNED	Requested	
755	RQ136819	OCC_208	cpcc3_sd	AC TRANSMISSION	(PG) CKT-1 220 KV AGRA(PG)- BHARATPUR(RS)	POWERGRID,	D	AMP WORK	19/Jul/2023	08:00	19/Jul/2023	18:00		PLANNED	Requested	
756	RQ135929	OCC_208	sldcrs_sd	LINE CIRCUIT AC	(PG) CKT-1 220 KV	RRVPNL	D	Quartererly maintenance and	06/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	HEERAPURA(RS)- MANSAROVAR(RS) (PG) CKT-1	POWERGRID, RRVPNL		testing of Bay Equipment								
757	RQ136342	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HEERAPURA(RS)- MANSAROVAR(RS)	POWERGRID,	С	For New CTs Erection & Commissioning in All the three phases under Add Cap	05/Jul/2023	08:00	08/Jul/2023	18:00		PLANNED	Requested	
758	RQ136759	OCC_208	cpcc3_sd	AC	(PG) CKT-1 220 KV AGRA(PG)-	RRVPNL	D	For rectification of S/D nature	01/Jul/2023	08:00	01/Jul/2023	18:00		PLANNED	Requested	
759	RQ136586	OCC_208	bbmb_sd	TRANSMISSION LINE CIRCUIT AC	SIKANDRA(UP) (PG) CKT-1 220 KV BHIWANI-	POWERGRID, RRVPNL	D	defects. Half yearly mtc	27/Jul/2023	08:00	27/Jul/2023	18:00		PLANNED	Requested	
760	RQ136613	OCC 208	siders sid	TRANSMISSION LINE CIRCUIT AC	HISSAR (BB) CKT-1 220 KV CHARKHI	ввмв	D	For Tree trimming & bay	20/Jul/2023	08:00	20/Jul/2023	19:00		DIANNED	Requested	
700	NQ130013	000_200	siucis_su	TRANSMISSION LINE CIRCUIT	DADRI(BB)- KHETRI(RS) (BB)			maintenance work	20/30// 2023	06.00	20/30// 2023	18.00		PEANINED	nequesteu	
761	RQ136612	OCC_208	sldcrs_sd	AC TRANSMISSION LINE CIRCUIT	CKT-2 220 KV CHARKHI DADRI(BB)- KHETRI(RS) (BB) CKT-1	BBMB	D	For Tree trimming & bay maintenance work	18/Jul/2023	08:00	18/Jul/2023	18:00		PLANNED	Requested	
762	RQ136585	OCC_208	bbmb_sd	AC TRANSMISSION	220 KV DEHAR- GANGUWAL (BB)		D	To attend three nos hot points & scheduled mtc. Work.	06/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
763	RQ136584	OCC_208	bbmb_sd	AC TRANSMISSION	CKT-2 220 KV DEHAR- GANGUWAL (BB)	ВВМВ	D	To attend four nos hot points & scheduled mtc. Work.	04/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
764	RQ136625	OCC_208	cpcc2_sd	LINE CIRCUIT AC TRANSMISSION LINE CIRCUIT	CKT-1 220 KV ABDULLAPUR(PG)- RAILWAYHR(RLY) (HVPNL) CKT-2	ВВМВ	D	For Stringing work at AP15/0- AP16/0 span of 220KV Abdullapur-Jagadhari Transmission line(DFCCIL Project) crossing span location no. 22 & 23 of 220KV D/C- 2	26/Jul/2023	10:00	26/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
765	RQ136624	OCC 208	cocc3 sd	AC	220 KV	HVPNL	D	no. 22 & 23 of 220 V D/C-2 Phase - Abdullapur-Jagadhari Railway Workshop TSS Transmission Line. For Stringing work at AP15/0-	26/Jul/2023	10:00	26/Jul/2023	18:00	Under construction	DIANNED	Requested	
				TRANSMISSION LINE CIRCUIT	ABDULLAPUR(PG)- RAILWAYHR(RLY) (HVPNL) CKT-1			AP16/0 span of 220KV Abdullapur-Jagahari Transmission line(DFCCIL Project) crossing span location no. 22 & 23 of 220KV D/c- 2 Phase - Abdullapur-Jagadhari Railway Workshop TSS Transmission Line.					head, Kindly Approve			
766	RQ136622	OCC_208	cpcc2_sd	AC TRANSMISSION	220 KV ABDULLAPUR(PG)-	HVPNL	D	For Stringing work at AP5/0- AP6/0 span of 220KV	20/Jul/2023	10:00	20/Jul/2023	18:00	Under construction head, Kindly	PLANNED	Requested	
				LINE CIRCUIT	RAMPUR(HV) (HVPNL) CKT-1	HVPNL		Abdullapur-Jagadhari Transmission line (DFCCIL Project) crossing of 220KV Abdullapur (POWERGRID)- DCRTPP Yamunanagar (HVPNL) TL 8. 220KV Abdullapur (POWERGRID)- Rampura Yamunanagar (HVPNL) TL at location no. 86 8.87.					Approve			
767	RQ136623	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV ABDULLAPUR(PG)- DCRTPPYAMUNAN AGAR(HV) (HVPNL) CKT-1	HVPNL	D	For Stringing work at APS/0- AP6/0 span of 2 20KV AP6/0 span of 2 20KV Abdullapur-Jagadhari Transmission line (DFCCL Project) crossing of 2 20KV Abdullapur (POWERGRID)- DCRTPP Yamunanagar (HVPNL) TL & 220KV Abdullapur (POWERGRID)- Rampura Yamunanagar (HVPNL) TL at location no. 86 & 87.	20/Jul/2023	10:00	20/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
768	RQ136528	OCC_208	cpcc1_sd		220 KV BHIWADI(PG)-		С	Overhauling of mechanism of CB	17/Jul/2023	08:00	22/Jul/2023	18:00	220kV Rewari-2(208 Main Bay)	PLANNED	Requested	
769	RQ136352	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	REWARI(HV) (HVPNL) CKT-2 220 KV MANESAR(PG)- MAU(HV) (HVPNL)	HVPNL	С	For NCRTC diversion work	16/Jul/2023	08:00	30/Jul/2023	18:00		PLANNED	Requested	
770	RQ136353	OCC_208	cpcc1_sd	AC	220 KV	HVPNL	C	For NCRTC diversion work	16/Jul/2023	08:00	30/Jul/2023	18:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	MANESAR(PG)- MAU(HV) (HVPNL) CKT-2	HVPNL										
771	RQ136345	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHIWADI(PG)- MAU(HV) (HVPNL)		С	For NCRTC diversion work	16/Jul/2023	08:00	30/Jul/2023	18:00		PLANNED	Requested	
772	RQ136313	OCC_208	cpcc1_sd	AC	CKT-1 220 KV	HVPNL	D	FOR AMP WORKS	07/Jul/2023	08:00	07/Jul/2023	18:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	MOHANA(HV)- SONIPAT(PG) (HVPNL) CKT-2	HVPNL										
773	RQ136583	OCC_208	bbmb_sd	AC TRANSMISSION LINE CIRCUIT	220 KV HISSAR(BB)- JINDAL STEEL(HR) (HVPNL) CKT-1	HVPNL	D	Half yearly mtc	03/Jul/2023	08:00	03/Jul/2023	18:00		PLANNED	Requested	
774	RQ136348	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHIWADI(PG)- HSIIDC BAWAL(HV)		С	For NCRTC diversion work	01/Jul/2023	08:00	15/Jul/2023	18:00		PLANNED	Requested	
					(HVPNL) CKT-1	HVPNL										

_																
775	RQ136346	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHIWADI(PG)- REWARI(HV) (HVPNL) CKT-1	HVPNL	С	For NCRTC diversion work	01/Jul/2023	08:00	15/Jul/2023	18:00		PLANNED	Requested	
776	RQ136347	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHIWADI(PG)- REWARI(HV) (HVPNL) CKT-2	HVPNL	С	For NCRTC diversion work	01/Jul/2023	08:00	15/Jul/2023	18:00		PLANNED	Requested	
777	RQ136338	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FARIDABAD SEC-58 (HV)- FARIDABAD(NT) (HVPNL) CKT-1	POWERGRID,	D	Earth wire rectification Tower No. 42 and 42A highway crossing by Ms PSH infra (to attend punch point)	26/Jul/2023	10:00	26/Jul/2023	14:00		PLANNED	Requested	
778	RQ136268	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_III(PG) FOUNGT SL_FTGH2 (NTPC_DEVINGT) (NTPC_DEVINGT) (NTPC_DEVINGT)	NTPC_DEVIK OT	D	Overhead crossing i.e. Stringing work of 400kV D/C Ramgarh II (Fatheparh-III) — Fatehgarh II transmission Line	26/Jul/2023	07:00	29/Jul/2023	19:00	Keeping in View of safety aspects and difficulty in power line crossing work in night hours & in night hours & in night hours sheft of conductor may occurred as theft issue is more in Jaisalmer area therefore to avoid any damage to M/S SBE Renewable Ten Pvt. ttd. line, shutdown is required in day hours only.	PLANNED	Requested	
779	RQ135876	OCC_208	ntpcos_sd	AC TRANSMISSION LINE CIRCUIT	220 KV UNCHAHAR(NT)- RAEBAREILLY(PG)	POWERGRID,	С	CT and bay equipment testing	25/Jul/2023	08:00	26/Jul/2023	18:00		PLANNED	Requested	
780	RQ136704	OCC_208	cpcc3_sd	AC TRANSMISSION LINE CIRCUIT	(PG) CKT-1 220 KV RAEBAREILLY(PG)- BACHRAVAN(UP)	POWERGRID, UPPTCL	D	AMP WORK	09/Jul/2023	08:00	09/Jul/2023	18:00		PLANNED	Requested	
781	RQ136072	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	(PG) CKT-1 220 KV WAGOORA(PG)- ZIANKOTE(JK) (PDD JK) CKT-1	DPPICE	D	As 220KV Zainakote-1 was charged via temporary arrangement and bypassing of isolators. After retrofitting of old isolators, the new isolators will be taken into service. 220KV Zainakote-1 5/0 will be taken to remove all the temporary arrangements and BUSES 5/0 is taken to connect jumpers from Both the Buses.	23/Jul/2023	09:00	23/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
						PDD JK										
	RQ136068			AC TRANSMISSION LINE CIRCUIT	220 KV WAGOORA(PG)- ZIANKOTE(JK) (PDD JK) CKT-1	PDD JK	D	Isolator retrofitting of 220KV Zainakorte-18 aw, (21089C & 21089L ISOLATORS). The 5/D is taken to 8 ypass the 21089L Isolator, the conductor from CT to 21089L Isolator shall be removed. For 21089C, Temporary arrangement will be made from CT to TBC connection so that 21089C isolator droppers from TBC shall be removed and WAGOORA-Zainakote-1 may be charged via 220KV TBC afterwards.	16/Jul/2023		16/Jul/2023		Under construction head, Kindly Approve	PLANNEU	Requested	
783	RQ135971	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SAMBA(PG)- HIRANAGAR(PDD) (PDD JK) CKT-2	PDD JK	D	For AMP work	14/Jul/2023	10:00	14/Jul/2023	16:00	Kindly Approve	PLANNED	Requested	
	RQ136073			AC TRANSMISSION LINE CIRCUIT	220 kV WAGOORA(PG)- ZIANKOTE(JK) (PDD JK) CKT-2	PDD JK	D	As 220KV Zainakote-2 was charged via temporary arrangement and bypassing of isolators. After retrofitting of old isolators, the new isolators will be taken into service. Presently the 220KV Zainakote-2 is charged via 220KV T8C bay, 220KV Zainakote-2 is charged via the temporary arrangements and BUSES 5/D is taken to connect jumpers from Both the Buses.	13/Jul/2023		13/Jul/2023		Under construction head, Kindly Approve	PLANNED	Requested	
785	RQ136063	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV WAGGORA(PG)- ZIANKOTE(JK) (PDD JK) CKT-2	PDD JK	D	isolator retrofitting of 220KV Zainakote-2 Bay (20589C & 20589L ISOLATORS). The 5/D is taken to Bypass the 20589L ISOLATORS). The 5/D is taken to Bypass the 20589L isolator, the conductor from CT to 20589L isolator shall be removed. For 20589C, Temporary arrangement will be made from CT to TBC connection so that 20589C isolator droppers from TBC shall be removed and WAGOORA-Zainakote-2: may be charged via 220kV TBC afterwards.	04/Jul/2023	09:00	04/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
	RQ135995			AC TRANSMISSION LINE CIRCUIT	220 KV CHAMBA(PG)- KARIAN(HP) (HPSEB) CKT-1	HPSEB	С	Bay shutdown is required for Connecting new bus with exsiting Bus Bar-1 & 2 (Through conductor) and stability testing work	21/Jul/2023		28/Jul/2023		Under construction head, Kindly Approve		Requested	
787	RQ135994	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHAMBA(PG)- KARIAN(HP) (HPSEB) CKT-1	HPSEB	С	Bay shutdown is required for erection of GIB & GIS Bushings for the new bay i.e. 207 bay.	13/Jul/2023	09:00	16/Jul/2023	19:00	Under construction head, Kindly Approve	PLANNED	Requested	

788	RQ135993	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHAMBA(PG)- KARIAN(HP) (HPSEB) CKT-1		С	Bay shutdown is required for connecting existing bus-1 & Bus-2 with proposed extended part (Excluding conductor) i.e. for extending the existing bus- 1 & Bus-2 for new bay (bay no. 207 -Future line bay for	01/Jul/2023	09:00	10/Jul/2023	19:00	Under construction head, Kindly Approve	PLANNED	Requested	
						HPSEB		Chamba-HPPTCL Majra)								
789	RQ136530	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV BHIWADI(PG)- BHIWADI(RS) (RS)		D	Replacement of relay	16/Jul/2023	08:00	16/Jul/2023	18:00		PLANNED	Requested	
790	RQ136529	OCC_208	cpcc1_sd	AC TRANSMISSION	CKT-2 220 KV BHIWADI(PG)-	RRVPNL	D	Replacement of relay	15/Jul/2023	08:00	15/Jul/2023	18:00		PLANNED	Requested	
791	RQ135936	OCC_208	sldcrs_sd	AC	BHIWADI(RS) (RS) CKT-1 220 KV DEBARI(RS)-	RRVPNL	D	General Maintenance of bay	13/Jul/2023	08:00	13/Jul/2023	18:00		PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	RAPS_A(NP) (RS) CKT-1	RRVPNL		and Line								
792	RQ136135	OCC_208	sldcjk_sd	AC TRANSMISSION LINE CIRCUIT	220 KV CHOWADHI (JK)-GLADNI(PDD) (PDD JK) CKT-1	POWERGRID,	D	Preventive Maintenance	16/Jul/2023	07:00	16/Jul/2023	12:00	20-50 MW load may be shifted and fed from the sister 220 KV grids subject to real time loading and availability of power from these grid s. Rest 200 MW load (approx.)shall be affected.	PLANNED	Requested	
793	RQ135970	OCC_208	cpcc2_sd	AC TRANSMISSION	220 KV SAMBA(PG)- BISHNAH(JK) (PDD	PDD JK	D	For AMP work	15/Jul/2023	10:00	15/Jul/2023	16:00	Kindly Approve	PLANNED	Requested	
794	RQ135969	OCC_208	cpcc2_sd	AC	JK) CKT-1 220 KV SAMBA(PG)-	POWERGRID, PDD JK	D	For AMP work	07/Jul/2023	10:00	07/Jul/2023	16:00	Kindly Approve	PLANNED	Requested	
				TRANSMISSION LINE CIRCUIT	SAMBA (JK) (PDD JK) CKT-2	POWERGRID, PDD JK										
795	RQ135968	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV SAMBA(PG)- SAMBA (JK) (PDD JK) CKT-1	POWERGRID,	D	For AMP work	06/Jul/2023	10:00	06/Jul/2023	16:00	Kindly Approve	PLANNED	Requested	
796	RQ136295	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(PG)- RENEW_JHARKHAN D 3 SL_FGARH_PG (RSEJ3PL) (RSEJ3PL) CKT-1	PDD JK	D	For testing and commissioning works with TBC Bay & LM Erection Works	07/Jul/2023	17:00	16/Jul/2023	23:00		PLANNED	Requested	
797	RQ136292	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	220 KV RENEW SUNBRIGHT SL_FGARH_PG (RSBPL)- FATEHGARH_II(PG) (RENEW SUN BRIGHT (RSBPL))	RENEW SUN BRIGHT (RSBPL)	D	For testing and commissioning works with TBC Bay & LM Erection Works	07/Jul/2023	17:00	16/Jul/2023	23:00		PLANNED	Requested	
798	RQ136296	OCC_208	cpcc1_sd	AC TRANSMISSION LINE CIRCUIT	CKT-1 220 KV FATEHGARH_II(PG)- RENEW SUNWAVE SL_FGRAH_PG (RSWPL) (RENEW SUN WAVE (RSWPL)) CKT-1	RENEW SUN WAVE (RSWPL)	D	For testing and commissioning works with TBC Bay & LM Erection Works	07/Jul/2023	17:00	16/Jul/2023	23:00		PLANNED	Requested	
	RQ136293			AC TRANSMISSION LINE CIRCUIT		AHEJ3L	D	For testing and commissioning works with TBC Bay	02/Jul/2023		07/Jul/2023				Requested	
	RQ136298			AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(PG)- AHEJOL PSS HB_FGRAH_PG (AHEJOL) (AHEJOL) CKT-2	AHEJOL	D	For testing and commissioning works with TBC Bay	02/Jul/2023		07/Jul/2023				Requested	
	RQ136297			AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(PG)- AHEJOL PSS HB_FGRAH_PG (AHEJOL) (AHEJOL) CKT-1	AHEJOL	D	For testing and commissioning works with TBC Bay	01/Jul/2023		06/Jul/2023				Requested	
	RQ136299			AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(PG)- EDEN SL_FGRAH_PG (ERCPL) (EDEN (ERCPL)) CKT-1	EDEN (ERCPL)	D	For testing and commissioning works with TBC Bay	01/Jul/2023		06/Jul/2023				Requested	
	RQ136289			AC TRANSMISSION LINE CIRCUIT	220 KV RENEW SOLARURIA SL_FGARH_PG (RSUPL)- FATEHGARH_II(PG) (RENEW SOLAR URJA (RSUPL)) CKT- 1	RENEW SOLAR URJA (RSUPL)	D	For testing and commissioning works with TBC Bay	01/Jul/2023		05/Jul/2023				Requested	
	RQ136294			AC TRANSMISSION LINE CIRCUIT	220 KV FATEHGARH_II(PG)- AHEJ2L PSS HB_FGRAH_PG (AHEJ2L) (AHEJ2L) CKT-1	AHEJ2L	D	For testing and commissioning works with TBC Bay	01/Jul/2023		06/Jul/2023				Requested	
805	RQ136023	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AD HYDRO(AD)- PHOZAL(HP)	ADHO:	D	NON - AUTO MODE required for OPGW installation works under ULDC scheme.	01/Jul/2023	07:00	31/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
806	RQ136025	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	(ADHPL) CKT-1 220 KV PHOZAL(HP) NALLAGARH(PG) (ADHPL) CKT-1	ADHPL	D	NON - AUTO MODE required for OPGW installation works under ULDC scheme.	01/Jul/2023	07:00	31/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
807	RQ136024	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AD HYDRO(AD)- NALLAGARH(PG)	ADHPL	D	NON - AUTO MODE required for OPGW installation works under ULDC scheme.	01/Jul/2023	07:00	31/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
808	RQ136026	OCC_208	cpcc2_sd	AC TRANSMISSION	(ADHPL) CKT-1 220 KV PHOZAL(HP) NALLAGARH(PG)	ADHPL	D	Shutdown required for reinstallation of Aviation	01/Jul/2023	07:00	15/Jul/2023	18:00	Under construction head, Kindly	PLANNED	Requested	
				LINE CIRCUIT	(ADHPL) CKT-1	ADHPL		Globules					Approve			

809	RQ136027	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	220 KV AD HYDRO(AD)- NALLAGARH(PG)		D	Shutdown required for reinstallation of Aviation Globules	01/Jul/2023	07:00	15/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
810	RQ136077	OCC_208	cpcc2_sd	BUS	(ADHPL) CKT-1 220KV BUS 2 AT WAGOORA(PG)	ADHPL POWERGRID	D	Retrofitted isolators will be connected to BUS-2 (20889B)	31/Jul/2023	14:00	31/Jul/2023	17:00	Under construction head, Kindly	PLANNED	Requested	
811	RQ136076	OCC_208	cpcc2_sd	BUS	220KV BUS 1 AT WAGOORA(PG)	POWERGRID	D	Retrofitted isolators will be connected to BUS-1 (20889A)	31/Jul/2023	09:00	31/Jul/2023	12:00	Approve Under construction head, Kindly Approve	PLANNED	Requested	
812	RQ136455	OCC_208	cpcc1_sd	BUS	220KV BUS 1 AT		D	For Busbar Bay unit	28/Jul/2023	08:00	28/Jul/2023	18:00	Арргоче	PLANNED	Requested	
813	RQ136458	OCC_208	cpcc1_sd	BUS	MANDOLA(PG) 220KV BUS 4 AT	POWERGRID	D	retrofitment For Busbar Bay unit	27/Jul/2023	08:00	27/Jul/2023	18:00		PLANNED	Requested	
914	RQ136457	OCC 208	cocc1 sd	BUS	MANDOLA(PG) 220KV BUS 3 AT	POWERGRID	D	retrofitment For Busbar Bay unit	26/Jul/2023	08:00	26/Jul/2023	18:00		DIANNED	Requested	
		_			MANDOLA(PG)	POWERGRID		retrofitment								
815	RQ136003	OCC_208	cpcc2_sd	BUS	220KV BUS 2 AT CHAMBA(PG)	POWERGRID	С	For Connecting new bus (through conductor) with exsiting Bus Bar-2 & stability	25/Jul/2023	09:00	28/Jul/2023	19:00	Under construction head, Kindly Approve	PLANNED	Requested	
816	RQ136439	OCC_208	cpcc1_sd	BUS	220 KV KURUKSHETRA(PG)	POWERGRID	С	test with Bus Bar-2 For connection of internal conductor of new ICT-3 GIS	25/Jul/2023	07:00	26/Jul/2023	20:00		PLANNED	Requested	
817	RQ136067	OCC 208	cncc2 sd	BUS	BUS 2 220KV BUS 2 AT	POWERGRID	D	bay with Existing GIS Bus-1 & Busbar Relay Testing For Bus Isolator retrofitting of	24/Jul/2023	14:00	24/Jul/2023	17:00	Under construction	PLANNED	Requested	
					WAGOORA(PG)	POWERGRID	_	220KV BUS-Coupler Bay (208), Jumpers of 220kV BUS-2 will be removed to isolate the 20889B isolator completely.	- 44				head, Kindly Approve			
818	RQ136066	OCC_208	cpcc2_sd	BUS	220KV BUS 1 AT WAGOORA(PG)		D	For Bus Isolator retrofitting of 220KV BUS-Coupler Bay (208), Jumpers of 220kV BUS-1 will be removed to isolate the 20889A isolator completely.	24/Jul/2023	09:00	24/Jul/2023	12:00	Under construction head, Kindly Approve	PLANNED	Requested	
819	RQ136456	OCC_208	cpcc1_sd	BUS	220KV BUS 2 AT MANDOLA(PG)	POWERGRID POWERGRID	D	For Busbar Bay unit retrofitment	24/Jul/2023	08:00	24/Jul/2023	18:00		PLANNED	Requested	
820	RQ136075	OCC_208	cpcc2_sd	BUS	220KV BUS 2 AT WAGOORA(PG)		D	As 220KV Zainakote-1 was charged via temporary arrangement and bypassing of	23/Jul/2023	14:00	23/Jul/2023	17:00	Under construction head, Kindly Approve	PLANNED	Requested	
								arrangement and bypassing or isolators. After retrofitting of old isolators, the new isolators will be taken into service. 220KV Zainakote-1 S/D will be taken to remove all the temporary arrangements and BUSES S/D is taken to connect jumpers from Both the Buses.					Approve			
821	RQ136074	OCC_208	cpcc2_sd	BUS	220KV BUS 1 AT	POWERGRID	D	As 220KV Zainakote-1 was	23/Jul/2023	09:00	23/Jul/2023	12:00	Under construction	PLANNED	Requested	
					WAGOORA(PG)	POWERGRID		charged via temporary arrangement and bypassing of isolators. After retrofitting of old isolators, the new isolators will be taken into service. 220KV Zainakote-15/0 will be taken to removall the temporary arrangements and BUSES S/D is taken to connect jumpers from Both the Buses.					head, Kindly Approve			
822	RQ136438	OCC_208	cpcc1_sd	BUS	220 KV KURUKSHETRA(PG) BUS 1	POWERGRID	С	For connection of internal conductor of new ICT-3 GIS bay with Existing GIS Bus-1 & Busbar Relay Testing	23/Jul/2023	07:00	24/Jul/2023	19:00		PLANNED	Requested	
823	RQ136002	OCC_208	cpcc2_sd	BUS	220KV BUS 1 AT CHAMBA(PG)	POWERGRID	С	For Connecting new bus (through conductor) with exsiting Bus Bar-1 & stability test with Bus Bar-1	21/Jul/2023	09:00	24/Jul/2023	19:00	Under construction head, Kindly Approve	PLANNED	Requested	
824	RQ136431	OCC_208	cpcc1_sd	BUS	220 KV KURUKSHETRA(PG)		С	For HV TEST OF 220 KV BUS-1 GIS EXTENSION	21/Jul/2023	07:00	22/Jul/2023	20:00		PLANNED	Requested	
825	RQ136001	OCC_208	cpcc2_sd	BUS	220KV BUS 2 AT CHAMBA(PG)	POWERGRID	С	HV Testing of newly installed bus wih Bus Bar-2	19/Jul/2023	09:00	20/Jul/2023	19:00	Under construction head, Kindly	PLANNED	Requested	
826	RQ136432	OCC_208	cpcc1_sd	BUS	220 KV KURUKSHETRA(PG)	POWERGRID	С	For HV TEST OF 220 KV BUS-2 GIS EXTENSION	19/Jul/2023	07:00	20/Jul/2023	20:00	Approve	PLANNED	Requested	
					BUS 2	POWERGRID										
827	RQ136490	OCC_208	cpcc1_sd	BUS	220 KV FATEHGARH_II(PG) BUS 7		D	For Bay extension and bus bar testing of 400 kV ICT-6 & 06 Nos. line Bay (Jumpering and bay extension work of new bays of Phase II)	18/Jul/2023	17:00	28/Jul/2023	23:00	400KV/220KV ICT-8 shall be under shutdown for ph 2 Construction works	PLANNED	Requested	
828	RQ135982	OCC_208	cpcc2_sd	BUS	220KV BUS 2 AT	POWERGRID	D	For AMP work	18/Jul/2023	09:00	18/Jul/2023	18:00	Kindly Approve	PLANNED	Requested	
	RQ136491			BUS	JALANDHAR(PG) 220 KV	POWERGRID	D	For Bay extension and bus bar	17/Jul/2023		28/Jul/2023				Requested	
523	~=>0431				FATEHGARH_II(PG) BUS 8			testing of line Bay A218(248) (Jumpering and bay extension work of new bays of Phase II)	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		_3/30// 2023				questeu	
830	RQ136000	OCC_208	cpcc2_sd	BUS	220KV BUS 1 AT	POWERGRID	С	HV Testing of newly installed	17/Jul/2023	09:00	18/Jul/2023	19:00	Under construction	PLANNED	Requested	
					CHAMBA(PG)	POWERGRID		bus wih Bus Bar-1					head, Kindly Approve			
831	RQ136418	OCC_208	cpcc1_sd	BUS	220KV BUS 2 AT BAHADURGARH(PG		D	FOR AMP WORK	16/Jul/2023	08:00	16/Jul/2023	18:00		PLANNED	Requested	
832	RQ136065	OCC_208	cpcc2_sd	BUS	220KV BUS 2 AT WAGOORA(PG)	POWERGRID	D	For Bus Isolator retrofitting of 220KV Zainakote-1 Bay (210), Jumpers of 220KV BUS-2 will be removed to isolate the 21089B isolator completely.	15/Jul/2023	14:00	15/Jul/2023	17:00	Under construction head, Kindly Approve	PLANNED	Requested	
833	RQ136064	OCC_208	cpcc2_sd	BUS	220KV BUS 1 AT	POWERGRID	D	For Bus Isolator retrofitting of	15/Jul/2023	09:00	15/Jul/2023	12:00	Under construction	PLANNED	Requested	
		,			WAGOORA(PG)	POWERGRID	_	220KV Zainakote-1 Bay (210), Jumpers of 220kV BUS-1 will be removed to isolate the 21089A isolator completely.	.,, 2023	-	,,,,,,		head, Kindly Approve		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	
834	RQ136417	OCC_208	cpcc1_sd	BUS	220KV BUS 1 AT	. OWLINGRID	D	FOR AMP WORK	14/Jul/2023	08:00	14/Jul/2023	18:00		PLANNED	Requested	
					BAHADURGARH(PG	POWERGRID										

835	RQ136401	OCC_208	cpcc1_sd	BUS	220 KV BHADLA_2 (PG) - BUS 5		D	BAY EXTENSION WORKS	13/Jul/2023	17:00	13/Jul/2023	23:00	During 220 KV Bus-5 shut down, 220 KV	PLANNED	Requested	
													AVADA Line Bay			
													(206) and 220 KV side of ICT-6 (bay			
													210) shall become			
													out as Avada line bay and ICT bay is			
						POWERGRID							charged through Bus-			
836	RQ136071	OCC_208	cpcc2_sd	BUS	220KV BUS 2 AT	POWERGRID	D	As 220KV Zainakote-2 was	13/Jul/2023	14:00	13/Jul/2023	17:00	5 only Under construction	PLANNED	Requested	
					WAGOORA(PG)			charged via temporary					head, Kindly			
								arrangement and bypassing of isolators. After retrofitting of					Approve			
								old isolators, the new isolators will be taken into service.								
								Presently the 220KV								
								Zainakote-2 is charged via 220kV TBC bay, 220KV								
								Zainakote-2 S/D will be taken								
								to remove all the temporary arrangements and BUSES S/D								
								is taken to connect jumpers								
								from Both the Buses.								
						POWERGRID										
837	RQ136070	OCC_208	cpcc2_sd	BUS	220KV BUS 1 AT WAGOORA(PG)		D	As 220KV Zainakote-2 was charged via temporary	13/Jul/2023	09:00	13/Jul/2023	12:00	Under construction head, Kindly	PLANNED	Requested	
								arrangement and bypassing of					Approve			
								isolators. After retrofitting of old isolators, the new isolators								
								will be taken into service.								
								Presently the 220KV Zainakote-2 is charged via								
								220kV TBC bay, 220KV								
								Zainakote-2 S/D will be taken to remove all the temporary							.	
								arrangements and BUSES S/D								
								is taken to connect jumpers from Both the Buses.								
						POWERGRID										
838	RQ136398	OCC_208	cpcc1_sd	BUS	220 KV BHADLA_2 (PG) - BUS 4	POWERGRID	D	BAY EXTENSION WORKS	12/Jul/2023	17:00	12/Jul/2023	23:00		PLANNED	Requested	
839	RQ136397	OCC_208	cpcc1_sd	BUS	220 KV BHADLA_2		D	BAY EXTENSION WORKS	11/Jul/2023	17:00	11/Jul/2023	23:00		PLANNED	Requested	
840	RQ136396	OCC_208	cpcc1_sd	BUS	(PG) - BUS 3 220 KV BHADLA_2	POWERGRID	D	BAY EXTENSION WORKS	10/Jul/2023	17:00	10/Jul/2023	23:00		PLANNED	Requested	
841	RQ136390	OCC_208	cpcc1_sd	BUS	(PG) - BUS 2 220 KV	POWERGRID	С	FOR TOWER STRENGTHING	10/Jul/2023	09:00	20/Jul/2023	18:00		PLANNED	Requested	
					BHADLA(PG) - BUS			WORK. DURING THIS SHUT DOWN SECTION A solar								
					2			generation lines								
								(203,205,206,207) along with								
								ICTs (ICT-01,2,3,4) will be isolated continously for 10							.	
842	RQ136389	OCC 200	cncc1 sd	BUS	220 KV	POWERGRID	С	days. FOR TOWER STRENGTHING	10/Jul/2023	09:00	20/Jul/2023	18:00		PLANNED	Requested	
342		JCC_208	-peci_su	303	BHADLA(PG) - BUS			WORK. DURING THIS SHUT	20,301,2023	25.55	20/301/2023	_0.00		. SAVINED	questeu	
					1			DOWN SECTION A solar generation lines								
								(203,205,206,207) along with							.	
								ICTs (ICT-01,2,3,4) will be isolated continously for 10								
943	RQ136395	000 300	cncc1 cd	BUS	220 KV BHADLA_2	POWERGRID	D	days. BAY EXTENSION WORKS	09/Jul/2023	17:00	09/Jul/2023	23:00		DIAMMEN	Requested	
		_			(PG) - BUS 1	POWERGRID									· ·	
844	RQ136391	UCC_208	cpcc1_sd	BUS	220 KV BHADLA(PG) - BUS		D	FOR AMP WORK	08/Jul/2023	19:00	09/Jul/2023	23:00		PLANNED	Requested	
945	RQ136392	OCC 200	cncc1 sd	BUS	3 220 KV	POWERGRID	D	FOR AMP WORK	08/Jul/2023	19:00	09/Jul/2023	23-00		DIANNED	Requested	
043	WG13039Z	JCC_208	chcci_sa	503	BHADLA(PG) - BUS		"	TON AIVIF WORK	JO/JUI/2023	15.00	05/101/2023	23.00		LANNED	nequested	
846	RQ136394	OCC 208	cpcc1 sd	BUS	4 220 KV	POWERGRID	D	FOR AMP WORK	08/Jul/2023	19:00	09/Jul/2023	23:00		PLANNED	Requested	
340		200_200	su	-33	BHADLA(PG) - BUS				30,301,2023		03,741,2023			. D. WALLED	questeu	
847	RQ136393	OCC_ 208	cpcc1 sd	BUS	6 220 KV	POWERGRID	D	FOR AMP WORK	08/Jul/2023	19:00	09/Jul/2023	23:00		PLANNED	Requested	
					BHADLA(PG) - BUS	DOMEDOS										
848	RQ136482	OCC_208	cpcc1_sd	BUS	220 KV	POWERGRID	D	For erection and	07/Jul/2023	17:00	11/Jul/2023	23:00		PLANNED	Requested	
					FATEHGARH_II(PG) - BUS 2	POWERGRID		commissioning works in TBC Bay								
849	RQ136480	OCC_208	cpcc1_sd	BUS	220 KV	LOWERGRID	D	For erection and	07/Jul/2023	17:00	11/Jul/2023	23:00		PLANNED	Requested	
					FATEHGARH_II(PG) - BUS 4	POWERGRID		commissioning works in TBC Bay								
850	RQ135983	OCC_208	cpcc2_sd	BUS	220KV BUS 3 AT		D	For AMP work	07/Jul/2023	09:00	07/Jul/2023	18:00	Kindly Approve for	PLANNED	Requested	
851	RQ136443	OCC_208	cpcc3 sd	BUS	JALANDHAR(PG) 220KV BUS 1 AT	POWERGRID	D	AMP works	07/Jul/2023	08:00	07/Jul/2023	18:00	Transfer Bus	PLANNED	Requested	
				BUS	LUCKNOW_1(PG)	POWERGRID		IPS TUBE ERECTION FOR BAY							·	
		OCC_208			220 KV JIND(PG) - BUS 2	POWERGRID	D	EXTENSION WORK	07/Jul/2023		07/Jul/2023				Requested	
853	RQ135999	OCC_208	cpcc2_sd	BUS	220KV BUS 2 AT CHAMBA(PG)		С	For connecting existing bus-2 with proposed extended part	06/Jul/2023	09:00	10/Jul/2023	19:00	Under construction head, Kindly	PLANNED	Requested	
								(Excluding conductor). i.e. for					Approve			
								extending the existing bus-2 for new bay (207)								
05.4	DO120000	000 225	ener3 : '	DUIC	220KV BUS 2 AT	POWERGRID	D		OF /11/2077	00:00	OE /11/205	17:20	Kindly A	DI ANIA/SS	Boguest 1	
854	RQ136009	JULU_208	cpccz_sa	BUS	MOGA(PG)		"	Bus bar realy testing after modification of bus bar	05/Jul/2023	09.00	05/Jul/2023	17.30	Kindly Approve	FLAININED	Requested	
855	RQ136387	OCC 208	cpcc1 sd	BUS	220 KV JIND(PG) -	POWERGRID	D	protection ERECTION OF ISOLATOR FOR	05/Jul/2023	08:00	05/Jul/2023	18:00		PLANNED	Requested	
					BUS 2	POWERGRID		BAY EXTENSION WORK							· ·	
856	RQ136423	JULC_208	cpcc1_sd	BUS	220 KV KURUKSHETRA(PG) -		С	For Erection of interface module for connection of ICT-	05/Jul/2023	07:00	08/Jul/2023	2U:UU		PLANNED	Requested	
					BUS 2			3 bay with existing Bus-2.								
								After erection, internal conductor link will be removed							.	
								and corona shield applied on							.	
								both ends to isolate existing & new GIS. Internal conductor								
						POWERGRID		will be connected after HV test.								
857	RQ136405	OCC_208	cpcc1_sd	BUS	220KV BUS 1 AT		С	For rectification of PD defect	04/Jul/2023	10:00	08/Jul/2023	20:00		PLANNED	Requested	
858	RQ136406	OCC_208	cpcc1_sd	BUS	BAGHPAT(PG) 220KV BUS 2 AT	POWERGRID	С	in 220 kV Bus 1 For rectification of PD defect	04/Jul/2023	10:00	08/Jul/2023	20:00		PLANNED	Requested	
		_	-		BAGHPAT(PG)	POWERGRID		in 220 kV Bus 1								
859	RQ136404	OCC 208	cpcc1 sd	IBUS	1220KV BUS 7 AT		l (.	Thor replacement of trans of	04/Jul/2023	108:00	06/Jul/2023	18:00		IPLANNED	Requested 1	
859	RQ136404	OCC_208	cpcc1_sd	BUS	220KV BUS 2 AT SAHARANPUR(PG)	POWERGRID	С	For replacement of flang of 202Q52 CB in 202 Bus Coupler Bay.	04/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	

860	RQ136062	OCC_208	cpcc2_sd	BUS	220KV BUS 2 AT		D	For Bus Isolator retrofitting of	03/Jul/2023	14:00	03/Jul/2023	17:00	Under construction	PLANNED	Requested	
					WAGOORA(PG)			220KV Zainakote-2 Bay (205), Jumpers of 220kV BUS-2 will be removed to isolate the 20589B isolator completely.					head, Kindly Approve			
861	RQ136008	OCC_208	cpcc2_sd	BUS	220KV BUS 1 AT MOGA(PG)	POWERGRID	D	Bus bar realy testing after modification of bus bar	03/Jul/2023	09:00	03/Jul/2023	17:30	Kindly Approve	PLANNED	Requested	
862	RQ136061	OCC_208	cpcc2_sd	BUS	220KV BUS 1 AT WAGOORA(PG)	POWERGRID	D	protection For Bus Isolator retrofitting of 220KV Zainakote-2 Bay (205), Jumpers of 220kV BUS-1 will be removed to isolate the	03/Jul/2023	09:00	03/Jul/2023	12:00	Under construction head, Kindly Approve	PLANNED	Requested	
						POWERGRID		20589A isolator completely.								
	RQ136680	_		BUS	220KV BUS 2 AT AGRA(PG)	POWERGRID	D	AMP works	03/Jul/2023		03/Jul/2023				Requested	
	RQ136386 RQ136483	_		BUS	220 KV JIND(PG) - BUS 1	POWERGRID	D	ERECTION OF ISOLATOR FOR BAY EXTENSION WORK	03/Jul/2023 02/Jul/2023		03/Jul/2023 13/Jul/2023		400KV/220KV ICT-8		Requested Requested	
805	KQ130483	OCC_208	cpcc1_sa	BUS	220 KV FATEHGARH_II(PG) BUS 5	POWERGRID	D	For Bay extension and bus bar testing of 400 kV ICT-6 & 06 Nos. line Bay (Jumpering and bay extension work of new bays of Phase II)	02/301/2023	17:00	13/Jul/2023	23:00	shall be under shutdown for ph 2 Construction works	PLANNED	Requested	
	RQ136484			BUS	220 KV FATEHGARH_II(PG) BUS 6	POWERGRID	D	For Bay extension and bus bar testing of line Bay A218(248) (Jumpering and bay extension work of new bays of Phase II)	02/Jul/2023		13/Jul/2023				Requested	
	RQ136434			BUS	220KV BUS 2 AT FATEHPUR(PG)	POWERGRID	D	AMP works	02/Jul/2023		02/Jul/2023				Requested	
868	RQ136489	OCC_208	cpcc1_sd	BUS	220 KV FATEHGARH_II(PG) BUS 3	POWERGRID	D	For erection and commissioning works in TBC Bay, Bus Bar, LBB Relay Testing Under Phase-1 commissioning works	01/Jul/2023	17:00	06/Jul/2023	23:00		PLANNED	Requested	
869	RQ136481	OCC_208	cpcc1_sd	BUS	220 KV FATEHGARH_II(PG) BUS 1		D	For erection and commissioning works in TBC Bay, Bus Bar , LBB Relay Testing Under Phase-1	01/Jul/2023	17:00	06/Jul/2023	23:00		PLANNED	Requested	
870	RQ135998	OCC_208	cpcc2_sd	BUS	220KV BUS 1 AT	POWERGRID	С	commissioning works For connecting existing bus-1	01/Jul/2023	09:00	05/Jul/2023	19:00	Under construction	PLANNED	Requested	
					CHAMBA(PG)	POWERGRID		with proposed extended part (Excluding conductor) i.e. for extending the existing bus-1 for new bay (207)					head, Kindly Approve			
	RQ136433	_		BUS	220KV BUS 1 AT FATEHPUR(PG)	POWERGRID	D	AMP works	01/Jul/2023		01/Jul/2023				Requested	
872	RQ136422	OCC_208	cpcc1_sd	BUS	220 KV KURUKSHETRA(PG) BUS 1		С	For Erection of interface module for connection of ICT-3 bay with existing Bus-2. After erection, internal conductor link will be removed and corona shield applied on both ends to isolate existing & new GIS. Internal conductor will be connected after HV	01/Jul/2023	07:00	04/Jul/2023	20:00		PLANNED	Requested	
873	RQ135875	OCC_208	ntpcos_sd	BUS	220KV BUS 2 AT	POWERGRID	С	test. Maint of Bus#2 side isolator of	17/Jul/2023	08:00	21/Jul/2023	18:00		PLANNED	Requested	
874	RQ135874	OCC_208	ntpcos_sd	BUS	UNCHAHAR(NT) 220KV BUS 1 AT	NTPC	С	diff bays. Maint of Bus#1 side isolator of	10/Jul/2023	08:00	14/Jul/2023	18:00		PLANNED	Requested	
	RQ136131			BUS	UNCHAHAR(NT) 220KV BUS 1 AT GLADNI(PDD)	NTPC PDD JK	D	diff bays. Preventive Maintenance	16/Jul/2023		16/Jul/2023		20 - 50 MW load may be shifted and fed from the sister 220 KV grids subject to real time loading and availability of power from these grid s. Rest 200 MW load (approx.)shall be affected.			
876	RQ136132	OCC_208	sldcjk_sd	BUS	220KV BUS 2 AT GLADNI(PDD)	PDD JK	D	Preventive Maintenance	16/Jul/2023	07:00	16/Jul/2023	12:00	20 - 50 MW load may be shifted and fed from the sister 220 KV grids subject to real time loading and availability of power from these grid s. Rest 200 MW load (approx.)shall be affected.	PLANNED	Requested	
	RQ136591			BUS	220KV BUS 1 AT DELHI RR(BB)	ввмв	D	Quarterly mtc	12/Jul/2023		12/Jul/2023				Requested	
			bbmb_sd	BUS	220KV BUS 1 AT HISSAR(BB)	ввмв	D	Half yearly mtc	07/Jul/2023		07/Jul/2023				Requested	
	RQ136863			AC TRANSMISSION LINE CIRCUIT	132 KV SITARGANJ(PG)- SITARGANJ(SIDCUL) (PTCUL) CKT-1	PTCUL	D	AMP WORK	21/Jul/2023		21/Jul/2023				Requested	
	RQ136862			AC TRANSMISSION LINE CIRCUIT	132 KV SITARGANJ(PG)- SITARGANJ(PTCUL) (PTCUL) CKT-3	PTCUL	D	AMP WORK	17/Jul/2023		17/Jul/2023				Requested	
	RQ136861			AC TRANSMISSION LINE CIRCUIT	132 KV SITARGANJ(PG)- SITARGANJ(PTCUL) (PTCUL) CKT-2	PTCUL	D	AMP WORK	15/Jul/2023		15/Jul/2023				Requested	
	RQ136592			AC TRANSMISSION LINE CIRCUIT	132 KV DEHAR(BB)- KANGOO(HP) (HPPTCL) CKT-1	HPPTCL	D	To attend two nos hot points on 132 KV Bus & scheduled mtc. Work.	10/Jul/2023		10/Jul/2023				Requested	
	RQ135898			AC TRANSMISSION LINE CIRCUIT	132 KV AMARPURATHEDI(R S)-HISAR(BB) (RS) CKT-1	RRVPNL	С	for Line Maintenance And Tree Trimming Work at various locations (total line length is 180 KM) in Haryana State	04/Jul/2023		06/Jul/2023				Requested	
884	RQ136030	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	132 KV KATHUA(JK)- MAHANPUR(JK) (PG) CKT-1		D	AR NON - AUTO MODE required for OPGW installation works under Northern Region OPGW Strengthening Scheme (NROSS).	01/Jul/2023	07:00	31/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
		l		1		POWERGRID		l				l		l		

885	RQ136029	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	132 KV SEWA_2(NH)- MAHANPUR(PDD) (PG) CKT-1	POWERGRID	D	AR NON - AUTO MODE required for OPGW installation works under Northern Region OPGW Strengthening Scheme (NROSS).	01/Jul/2023	07:00	31/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
886	RQ136028	OCC_208	cpcc2_sd	AC TRANSMISSION LINE CIRCUIT	132 KV SEWA_2(NH)- KATHUA(JK) (PG) CKT-1	POWERGRID	D	AR NON - AUTO MODE required for OPGW installation works under Northern Region OPGW Strengthening Scheme (NROSS).	01/Jul/2023	07:00	31/Jul/2023	18:00	Under construction head, Kindly Approve	PLANNED	Requested	
887	RQ136428	OCC_208	cpcc3_sd	BUS	132 KV SITARGANJ(PG) -		D	AMP works	20/Jul/2023	08:00	20/Jul/2023	18:00		PLANNED	Requested	
888	RQ136590	OCC_208	bbmb_sd	BUS	BUS 1 132 KV DEHAR(BB) - BUS 1	POWERGRID	D	To attend two nos hot points & scheduled mtc. Work.	10/Jul/2023	08:00	10/Jul/2023	18:00		PLANNED	Requested	
889	RQ136498	OCC_208	cpcc1_sd	BR/BSR/MSC/M SR	REACTOR NO 1 AT 220 KV	BBMB	D	FOR AMP WORK	17/Jul/2023	08:00	17/Jul/2023	18:00		PLANNED	Requested	
800	RQ136069	OCC 208	cocc3 sd	BAY	MANDOLA(PG) 208 BUS COUPLER	POWERGRID	С	BUS-Couper Bay will remain	24/Jul/2023	00:00	31/Jul/2023	17:00	Under construction	DIANNED	Requested	
850	6000ELDV	000_208	cpccz_su	DAT	200 SUSTICES BAY - 220KV BUS 1 AT WAGOORA(PG) (POWERGRID) AND 220KV BUS 2 AT WAGOORA(PG) AT 220 KV WAGOORA(PG) (POWERGRID)	POWERGRID		under S/D due to Isolator retrofitting 20889A, 20889B	24/301/2025	09.00	31/10/2023	17.00	Approve	PLANNED	nequesteu	
891	RQ136508	OCC_208	cpcc1_sd	BAY	A214 BUS		D	construction related works of	14/Jul/2023	17:00	19/Jul/2023	23:00		PLANNED	Requested	
					SECTIONALIZER BAY - 220 KV FATEHGARH_II(PG) - BUS 7 (POWERGRID) AND 220 KV FATEHGARH_II(PG) - BUS 8 AT 220 KV FATEHGARH_II(PG) (POWERGRID)	POWERGRID		Phase II (Jumpering and bay extension work of new bays of Phase II)								
892	RQ136522	OCC_208	cpcc1_sd	BAY	212 MAIN BAY - 220 KV RAPS_B(NP)- DEBARI(RS) (PG) CKT-1 AT DEBARI(RS)		С	FOR RETROFITMENT OF LBB RELAY, LINE REMAIN IN SERVICE THROUGH TRANSFER BUS CIRCUIT BREAKER AT DEBARI END/ RRVPNL DEBARI (UDAIPUR) AUTORECLOSE WILL BE OUT OF SERVICE DURING LINE REMAIN IN SERVICE WITH TRANSFER BUS	07/Jul/2023	08:00	08/Jul/2023	18:00		PLANNED	Requested	
893	RQ136520	OCC 208	cpcc1 sd	BAY	209 MAIN BAY -	POWERGRID	С	FOR RETROFITMENT OF LBB	05/Jul/2023	08:00	06/Jul/2023	18:00		PLANNED	Requested	
					220 KV RAPS_B(NP)- CHITTORGARH(RS) (PG) CKT-2 AT CHITTORGARH(RS)	POWERGRID		RELAY, LINE REMAIN IN SERVICE THROUGH TRANSFER BUS CIRCUIT BREAKER AT CHITTORGARH ENDY RRYPNI. (CHANDERIYA) A UTORECLOSE WILL BE OUT OF SERVICE DURING LINE REMAIN IN SERVICE WITH TRANSFER BUS CB							·	
894	RQ136503	OCC_208	cpcc1_sd	ВАУ	202 BUS COUPLER BAY - 220KV BUS 1 AT SAHARANPUR(PG) (POWERGRID) AND 220KV BUS 2 AT SAHARANPUR(PG) AT 220 KV SAHARANPUR(PG) (POWERGRID)	POWERGRID	С	For replacement of flang of 202052 CB in 202 Bus Coupler Bay.	04/Jul/2023		06/Jul/2023			PLANNED	Requested	
895	RQ136505	OCC_208	cpcc1_sd	ВАУ	204 BUS COUPLER BAY - 220KV BUS 1 AT BAGHPAT(PG) (POWERGRID) AND 220KV BUS 2 AT BAGHPAT(PG) AT 220 KV BAGHPAT(PG) (POWERGRID)	POWERGRID	С	For rectification of PD defect in 220 kV Bus 1	04/Jul/2023	08:00	08/Jul/2023	18:00		PLANNED	Requested	
896	RQ136060	OCC_208	cpcc2_sd	BAY	205 MAIN BAY -		С	CB retrofitting under ADD CAP.	03/Jul/2023	09:00	12/Jul/2023	18:00	Under construction	PLANNED	Requested	
					220 KV WAGOORA(PG)- ZIANKOTE(JK) (PDD JK) CKT-2 (POWERGRID) AT 220 KV WAGOORA(PG)	POWERGRID		220kV Zainakote-2 will remain charged via TBC					head, Kindly Approve			
897	RQ136521	OCC_208	cpcc1_sd	BAY	208 MAIN BAY -		С	FOR RETROFITMENT OF LBB	03/Jul/2023	08:00	04/Jul/2023	18:00		PLANNED	Requested	
					220 KV RAPS_B(NP)- CHITTORGARH(RS) (PG) CKT-1 AT CHITTORGARH(RS)	POWERGRID		RELAY, LINE REMAIN IN SERVICE THROUGH TRANSFER BUS CIRCUIT BREAKER AT CHITTORGARH ENDY, RRVPNL (CHANDERIVA) A JUTORECLOSE WILL BE OUT OF SERVICE DURING LINE REMAIN IN SERVICE WITH TRANSFER BUS CB								
898	RQ136510	OCC_208	cpcc1_sd	ВАУ	A208 BUS COUPLER BAY - 220 KV FATEHGARH_II(PG) - BUS 5 (POWERGRID) AND 220 KV FATEHGARH_II(PG) - BUS 6 AT 220 KV FATEHGARH_II(PG) (POWERGRID)	POWERGRID	D	FOR ConstructionWORKS OF PHASE-2	01/Jul/2023	15:00	05/Jul/2023	23:00		PLANNED	Requested	

899	RQ136507	OCC_208	cpcc1_sd	ВАУ	A217 BUS COUPLER BAY - 220 KV FATEHGARH_II(PG) - BUS 7 (POWERGRID) AND 220 KV FATEHGARH_II(PG) - BUS 8 AT 220 KV FATEHGARH_II(PG) (POWERGRID)		D	FOR ConstructionWORKS OF PHASE-2	01/Jul/2023	15:00	05/Jul/2023	23:00	PLANNED	Requested	
900	RQ136752	OCC_208	cpcc3_sd	FILTER BANK	400 KV 60 MVAR Filter Bank No B2Z13 at Vindhyachal-	POWERGRID	D	PSD FINE TUNING	31/Jul/2023	08:00	31/Jul/2023	18:00	PLANNED	Requested	
901	RQ136751	OCC_208	cpcc3_sd	FILTER BANK	North(PG) 400 KV 60 MVAR Filter Bank No B2Z11 at Vindhyachal-	POWERGRID	D	PSD FINE TUNING	31/Jul/2023	08:00	31/Jul/2023	18:00	PLANNED	Requested	
902	RQ136736	OCC_208	cpcc3_sd	FILTER BANK	North(PG) 400 KV 41.6 MVAR Filter Bank No B1Z12 at Vindhyachal-	POWERGRID	D	PSD FINE TUNING	29/Jul/2023	08:00	29/Jul/2023	18:00	PLANNED	Requested	
903	RQ136735	OCC_208	cpcc3_sd	FILTER BANK	North(PG) 400 KV 60 MVAR Filter Bank No B1Z11 at Vindhyachal-	POWERGRID	D	PSD FINE TUNING	29/Jul/2023	08:00	29/Jul/2023	18:00	PLANNED	Requested	
904	RQ136737	OCC_208	cpcc3_sd	FILTER BANK	North(PG) 400 KV 60 MVAR Filter Bank No B1Z13 at Vindhyachal- North(PG)	POWERGRID	D	PSD FINE TUNING	29/Jul/2023	08:00	29/Jul/2023	18:00	PLANNED	Requested	
905	RQ136644	OCC_208	cpcc3_sd	FILTER BANK	400 KV 70 MVAR Filter Bank No Z3- Sub Filter Z.33 at Rihand(PG)		С	Replacement of neutral CT along with resctification of issue of Nut Blot rusting in CB- 33.Q. There shall not be any restriction on HVDC power	24/Jul/2023	08:00	25/Jul/2023	18:00	PLANNED	Requested	
906	RQ136465	OCC_208	cpcc3_sd	TCSC	TCSC OF 400 KV GORAKHPUR- MUZAFFARPUR (PG) CKT-2 AT GORAKHPUR(PG)	POWERGRID	D	Flow. OPTO Card troubleshooting	23/Jul/2023	08:00	23/Jul/2023	18:00	PLANNED	Requested	
907	RQ136645	OCC_208	cpcc3_sd	FILTER BANK	400 KV 40 MVAR Filter Bank No Z3- Sub Filter Z.32 at Rihand(PG)	POWERGRID	С	Replacement of neutral CT along with resctification of issue of Nut Blot rusting in CB- 32.Q. There shall not be any restriction on HVDC power Flow.	20/Jul/2023	08:00	21/Jul/2023	18:00	PLANNED	Requested	
908	RQ136646	OCC_208	cpcc3_sd	FILTER BANK	400 KV 120 MVAR Filter Bank No Z3- Sub Filter Z.31 at Rihand(PG)	POWERGRID	С	Replacement of neutral CT along with resctification of issue of Nut Blot rusting in CB- 31.Q. There shall not be any restriction on HVDC power Flow.	17/Jul/2023	08:00	18/Jul/2023	18:00	PLANNED	Requested	
909	RQ136466	OCC_208	cpcc3_sd	TCSC	TCSC OF 400 KV GORAKHPUR- MUZAFFARPUR (PG) CKT-1 AT GORAKHPUR(PG)	POWERGRID	D	OPTO Card troubleshooting	16/Jul/2023	08:00	16/Jul/2023	18:00	PLANNED	Requested	
910	RQ136672	OCC_208	cpcc3_sd	FILTER BANK	400 KV 40 MVAR Filter Bank No 2 at Rihand(PG)	POWERGRID	С	S/D of AC SUB FILTER BANK 22.Z23 at Rihand for Replacement of neutral CT along with resctification of issue of Nut Blot rusting in CB- Z23.Q	14/Jul/2023	08:00	15/Jul/2023	18:00	PLANNED	Requested	
911	RQ136814	OCC_208	cpcc3_sd	FILTER BANK	400 KV 40 MVAR Filter Bank No 2 at Rihand(PG)	POWERGRID	С	S/D of AC SUB FILTER BANK 22.Z22 at Rihand for Replacement of neutral CT along with resctification of issue of Nut Blot rusting in CB- 222.Q	12/Jul/2023	08:00	13/Jul/2023	18:00	PLANNED	Requested	
912	RQ136663	OCC_208	cpcc3_sd	FILTER BANK	400 KV 40 MVAR Filter Bank No 2 at Rihand(PG)	POWERGRID	С	S/D of AC SUB FILTER BANK 22.221 at Rihand for Replacement of neutral CT along with resctification of issue of Nut Blot rusting in CB-	10/Jul/2023	08:00	11/Jul/2023	18:00	PLANNED	Requested	
913	RQ136673	OCC_208	cpcc3_sd	FILTER BANK	400 KV 240 MVAR Filter Bank No 1 at Rihand(PG)		C	221.Q S/D of AC SUB FILTER BANK 21.213 at Rihand for Replacement of neutral CT along with resctification of issue of Nut Blot rusting in CB-	07/Jul/2023	08:00	08/Jul/2023	18:00	PLANNED	Requested	
914	RQ136815	OCC_208	cpcc3_sd	FILTER BANK	400 KV 240 MVAR Filter Bank No 1 at Rihand(PG)	POWERGRID	С	Z13.Q S/D of AC SUB FILTER BANK Z1.212 at Rihand for Replacement of neutral CT along with resctification of issue of Nut Blot rusting in CB-	05/Jul/2023	08:00	06/Jul/2023	18:00	PLANNED	Requested	
915	RQ136664	OCC_208	cpcc3_sd	FILTER BANK	400 KV 240 MVAR Filter Bank No 1 at Rihand(PG)	POWERGRID	С	Z12.Q S/D of AC SUB FILTER BANK Z1.Z11 at Rihand for Replacement of neutral CT along with resctification of issue of Nut Blot rusting in CB-	03/Jul/2023	08:00	04/Jul/2023	18:00	PLANNED	Requested	
916	RQ136857	OCC_208	cpcc3_sd	HVDC POLE	205 KV SASARAM(PG) POLE- 1	POWERGRID	C	Z11.Q Valve cooling PLC Maintenance work and BPI replacement work in Filter Main Bay by ER1. AC bypass will not be in service due to non availability of filter bay.	11/Jul/2023	08:00	12/Jul/2023	18:00	PLANNED	Requested	
917	RQ136463	OCC_208	cpcc3_sd	FSC	FSC(45%) OF 400 KV BAREILLY-UNNAO (UP) CKT-2 AT UNNAO(UP)	POWERGRID UPPTCL	D	AMP works	19/Jul/2023	08:00	19/Jul/2023	18:00	PLANNED	Requested	
918	RQ136464	OCC_208	cpcc3_sd	FSC	FSC(45%) OF 400 KV BAREILLY-UNNAO (UP) CKT-1 AT UNNAO(UP)	UPPTCL	D	AMP works	12/Jul/2023	08:00	12/Jul/2023	18:00	PLANNED	Requested	