



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
उत्तर क्षेत्रीय विद्युत समिति
Northern Regional Power Committee

विषय: उत्तर क्षेत्रीय विद्युत समिति की प्रचालन समन्वय उप-समिति की 221^{वीं} बैठक का कार्यवृत्त |

Subject: Minutes of the 221st OCC meeting of NRPC.

उत्तर क्षेत्रीय विद्युत समिति की प्रचालन समन्वय उप-समिति की 221^{वीं} बैठक दिनांक 19.07.2024 को आयोजित की गयी थी। उक्त बैठक का कार्यवृत्त उत्तर क्षेत्रीय विद्युत समिति की वेबसाइट <http://164.100.60.165> पर उपलब्ध है। यदि कार्यवृत्त पर कोई टिप्पणी हो तो कार्यवृत्त जारी करने के एक सप्ताह के अन्दर इस कार्यालय को भेजें |

The 221st meeting of the Operation Co-ordination Sub-Committee (OCC) of NRPC was held on 19.07.2024. The Minutes of this meeting has been uploaded on the NRPC website <http://164.100.60.165>. Any comments on the minutes may kindly be submitted within a week of issuance of the minutes.

संलग्नक: यथोपरि।

Signed by Dharmendra
Kumar Meena
Date: 08-08-2024 15:05:51

(डी. के. मीना)
अधीक्षण अभियंता (प्रचालन)

सेवा में,

उ.क्षे.वि.स. के प्रचालन समन्वय उप-समिति के सभी सदस्य

Contents

A.1. Confirmation of Minutes.....	4
A.2. Status of action taken on decisions of 220th OCC meeting of NRPC.....	4
A.3. Review of Grid operations of June 2024.....	4
A.4. Maintenance Programme of Generating units and Transmission Lines.....	5
A.5. Anticipated Power Supply Position in Northern Region for August 2024.....	6
A.6. Follow-up of issues from various OCC Meetings - Status update.....	7
A.7. NR Islanding scheme.....	8
A.8. Coal Supply Position of Thermal Plants in Northern Region.....	8
A.9. Status of availability of ERS towers in Northern Region (Agenda by NRPC Sectt.)	9
A.10. System Implementation of AUFLS and df/dt Scheme in Northern Region (Agenda by NRPC Sectt.).....	9
A.11. Updating outage Details by Generating Station/utilities (Agenda by CEA).....	10
A.12. Increasing capacity of ICT's at 400 KV Agra,400 KV Lucknow, Gorakhpur & Mainpuri Sub-Station (Agenda by Powergrid NR-3).....	11
A.13. Requirement of additional 400/132/33 KV,200 MVA ICT at HVDC Ballia Sub-Station. (Agenda by Powergrid NR-3).....	12
A.14. Controlling overloading of 400kV Jhatikra –Bamnauli Line (Agenda by Powergrid DTL).....	13
A.15. Revised SPS for 2X315 MVA, 400/220kV ILTs at 400kV GSS Jodhpur (Agenda by RVPN).....	14
A.16. Table Agenda1: Streamlining of Online Submission of Generation data in NPP Portal (Agenda by CEA).....	14
A.17. Table Agenda 2: Frequent auto reclosing of 400 KV Allahabad-1& 2 Breakers (Agenda by NTPC).....	15
B.1 NR Grid Highlights for June 2024.....	16
B.2 Sharing of ATC/TTC assessment and basecase with NRLDC.....	19
B.3 Grid Operation related issues in Northern region.....	23
B.4 Frequent tripping of transmission elements in the month of June'24:.....	30
B.5 Multiple element tripping events in Northern region in the month of June '24:..	31
B.6 Review and uniformity of df/dt (ROCOF) protection philosophy in Northern Region	32
B.7 Details of tripping of Inter-Regional lines from Northern Region for June' 24:..	33

B.8 Status of submission of DR/EL and tripping report of utilities for the month of June'24.	33
B.9 Frequency response characteristic:.....	34
B.10 Mock trial run and testing of black start facilities at generating stations in Northern Region.....	44
B.11 Mock testing of System Protection Schemes (SPS) in Northern Region.....	45
B.12 Availability and Standardization of recording instrument (Disturbance recorder and Station Event Logger):.....	46

उत्तर क्षेत्रीय विद्युत समिति की प्रचालन समन्वय उप-समिति की 221^{वीं} बैठक का कार्यवृत्त

The 221th OCC meeting of NRPC was held on 19.07.2024 through video conferencing.

खण्ड-क:उ.क्षे.वि.स.

PART-A:NRPC

A.1. Confirmation of Minutes

Minutes of the 220th OCC meeting was issued on 10.07.2024.

- With regard to agenda No. A.3, HPSLDC representative informed that there is a typographical error, “*The Anticipation in Energy Requirement & Peak Demand in respect of Himachal Pradesh for the month of April, 2024 came on the lower side due to consistent bad weather*” shall be replaced with following:

“*The Anticipation in Energy Requirement & Peak Demand in respect of Himachal Pradesh for the month of **May, 2024** came on the lower side due to consistent bad weather*”

- Further with regard to point no. A.7.6 of agenda No. A.7 in respect to “NR Islanding Scheme”, HPSLDC has requested that following may be modified: -

“*With regard to “Shimla-Solan Islanding Scheme” representative from **HPSEB** intimated to forum that HPSEB has been taken up the matter with M/s GE and they have given clearance to enable the UFR setting of Bhaba HEP at 47.5 Hz. M/s GE has submitted a performa invoice for 100% advance payment regarding the same.*”

OCC confirmed the minutes of the 220th OCC meeting with above modifications in agenda No.A.3 and point no. A.7.6 of agenda No. A.7.

A.2. Status of action taken on decisions of 220th OCC meeting of NRPC

A.2.1.MS, NRPC conveyed that the agenda has been taken to track the status of action taken as per decision of last meeting. Accordingly, issues may be resolved at the earliest.

A.2.2.Concerned utilities submitted the status of action taken.

Decision of OCC Forum:

Concerned utilities submitted the status of action taken and the same has been complied as Annexure- 0.

A.3. Review of Grid operations of June 2024

Anticipated vis-à-vis Actual Power Supply Position (Provisional) for June 2024

Reasons submitted by States for significant deviation of actual demand from anticipated figures during the month of June 2024 are as under:

- **Delhi**

Delhi experienced unexpected scorching heat wave in month of June-2024. So, actual peak demand and energy consumption in June-2024 are much higher than expected.

- **Haryana**

It is intimated that the deviation in Actual Power Supply Position (Provisional) vis-à-vis Anticipated figures was due to severe heat wave in northern region and increase in demand ranging from ~ 20% to 355% in the agricultural sector for the first half of the month as compared to last year data for the same period.

- **Punjab**

It is intimated that actual energy requirement is more as compared to anticipated energy requirement because of higher temperature and deficit of rainfall in the month of June 2024 in the state of Punjab.

- **Rajasthan**

The Actual Energy requirement and Peak Demand w.r.t. Anticipated Energy requirement and Peak Demand increased by 16.3% and 7.7% respectively for June' 2024 due to unexpected load growth (27.06% w.r.t. June' 2023) during the month as unexpected temperature rise & heat waves in the state control area.

- **Uttar Pradesh**

Actual energy consumption and demand was higher than anticipated due to severe heat wave and persistent 4-5 degree higher temperature in June 2024 in comparison to June 2023.

- **Uttarakhand**

The reason for significant variation in energy requirements (14.4%) and Peak Demand (10.1%) for month of June'24 against anticipated figures were due to persistent heat wave conditions along with 6-7 degree increase in temperature throughout the month and delay in pre-monsoon as compared to previous years.

A.4. Maintenance Programme of Generating units and Transmission Lines

The maintenance programme of generating units and transmission lines for the month of August 2024 was deliberated in the meeting held on 15.07.2024.

Following shutdowns was also deliberated in the OCC meeting:

Element Name	Daily/ Cont.	Reason	Requested From	Requested To	Decision of OCC
400KC D/C BARMER BHINMAL LINE Ckt I & 2	C	Shutdown is required for height raising / shifting work of overhead EHV line of 400KV D/C BARMER - Bhinmal line by the NHAI under the bharmala pariyojana (Phase-1)	20.07.2024 09:00 Hrs	10.08.2024 18:00 hrs.	Rejected. PowerGrid denied consent as they are carrying out some work at Bhinmal S/s and asked RVPN to apply for s/d in first week of August

A.5. Anticipated Power Supply Position in Northern Region for August 2024

The updated anticipated Power Supply Position for August 2024 is as below:

State / UT	Availability / Requirement	Revised Energy (MU)	Revised Peak (MW)	Date of revision
CHANDIGARH	Availability	240	400	No Revision submitted
	Requirement	231	457	
	Surplus / Shortfall	9	-57	
	% Surplus / Shortfall	4.0%	-12.5%	
DELHI	Availability	5303	7607	14-Jun-24
	Requirement	3900	7100	
	Surplus / Shortfall	1403	507	
	% Surplus / Shortfall	36.0%	7.1%	
HARYANA	Availability	7829	13811	12-July-24
	Requirement	8123	13124	
	Surplus / Shortfall	-294	687	
	% Surplus / Shortfall	-3.6%	5.2%	
HIMACHAL PRADESH	Availability	1374	1848	09-July-24
	Requirement	1139	1800	
	Surplus / Shortfall	235	48	
	% Surplus / Shortfall	20.7%	2.7%	
J&K and	Availability	1844	2478	17-July-24

State / UT	Availability / Requirement	Revised Energy (MU)	Revised Peak (MW)	Date of revision
LADAKH	Requirement	1846	3103	
	Surplus / Shortfall	-2	-625	
	% Surplus / Shortfall	-0.1%	-20.1%	
PUNJAB	Availability	10200	14200	19-July-24
	Requirement	11700	15500	
	Surplus / Shortfall	-1500	-1300	
	% Surplus / Shortfall	-12.8%	-8.4%	
RAJASTHAN	Availability	10560	17790	18-July-24
	Requirement	9824	17000	
	Surplus / Shortfall	736	790	
	% Surplus / Shortfall	7.5%	4.6%	
UTTAR PRADESH	Availability	17670	30500	09-July-24
	Requirement	17360	30500	
	Surplus / Shortfall	310	0	
	% Surplus / Shortfall	1.8%	0.0%	
UTTARAKHAND	Availability	1463	2300	03-July-24
	Requirement	1476	2400	
	Surplus / Shortfall	-12	-100	
	% Surplus / Shortfall	-0.8%	-4.2%	
NORTHERN REGION	Availability	56483	84300	
	Requirement	55598	84300	
	Surplus / Shortfall	885	0	
	% Surplus / Shortfall	1.6%	0.0%	

A.6. Follow-up of issues from various OCC Meetings - Status update

- A.6.1. The updated status of agenda items is enclosed at **Annexure-A.I**.
- A.6.2. In 221st OCC, SLDCs were requested again to coordinate with respective Transmission Utilities of states/UTs and submit details about the updated status of Down Stream network by State Utilities from ISTS Station (enclosed as **Annexure-A-I.I**) before every OCC meeting.
- A.6.3. MS, NRPC suggested States/UTs of NR to constitute State Operation Co-ordination Committee with participation from SLDC, STU, State DISCOMs and State GENCOs to address their internal grid/operation issues regularly and in effective manner.

A.7. NR Islanding scheme

- A.7.1. In the meeting (221st OCC), UPPTCL representative mentioned that telemetry for few stations for Unchahar islanding scheme is pending. MS, NRPC asked UPPTCL to intimate the sub-station wise timelines for the telemetry work remaining.
- A.7.2. With regard to Agra islanding scheme, UPPTCL representative apprised forum that procurement of UFR is under process and tender would be floated soon.
- A.7.3. RRVPNL representative mentioned that logic for Jodhpur-Barmer-Rajwast islanding scheme is under implementation and DPR for implementation of Suratgarh islanding scheme is under finalization.
- A.7.4. With regard to Patiala-Nabha Power Rajpura islanding scheme representative from Punjab SLDC informed that DPR for PSDF funding has been approved from their management and it has been submitted to PSDF Secretariat. In the meeting, Punjab SLDC informed that there were some observations from PSDF Sectt. and reviewed scheme has been submitted last week.
- A.7.5. With regard to Kullu-Manali Islanding scheme, HPSLDC representative apprised forum that the appraisal Committee meeting was held on 06.07.2024 and MoM of same is awaited.
- A.7.6. With regard to Shimla-Solan Islanding scheme, SE(O) highlighted that there is no progress from last few months and mentioned that a physical meeting would be conveyed by NRPC Sectt. with all stakeholders. HPSLDC to ensure participation of GE officials in the said meeting.

A.8. Coal Supply Position of Thermal Plants in Northern Region

- A.8.1. In the meeting, NRPC representative apprised forum about the coal stock position of generating stations in northern region during current month (till 09th July 2024).
- A.8.2. Average coal stock position of generating stations in northern region, having critical stock, during first nine days of July 2024 is as follows:

Station	Capacity (MW)	PLF % (prev. months)	Normative Stock Req'd. (Days)	Actual Stock (Days)
SURATGARH TPS	1500	0.69	22	3.8
TALWANDI SABO TPP	1980	0.62	22	4.7
CHHABRA-I PH-1 TPP	500	0.50	22	4.8

MS, NRPC asked above Generators to make efforts for the enhancement of coal stock as per the normative requirement.

A.9. Status of availability of ERS towers in Northern Region (Agenda by NRPC Sectt.)

A.9.1 In the meeting, EE(O) NRPC apprised forum updated inputs received from utilities are attached as **Annexure-A.II.**

A.9.2 MS, NRPC asked transmission utilities of NR that have not submitted the status of ERS set/towers available with them to submit the requisite information before next OCC meeting.

Decision of the OCC forum

- *Forum asked the transmission utilities of NR that have not submitted the status of ERS set/towers available with them to submit the requisite information before next OCC meeting.*

A.10. System Implementation of AUFLS and df/dt Scheme in Northern Region (Agenda by NRPC Sectt.)

A.10.1 NRPC representative apprised forum that the report of Task Force on Automatic Under Frequency Load Shedding (AUFLS) and df/dt scheme was approved by the NPC in 14th NPC meeting. The same needed to be taken up for implementation by NRPC.

A.10.2 NRPC representative presented the recommendation of the report to the OCC forum as below:

- i. NPC Secretariat will communicate region wise relief quantum (based on Regional Peak Demand Met during the previous FY) by 31st of May to RPCs for implementation in the next Financial Year (FY).
- ii. Distribution of relief among State/UT to be carried out based on Regional relief and demand contribution in the average of Peak demand met ratio and demand met (consumption) ratio of State/UT in the previous FY by RPCs.
- iii. Guidelines for identification of AUFLS feeders: Stage-1 & Stage-2 for downstream network at 11/22/33 kV level and Stage-3 & Stage-4 for upstream network at EHV (66/110/132 kV) level.
- iv. Prioritization of the loads under the AUFLS and df/dt scheme: Feeders catering to critical loads are to be avoided. VIP areas, Airport, Metro, Railways and Defence etc. has been prioritized.
- v. Quantum Identification for AUFLS by States/UT and monthly vetting: Each SLDC shall carry out month-wise Stage-wise analysis and furnish to RPC/RLDC. Actual Relief for the month and recommended Relief for the month for each Stage. The data would be vetted by RLDC and discussed in OCC Meetings of RPC. As a general Guideline Actual Relief for the month should be 10% more than the recommended Relief for the month considering the Relay/breaker issues and a resilient safety net.
- vi. Analysis of AUFLS Event and discussion in OCC Meetings of RPC.
- vii. Mapping of AUFLS feeder at SLDC and RLDC level.
- viii. SLDCs shall download the data and store it for two years. The Data should be made available to RPCs/RLDCs/CEA/CERC for further studies or analysis.

- ix. Settings of UFR for Pumping load/Energy Storage Systems: All Energy Storage Systems would change from charging mode to discharging mode at 49.50 Hz. If it is not possible then they would be tripped at 49.50 Hz. If ESS is injecting active power at 49.50 Hz not to be tripped. Pumping load will be tripped before AUFLS first stage. Irrigation Pumps would be tripped at 49.50 Hz.
- x. All the relays procured in future to have a sampling period ranging from three (03) cycles to five (05) Cycles. No additional time delay to be incorporated in the relay other than the inherent measuring time.
- xi. Testing/Inspection of UFR: SLDCs responsible for testing and chalk out a plan of relays testing schedule before 1st of December and submit the same to RPC/RLDC. The periodicity of testing of relays shall be twice in a year at 110 / 132 kV level and above Substations and once in a year at 66 kV level and below Substations.
- xii. RPC would carry UFR inspection randomly on sample basis by the RPC Secretariat or through RLDC.
- xiii. df/dt Scheme: It is specific to regions and therefore, the quantum of load shedding may be discussed at regional levels in the RPCs in consultation with the stakeholders.

A.10.3 Representative of HP SLDC stated that they would face difficulty in testing of UFRs due to non-availability of sufficient manpower with SLDC for this purpose.

A.10.4 Representative of NRLDC stated that SLDC may carry out testing of UFRs through respective STUs and SLDC may coordinate for the same.

A.10.5 CGM, NRLDC stated that NR constituents may go through the report of the task force and submit queries, if any, to NRPC Secretariat before the next OCC meeting.

Decision of OCC Forum:

Forum requested NR constituents to go through the report of the task force and submit queries, if any, to NRPC Secretariat before the next OCC meeting.

A.11. Updating outage Details by Generating Station/utilities (Agenda by CEA)

A.11.1. NRPC representative apprised forum that to enhance the monitoring of approved Planned Maintenance schedules, CEA has asked that information regarding actual maintenance availed against approved planned maintenance is to be updated on priority by respective RPCs regularly on monthly basis.

A.11.2. In this regard, list of Planned Maintenance schedules versus actual maintenance availed for the year 2024-25 for the month of April, May & June-2024 attached as Annexure-A.VI. of agenda was shared with the relevant generating stations of NR and based on the inputs received from them the updated information is attached as **Annexure-A.III**.

A.11.3. Chief Engineer (OPM), CEA requested RPC Sectt. to kindly update the google sheet circulated by them about Planned Maintenance schedules versus actual maintenance

availed for the year 2024-25 and also ensure that Generating Station/utilities of NR are submitting for each month the details of the maintenance activities that transpired against the originally planned schedule. Further, any deviations from the planned schedule shall be explained by the concerned generating entities.

- A.11.4. MS, NRPC was of view that said matter to be taken as agenda in every OCC meeting and generating stations of NR to update the status of Planned Maintenance schedules versus actual maintenance availed for the previous month before every OCC meeting.

Decision of OCC Forum:

Forum agreed to take this matter as agenda in every OCC meeting and asked generating stations of NR to update the status of Planned Maintenance schedules versus actual maintenance availed for the previous month before every OCC meeting.

A.12. Increasing capacity of ICT's at 400 KV Agra, 400 KV Lucknow, Gorakhpur & Mainpuri Sub-Station (Agenda by Powergrid NR-3)

- A.12.1. Powergrid NR-3 representative apprised forum that ICTs at Agra, Gorakhpur, Lucknow and & Mainpuri Sub-Station under the peak loading are not complying N-1 contingency criteria.
- A.12.2. Further he mentioned that regarding addition of new ICTs at above Substations, space requirement was identified and observed that space for new ICT is available at all Substations i.e. Agra (with provision of outdoor GIS bays), at 400kV Lucknow (with provision of outdoor GIS bays), at 400kV Gorakhpur (with provision of outdoor GIS bays) and at Mainpuri S/S.
- A.12.3. CTU representative acknowledged that based on the load pattern of ICT for above mentioned substations for past one year, there is an issue of overloading of ICT's at Agra and Lucknow S/s. However, loading of ICTs at 400kV Gorakhpur and Mainpuri substations are within n-1 limit.
- A.12.4. CTU representative also mentioned that for 400/220kV Lucknow (PG) ICT augmentation, confirmation from UPPTCL is required as Mohanlalganj has also been commissioned near Lucknow.
- A.12.5. NRLDC mentioned that they have highlighted in quarterly feedback to CTUIL their concern regarding N-1 non-compliant ICTs at 400kV Agra and 400 kV Lucknow Sub-Station of Northern Region-3.
- A.12.6. MS, NRPC asked UPPTCL to give their inputs on the said matter to CTU in next 10 days. Subsequently the issue may be taken up in the CMETS meeting of CTU.

Decision of OCC Forum:

Forum asked UPPTCL to give their inputs on the said matter to CTU in next 10 days and subsequently the issue may be taken up in the CMETS meeting of CTU.

**A.13. Requirement of additional 400/132/33 KV,200 MVA ICT at HVDC Ballia Sub-Station.
(Agenda by Powergrid NR-3)**

- A.13.1. Powergrid NR-3 representative apprised forum that as on date no spare ICT of 200MVA, 400/132kV rating is available in Northern Region-3.
- A.13.2. Regarding auxiliary supply from tertiary of 400/132 KV 200 MVA ICT, Powergrid NR-3 mentioned that there are 02 nos 132 KV transmission lines of UPPTCL connected to UPPTCL SubStation. There are frequent faults in these lines which are being fed by this ICT, Hence the reliability of this ICT is also not good.
- A.13.3. Therefore, for reliability of HVDC Ballia-Bhiwadi link Powergrid has requested following:
- Approval of one additional 200MVA, 400/132/33kV ICT along with bays at Ballia (PG) substation on priority basis, for which space is available at Ballia Substation.
- A.13.4. Allowing procurement of one spare 200MVA, 400/132/33kV ICT to meet out contingency requirement.
- A.13.5. CGM, NRLDC stated that with regard to the requirement of an additional 200MVA, 400/132/33kV ICT, views of UPPTCL are required on as the power from the proposed ICT would ultimately be fed in UP system. Further, in respect of requirement of spare ICT, CEA Regulations/norms may be referred.
- A.13.6. Powergrid representative stated that there is no spare available with POWERGRID in UP & Uttarakhand states of this rating.
- A.13.7. CGM, NRLDC enquired about the number of ICTs with this rating installed in the Powergrid system in the northern region. Powergrid NR-3 responded that this is the only ICT of this rating in their system in the NR.
- A.13.8. Further, NRLDC representative informed that Agra South S/s (UP) has similar 200 MVA, 400/132kV ICTs.
- A.13.9. MS, NRPC asked UPPTCL to give their views on the Powergrid proposal before the next OCC meeting.

Decision of OCC Forum:

Forum asked UPPTCL to give their views on the Powergrid proposal before the next OCC meeting.

A.14. Controlling overloading of 400kV Jhatikra –Bamnauli Line (Agenda by Powergrid DTL)

- A.14.1. In the meeting, DTL representative explained the proposal from their side. Due to LILO of only single ckt of 400kV Bamnauli-Jhatikara D/C line at Dwarka, flow on 400kV

Bamnauli-Dwarka is much lower whereas loading of 400kV Bamnauli-Jhatikara line remains high, thus loading on one section is lower.

- A.14.2. DTL further expressed concern that due to LILO at Jhatikara, some portion of line is quad moose whereas majority of portion of line is quad bersimis.
- A.14.3. CTUIL representative stated that additional connection of 400kV Dwarka is already under implementation by POWERGRID as new 400kV Jhatikara-Dwarka D/C, therefore, long-term solution is already under implementation.
- A.14.4. NRLDC representative stated that Short-term proposal seems effective for loading management, however, bus-split operation at 400kV Bamnauli leads to reduced reliability of Bamnauli load (also feeding DIAL). Further, there is likely to be slight reduction in voltage, this will increase possibility of sudden load reduction in case of tripping as seen on 17Jun 2024 and 16Jul 2024.
- A.14.5. Further, NRLDC mentioned that the proposed arrangement would also increase loading of 400/220kV Bamnauli ICTs. In event of tripping of 400kV Jhatikara - Dwarka line after bus splitting, loading of 400/220kV ICTs at Bamnauli will increase by ~450 MW cumulatively.
- A.14.6. DTL representative stated that short term proposal was included for comments from all stakeholders and as discussed, the short-term proposal reduces reliability.
- A.14.7. OCC agreed that short-term proposal may not be implemented as it reduces reliability.
- A.14.8. OCC asked DTL to refer their long-term proposal to CEA/CTUIL for discussion at CMETS level to avoid issues during next summer season. Subsequently, the matter may be taken up at TCC/NRPC level. OCC also asked POWERGRID to expedite commissioning of 400kV Jhatikara-Dwarka D/C lines.

Decision of OCC Forum:

Forum was of view that short-term proposal of DTL may not be implemented as it reduces reliability and asked DTL to refer their long-term proposal to CEA/CTUIL for discussion at CMETS level to avoid issues during next summer season. Subsequently, the matter may be taken up at TCC/NRPC level. OCC also asked POWERGRID to expedite commissioning of 400kV Jhatikara-Dwarka D/C lines.

A.15. Revised SPS for 2X315 MVA, 400/220kV ILTs at 400kV GSS Jodhpur (Agenda by RVPN)

- A.15.1. EE(O) NRPC intimated forum that SPS for 2X315 MVA, 400/220 kV ILTs at 400kV GSS Jodhpur (Surpura) was approved in 197th OCC meeting.
- A.15.2. RVPN vide letter dated 28.06.2024 has submitted that due to increased loading in the Bilara, Jodhpur and Bhawad region, operational arrangement of lines and transformers has been changed at 400kV GSS Jodhpur. This has necessitated the revision of the approved and implemented SPS.

A.15.3. In this regard, RVPN has submitted the revised SPS for for 2X315 MVA, 400/220kV ILTs at 400kV GSS Jodhpur (Surpura). (Copy attached as Annexure-A.IX of agenda)

A.15.4. NRLDC representative mentioned that RVPN has submitted four logic for the revised SPS. Upon examination of same following are their observations:

- Group-1 logic seems ok
- Group-2 logic seems to increase loading
- Group-3 logic seems ok
- Group-4 logic seems ok

A.15.5. NRLDC mentioned that Group-1 and Group-4 logics seems to cause load loss and asked RVPN may confirm no important load connecting these groups.

A.15.6. Further, NRLDC stated that between different groups there is difference of only 200ms, it is suggested that this difference may be kept as 500ms/1sec, so that line flows become stable after 1st logic operation.

A.15.7. MS, NRPC asked RVPN to reply vide mail to the above queries of NRLDC and matter may be further deliberated in the upcoming PSC meeting of NRPC.

Decision of OCC Forum:

Forum asked RVPN to reply vide mail to the above queries of NRLDC and matter may be further deliberated in the upcoming PSC meeting of NRPC.

A.16. Table Agenda-1: Streamlining of Online Submission of Generation data in NPP Portal (Agenda by CEA)

A.16.1 NRPC representative apprised forum that all Generating Utilities/Stations in Northern Region need to be submitted their online generation data through NPP Portal.

A.16.2 Chief Engineer (OPM), CEA informed that currently many of Generating Utilities/Stations of NR are either not submitting the data or submitting the data by mail. List of such station is attached as **Annexure-A.IV**.

A.16.3 MS, NRPC asked OPM division CEA to once again share the login credentials for NPP portal with generating stations who are not submitting data online.

Decision of OCC Forum:

Forum asked all Generating Utilities/Stations in Northern Region to submit their online generation data through NPP Portal.

OPM division CEA was requested to once again share the login credentials for NPP portal with generating stations who are not submitting data online.

A.17. Table Agenda 2: Frequent auto reclosing of 400 KV Allahabad-1& 2 Breakers (Agenda by NTPC)

A.17.1. NTPC representative intimated that 400 KV Allahabad line-1 & 2 are getting frequent auto re-closures due to transient faults.

Details of Auto re-closure are as given below:-

Date	Line	Fault distance
27.06.24 @2:46:25:536 PM	Ald#1 for Bph- E	204 Km from Rihand, current 1.71 KA
04.07.24 @6:55:02:975 PM	Ald#2 Yph-E	230 Km from Rihand, current 1.45 KA
11.07.24 @4:13:47:671 PM	Ald#1 Bph-E	100.8 Km from Rihand, current 3.38 KA
14.07.24 @2:36:06:081 AM	Ald#2 Rph-E	11.5 Km from Rihand, Current 18.91 KA

A.17.2. Further, he stated that Frequency of Auto reclosures due to transient faults is significantly increasing in nature, during the fault on 14.07.2024 due to shorter distance of fault location the fault current was significantly higher in magnitude and all the Generators U#1,2,3 & 4 Fed this fault current.

A.17.3. He requested that for reliable operation of our generators and associated equipment, frequent auto re-closures of these lines need to be addressed.

A.17.4. Powergrid representative mentioned that most of the above fault are transient in nature and are due to lightning and assured to get these faults checked from the field officials.

A.17.5. MS, NRPC asked Powergrid to address this issue at the earliest.

Decision of OCC Forum:

Forum asked Powergrid to kindly get these faults checked and resolve this issue at the earliest.

खण्ड-ख: उ.क्षे.भा.प्रे.के.

Part-B: NRLDC

B.1 NR Grid Highlights for June 2024

Major grid highlights of Northern region grid for June 2024 were presented in the meeting as shown below:

Demand met details of NR

S.No.	Constituents	Max Demand met (in MW)	Date & Time of Max Demand	Max Consumption (in MUs)	Date of Max Consumption	Average Demand met (in Mus)
-------	--------------	------------------------	---------------------------	--------------------------	-------------------------	-----------------------------

			d met			
1	Chandigarh	443	13.06.2 4 at 14:00	9.1	18.06.24	7.9
2	Delhi	8656	19.06.2 4 at 15:06	177.7	18.06.24	151.8
3	Haryana	14469	19.06.2 4 at 15:00	293.4	19.06.24	259.6
4	H.P.	1919	26.06.2 4 at 11:45	41.2	26.06.24	38.3
5	J&K	2902	17.06.2 4 at 05:00	58.7	17.06.24	54.6
6	Punjab	16089	29.06.2 4 at 12:45	357.2	26.06.24	293.2
7	Rajasthan	17774	18.06.2 4 at 11:45	378.8	19.06.24	344.8
8	U.P	30618	13.06.2 4 at 22:00	658.8	17.06.24	601.9
9	Uttarakhand	2863	14.06.2 4 at 22:00	62.1	14.06.24	56.8
10	Northern Region	91234*	19.06.2 4 at 14:37	1986.1	18.06.24	1809.0


***As per SCADA**

- In June'24, the Maximum energy consumption of Northern Region was **1986.1 MUs** on 18th June'24 and it was 16 % higher than June'23 (1714 MU 23rd June'23)
- In June'24, the Average energy consumption per day of Northern Region was **1809 MUs** and it was 23% higher than June'23 (1477 MUs/day)

- In June'24, the Maximum Demand met of Northern Region was **91234 MW** on 19th June'24 @14:37 hours (as per scada data) as compared to **77898 MW** on 23rd June'23 @22:00 hours.
- **Comparison of Average Energy Consumption (MUs/Day) of NR States for the June'23 vs June'24**

क्षेत्र/राज्य	जून- 2023	जून- 2024	% अंतर
चंडीगढ़	6.1	7.9	30.2%
दिल्ली	122.2	151.8	24.2%
हिमाचल प्रदेश	31.1	38.3	23.1%
हरियाणा	204.6	259.6	26.9%
जम्मू और कश्मीर	52.0	54.6	5.0%
पंजाब	235.9	293.2	24.3%
राजस्थान	271.1	344.8	27.2%
उत्तराखंड	49.7	56.8	14.3%
उत्तर प्रदेश	503.9	601.9	19.5%
उत्तरी क्षेत्र	1476.6	1809.0	22.5%

Energy Consumptions




Northern Region all-time high value recorded in June'24:

States	Max. Demand Met during the day (MW)		Energy Consumption (MU)	
	As per Format28/hourly data Submitted by States (MW)	As on date	As per PSP (Mus)	As on date
Chandigarh	443	13.06.24 at 14:00	9.1	18.06.24
Delhi	8656	19.06.24 at 15:06	177.7	18.06.24
Haryana	14469	19.06.24 at 15:00	293.4	19.06.24
Punjab	16089	29.06.24 at 12:45	357.2	26.06.24
U.P	30618	13.06.24 at 22:00	658.8	17.06.24
Uttarakhand	2863	14.06.24 at 22:00	62.1	14.06.24
Northern Region	91234	19.06.24 at 14:37	1986.1	18.06.24

Frequency profile

Month	Avg. Freq. (Hz)	Max. Freq. (Hz)	Min. Freq. (Hz)	<49.90 (% time)	49.90 – 50.05 (% time)	>50.05 (% time)
June'24	50.00	50.67 (07.06.24 at 18:02:40 hrs)	49.63 (11.06.24 at 00:02:40 hrs)	4.50	79.18	16.32
June'23	50.01	50.41 on 14.06.23 at 08:00:10 hrs	49.51 on 14.06.23 at 22:33:50 hrs	6.5	67.8	25.7

Reservoir Level and Generation on Last Day of Month



Detailed presentation on grid highlights of June'2024 as shared by NRLDC in OCC meeting is attached as **Annexure-B.I**.

B.2 Sharing of ATC/TTC assessment and basecase with NRLDC

All NR states except Chandigarh UT are sharing basecase and ATC/TTC assessment with NRLDC. OCC has advised all states to timely declare TTC/ATC for prospective months and revise the figures as per requirement.

CERC vide their order dated 29.09.2023 has granted approval of “Detailed Procedure for Allocation of Transmission Corridor for Scheduling of General Network Access and Temporary General Network Access under Central Electricity Regulatory Commission (Connectivity and General Network Access to the inter-State Transmission System) Regulations, 2022”.

Detailed roles and responsibilities for State Load Dispatch Centers in various timelines of the approved procedure are provided in the table below.

Purpose	S No	Action of Stakeholder	Resp onsibili	Submis sion to	Data/ Informa
---------	------	-----------------------	---------------	----------------	---------------

			ty		tion Submission Time line
1. Revision 0 TTC/ATC Declaration for Month 'M'	1(a)	Submission of node wise Load and generation data along with envisaged	SLDC	RLDC	10 th Day of 'M-12' month
		scenarios for assessment of transfer capability			
	Assessment of TTC/ATC of the import/export capability of the state and intra-state system and sharing of updated network simulation models				
1(b)	Declaration of TTC/ATC of the intra- state system by SLDC in consultation with RLDC			26 th Day of 'M-12' month	
2. Interconnecti on Studies for elements to be integrated in the month 'M'	2(a)	Submission of node-wise load and generation data & sharing of network simulation models for intra-state elements coming in the next six months	SLDC	RLDC	8 th Day of 'M- 6' month
	2(b)	Sharing of inter-connection study results			21 st Day of 'M-6' month
3. Month Ahead TTC/ATC Declaration & Base case for Operational Studies for Month 'M'	3(a)	Submission of node wise Load and generation data along with envisaged scenarios for assessment of transfer capability	SLDC	RLDC	8 th Day of 'M- 1' month
		Assessment of TTC/ATC of the intra- state system and sharing of updated network simulation models			
	3(b)	Declaration of TTC/ATC of the intra- state system in consultation with RLDC	SLDC	RLDC	22 nd Day of 'M-1' month

To encourage participation from SLDCs regarding basecase preparation and ATC/TTC assessment, two workshops have been conducted from Grid-India/NRLDC side. One workshop was conducted 31.08.2023 before the finalization of the procedure and another on 10.01.2024 recently to involve further participation from SLDCs.

Although all SLDCs are now involved in preparation of basecase & ATC/TTC assessment, it is seen that the timelines as per CERC approved procedure are not being followed and number of times basecases are not received from SLDC side.

B.2.1 ATC/TTC assessment sharing 11 months in advance

The procedure mentions that:

“SLDCs in consultation with RLDCs shall declare the import and export TTC, ATC, and TRM of the individual control/bid areas within the region in accordance with Regulation 44 (3) of the Grid Code 2023. RLDCs shall assess the import and export TTC, TRM and ATC for the group of control/bid areas within the region (if required). The computed TTC, TRM and ATC figures shall be published on the website of respective SLDCs and RLDCs, along with the details of the basis of calculations, including assumptions, if any, **at least eleven (11) months in advance**. The specific constraints indicated in the system study shall also be published on the website.”

Accordingly, SLDCs are requested to send the PSSE cases for four scenarios for July'25 i.e. Afternoon Peak, Solar Peak, Evening Peak & Off-Peak hours as given below

S. No.	Scenario	Time of Scenario
1	Off-Peak	06:00 Hrs
2	Afternoon Peak	15:00 Hrs
3	Evening Peak	22:30 Hrs
4	Solar Peak	12:00 Hrs

It is requested that the basecases as well as ATC/TTC assessments may be shared with NRLDC as per CERC approved procedure. Further, the above exercise needs to be carried out regularly monthly.

It was discussed in last several OCC meetings & all states were requested to share basecase as well as ATC/TTC assessments for M-11 scenarios on monthly basis with NRLDC as per CERC approved procedure. Accordingly, it was requested to submit the basecase as well as ATC/TTC assessments.

B.2.2 Sharing of Data and study results for interconnection studies

As per **Regulation 33 of IEGC 2023**,

(9) Each SLDC shall undertake a study on the impact of new elements to be commissioned in the intra-state system in the next six (6) months on the TTC and ATC for the State and share the results of the studies with RLDC.

(10) Each RLDC shall undertake a study on the impact of new elements to be commissioned in the next six (6) months in (a) the ISTS of the region and (b) the intra-state system on the inter-state system and share the results of the studies with NLDC.

(11) NLDC shall undertake study on the impact of new elements to be commissioned in the next six (6) months in (a) inter-regional system, (b) cross-border link and (c) intra-regional system on the inter-regional system.

In line with above, utilities are requested to share the list of elements/LGB data/interconnection study results etc as per the approved procedure which are expected to be commissioned within next six months. This needs to be practised as monthly exercise on regular basis.

The agenda was discussed in last several OCC meetings & all utilities were requested to share list of elements/LGB data/interconnection study results etc as per the approved procedure on monthly basis.

B.2.3 TTC/ATC of state control areas for monsoon 2024 (M-1)

As discussed in previous OCC meetings, most of the NR states except Ladakh and Chandigarh U/Ts are sharing basecase and ATC/TTC assessment with NRLDC.

Based on simulation studies and discussions between SLDCs and NRLDC, ATC/TTC limits for NR states for the month of Aug'2024 are attached as **Annexure-B.I of agenda**.

OCC has advised all states to timely declare TTC/ATC for prospective months and revise the figures as per requirement.

January 2024 Mails							February 2024 Mails							March 2024 Mails																					
ATC/TTC Declaration						Interconnection Studies						ATC/TTC Declaration						Interconnection Studies						ATC/TTC Declaration						Interconnection Studies					
M-1 (Feb-24)			M-11 (Jan-25)			M-6 (July-24)			M-1 (Mar-24)			M-11 (Feb-25)			M-6 (August-24)			M-1 (Apr-24)			M-11 (Mar-25)			M-6 (Sep-24)											
Data Values	Basecases		Data Values	Basecases		Data Values	Basecases		Data Values	Basecases		Data Values	Basecases		Data Values	Basecases		Data Values	Basecases		Data Values	Basecases		Data Values	Basecases										
Chandigarh	No	No	No	No	No	No	No	No	Chandigarh	No	No	No	No	No	No	No	No	Chandigarh	No	No	No	No	No	No	No	No									
Delhi	No	No	No	No	No	No	No	No	Delhi	No	No	No	No	No	No	No	No	Delhi	No	No	Yes	Yes	No	No	No	No									
Haryana	No	No	No	No	No	No	No	No	Haryana	No	No	No	Yes	No	No	No	No	Haryana	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes									
Himachal Pradesh	No	No	No	No	No	No	No	No	Himachal Pradesh	No	No	No	No	No	No	No	No	Himachal Pradesh	No	No	No	No	No	No	No	No									
Jammu and Kashmir	Yes	No	Yes	No	No	No	No	No	Jammu and Kashmir	Yes	No	Yes	No	Yes	No	No	No	Jammu and Kashmir	Yes	No	Yes	Yes	Yes	Yes	Yes	No									
Ladakh	No	No	No	No	No	No	No	No	Ladakh	No	No	No	No	No	No	No	No	Ladakh	No	No	No	No	No	No	No	No									
Punjab	No	No	Yes	No	Yes	Yes	Yes	No	Punjab	No	No	Yes	No	Yes	No	No	No	Punjab	No	No	No	No	No	No	No	No									
Rajasthan	No	No	No	No	No	No	No	No	Rajasthan	No	No	No	No	No	No	No	No	Rajasthan	No	No	No	No	No	No	No	No									
Uttar Pradesh	No	No	No	No	Yes	Yes	Yes	No	Uttar Pradesh	No	No	Yes	Yes	Yes	Yes	Yes	Yes	Uttar Pradesh	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes									
Uttarakhand	No	No	No	No	No	No	No	No	Uttarakhand	No	No	No	No	No	No	No	No	Uttarakhand	No	No	No	No	No	No	No	No									

April 2024 Mails							May 2024 Mails							June 2024 Mails																					
ATC/TTC Declaration						Interconnection Studies						ATC/TTC Declaration						Interconnection Studies						ATC/TTC Declaration						Interconnection Studies					
M-1 (May-24)			M-11 (Apr-25)			M-6 (Oct-24)			M-1 (June-24)			M-11 (May-25)			M-6 (Nov-24)			M-1 (July-24)			M-11 (June-25)			M-6 (Dec-24)											
Data Values	Basecases		Data Values	Basecases		Data Values	Basecases		Data Values	Basecases		Data Values	Basecases		Data Values	Basecases		Data Values	Basecases		Data Values	Basecases		Data Values	Basecases										
Chandigarh	No	No	No	No	No	No	No	No	Chandigarh	No	No	No	No	No	No	No	No	Chandigarh																	
Delhi	No	No	Yes	Yes	No	No	No	No	Delhi	No	No	Yes	Yes	No	No	No	No	Delhi		Yes	Yes														
Haryana	No	No	No	No	No	No	No	No	Haryana	No	No	No	No	No	No	No	No	Haryana																	
Himachal Pradesh	No	No	No	No	No	No	No	No	Himachal Pradesh	No	No	No	No	No	No	No	No	Himachal Pradesh																	
Jammu and Kashmir	Yes	No	Yes	No	Yes	No	No	No	Jammu and Kashmir	Yes	No	Yes	No	Yes	No	Yes	No	Jammu and Kashmir	Yes		Yes		Yes												
Ladakh	No	No	No	No	No	No	No	No	Ladakh	No	No	No	No	No	No	No	No	Ladakh																	
Punjab	No	No	No	No	No	No	No	No	Punjab	No	No	No	No	No	No	No	No	Punjab																	
Rajasthan	No	No	No	No	No	No	No	No	Rajasthan	No	No	No	No	No	No	No	No	Rajasthan																	
Uttar Pradesh	Yes	Yes	Yes	Yes	Yes	Yes	No	No	Uttar Pradesh	Yes	Yes	No	No	Yes	Yes	Yes	Yes	Uttar Pradesh	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes									
Uttarakhand	No	No	No	No	No	No	No	No	Uttarakhand	No	No	No	No	No	No	No	No	Uttarakhand																	

NRLDC representative stated that the agenda was also discussed in 220 OCC meeting wherein all states agreed to send the data as well as PSSE basecases on time for all three (M-1, M-6, M-11) scenarios. NRLDC CGM had asked states to get help from NRLDC in case of any difficulty and emphasized on the need for regularity in sharing the data.

In 221 OCC meeting,

- **NRLDC representative stated that Haryana, UP and J&K are generally sharing basecase as well ATC/TTC assessment with NRLDC. It was requested that other SLDCs may also timely share the same.**
- **All SLDCs agreed to share basecase as well as ATC/TTC assessment as per CERC approved procedure.**

B.3 Grid Operation related issues in Northern region

a) Voltage stability studies carried out by NRLDC

In view of the high demand season of NR and event witnessed on 17.06.2024, NRLDC has carried out voltage stability analysis for Northern region as well as individual states

Following are results from simulation studies carried out on latest All India basecase prepared in consultation with all stakeholders.

- It is observed that with NR Demand of ~92.25 GW and high IR import during peak solar, voltage stability limits are being reached particularly in Western Raj area.
- Further in case of outage of both bipoles of HVDC Champa - Kurukshetra corresponding NR Demand limit comes as 90.5 GW.

Accordingly, NRLDC requested that:

- All control room operators are extra alert when demand crosses 85GW
- In the event on 17th June 2024, it is suspected that as the grid voltages were not that low, so either the stalling of motors has taken place at comparatively higher voltages (~0.8 - 0.9 p.u. voltage), or the voltages at distribution level were very low. Accordingly, matter may be taken up with DISCOMs
- All generators to provide maximum reactive power support by injecting MVAR (30-40% of MW generation) in real-time to avoid issues of low voltage in the grid especially during solar hours.
- SLDCs/DISCOMs to ensure that available capacitor banks in their control area are healthy and in service as per requirement
- Till the availability of adequate dynamic reactive power support, the voltages in the system may be kept slightly on the higher side (not below 390 kV) so as to prevent similar incidents as seen on 17th June 2024 in future

All members agreed to adhere to above actions during the high demand season.

b) Crossing of EHVAC lines with other EHVAC/HVAC/HVDC lines

It has come to notice of NRLDC that emergency shutdowns have been applied by constituents/Transmission licensees related to the power line crossings. The shutdowns were taken as either there was clearance issue with other EHV power lines or as a safety measure due to imminent tower collapse of lower voltage transmission lines (220 KV) which are crossing over the higher voltage lines (400 KV lines).

In view of the above issues observed OCC forum agreed that:

- 1. Wherever there is likelihood of clearances with the other power line crossings during high wind/stormy weather conditions, preventive measures like putting counterweights etc. is to be carried. Shutdown for the same during low demand period would be facilitated as per the approved outage planning procedure.***

2. ***For the upcoming projects utilities to explore all possibilities for avoiding high voltage power lines undercrossing the low voltage lines. This would help in preventing multiple outages due to unforeseen circumstances like tower collapse conditions of the lower voltage transmission lines which may fall on the high voltage lines carrying larger amounts of power.***

c) Baglihar bus coupling

The agenda related to only single 400 kV outgoing line from both Baglihar stage-I (3X150MW) and stage-II (3X150MW) to Kishenpur was discussed in special meeting called by NRPC on 28.07.2020 via video conferencing to deliberate on issues related to UT of J&K and Ladakh. Tripping of one line can lead to outage of entire corresponding generating plant. JKPDD had been requested in the past to expedite coupling of two buses of Baglihar stage-I & II to minimize the chances of generation losses.

During the meeting, J&K representative informed that both these stages are coupled with cables and we will explore the further possibility for healthiness of bus coupler between both these stages. J&K agreed to take action on this front in upcoming lean hydro period i.e.in winter months.

Subsequently, on 21.06.2024, JKPDD and Baglihar HEP requested for emergency Shutdown of BHEP-I and II generating units (900 MW) along with 400 KV Baglihar-Kishenpur-I, 400 KV Baglihar- Kishenpur-III and 400 KV Baglihar- New Wanpoh-I.

During the shutdown, Baglihar Stage-I and Stage-II were coupled together and are since then getting evacuated through 400kV Baglihar-Kishenpur ckt1 and ckt2 lines while 400 KV Baglihar(JK)-Kishenpur(PG) (JKSPDCL) Ckt-3 & 400 KV New Wanpoh(PG)-Baglihar(JK) continue to remain out of service.

Further, due to absence of bus coupler in Stage-I, 3*150MW generating units of each stage are still getting evacuated separately through individual 400kV lines.

Accordingly, Baglihar HEP (JKSPDCL) was requested to provide update regarding operation of Stage-I and Stage-II units coupled together and also explore for coupling of two buses of Stage-I section.

JKSPDCL representative stated that Stage-1 and Stage-2 both stages have bus couplers. Stage-1 bus coupler is out since last one year and support from OEM is being taken as it is GIS substation. Stage-2 generation is getting evacuated through interconnection cable between Stage-1 and Stage-2 as 400kV Baglihar-Kishenpur ckt 3 and 400kV Baglihar-New Wanpoh lines are under outage. Interconnection cable between Stage-1 and Stage-2 is 800 sq. mm cable whereas 400kV lines from Baglihar are having some part as 630 sq. mm cable. Stage-2 bus coupler is available and would be charged shortly. Stage-1 and Stage-2 sections can be coupled using disconnecter switch and there is no breaker provision for connecting Stage-1 and Stage-2 buses.

NRLDC representative stated that as generally 4 evacuating lines are available for evacuation of Baglihar HEP, there is not likely to be much issue in case of N-1 contingency, accordingly, both stages may be run in synchronization.

JKSPDCL representative stated that connecting both stages is possible and same would be implemented shortly in consultation with NRLDC after revival of 400kV Baglihar-Kishenpur ckt 3 and 400kV Baglihar-New Wanpoh lines.

d) Update of Operating Procedure document in line with IEGC:

In compliance with Regulation 28.4 of Indian Electricity Grid Code-2023, Operating Procedure document would be updated by NRLDC in mid-July 2024.

NRLDC has revised the operating procedure document and same is available at

https://nrldc.in/download/draft_operatingprocedures_nr_rev0/?wpdmdl=13575&lang=en


In 220 OCC meeting, all utilities were requested to provide their inputs/comments for any suggested changes in the document.

It is requested that inputs/comments may be provided by 18th July 2024. Thereafter, the document would be uploaded by NRLDC based on comments received.


Members noted the same.

e) Near Real Time Silt Monitoring of hydro stations

Availability of near real time silt measurement data to NRLDC/ SLDCs will be helpful for real time system operation in view of frequent hydro generation outage due to silt. PPM numbers are being punched directly from the site/control room at NRLDC server providing silt measurement at NRLDC control room. During previous years also, for Nathpa Jhakri, Baspa, Karcham and other small HEPs of Uttarakhand, trends of silt data were made available at NRLDC & being monitored by system operators in real-time.



Sample available data of silt shown below suggests that there is some lead-time (varying from few hours to several hours) available with system operators to accommodate outage of hydro generators on account of high silt level.



All hydro stations are requested to take actions to provide this near-real time silt measurement to control centers (RLDCs/SLDCs) as this would help them gain some lead-time for better tackling of hydro generator outage on silt.

In 220 OCC meeting, members agreed to share the data on real-time basis with NRLDC control room and perform coordinated operations of hydro generators during monsoon season.

As per the latest status available at NRLDC, real-time silt monitoring data is being received from most of the hydro plants. All other hydro generators such as Bairasuil, Chamera-1, Chamera-3, Kishenganga, Salal, Sainj, Maneri Bhali, Chilla, Baspa, Khodri, Chibro are also requested to regularly share data.

Status of NHPC Plants as on 19.07.2024 at 10:00 hrs		Status of Other Hydro Plants as on	
Bairasuil	Not yet	Sainj	Not yet
CPS-1	Not yet	Maneri Bhali	Not yet
Kishenganga	Not yet	Chilla	Not yet
Salal	Not yet	Baspa	Not yet
Uri-1	Not yet	Khodri	Not yet
Uri-2	Not yet	Chibro	Not yet
Parbati-3	Last update on 06.07.2027		
Tanakpur	only once on 08.07.2027		
CPS-2	Last update on 16.07.2024		
CPS-3	Last update on 13.07.2025		
Dhauliganga	Last update on 17.07.2026		
Dulhasti	only once on 08.07.2027		
Sewa-2	Updating timely		
Status of SJVNL Plants and near Complexes on 19.07.2024 at 10:00 hrs			
Nathpa Jhakri HPS	Last update on 18.07.2024		
KARCHAM	Last update on 18.07.2025		

NHPC representative stated that there was some IP address issue in NHPC substations and the issue would be resolved shortly.

NRLDC representative stated that as mentioned above, some NHPC substations are sharing the silt data but frequency of sharing also needs to be improved.

All hydro generators agreed to share the data in real-time with NRLDC control room.

f) Restoration of lines outage on tower collapse

Following lines are under long outage due to tower collapse in Rajasthan state control area:

1. 400kV Bhadla-Jodhpur
2. 400kV Bhadla-Merta

Further, as per information shared by Rajasthan, tower collapse has been reported at loc no 476-480. Due to the unavailability of these two lines, issues are being observed in evacuation of RE power from Western Rajasthan.

The non-availability of these lines also leads to critical loading of other transmission elements including high loading of 400kV Bhadla(RJ)-Bikaner(RJ) which is not well maintained and reservations have been made from RVPN/Rajasthan SLDC side for this line.

Moreover, at the time of high solar and high wind generation in Western Rajasthan, voltage oscillations have also been observed due to the degraded short circuit ratio.

Further, following lines are under long outage due to tower collapse in J&K state control area:

1. 220 KV Kishenpur(PG)-Mir Bazar(PDD)
2. 220 KV Kishenpur(PG)-Ramban(PDD)

Outage of these lines has impact on reliability of J&K control area as redundancy of supply to 220kV Mir Bazar and 220kV Ramban substations will not be there.

RVPN/JKPDD were requested to expedite restoration of these two lines and also intimate the latest status to OCC forum.

Further, Committee under chairmanship of SE(O), NRPC, also visited site for issues observed in 400kV Bhadla-Bikaner D/C lines of RVPN. The Committee had also submitted its report to OCC/NRPC forum and listed out number of actions to be taken from RVPN side.

RVPN was requested to provide update on the works being carried out from their side on 400kV Bhadla-Bikaner D/C lines based on Committee recommendation.

J&K SLDC representative stated that stringing of 220kV Kishenpur-Ramban is completed and expected to be revived shortly. 220kV Kishenpur-Mirbazar is not expected to be charged shortly. Further, clearance would also be provided to charge 400kV Baglihar-Kishenpur ckt 3 and 400kV Bagilhar-New Wanpoh lines in one or two day.

RVPN representative stated that 400kV Bhadla-Merta is expected to be revived shortly on ERS. Revival of 400kV Bhadla-Jodhpur would be done on normal tower configuration in due course.

OCC asked JKPTCL and RRVPNL to expedite revival of lines under long outage on tower collapse. If revival is expected to take time, option of ERS to be explored.

g) Sharing of data for event analysis of 17th June 2024 load loss event

A Committee under Chairmanship of Member (GO&D), CEA has been constituted to analyse the issues of multiple tripping incidents occurred in the National grid at 13:53 hours of 17th June 2024 during which about 16.5 GW of consumer load in Northern Region got interrupted for a brief period.

The Committee has proposed analysis on following areas:

- Detailed analysis of cause of outage of HVDC Champa-Kurukshetra bipole
- Detailed analysis of cause of Load Drop and its impact and estimation of ATC/TTC in view of the grid event
- Detailed analysis of behaviour of Renewable Plants in Rajasthan RE complex during incident and STATCOM/SVC/TCR of NR
- Detailed analysis of Primary Response & Reactive power support of conventional plants
- Detailed review of Over Voltage Protection Settings and suggesting optimum voltage grading philosophy
- Simulation of the load reduction and estimation of dynamic reactive reserve required near affected load centres

The Committee has already conducted two meetings and planning to prepare the final report by 20th July 2024. For carrying out thorough analysis of the events, the Committee requires extensive granular data from all utilities which has also been requested through email from NRLDC/NRPC side.

All utilities agreed to cooperate and share data as requested through email at the earliest for analysis by the Committee.

h) Long outage of transmission elements

It is requested to expedite restoration of the Grid elements under long outage at the earliest and also provide an update regarding their expected restoration date/time in the meeting/ NRLDC outage portal.

Some of the key elements that need to be revived at the earliest are listed below:

S. No.	Element Name	Outage Date
1	400/220 kV 315 MVA ICT 2 at Mundka(DV)	20-09-2019
2	400/220 kV 315 MVA ICT 1 at Muradnagar_1(UP)	13-03-2020

3	50 MVAR Bus Reactor No 1 at 400KV Moradabad(UP)	03-12-2021
4	400/220 kV 240 MVA ICT 3 at Moradabad(UP)	13-12-2021
5	220 KV Gazipur(DTL)-Noida Sec62(UP) (UP) Ckt-1	30-04-2022
6	220 KV Gazipur(DTL)-Shahibabad(UP) (UP) Ckt-2	30-04-2022
7	400 KV Noida Sec 148-Noida Sec 123 (UP) Ckt-2	09-03-2023
8	400/220 KV 500 MVA ICT 1 AT RAMGARH(RS)	26-04-2023
9	400/220 kV 240 MVA ICT 1 at Muradnagar_2(UP)	05-06-2023
10	400/220 kV 500 MVA ICT 1 at Rasra (UP)	26-10-2023
11	225 MVAR Bus Series Reactor No 1 at 400 KV Ballabgarh(PG)	02-02-2024

Apart from this, other number of grid elements are also under long outage. These details are available in NRLDC website.

Update as received from UP SLDC in the meeting is shown below:

S.No.	Element Name	Date of Outage	Tenative date of revival	Outage reason
1	315 MVA ICT I at 400kV Muradnagar (Old)	13.03.2020	TWC approved on 09.12.2021 for replacement with 500MVA new ICT	Damaged
2	240 MVA ICT - III at 400kV Moradabad	13.12.2021	Alloted from Unnao and will be lifted from Unnao after installation of 500 MVA ICT at Unnao	It has been informed that 315MVA ICT has been aproved
3	240MVAICT-I at 400kV Muradnagar (New)	05.06.2023		
4	50 MVAR Bus Reactor No 1 at 400KV Moradabad(UP)	03.12.2021	Already charged	
5	500MVAICT-I at 400kV Rasra	26.10.2023	Dec-24	
6	400kV Noida sec 148 - Noida sec 123 ckt - II	09.03.2023	Oct-24	
7	220 KV Gazipur(DTL)- Shahibabad(UP) (UP) Ckt- 2	30-04- 2022	Line under break down , no further status till now . Fund not provided by MCD, Delhi.	Line remains charge at No load from UP end. Manually open at 19:30 on 30/04/22 due bending of tower

				no. 4
8	220 KV Gazipur(DTL)- Noida Sec62(UP) (UP) Ckt-1	30-04- 2022	Line under break down , no further status till now . Fund not provided by MCD, Delhi.	Tower tilted on one side at tower no 10 from Gazipur (DTL) end

All utilities agreed to expedite restoration as well as regularly update the likely revival time of elements under long outage on NRLDC OMS portal.

B.4 Frequent tripping of transmission elements in the month of June'24:

The following transmission elements were frequently tripping during the month of **June'24**:

S. NO.	Element Name	No. of forced outages	Utility/SLDC
1	400 KV Kala Amb(PKTL)- Wangto_GIS(HP) (HPPTCL) Ckt-1	3	POWERGRID/HP
2	400 KV Kala Amb(PKTL)-Sorang(Greenko) (Greenko) Ckt-1	3	POWERGRID/ Sorang
3	400 KV Abdullapur(PG)-Bawana(DV) (PG) Ckt-1	4	POWERGRID/Delhi
4	220 KV RAPS_A(NP)-Sakatpura(RS) (RS) Ckt-2	3	RAPS/Rajasthan
5	220 KV Khara(UP)-Saharanpur(PG) (UP) Ckt-1	5	POWERGRID/UP
6	220 KV Delhi RR(BB)-Narela(DV) (BBMB) Ckt-1	5	BBMB/Delhi

The complete details are attached at **Annexure-B.II of agenda**.

It may be noted that frequent tripping of such elements affects the reliability and security of the grid. Hence, utilities are requested to analyze the root cause of the tripping and share the remedial measures taken/being taken in this respect.

Agenda was deferred for discussion in Protection Sub-Committee meeting on 23.07.2024.

B.5 Multiple element tripping events in Northern region in the month of June '24:

A total of 36 grid events occurred in the month of June'24 of which **01** is of GD-2 category, **14** are of GD-1 category, **10** are of GI-2 Category and **11** are of GI-1 Category. The tripping report of all the events have been issued from NRLDC. A list of all these events is attached at **Annexure-B.III of agenda**.

Maximum delayed clearance of fault observed in event of multiple elements tripping at 400/220kV Mandaula(PG) on 11th June, 2024 (As per PMU at Mandaula(PG), B-N phase to

earth fault converted to Y-B-N double phase to earth fault with delayed fault clearing time of 2320ms is observed).

Delayed clearance of fault (more than 100ms for 400kV and 160ms for 220kV system) observed in total 12 events out of 36 grid events occurred in the month. In 07 (no.) of grid events, there was no fault in the grid.

Remedial actions taken by constituents to avoid such multiple elements tripping may be shared.

As per IEGC clause 37.2 (c), Disturbance Recorder (DR), station Event Logger (EL), Data Acquisition System (DAS) shall be submitted within 24 hrs of the event and as per IEGC clause 37.2 (e), the user shall submit a detailed report in the case of grid disturbance or grid incidence within one (1) week of the occurrence of event to RLDC and RPC.

DR/EL of the following grid events not received till date:

- a) 220kV Pong(BBMB) on 03rd Jun'24
- b) 220kV Jalandhar(BBMB) on 07th Jun'24
- c) 220kV Hiranagar(J&K) on 13th Jun'24
- d) 400/220kV Kankani(RS) on 16th Jun'24
- e) Load loss event on 17th Jun'24
- f) 400kV Rajwest(RS) on 19th Jun'24
- g) 220kV Mund(HV) on 19th Jun'24
- h) 400kV Bikaner2(PG) and Banderwala(TATA) RE station on 20th Jun'24
- i) 220kV Mohali(PSTCL) on 21st Jun'24
- j) 220kV Tughlakabad(DTL) on 23rd Jun'24

Detail report of majority of the grid events not received yet.

Members may take necessary preventive measures to avoid such grid incidents / disturbances in future and report actions taken by respective utilities in OCC & PSC forum. Moreover, utilities may impress upon all concerned for providing the Preliminary Report, DR/EL & Detailed Report of the events to RLDC in line with the regulations.

Agenda was deferred for discussion in Protection Sub-Committee meeting on 23.07.2024.

B.6 Review and uniformity of df/dt (ROCOF) protection philosophy in Northern Region

Multiple incidents of load shedding on df/dt (ROCOF) protection operation have been reported during recent past. Major operations were reported from Punjab control area. Delhi, Rajasthan & UP have also reported load shedding on df/dt operation during some of the incidents. Incidents during which df/dt operation reported is attached as **Annexure B.IV of agenda.**

In view of frequent incidents of tripping of distribution feeders on df/dt operation, analysis and review of df/dt operation is necessary. Communication has already been sent to SLDCs via mail to provide details of stage wise quantum of load relief on df/dt operation and protection setting adopted (average cycle, time delay etc.)

Name of State	df/dt settings (average cycles considered, time delay etc)	Maximum quantum of relief (MW)		
		Stage-1	Stage-2	Stage-3

Details received from Haryana only. Details received from Haryana are attached in **Annexure B.V of agenda.**

SLDCs are requested to share the adopted philosophy of df/dt protection and confirm whether uniform philosophy has been adopted throughout the state or not. Kindly share the details at the earliest so that analysis and review of df/dt operation and its philosophy may be done.

Further review of df/dt protection setting also need to be done to ensure its uniformity and to avoid undesired operation and load loss.

Agenda was deferred for discussion in Protection Sub-Committee meeting on 23.07.2024.

B.7 Details of tripping of Inter-Regional lines from Northern Region for June' 24:

A total of 13 inter-regional lines tripping occurred in the month of June'24. The list is attached at **Annexure-B.VI of agenda.** The status of receipt of preliminary reports, DR/EL within 24hrs of the event and fault clearing time as per PMU data has also been mentioned in the table. The non-receipt of DR/EL & preliminary report within 24hrs of the event from SLDCs / ISTS licensees / ISGSs is in violation of regulation 37.2(c) of IEGC and regulation 15(3) of CEA Grid Standards. As per regulations, all the utilities shall furnish the DR/EL, flag details & preliminary report to RLDC/RPC within 24hrs of the event. They shall also furnish the detailed investigation report within 7 days of the event if fault clearance time is higher than that mandated by CEA (Grid Standard) Regulations.

Members may please note and advise the concerned for taking corrective action to avoid such tripping as well as timely submission of the information.

Agenda was deferred for discussion in Protection Sub-Committee meeting on 23.07.2024.

B.8 Status of submission of DR/EL and tripping report of utilities for the month of June'24.

The status of receipt of DR/EL and tripping report of utilities for the month of June'24 is attached at **Annexure-B.VII of agenda.** It is to be noted that as per the IEGC provision under clause 37.2 (c), tripping report along with DR/EL has to be furnished within 24 hrs of the occurrence of the event. However, it is evident from the submitted data that reporting status is not satisfactory and needs improvement.

Members may please note and advise the concerned for timely submission of the information. It is requested that DR/EL of all the trippings shall be **uploaded on Web Based Tripping Monitoring System “<http://103.7.128.184/Account/Login.aspx>”** within 24 hours of the events as per IEGC clause 37.2(c) and clause 15.3 of CEA grid standard. Apart from prints of DR outputs, the corresponding COMTRADE files may please also be submitted in tripping portal / through email.

Agenda was deferred for discussion in Protection Sub-Committee meeting on 23.07.2024.

B.9 Frequency response characteristic:

The FRC based event occurred in the month of **June-2024**. Description of the event is as given below:

Table:

S. No.	Event Date	Time (In hrs.)	Event Description	Starting Frequency (in Hz)	Nadir Frequency (in Hz)	End Frequency (in Hz)	Δf	NR FRP during the event
1	04-Jun-24	10:26hrs	On 4th June 2024 at 10:26 hrs, dip in RE generation in Rajasthan RE generation complex (NR) was observed. The net generation loss of approx. 1090 MW occurred in this event. Therefore generation loss of 1090MW has been considered for FRC computation.	50.07	49.954	49.995	-0.08	0.38

2	04-Jun-24	10:34hrs	On 4th June 2024 at 10:34 hrs, dip in RE generation in Rajasthan RE generation complex (NR) was observed. The net generation loss of approx. 1295 MW occurred in this event. Therefore, generation loss of 1295 MW has been considered for FRC computation.	50.073	49.965	50.021	-0.05	1.80
3	11-Jun-24	14:10hrs	As reported, at 14:10 hrs on 11th June 2024, 400/220 kV 500 MVA ICT-3 at Mandola s/s tripped due to fire in isolator of ICT-3 (Transfer Bus side). ICT-3 was charged from transfer bus, as Main Bay (212) was under planned shutdown. At the same time, remaining 03 Nos 400/220 kV 500 MVA ICTs also tripped. As reported by SLDC Delhi, 1601 MW	49.929	50.027	50.006	0.08	1.33

			load loss and generation loss of 279 MW at Pragati (Units-10,11 and 12) were observed. Hence net load loss of (1601-279=) 1322 MW is considered for FRC/FRP Calculation.					
4.	11-Jun-24	14:10hrs	As reported, at 13:53 Hrs of 17th June 2024, NR demand experienced a reduction in load of the order of 16.5 GW. The incident occurred immediately after tripping of both bipoles of +/-800 kV HVDC Champa (WR)-Kurukshetra (NR) which was carrying 4,500 MW from the WR to NR. After tripping of the HVDC link, low voltages were observed across the Northern region and multiple lines and generation tripping occurred. Partial outage of the 765/400kV Aligarh (PGCIL) station occurred due to reported tripping of five (5) nos 765 kV lines. In the Northern Region hydro generating	50.034	50.681	50.629	0.59	0.62

			<p>units tripped at Bhakra, Karcham, Sainj, Ranjit Sagar Dam. Thermal generating units in NR tripped at Lalitpur, Rajwest and Panipat. NR Renewable Generation (Solar) of 2,870 MW approx. (majorly in Rajasthan) was also affected. Moreover, tripping of generation units at Mahan Energen (MEL) in WR and two modules of OTPC Palatana in the North Eastern Region were reported. Hence net load loss of 9725 MW [16500 (Change in NR demand) - 5240 (NR generation loss)- 1117 (MEL generation loss) - 418 (OTPC Palatana generation loss)] is considered for FRC/FRP Calculation.</p>					
			<p>At 12:42 hrs on 19th June 2024, dip in solar, wind generation and load loss in Punjab, Rajasthan and UP was observed. At the same time as per SCADA and data received from SLDCs around 3893 MW dip in</p>					

5.	19-Jun-24	12:42hrs	<p>solar generation, 597 MW dip in wind generation was observed. Rajwest IPP Units-2,4,5,6 & 8 also tripped at the same time reportedly due to grid voltage fluctuations. Further, load throw-off (1050 MW) occurred in Punjab, UP and Rajasthan control area due to df/dt relay operation. Hence net generation loss of 4480 MW [=3490 MW (Rajasthan ISTS connected RE) + 843 MW (Rajasthan Solar) + 597 MW (Rajasthan wind)+ 600 MW (Rajwest IPP)-1050 MW (df/dt load throw off)] is considered for FRC/FRP Calculation.</p>	50.060	49.653	49.873	-0.19	1.72
----	-----------	----------	--	--------	--------	--------	-------	------

As per IEGC 2023 Clause 30.10.(n), "Each control area shall assess its frequency response characteristics and share the assessment with the concerned RLDC along with high resolution data of at least 1 (one) second for regional entity generating stations and energy storage systems and 10 (ten) seconds for the state control area."

As per sub-clause (a(v)) of clause (9) of IEGC 2023 Annexure-2, "All the SLDCs shall work out FRC for all the intra-state entities (for events indicated by the Regional Load Despatch Centres) based on the HDR available at their respective SLDCs and submit the same to respective RLDC within six (6) working days after the event. (Format as per Table-B)."

As per sub-clause (a(vi)) of clause (9) of IEGC 2023 Annexure-2, "All regional entity generating stations shall also assess the FRC for their respective stations and submit the same to respective RLDC within six (6) working days. (Format as per Table-B). The high-resolution data (1 second or better resolution) of active power generation and frequency shall also be shared with RLDC."

Status of details received from constituents is:

FRC computation and data submission status						
S. No	Control Area	Event Date				
		04-06-2024_10:26hrs	04-06-2024_10:34hrs	11-06-2024	17-06-2024	19-06-2024
1	Punjab	Not Received	Not Received	Not Received	Not Received	Not Received
2	Haryana	Not Received	Not Received	Not Received	Not Received	Not Received
3	Rajasthan	Not Received	Not Received	Not Received	Not Received	Not Received
4	Delhi	Not Received	Received*	Not Received	Received*	Not Received
5	Uttar Pradesh	Received	Received	Not Received	Received	Received
6	Uttarakhand	Not Received	Not Received	Not Received	Not Received	Not Received
7	Chandigarh*	NA	NA	NA	NA	NA
8	Himachal Pradesh	Received	Received	Received	Received	Received
9	J&K(UT) and Ladakh(UT)	Not Received	Not Received	Not Received	Not Received	Not Received
10	Dadri -1 (TH)	Received	Received	Not Received	Not Received	Not Received
11	Dadri -2 (TH)	Received	Received	Not Received	Not Received	Not Received
12	Jhajjar (TH)	Not Received	Not Received	Not Received	Not Received	Not Received
13	Rihand-1 (TH)	Received	Received	Received	Received	Not Received
14	Rihand-2 (TH)	Received	Received	Received	Received	Not Received
15	Rihand-3 (TH)	Received	Received	Received	Received	Not Received
16	Shree Cement (TH)	Not Received	Not Received	Not Received	Not Received	Not Received
17	Singrauli (TH)	Received	Received	Received	Received	Received
18	Tanda-2 (TH)	Not Received	Not Received	Not Received	Received	Not Received
19	Unchahar stg-4 (TH)	Received	Received	Received	Received	Not Received
20	Unchahar (TH)	Received	Received	Received	Received	Not Received
21	Anta (G)	Received	Received	Not Received	Not Received	Not Received

22	Auraiya (G)	Not Received	Not Received	Not Received	Not Received	Not Received
23	Dadri (G)	Not Received	Not Received	Not Received	Not Received	Not Received
24	AD Hydro (H)	Received	Received	Received	Received	Received
25	Bairasiul (H)	Not Received	Not Received	Not Received	Not Received	Not Received
26	Bhakra (H)	Not Received	Not Received	Not Received	Not Received	Not Received
27	Budhil (H)	Received	Received	Not Received	Not Received	Not Received
28	Chamera-1 (H)	Not Received	Not Received	Not Received	Not Received	Not Received
29	Chamera-2 (H)	Not Received	Not Received	Not Received	Not Received	Not Received
30	Chamera-3 (H)	Not Received	Not Received	Not Received	Not Received	Not Received
31	Dehar (H)	Not Received	Not Received	Not Received	Not Received	Not Received
32	Dhauliganga (H)	Not Received	Not Received	Not Received	Not Received	Not Received
33	Dulhasti (H)	Not Received	Not Received	Not Received	Not Received	Not Received
34	Karcham (H)	Received	Received	Received	Received	Received
35	Kishanganga	Not Received	Not Received	Not Received	Not Received	Not Received
36	Koldam (H)	Received	Received	No Gen	Received	Received
37	Koteshwar (H)	No Gen	No Gen	No Gen	No Gen	No Gen
38	Malana-2 (H)	NA	NA	NA	NA	NA
39	Nathpa Jhakri (H)	Received	Received	Received	Received	Received
40	Parbati-2 (H)	No Gen	No Gen	No Gen	No Gen	No Gen
41	Parbati-3 (H)	No Gen	No Gen	No Gen	No Gen	No Gen
42	Pong (H)	Not Received	Not Received	Not Received	Not Received	Not Received
43	Rampur (H)	Received	Received	Not Received	Received	Received
44	Sainj (H)	Not Received	Not Received	Not Received	Not Received	Not Received
45	Salal (H)	Not Received	Not Received	Not Received	Not Received	Not Received
46	Sewa-II (H)	No Gen	No Gen	No Gen	No Gen	No Gen
47	Singoli Bhatwari (H)	Not Received	Not Received	Not Received	Not Received	Not Received
48	Sorang (H)	Not Received	Not Received	Not Received	Not Received	Not Received
49	Tanakpur (H)	Not Received	Not Received	Not Received	Not Received	Not Received

50	Tehri (H)	No Gen	No Gen	No Gen	No Gen	No Gen
51	Uri-1 (H)	Not Received	Not Received	Not Received	Not Received	Not Received
52	Uri-2 (H)	Not Received	Not Received	Not Received	Not Received	Not Received

FRC/FRP as per SCADA data at NRLDC is as follows:

Frequency response Performance						
S. No	Control Area	Event Date				
		04-06-2024_10:26hrs	04-06-2024_10:34hrs	11-06-2024	17-06-2024	19-06-2024
1	Punjab	0.71	0.96	0.72	-0.04	-0.10
2	Haryana	0.18	0.31	0.41	-0.18	1.29
3	Rajasthan	-2.31	0.29	-0.48	0.89	1.79
4	Delhi	0.62	-1.30	1.28	-2.13	-0.23
5	Uttar Pradesh	-0.13	0.84	-0.22	0.51	0.58
6	Uttarakhand	-0.64	0.47	0.10	-0.12	0.45
7	Chandigarh*	NA	NA	NA	NA	NA
8	Himachal Pradesh	-1.88	0.11	-1.25	1.22	-1.04
9	J&K(UT) and Ladakh(UT)	0.68	-0.12	0.52	-3.24	0.18
10	Dadri -1 (TH)	1.33	2.97	0.28	1.58	3.60
11	Dadri -2 (TH)	-0.50	-1.55	0.58	1.34	6.17
12	Jhajjar (TH)	-1.62	3.05	-0.23	1.33	5.18
13	Rihand-1 (TH)	-6.33	-0.26	1.42	1.62	3.31
14	Rihand-2 (TH)	1.24	2.41	-0.16	1.67	2.55
15	Rihand-3 (TH)	0.00	1.05	0.00	0.06	-0.29
16	Shree Cement (TH)	1.01	1.47	0.00	0.00	2.05
17	Singrauli (TH)	0.78	-3.24	0.03	0.45	1.76
18	Tanda-2 (TH)	0.08	0.38	1.11	2.48	3.00
19	Unchahar stg-4 (TH)	2.52	10.39	0.92	1.90	6.16
20	Unchahar (TH)	-0.05	0.01	0.16	-0.01	-0.02
21	Anta (G)	0.36	1.26	1.23	-0.59	2.95
22	Auraiya (G)	0.78	0.41	-0.39	6.73	0.23
23	Dadri (G)	3.92	5.51	2.49	6.12	4.85
24	AD Hydro (H)	14.79	24.32	-1.82	5.19	8.26
25	Bairasiul (H)	0.00	0.00	0.00	-0.02	0.00
26	Bhakra (H)	0.11	0.10	-0.15	38.81	0.01
27	Budhil (H)	0.19	0.82	0.18	0.12	-0.30
28	Chamera-1 (H)	0.07	-1.46	0.21	5.13	6.55
29	Chamera-2 (H)	-0.63	2.58	0.76	2.89	0.37
30	Chamera-3 (H)	0.00	0.00	-0.19	2.16	0.01

31	Dehar (H)	1.24	1.60	0.17	0.26	0.09
32	Dhauliganga (H)	-6.99	6.81	2.30	5.21	0.47
33	Dulhasti (H)	-1.03	1.70	0.15	4.32	0.29
34	Karcham (H)	8.49	13.28	8.28	57.64	2.92
35	Kishenganga	-0.27	0.49	0.12	-0.03	-0.02
36	Koldam (H)	2.56	6.55	No Gen	7.57	0.00
37	Koteshwar (H)	No Gen	No Gen	No Gen	No Gen	No Gen
38	Malana-2 (H)	NA	NA	NA	NA	NA
39	Nathpa Jhakri (H)	8.46	8.38	7.04	7.84	2.10
40	Parbati-2 (H)	No Gen	No Gen	No Gen	No Gen	No Gen
41	Parbati-3 (H)	No Gen	No Gen	No Gen	No Gen	No Gen
42	Pong (H)	0.78	-0.72	-0.31	0.05	-0.02
43	Rampur (H)	2.59	7.57	0.85	8.38	-0.35
44	Sainj (H)	0.00	0.00	-0.22	87.21	0.36
45	Salal (H)	0.31	0.67	0.05	8.00	-0.08
46	Sewa-II (H)	No Gen	No Gen	No Gen	No Gen	No Gen
47	Singoli Bhatwari (H)	0.02	0.04	0.08	-0.04	-0.17
48	Sorang (H)	-0.08	0.19	0.15	-0.04	-0.13
49	Tanakpur (H)	21.01	-0.85	-2.86	-0.36	0.40
50	Tehri (H)	No Gen	No Gen	No Gen	No Gen	No Gen
51	Uri-1 (H)	0.35	0.58	0.14	2.90	0.55
52	Uri-2 (H)	0.00	0.00	-1.18	0.00	-0.48

Members are requested to analyse the frequency response of their respective control area and share the FRC/FRP analysis of generating stations along with unit wise 01 sec data of for the aforementioned event.

ISGS were requested to confirm whether FGMO as per IEGC 2023 has been implemented at their respective stations or not. Updated sheet on the basis of details received is as follows:

Sl. No.	Entity	Capacity(MW)	Governor Mode (FGMO as per IEGC 2023) Yes or No	Drop setting (%)	Remarks (if any)
1	Dadri-1 (TH)	4*200			
2	Dadri -2 (TH)	2*490			
3	Jhajjar (TH)	3*500			
4	Rihand-1 (TH)	2*500	Yes	5.0	Under Implementation
5	Rihand-2 (TH)	2*500	Yes	5.0	Under Implementation

6	Rihand-3 (TH)	2*500	Yes	5.0	Under Implementati on
7	Shree Cement (TH)	(2 * 150)			
8	Singrauli (TH)	2*500+5*200			
9	Tanda-2 (TH)	2*660			
10	Unchahar stg-4 (TH)	1*500			
11	Unchahar (TH)	2*210			
12	Anta (G)	(1 * 153.2 + 3 * 88.71)			
13	Auraiya (G)	(2 * 109.3 + 4 * 111.19)			
14	Dadri (G)	(2 * 154.51 + 4 * 130.19)			
15	AD Hydro (H)	(2 * 96)	YES	4.0	-
16	Bairasiul (H)	(3 * 60)	Yes	4.0	
17	Bhakra (H)	(5 * 126 + 5 * 157)			
18	Budhil (H)	(2 * 35)			
19	Chamera-1 (H)	(3 * 180)	Yes	5.0	
20	Chamera-2 (H)	(3 * 100)	Yes	5.0	
21	Chamera-3 (H)	(3 * 77)	Yes	4.0	
22	Dehar (H)	(6 * 165)			
23	Dhauliganga (H)	(4 * 70)	Yes	5.0	
24	Dulhasti (H)	(3 * 130)	Yes	5.0	
25	Karcham (H)	(4 * 261.25)	Yes	5.0	
26	Kishenganga	(3 * 110)	Yes	4.0	
27	Koldam (H)	(4 * 200)	Yes	4.0	
28	Koteswar (H)	(4 * 100)	Yes	4.0	
29	Malana-2 (H)	(2 * 50)			
30	Nathpa Jhakri (H)	(6 * 250)	Yes	5.5	
31	Parbati-2 (H)	(4 * 200)			
32	Parbati-3 (H)	(4 * 130)	Yes	4.0	
33	Pong (H)	(6 * 66)			
34	Rampur (H)	(6 * 68.67)			
35	Sainj (H)	(2 * 50)			
36	Salal (H)	(6 * 115)	Yes	3.0	
37	Sewa-II (H)	(3 * 40)	Yes	4.0	
38	Singoli Bhatwari (H)	(3 * 33)			
39	Sorang (H)	(2 * 50)			
40	Tanakpur (H)	(1 * 31.42 + 2 * 31.4)	Yes	4.0	
41	Tehri (H)	(4 * 250)	Yes	4.0	
42	Uri-1 (H)	(4 * 120)	Yes	6.0	

43	Uri-2 (H)	(4 * 60)	Yes	5.0	
----	-----------	------------	-----	-----	--

Constituents are requested to share the details at the earliest.

Agenda was deferred for discussion in Protection Sub-Committee meeting on 23.07.2024. Mock trial run and testing of black start facilities at generating stations in Northern Region

As per Indian Electricity Grid Code (IEGC) clause 34.3

“Detailed procedures for restoration post partial and total blackout of each user system within a region shall be prepared by the concerned user in coordination with the concerned SLDC, RLDC or NLDC, as the case may be. The concerned user shall review the procedure every year and update the same. The user shall carry out a mock trial run of the procedure for different sub-systems including black-start of generating units along with grid forming capability of inverter based generating station and VSC based HVDC black-start support at least once a year under intimation to the concerned SLDC and RLDC. Diesel generator sets and other standalone auxiliary supply source to be used for black start shall be tested on a weekly basis and the user shall send the test reports to the concerned SLDC, RLDC and NLDC on a quarterly basis”.

Hydro and gas-based plants are capable of self-black-start. Conducting periodic mock black start exercises are extremely important to ensure the healthiness of black start facilities and also to build awareness as well as confidence among the system operators.

In view of above, regional entity generating stations shall conduct the dead bus charging of their units on rotation basis as per availability of schedule under intimation to the NRLDC. Testing of Diesel generator sets and other standalone auxiliary supply source to be used for black start shall also be done on a weekly basis. SLDC shall also ensure the same in their respective control area. This will ensure the healthiness of blackstart facility at generating stations. Further, NRLDC shall coordinate with the ISGS and states to conduct the mock black start exercise of subsystems.

Therefore, regional entity generating stations and SLDCs are requested to share the annual schedule plan for conducting dead bus charging / mock black start exercise of generating stations / sub-systems during 2024-25 in the format attached as **Annexure-B.VIII of agenda**. Constituents are also requested to share the test report of diesel generators / auxiliary supply on a quarterly basis. In this regard, a communication has already been sent to constituents through NRLDC letter dated 24.04.2024.

Details received from AD Hydro HEP, Tehri HEP, Karcham Wangtoo HEP, Koteshwar HEP, SJVN, Budhil, Chamera-III, Auraiya GPS, Singoli Bhatwari HEP, Koldam HEP, Dadri GPS, Delhi, Punjab and Uttarakhand.

Members are requested to share the tentative schedule of mock black start exercise of generating stations in their respective control area. SLDCs are also requested to share the tentative schedule plan of mock black start exercise of generating stations in their respective control area and share the report of the same.

Agenda was deferred for discussion in Protection Sub-Committee meeting on 23.07.2024.

B.10 Mock testing of System Protection Schemes (SPS) in Northern Region

There are 53 numbers of System Protection Scheme (SPS) approved in Northern Region out of which 05 number of SPS are under implementation stage. These SPS are implemented at major generation complexes, important evacuating transmission lines and ICTs which are N-1 non complaint. Details of SPS in Northern Region is available on NRLDC website at link <https://nrlcdc.in/download/nr-sps-2024/?wpdmdl=13255&lang=en> .

SPS is designed to detect abnormal system conditions and take predetermined, corrective action to preserve system integrity and provide acceptable system performance. Therefore, correct operation of SPS as per designed logic is important to serve its purpose. To ensure this, mock testing of SPS needs to be conducted at a regular period. Clause 16.2 of IEGC 2023 also mandates the mock testing of SPS for reviewing SPS parameters & functions, at least once a year.

In view of the above, concerned constituents / utility are requested to share the tentative schedule plan for conducting mock testing of SPS in their respective control area during 2024-25 in format attached as **Annexure-B.IX of agenda**. In this regard, a communication has already been sent to constituents through NRLDC letter dated 01.05.2024.

Details only received from Uttarakhand & UP.

Members are requested to share the tentative schedule of mock testing of SPS implemented on their control area and share the report of the same.

Agenda was deferred for discussion in Protection Sub-Committee meeting on 23.07.2024.

B.11 Availability and Standardization of recording instrument (Disturbance recorder and Station Event Logger):

As per IEGC clause 17

- 1) *All users shall keep the recording instruments (disturbance recorder and event logger) in proper working condition.*
- 2) *The disturbance recorders shall have time synchronization and a standard format for recording analogue and digital signals.*

IEGC clause 37.2 (c) also mandates the submission of Disturbance Recorder (DR), station Event Logger (EL), Data Acquisition System (DAS) within 24 hrs of the event.

Data of recording instruments (DR/EL) are very helpful in grid event analysis and also is being used in availability verification of transmission lines. Complete and conclusive analysis of any grid event is not possible without these recording instruments and thus their standardization is very important.

Therefore, availability of disturbance recorder with standardization, time sync and correct nomenclature and station event logger need to be ensured by users at the station of their respective control area.

In view of the above, all the constituents are requested to share the details w.r.t. availability and standardization of disturbance recorder and event logger at the station of their respective control area in format attached as **Annexure-B.X of agenda**.

Details only received from Haryana & UP.

Members are requested to share the share the details w.r.t. availability and standardization of disturbance recorder and event logger at the station of their respective control area.

Agenda was deferred for discussion in Protection Sub-Committee meeting on 23.07.2024.

Status of action taken on decision in 220th OCC meeting of NRPC

S.N.	Agenda	Decision of 220 th OCC meeting of NRPC	Status of action taken
1	A.11 Requirement of additional 500 MVA, 400/220/33kV ICT at Samba (PG) Substation to meet increasing load demand of Jammu city (Agenda by JKPTCL)	Forum asked JKPTCL that since it is an ISTS network they may approach CTU along with details regarding the timeframe the downstream network is expected.	JKPTCL informed that they have approached CEA on the said matter.
2	A.12 Construction of 320MVA, 220/66 KV, Grid Sub-Station, Bhaathall Kathua (Agenda by JKPTCL)	Forum asked JKPTCL to approach CEA on the cited matter.	JKPTCL informed that they have approached CEA on the said matter.
3	A.13 Revised System Protection Scheme (SPS) scheme for Anpara Complex (Agenda by UPSLDC)	Forum directed that a separate meeting among constituents may be held next week to review the SPS scheme for Anpara Complex.	UPSLDC informed that they have submitted agenda for revised SPS for Anpara Complex in upcoming PSC meeting scheduled on 23.07.2024.
4	A.14 N-1 contingency violation in 400/220/33KV 315MVA ICT-I at BBMB Dehar (Agenda by Powergrid NR-2)	Forum asked Powergrid, PSTCL, HPPTCL and BBMB to internally have a discussion/study on the SPS as temporary relief for Transformer overloading at BBMB Dehar and submit accordingly. Further, for installation of new transformer at BBMB Dehar S/s, proposal may be submitted by Powergrid to CTU for study.	BBMB informed that an internal meeting with HPPTCL, PSTCL and Powergrid is scheduled on 25.07.2024 on said matter.

Status of action taken on decision in 220th OCC meeting of NRPC

5	A.16 Tapping Tertiary of 765/400/33 kV ICT - 2 for Reliable Auxiliary Power Supply to ±500kV HVDC Ballia Sub-Station (Agenda by POWERGRID, NR3)	Forum agreed with the Powergrid proposal of Additional source of Auxiliary Power connectivity from tertiary of 765/400/33 KV ICT-2 for reliable auxiliary supply to HVDC Ballai Sub-Station and asked POWERGRID that since they have submitted that cost estimate may be considered under ADD-Cap therefore the same may be brought up as Agenda by POWERGRID in the NRPC board meeting for approval of NRPC Forum.	Approval accorded by NRPC forum to Powergrid proposal of Additional source of Auxiliary Power connectivity from tertiary of 765/400/33 KV ICT-2 for reliable auxiliary supply to HVDC Ballai Sub-Station.
6	A.19 Restoration of damaged tower No.4 (C-Type) of double circuit line connecting Noida Sector-62 and Sahibabad to DTL 220kV Gazipur S/Stn. [Delhi-UP Corridor]. (Agenda by DTL)	Forum asked DTL to take up the matter with the higher officials of MCD for reimbursement of cost of repair of this tower.	NRPC to send a D.O. letter to DTL and UPPTCL for early restoration of these lines.

Follow up issues from previous OCC meetings

Annexure-A. I

1	Down Stream network by State utilities from ISTS Station	Augmentation of transformation capacity in various existing substations, addition of new substations along with line bays as well as requirement of line bays by STUs for downstream network are under implementation at various locations in Northern Region. Further, 220kV bays have already been commissioned at various substations in NR. For its utilization, downstream 220kV system needs to be commissioned.	List of downstream networks is enclosed in Annexure-A. I. I.																																								
2	Progress of installing new capacitors and repair of defective capacitors	Information regarding installation of new capacitors and repair of defective capacitors is to be submitted to NRPC Secretariat.	<p>Data upto following months, received from various states / UTs:</p> <table border="1" data-bbox="951 801 1548 1070"> <tr><td>⊙ CHANDIGARH</td><td>Sep-2019</td></tr> <tr><td>⊙ DELHI</td><td>May-2024</td></tr> <tr><td>⊙ HARYANA</td><td>May-2024</td></tr> <tr><td>⊙ HP</td><td>Feb-2024</td></tr> <tr><td>⊙ J&K and LADAKH</td><td>Not Available</td></tr> <tr><td>⊙ PUNJAB</td><td>Jun-2024</td></tr> <tr><td>⊙ RAJASTHAN</td><td>Jun-2024</td></tr> <tr><td>⊙ UP</td><td>Jun-2024</td></tr> <tr><td>⊙ UTTARAKHAND</td><td>Jun-2024</td></tr> </table> <p>All States/UTs are requested to update status on monthly basis.</p>	⊙ CHANDIGARH	Sep-2019	⊙ DELHI	May-2024	⊙ HARYANA	May-2024	⊙ HP	Feb-2024	⊙ J&K and LADAKH	Not Available	⊙ PUNJAB	Jun-2024	⊙ RAJASTHAN	Jun-2024	⊙ UP	Jun-2024	⊙ UTTARAKHAND	Jun-2024																						
⊙ CHANDIGARH	Sep-2019																																										
⊙ DELHI	May-2024																																										
⊙ HARYANA	May-2024																																										
⊙ HP	Feb-2024																																										
⊙ J&K and LADAKH	Not Available																																										
⊙ PUNJAB	Jun-2024																																										
⊙ RAJASTHAN	Jun-2024																																										
⊙ UP	Jun-2024																																										
⊙ UTTARAKHAND	Jun-2024																																										
3	Healthiness of defence mechanism: Self-certification	<p>Report of mock exercise for healthiness of UFRs carried out by utilities themselves on quarterly basis is to be submitted to NRPC Secretariat and NRLDC. All utilities were advised to certify specifically, in the report that “All the UFRs are checked and found functional” .</p> <p>In compliance of NPC decision, NR states/constituents agreed to raise the AUFRR settings by 0.2 Hz in 47th TCC/49th NRPC meetings.</p>	<p>Data upto following months, received from various states / UTs:</p> <table border="1" data-bbox="951 1261 1548 1563"> <tr><td>⊙ CHANDIGARH</td><td>Not Available</td></tr> <tr><td>⊙ DELHI</td><td>Jun-2024</td></tr> <tr><td>⊙ HARYANA</td><td>Jun-2024</td></tr> <tr><td>⊙ HP</td><td>Jun-2024</td></tr> <tr><td>⊙ J&K and LADAKH</td><td>Not Available</td></tr> <tr><td>⊙ PUNJAB</td><td>Mar-2024</td></tr> <tr><td>⊙ RAJASTHAN</td><td>Mar-2024</td></tr> <tr><td>⊙ UP</td><td>Jun-2024</td></tr> <tr><td>⊙ UTTARAKHAND</td><td>Jun-2024</td></tr> <tr><td>⊙ BBMB</td><td>Jun-2024</td></tr> </table> <p>All States/UTs are requested to update status for healthiness of UFRs on monthly basis for islanding schemes and on quarterly basis for the rest .</p> <p>Status:</p> <table border="1" data-bbox="951 1776 1548 2078"> <tr><td>⊙ CHANDIGARH</td><td>Not Available</td></tr> <tr><td>⊙ DELHI</td><td>Increased</td></tr> <tr><td>⊙ HARYANA</td><td>Increased</td></tr> <tr><td>⊙ HP</td><td>Increased</td></tr> <tr><td>⊙ J&K and LADAKH</td><td>Increased</td></tr> <tr><td>⊙ PUNJAB</td><td>Increased</td></tr> <tr><td>⊙ RAJASTHAN</td><td>Increased</td></tr> <tr><td>⊙ UP</td><td>Increased</td></tr> <tr><td>⊙ UTTARAKHAND</td><td>Increased</td></tr> <tr><td>⊙ BBMB</td><td>Increased</td></tr> </table>	⊙ CHANDIGARH	Not Available	⊙ DELHI	Jun-2024	⊙ HARYANA	Jun-2024	⊙ HP	Jun-2024	⊙ J&K and LADAKH	Not Available	⊙ PUNJAB	Mar-2024	⊙ RAJASTHAN	Mar-2024	⊙ UP	Jun-2024	⊙ UTTARAKHAND	Jun-2024	⊙ BBMB	Jun-2024	⊙ CHANDIGARH	Not Available	⊙ DELHI	Increased	⊙ HARYANA	Increased	⊙ HP	Increased	⊙ J&K and LADAKH	Increased	⊙ PUNJAB	Increased	⊙ RAJASTHAN	Increased	⊙ UP	Increased	⊙ UTTARAKHAND	Increased	⊙ BBMB	Increased
⊙ CHANDIGARH	Not Available																																										
⊙ DELHI	Jun-2024																																										
⊙ HARYANA	Jun-2024																																										
⊙ HP	Jun-2024																																										
⊙ J&K and LADAKH	Not Available																																										
⊙ PUNJAB	Mar-2024																																										
⊙ RAJASTHAN	Mar-2024																																										
⊙ UP	Jun-2024																																										
⊙ UTTARAKHAND	Jun-2024																																										
⊙ BBMB	Jun-2024																																										
⊙ CHANDIGARH	Not Available																																										
⊙ DELHI	Increased																																										
⊙ HARYANA	Increased																																										
⊙ HP	Increased																																										
⊙ J&K and LADAKH	Increased																																										
⊙ PUNJAB	Increased																																										
⊙ RAJASTHAN	Increased																																										
⊙ UP	Increased																																										
⊙ UTTARAKHAND	Increased																																										
⊙ BBMB	Increased																																										

4	<p>Status of FGD installation vis-à-vis installation plan at identified TPS</p>	<p>List of FGDs to be installed in NR was finalized in the 36th TCC (special) meeting dt. 14.09.2017. All SLDCs were regularly requested since 144th OCC meeting to take up with the concerned generators where FGD was required to be installed.</p> <p>Further, progress of FGD installation work on monthly basis is monitored in OCC meetings.</p>	<p>Status of the information submission (month) from states / utilities is as under:</p> <table border="1" data-bbox="951 342 1549 499"> <tr><td>⊙ HARYANA</td><td>Jun-2024</td></tr> <tr><td>⊙ PUNJAB</td><td>Jun-2024</td></tr> <tr><td>⊙ RAJASTHAN</td><td>Jul-2024</td></tr> <tr><td>⊙ UP</td><td>Jan-2024</td></tr> <tr><td>⊙ NTPC</td><td>Feb-2023</td></tr> </table> <p>FGD status details are enclosed as Annexure-A. I. II.</p> <p>All States/utilities are requested to update status of FGD installation progress on monthly basis.</p>	⊙ HARYANA	Jun-2024	⊙ PUNJAB	Jun-2024	⊙ RAJASTHAN	Jul-2024	⊙ UP	Jan-2024	⊙ NTPC	Feb-2023																								
⊙ HARYANA	Jun-2024																																				
⊙ PUNJAB	Jun-2024																																				
⊙ RAJASTHAN	Jul-2024																																				
⊙ UP	Jan-2024																																				
⊙ NTPC	Feb-2023																																				
5	<p>Submission of breakup of Energy Consumption by the states</p>	<p>All states/UTs are requested to submit the requisite data as per the billed data information in the format given as under:</p> <table border="1" data-bbox="389 869 935 1037"> <thead> <tr> <th>Category→</th> <th>Consumption by Domestic Loads</th> <th>Consumption by Commercial Loads</th> <th>Consumption by Agricultural Loads</th> <th>Consumption by Industrial Loads</th> <th>Traction supply load</th> <th>Miscellaneous / Others</th> </tr> </thead> <tbody> <tr> <td><Month></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Category→	Consumption by Domestic Loads	Consumption by Commercial Loads	Consumption by Agricultural Loads	Consumption by Industrial Loads	Traction supply load	Miscellaneous / Others	<Month>							<p>Status of the information submission (month) from states / utilities is as under:</p> <table border="1" data-bbox="951 835 1549 1160"> <thead> <tr> <th>State / UT</th> <th>Upto</th> </tr> </thead> <tbody> <tr><td>⊙ CHANDIGARH</td><td>Not Submitted</td></tr> <tr><td>⊙ DELHI</td><td>Apr-24</td></tr> <tr><td>⊙ HARYANA</td><td>May-24</td></tr> <tr><td>⊙ HP</td><td>Jun-24</td></tr> <tr><td>⊙ J&K and LADAKH</td><td>Not Submitted</td></tr> <tr><td>⊙ PUNJAB</td><td>Apr-24</td></tr> <tr><td>⊙ RAJASTHAN</td><td>Apr-24</td></tr> <tr><td>⊙ UP</td><td>Mar-24</td></tr> <tr><td>⊙ UTTARAKHAND</td><td>Feb-24</td></tr> </tbody> </table> <p>J&K and Ladakh and Chandigarh are requested to submit the requisite data w.e.f. April 2018 as per the billed data information in the given format</p>	State / UT	Upto	⊙ CHANDIGARH	Not Submitted	⊙ DELHI	Apr-24	⊙ HARYANA	May-24	⊙ HP	Jun-24	⊙ J&K and LADAKH	Not Submitted	⊙ PUNJAB	Apr-24	⊙ RAJASTHAN	Apr-24	⊙ UP	Mar-24	⊙ UTTARAKHAND	Feb-24
Category→	Consumption by Domestic Loads	Consumption by Commercial Loads	Consumption by Agricultural Loads	Consumption by Industrial Loads	Traction supply load	Miscellaneous / Others																															
<Month>																																					
State / UT	Upto																																				
⊙ CHANDIGARH	Not Submitted																																				
⊙ DELHI	Apr-24																																				
⊙ HARYANA	May-24																																				
⊙ HP	Jun-24																																				
⊙ J&K and LADAKH	Not Submitted																																				
⊙ PUNJAB	Apr-24																																				
⊙ RAJASTHAN	Apr-24																																				
⊙ UP	Mar-24																																				
⊙ UTTARAKHAND	Feb-24																																				
6	<p>Information about variable charges of all generating units in the Region</p>	<p>The variable charges detail for different generating units are available on the MERIT Order Portal.</p>	<p>All states/UTs are requested to submit daily data on MERIT Order Portal timely.</p>																																		
7	<p>Status of Automatic Demand Management System in NR states/UT's</p>	<p>The status of ADMS implementation in NR, which is mandated in clause 5.4.2 (d) of IEGC by SLDC/SEB/DISCOMs is presented in the following table:</p>	<p>The status of ADMS implementation in NR is enclosed in Annexure-A. I. II.</p> <table border="1" data-bbox="951 1559 1549 1921"> <tr><td>⊙ DELHI</td><td>Scheme Implemented but operated in manual mode.</td></tr> <tr><td>⊙ HARYANA</td><td>Scheme not implemented</td></tr> <tr><td>⊙ HP</td><td>Scheme not implemented</td></tr> <tr><td>⊙ PUNJAB</td><td>Scheme not implemented</td></tr> <tr><td>⊙ RAJASTHAN</td><td>Under implementation.</td></tr> <tr><td>⊙ UP</td><td>Scheme implemented by NPCIL only</td></tr> <tr><td>⊙ UTTARAKHAND</td><td>Scheme not implemented</td></tr> </table>	⊙ DELHI	Scheme Implemented but operated in manual mode.	⊙ HARYANA	Scheme not implemented	⊙ HP	Scheme not implemented	⊙ PUNJAB	Scheme not implemented	⊙ RAJASTHAN	Under implementation.	⊙ UP	Scheme implemented by NPCIL only	⊙ UTTARAKHAND	Scheme not implemented																				
⊙ DELHI	Scheme Implemented but operated in manual mode.																																				
⊙ HARYANA	Scheme not implemented																																				
⊙ HP	Scheme not implemented																																				
⊙ PUNJAB	Scheme not implemented																																				
⊙ RAJASTHAN	Under implementation.																																				
⊙ UP	Scheme implemented by NPCIL only																																				
⊙ UTTARAKHAND	Scheme not implemented																																				

8	Reactive compensation at 220 kV/ 400 kV level at 15 substations			
	State / Utility	Substation	Reactor	Status
i	POWERGRID	Kurukshetra	500 MVar TCR	500 MVar TCR at Kurukshetra has been commissioned on dated 15th December 2023
ii	DTL	Peeragarhi	1x50 MVar at 220 kV	1x50 MVar Reactor at Peeragarhi has been commissioned on dated 18.09.2023
iii	DTL	Harsh Vihar	2x50 MVar at 220 kV	2x50 MVAR Reactor at Harsh Vihar has been commissioned on dated 31th March 2023.
iv	DTL	Mundka	1x125 MVar at 400 kV & 1x25 MVar at 220 kV	Bay work completed on 25.03.2023. Reactor part tender is dropped and at present same is under revision.
v	DTL	Bamnauli	2x25 MVar at 220 kV	Bay work completed on 25.03.2023. Reactor part tender is dropped and at present same is under revision.
vi	DTL	Indraprastha	2x25 MVar at 220 kV	Bay work completed on 07.11.2023. Reactor part tender is dropped and at present same is under revision.
vii	DTL	Electric Lane	1x50 MVar at 220 kV	Under Re-tendering due to Single Bid
viii	PUNJAB	Dhuri	1x125 MVar at 400 kV & 1x25 MVar at 220 kV	400kV Reactors - 1x125 MVAR Reactor at Dhuri has been commissioned on dated 30th March 2023. 220kV Reactors - 1x25 MVAR Reactor at Dhuri has been commissioned on dated 27th January 2023.
ix	PUNJAB	Nakodar	1x25 MVar at 220 kV	1x25 MVAR Reactor at Nakodar has been commissioned on dated 13th February 2023.
x	PTCUL	Kashipur	1x125 MVAR at 400 kV	SLDC informed that PTCUL has intimated that bid extension has been done till 18.07.2024.
xi	RAJASTHAN	Akal	1x25 MVar	1x25 MVAR Reactor at Akal has been commissioned on dated 25th July' 2022.

xii	RAJASTHAN	Bikaner	1x25 MVar	1x25 MVAR Reactor at Bikaner has been commissioned on dated 24th June 2023.
xiii	RAJASTHAN	Suratgarh	1x25 MVar	1x25 MVAR Reactor at Suratgarh has been commissioned on dated 25th November 2022.
xiv	RAJASTHAN	Barmer & others	13x25 MVar	Agreement signed on dt. 22.06.2020. Grant of Ist Instalment received on dt.19.02.21 & work order placed on dt. 07.04.2022 to M/s Kanoor Electricals Ltd. Schedule time is 18 months. Out of 13 Nos. of reactors, 07 Nos. have been commissioned and rest are under progress. Tentative charging plan is to be intimated by Rajasthan SLDC.
xv	RAJASTHAN	Jodhpur	1x125 MVar	Agreement signed on dt. 22.06.2020. Grant of Ist Instalment received on dt.19.02.21 & work order placed on dt. 07.04.2022 to M/s Kanoor Electricals Ltd. Schedule time is 18 months. 01 No. of 125 MVAR reactor is under testing which is expected to done by end of May 2024. Tentaive charging plan is to be intimated by Raiasthan SLDC.

1. Down Stream network by State utilities from ISTS Station:						
Sl. No.	Substation	Downstream network bays	Status of bays	Planned 220 kV system and Implementation status	Revised Target	Remarks
1	400/220kV, 3x315 MVA Samba	Commissioned: 8 Total: 8	Utilized: 6 Unutilized: 2	• Network to be planned for 2 bays.	Mar'25	02 No. of bays shall be utilized for LILO-II of 220kV Jatwal-Bishnah Transmission Line, the work of which is delayed due to persisting RoW issues. expected date of completion is Mar 2025 subject to availability of funds and resolving of RoW issues), Updated in 220th OCC by JKPTCL.
2	400/220kV, 2x315 MVA New Wanpoh	Commissioned: 6 Total: 6	Utilized: 2 Unutilized: 4	• 220 kV New Wanpoh - Alusteng D/c Line	Mar'25	02 No. of bays are to be utilized for connecting 220kV New Wanpoh-Alusteng D/c Line. RoW issues persisting; At present new-wampoh-mirbazar 5km and harwan-alstung 16km have been completed, expected date of completion is Mar 2025 subject to availability of funds and resolving of RoW issues), Updated in 214th OCC by JKPTCL.
				• 220 kV New Wanpoh - Mattan D/c Line	End of 2024	02 No. of bays are to be utilized for connecting 220kV New Wanpoh-Mattan D/c Line. The funding source for the project is being identified and the project is expected to be completed by ending 2024. Updated in 204th OCC by JKPTCL.
3	400/220kV, 2x315 MVA Amargarh	Commissioned: 6 Total: 6	Utilized: 4 Unutilized: 2	• 220kV D/C line from 400/220kV Kunzar - 220/33kV Sheeri	End of 2024	02 No. of bays are proposed to be utilized for connecting 220/132 kV GSS Loolipora. The funding source for the project is being identified and the project is expected to be completed by ending 2024. Updated in 204th OCC by JKPTCL.
4	400/220kV, 2x500 MVA Kurukshetra (GIS)	Commissioned: 8 Total: 8	Utilized: 6 Unutilized: 2	• 220kV Bhadson (Kurukshetra) – Ramana Ramani D/c line	Jul'24	Updated in 205th OCC by HVPNL
5	400/220 kV, 2x315 MVA Dehradun	Commissioned: 6 Total: 6	Utilized: 2 Unutilized: 4	• Network to be planned for 4 bays	-	PTCUL to update the status.
6	Shahjahanpur, 2x315 MVA 400/220 kV	Commissioned: 6 Approved/Under Implementation:1	Utilized: 7	• 220 kV D/C Shahjahanpur (PG) - Gola line	Commissioned	Energization date: 26.10.2023 updated by UPPTCL in 215th OCC
				• LILO of Sitapur – Shahjahanpur 220 kV SC line at Shahjahanpur (PG)	Commissioned	Energization date: 25.02.2022 updated by UPPTCL in 196th OCC
7	Hamirpur 400/220 kV Sub-station	Commissioned: 8 Total: 8	Utilized: 4 Unutilized: 4	• 220 kV Hamirpur-Dehan D/c line	Commissioned	HPPTCL has commissioned the Planned 220kV Dehan-Hamirpur TL utilizing 2 No. 220kV Bays.Commissioned date: 09.06.2022. Updated in 198th OCC by HPPTCL
				• Network to be planned for 4 bays	-	HPPTCL to update the status.
8	Sikar 400/220kV, 1x 315 MVA S/s	Commissioned: 8 Total: 8	Utilized: 6 Unutilized: 2	• LILO of 220 kV Sikar (220 kV GSS)-Dhod S/c line at Sikar (PG)	Commissioned	LILO of 220 kV S/C Sikar-Dhod line at 400 kV GSS PGCIL, Sikar has been charged on dt. 31.03.2022
				• Network to be planned for 2 bays.	-	Against the 3rd ICT at 400 kV GSS Sikar, only 2 bays were constructed and same has been utilized by RVPNL by constructing LILO of 220 kV S/C Sikar – Dhod line as updated by RVPNL in 195th OCC
9	Bhiwani 400/220kV S/s	Commissioned: 6 Total: 6	Utilized: 2 Unutilized: 4	• 220 kV D/C line Bhiwani (PG) – Bhiwani (HVPNL) line	Commissioned	Updated in 202nd OCC by HVPNL
				• 220 kV Bhiwani (PG) - Isherwal (HVPNL) D/c line.	Dec'24	Issue related to ROW as intimated in 218th OCC by HVPNL. Status: Work was stalled since 29.07.2021 due to ROW issues and farmers agitation and further restarted on 9.10.2023 with the help of district administration. Now, work was again stalled since 30.11.2023 due to severe ROW issues. Expected to be completed by 31.12.2024. Foundation 209/212. Erection 193/212. Stinging 37.8/50.3 km
				• 220 kV Bhiwani (PG) - Dadhibana (HVPNL) D/c line.	Oct'25	Line work awarded to M/s R S Infra Projects Pvt. Ltd. Noida, Uttar Pradesh on dated 09.03.2024. Work of route plan and route alignment has been started by the firm as intimated in 218th OCC by HVPNL.
10	Jind 400/220kV S/s	Commissioned: 4 Approved:4 Total: 8	Utilized: 4 Unutilized: 0	• LILO of both circuits of 220 kV Jind HVPNL to PTPS D/C line at 400 kV substation PGCIL Khatkar (Jind) with 0.5 sq inch ACSR conductor	Dec'24	Work in progress. Updated in 220th OCC by HVPNL.
11	400/220kV Tughlakabad GIS	Commissioned: 6 Under Implementation: 4	Utilized: 6 Unutilized: 0	• RK Puram – Tughlakabad (UG Cable) 220kV D/c line – March 2023.	Commissioned	Updated in 216th OCC by DTL
				• Masjid Mor – Tughlakabad 220kV D/c line.	Commissioned	Updated in 216th OCC by DTL

Sl. No.	Substation	Downstream network bays	Status of bays	Planned 220 kV system and Implementation status	Revised Target	Remarks
12	400/220kV Kala Amb GIS (TBCB)	Commissioned: 6 Total: 6	Utilized: 2	• HPPTCL has planned one no. of 220kV D/c line from Kala Amb 400/220kV S/s to 220/132kV Kala Amb S/s	Commissioned	Energization date: 31.05.2024 updated by HPPTCL in 220th OCC
			Unutilized: 2	• HPPTCL has planned one no. of 220kV D/c line from Kala Amb 400/220kV S/s to 220/132kV Giri S/s	-	Tendering process is yet to be started.Updated in 219th OCC by HPPTCL
			Under Implementation:2	• Network to be planned for 2 bays	-	HPPTCL to update the status.
13	400/220kV Kadarpur Sub-station	Commissioned: 8 Total: 8	Utilized: 0 Unutilized: 8	• D/C line Kadarpur - Sec-56 Gurugram.	Jul'24	Initial proposal of LILO of 220kV Pali-Sector 56 Line and Pali-Sector 52 line was descope due to forest issue. Proposl to evacuate power from 220kV D/C Pali-Sector 56 line to Sector 56 and 52 with bunching of lines is under consideration. Updated in 218th OCC by HVPNL
				• S/C line Kadarpur - Sec-52 Gurugram	Jul'24	Initial proposal of LILO of 220kV Pali-Sector 56 Line and Pali-Sector 52 line was descope due to forest issue. Proposl to evacuate power from 220kV D/C Pali-Sector 56 line to Sector 56 and 52 with bunching of lines is under consideration. Updated in 218th OCC by HVPNL
				• S/C line Kadarpur - Pali	Jul'24	Initial proposal of LILO of 220kV Pali-Sector 56 Line and Pali-Sector 52 line was descope due to forest issue. Proposl to evacuate power from 220kV D/C Pali-Sector 56 line to Sector 56 and 52 with bunching of lines is under consideration. Updated in 218th OCC by HVPNL
14	400/220kV Sohna Road Sub-station	Commissioned: 8 Total: 8	Utilized: 4 Unutilized: 4	• LILO of both circuits of 220kV D/c Sohna-Rangla Rajpur at Roj Ka Meo line at 400kV Sohna Road	Dec'24	Updated in 216th OCC by HVPNL
				• LILO of both circuits of 220kV D/c Badshahpur-Sec77 line at 400kV Sohna Road	-	The matter is subjudice in Hon'ble Punjab & Haryana High court, Chandigarh Updated in 205th OCC by HVPNL. Status:- Earlier 02 nos 220 kV line bays were to be utilized for the 220 kV GIS S/Stn. Sec-77, Gurugram but due to denotification of land of the 220 kV GIS S/Stn. Sec-77 the said substation is now going to be dismantled and a new substation is proposed at Sec-75A, Gurugram. Now, these 02 no. 220 kV line bays may be utilized at 220 kV GIS S/Stn Sec-75A, Gurugram.
15	400/220kV Prithla Sub-station	Commissioned: 8 Approved: 2 Total: 10	Utilized: 4 Unutilized: 4 Under Implementation:2	• 220kV D/C line from Prithla to Harfali with LILO of one circuit at 220kV Meerpur Kurali	Mar'25	Contract awarded on 8.08.23 to M/s Skipper with completion in March 25.Updated in 218th OCC by HVPNL
				• LILO of both ckt of 220kV D/c Ranga Rajpur – Palwal line	Commissioned	Energization date: 31.12.2021. Updated in 198th OCC by HVPNL
				• 220kV D/C for Sector78, Faridabad	30.09.2024	Issue related to ROW and Pending crossing approval from Northern Railways and DFCCIL. as intimated in 218th OCC by HVPNL.
16	400/220kV Sonapat Sub-station	Commissioned: 6 Under Implementation:2 Total: 8	Utilized: 2 Unutilized: 4 Under Implementation:2	• LILO of both circuits of 220kV Samalkha - Mohana line at Sonapat	15.07.2024	Updated in 220th OCC by HVPNL. Status: Work was held up due to ROW at T.L. No. 7,8,11,12 & 13 by the farmers of Jajji villagers during July'23 and now the matter has been resolve and work under progress from 01.08.2023. The erection work of T.no. 1 is pending due to non availability of shut down at 220KV Mohana-Smk line and 220KV Jajji-Mohana line. • PLCC protection coupler and Forest approval is also pending.
				• Sonapat - HSIISC Rai 220kV D/c line	Commissioned	Energization date: 31.05.2024 updated by HVPNL in 220th OCC
				• Sonapat - Kharkhoda Pocket A 220kV D/c line	08.03.2025	Updated in 212th OCC by HVPNL. Status: Work order has been issued to M/s R.S Infra on dated 09.08.2023 by O/o CE/PD&C, Panchkula for construction of line. Both bays are under construction and erection of electrical equipment is under progress. Tetative date of completion of both bays at PGCIL end is end of July 2024.
17	400/220kV Neemrana Sub-station	Commissioned: 6 Total: 6	Utilized: 4 Unutilized: 2	• LILO of Bhiwadi - Neemrana 220kV S/c line at Neemrana (PG)	-	Work is under progres. Stub Setting: 14/2017. Permission for Highway is awaited from concerned department as updated in 218th OCC by RVPNL.
18	400/220kV Kotputli Sub-station	Commissioned: 6 Total: 6	Utilized: 4 Unutilized: 2	• Kotputli - Pathreda 220kV D/c line	-	Date of bid opening has been extended up to 30.04.2024 as updated in 218th OCC by RVPNL.
19	400/220kV Jalandhar Sub-station	Commissioned: 10 Total: 10	Utilized: 8 Unutilized: 2	• Network to be planned for 2 bays	Nov'24	LILO of 220 kV BBMB Jalandhar - Butari line at 400 kV PGCIL Jalandhar being planned. Work expected to be completed by PSTCL. Updated in 198th OCC by PSTCL. 6 months more are needed due to ROW issues as updated by PSTCL in 220th OCC

Sl. No.	Substation	Downstream network bays	Status of bays	Planned 220 kV system and Implementation status	Revised Target	Remarks
20	400/220kV Roorkee Sub-station	Commissioned: 6 Total: 6	Utilized: 4 Unutilized: 2	• Roorkee (PG)-Pirankaliyar 220kV D/c line	Commissioned	Roorkee (PG)-Pirankaliyar 220kV D/c line commissioned in 2020 as intimated by PTCUL in 197th OCC
21	400/220kV Lucknow Sub-station	Commissioned: 8 Total: 8	Utilized: 4 Unutilized: 4	• Network to be planned for 2 bays	Commissioned	• Lucknow -Kanduni, 220 kV D/C line work energized on 05.10.2023. Updated in 212th OCC by UPPTCL. • No planning for 2 no. of bays upated by UPPTCL in 196th OCC. The same has been communicated to Powergrid.
22	400/220kV Gorakhpur Sub-station	Commissioned: 6 Total: 6	Utilized: 4 Unutilized: 2	• Network to be planned for 2 bays	Commissioned	• Gorakhpur(PG)- Maharajganj, 220 kV D/C line energized on 27.09.2023 updated by UPPTCL in 212th OCC
23	400/220kV Fatehpur Sub-station	Commissioned: 8 Under Implementation:2 Total: 10	Utilized: 6 Unutilized: 2 Under Implementation:2	• Network to be planned for 2 bays	-	• UPPTCL intimated that 02 no. of bays under finalization stage. In 201st OCC, UPPTCL intimated that it is finalized that Khaga s/s will be connected (tentative time 1.5 years). • No planning for 2 no. of bays updated by UPPTCL in 196th OCC. The same has been communicated to Powergrid.
24	400/220kV Abdullapur Sub-station	Commissioned: 10 Under Implementation:2 Total: 12	Utilized: 10 Unutilized: 0 Under Implementation:2	• Abdullapur – Rajokheri 220kV D/c line	Sep'24	Line charged from Rajokheri end on 09.02.2020. The work of construction was awarded to M/s IKE ltd but due to non completion of work firm is blacklisted, Now the pending work of SCADA , Telemetry and Data Integration is being carried out departmentally through OeM M/s ZIV . After completion of these statutory requirement of NRLDC the load will be taken from the Abdullapur. Tentative date of completion of work will be 30.09.2024. Updated in 218th OCC by HVPNL
25	400/220kV Pachkula Sub-station	Commissioned: 8 Under tender:2 Total: 10 Out of these 10 nos. 220kV	Utilized: 2 Unutilized: 4 Under Implementation:2	• Panchkula – Pinjore 220kV D/c line	Commissioned	Updated in 218th OCC by HVPNL
				• Panchkula – Sector-32 220kV D/c line	Commissioned	Energization date: 24.05.2024 updated by HVPNL in 220th OCC
				• Panchkula – Raiwali 220kV D/c line	Commissioned	Updated in 194th OCC by HVPNL
				• Panchkula – Sadhaura 220kV D/c line: Sep'23	Jul'24	Updated in 205th OCC by HVPNL
26	400/220kV Amritsar S/s	Commissioned:7 Approved in 50th NRPC- 1 no. Total: 8	Utilized: 6 Under Implementation:2	• Amritsar – Patti 220kV S/c line	31.07.2024	One bay is ready and another bay from Powergrid is pending it would be completed by 31.07.2024. Updated in 220th OCC by PSTCL.
				• Amritsar – Rashiana 220kV S/c line (2 bays shall be required for above lines. However, 1 unutilized bay shall be used for Patti and requirement of one additional bay approved for Rashiana by NRPC)	31.07.2024	One bay is ready and another bay from Powergrid is pending it would be completed by 31.07.2024. Updated in 220th OCC by PSTCL.
27	400/220kV Bagpat S/s	Commissioned: 8 Total: 8	Utilized:6 Unutilized: 2	• Bagpat - Modipuram 220kV D/c line	Commissioned	Updated in 201st OCC by UPPTCL
28	400/220kV Bahardurgarh S/s	Commissioned: 4 Approved: 4 Total: 8	Utilized:2 Unutilized: 2	• LILO of 220 kV Nunamajra- Daultabad S/c line at 400 kV Bahadurgarh PGCIL	Mar'25	Updated in 220th OCC by HVPNL. Status: NIT has been floated vide NIT No. EPC-D-96 dated 15.10.23 to be opened on 22.12.23. • Now, the tender has been dropped and likely to be refloated by 31.07.2024.
				• Bahadurgarh - METL 220kV D/c line (Deposit work of M/s METL)	Mar'25	Updated in 220th OCC by HVPNL. Status: • Revised BOQ forwarded from Design wing to contract wing. • Tender has floated vide NIT No. EPC-D-100 dated 04.01.2024 with tender opening date of 26.02.2024. • Tender has been opened on 26.03.24 and 03 nos. bids has been received. The work is likely to be awarded by the 31.07.2024.
				• Bahadurgarh - Kharkhoda Pocket B 220kV D/c line	08.03.2025	Updated in 220th OCC by HVPNL. Status: Contract awarded on 09.08.23 to M/s R S Infra Noida. Work has been started.
29	400/220kV Jaipur (South) S/s	Commissioned: 4 Total: 4	Utilized:2 Unutilized: 2	• LILO of 220 kV S/C Dausa – Sawai Madhopur line at 400 kV GSS Jaipur South (PG)	06.10.2025	Work order has been issued on 06.10.2023, work under progress as updated by RVPNL in 215th OCC
30	400/220kV Sohawal S/s	Commissioned: 8 Total: 8	Utilized: 8	• Sohawal - Barabanki 220kV D/c line	Commissioned	Energization date: 14.04.2018 updated by UPPTCL in 196th OCC
				• Sohawal - New Tanda 220kV D/c line	Commissioned	Energization date: 28.05.2019 updated by UPPTCL in 196th OCC
				• Network to be planned for 2 bays	Commissioned	• Sohawal - Gonda 220kV S/c line (Energization date: 27.04.2020) updated by UPPTCL in 196th OCC • Sohawal - Bahraich 220kV S/c line (Energization date: 15.02.2021) updated by UPPTCL in 196th OCC
31	400/220kV, Kankroli	Commissioned: 6 Total: 6	Utilized: 4 Unutilized: 2	• 220 kV D/C Kankroli(PG) - Nathdwara line	Jul'24	Price bid opened on 29.01.2024, tender dropped due to price variation. Retendering would be done after general election as updated by RVPN in 218th OCC.

Sl. No.	Substation	Downstream network bays	Status of bays	Planned 220 kV system and Implementation status	Revised Target	Remarks
32	400/220kV, Manesar	Commissioned: 8 Total: 8	Utilized: 4 Unutilized: 4	• Network to be planned for 2 bays	-	Status:- 2nos bays are being utilised for 220 kV D/C Panchgaon (PGCIL)-Panchgaon Ckt-I & 220 kV D/C Panchgaon (PGCIL)-Panchgaon Ckt-II, charged on dated 05.09.2022 & 20.10.2022 respectively. The 2nos bays may be utilised by HVPNL in future.
33	400/220kV, Saharanpur	Commissioned: 6 Under Implementation:2 Total: 8	Utilized: 6 Unutilized: 0 Under Implementation:2	• Network to be planned for 2 bays	Commissioned	Saharanpur(PG)-Devband D/c line (Energization date: 20.04.2023) updated by UPPTCL in 207th OCC
34	400/220kV, Wagoora	Commissioned: 10 Total: 10	Utilized: 6 Unutilized: 4	• Network to be planned for 4 bays	-	PDD, J&K to update the status.
35	400/220kV, Ludhiana	Commissioned: 9 Total: 9	Utilized: 8 Unutilized: 1	• Network to be planned for 1 bay	Commissioned	Direct circuit from 220 kV Lalton Kalan to Dhandari Kalan to be diverted to 400 kV PGCIL Ludhiana. Work completed , final agrrement is expected to be signed by May'24. Updated in 218th OCC by PSTCL.
36	400/220kV, Chamba (Chamera Pool)	Commissioned: 3 Under tender:1 Total: 4	Utilized:3 Unutilized: 0 Under tender:1	• Stringing of 2nd ckt of Chamera Pool – Karian 220kV D/c line	Commissioned	Stringing of 2nd Circuit of Chamera Pool-Karian Transmission line has been completed & terminal bay at 400/220 kV chamera pooling substation (PGCIL) is commissioned on 20.01.2024. Updated in 217th OCC by HPPTCL.
37	400/220kV, Mainpuri	Commissioned: 6 Under Implementation:2 Total: 8	Utilized: 6 Unutilized: 0 Under Implementation:2	• Network to be planned for 2 bays	-	• 02 no. of bays under finalization stage updated by UPPTCL in 196th OCC. Mainpuri S/s planned. Land is not finalized, therefore timeline not available as intimated by UPPTCL in 201st OCC.
38	400/220kV, Patiala	Commissioned: 8 Total: 8	Utilized: 6 Unutilized: 2	• Network to be planned for 2 bays	May'25	2 Nos. bays for 400 kV PGCIL Patiala - 220 kV Bhadson (D/C) line being planned. Tender is yet to be awarded. Timeline one year communicated by PSTCL in 220th OCC meeting

Status of ADMS implementation in NR:

Sl. No.	State / UT	Status	Remarks
1	DELHI	Scheme Implemented but operated in manual mode.	A committee has been constituted under the chairmanship of GM, SLDC Delhi to formulate the logic for implementation of ADMS. Delhi SLDC informed that two meetings have been held by the committee and based on the deliberation in those meetings, SoP has been formed by the committee. Delhi SLDC has shared the logic for implementation of ADMS with NRLDC for their observation.
2	HARYANA	Scheme not implemented	Haryana SLDC intimated that the matter has been taken up with Powergrid by XEN/SLDC Design, HVPNL, Panchkula regarding the LSS /ADMS application in ULDC Phase-III for SCADA/EMS upgradation project of SLDCs of Northern region. HVPNL has sought comments & suggestions from Powergrid that LSS/ADMS under SCADA upgradation project will suffice the purpose of ADMS or this LSS/ADMS software is meant for emergency control for SLDC only. The reply from Powergrid is awaited and updated status would be provided by the Design Wing in its accordance.
3	HP	Scheme not implemented	HP SLDC intimated that HPSEB had intimated that initially 142 Nos. of feeders were identified for operation under ADMS functionality but most of these feeders were from same sub-station. Therefore, now they have increased the no. of sub-station and identified the non-critical feeders. Load relief to be given through these feeders is under finalization. The revised feeder list to shared by HPSEBL with the SLDC within one month.
4	PUNJAB	Scheme not implemented	i. A committee comprising of following officers of PSPCL & PSTCL has been constituted to finalize the logic regarding implementation of Automatic Demand Management System in Punjab Control Area. A meeting in this regard was held on dated 26-02-2024 at PSLDC Complex, Patiala. The committee deliberated various loading scenarios and proposed the following logic for the management of demand: 1. If the frequency sustains below 49.90 Hz for duration of 3 minutes, the Automatic Demand Management System will initiate a 50% reduction in the Over Drawl. 2. In case the frequency falls further below 49.85 Hz, the Over Drawl will be reduced to zero. 3. The software at the SLDC end for ADMS shall be available with ULDC phase –III SCADA system which is under implementation.
5	RAJASTHAN	Under implementation. Likely completion schedule is 31.03.2024	RVPN informed that the issue of cyber security of link between SATNAM centre and SLDC control room has been resolved. Final testing is rescheduled for 22.07.2024.
6	UP	Scheme implemented by NPCIL only	i. A meeting regarding ADMS was held on 15.01.2023 with the UPPCL under the chairmanship of MD UPPTCL ii. A committee formed for identification of load at 33 kV level under the chairmanship of Director (Distribution), UPPCL. iii. Another committee under the chairmanship of Director UPSLDC shall identify the technical and operational requirement for ADMS implementation iv. The software at the SLDC end for ADMS shall be available with ULDC phase –III SCADA system which is under implementation and likely to be commissioned by March 2025. v. In order to operate identified 33 kV feeders under ADMS scheme, integration of 132 kV substations with SCADA system is under implementation in the Reliable Communication Scheme and expected date of completion of the scheme is October 2024.
7	UTTARAKHAND	Scheme not implemented	i. UPCL has prepared a system architecture in which all the non-monitored sub-stations have been selected and 11kV feeders have been considered for ADMS operation. For the scheme, discom has also done group-wise selection of feeders and quantum of MW relief to be given for automatic demand response at 11kV level has also been decided. UPCL has awarded the tender for implementation of the aforementioned scheme to M/s Metergy Pvt.Ltd. ii. As per the status report submitted by M/s Metergy Pvt.Ltd, the survey work of 30 nos. incomer sites have been completed and order has been placed by UPCL for hardware equipments. iii. Uttarakhand SLDC informed that feeder list at 11kV level has been finalized and logic of ADMS implementation is under finalization.

FGD Status

Updated status of FGD related data submission

NTPC (27.02.2023)

MEJA Stage-I

RIHAND STPS

SINGRAULI STPS

TANDA Stage-I

TANDA Stage-II

UNCHAHAR TPS

UPRVUNL (10.01.2024)

ANPARA TPS

HARDUAGANJ TPS

OBRA TPS

PARICHHA TPS

PSPCL (18.06.2024)

GGSSSTP, Ropar

GH TPS (LEH.MOH.)

RRVUNL (09.07.2023)

CHHABRA SCPP

CHHABRA TPP

KALISINDH TPS

KOTA TPS

SURATGARH SCTPS

SURATGARH TPS

Updated status of FGD related data submission

**Lalitpur Power Gen. Co. Ltd.
(10.01.2024)**

Lalitpur TPS

**Lanco Anpara Power Ltd.
(01.01.2024)**

ANPARA-C TPS

HGPCL (14.06.2024)

PANIPAT TPS

RAJIV GANDHI TPS

YAMUNA NAGAR TPS

Adani Power Ltd. (18.02.2022)

KAWAI TPS

**Rosa Power Supply Company
(01.01.2024)**

Rosa TPP Phase-I

**Prayagraj Power Generation
Company Ltd. (05.01.2024)**

Prayagraj TPP

APCPL (01.05.2024)

INDIRA GANDHI STPP

Pending submissions

GVK Power Ltd.

GOINDWAL SAHIB

NTPC

DADRI (NCTPP)

Talwandi Sabo Power Ltd.

TALWANDI SABO TPP

L&T Power Development Ltd.

Nabha TPP (Rajpura TPP)

Target Dates for FGD Commissioning (Utility-wise)

Adani Power Ltd.	KAWAI TPS U#1 (Target: 31-12-2024), KAWAI TPS U#2 (Target: 31-12-2024)
APCPL	INDIRA GANDHI STPP U#2 (Target: 30-09-2023), INDIRA GANDHI STPP U#3 (Target: 30-06-2023)
GVK Power Ltd.	GOINDWAL SAHIB U#1 (Target: 30-04-2020), GOINDWAL SAHIB U#2 (Target: 29-02-2020)
HGPCL	PANIPAT TPS U#6 (Target: 31-12-2026), PANIPAT TPS U#7 (Target: 31-12-2026), PANIPAT TPS U#8 (Target: 31-12-2026), RAJIV GANDHI TPS U#1 (Target: 31-12-2024), RAJIV GANDHI TPS U#2 (Target: 31-12-2024), YAMUNA NAGAR TPS U#1 (Target: 31-12-2024), YAMUNA NAGAR TPS U#2 (Target: 31-12-2024)

NTPC

DADRI (NCTPP) U#1 (Target: 31-12-2020), DADRI (NCTPP) U#2 (Target: 31-10-2020), DADRI (NCTPP) U#3 (Target: 31-08-2020), DADRI (NCTPP) U#4 (Target: 30-06-2020), DADRI (NCTPP) U#5 (Target: 30-06-2022), DADRI (NCTPP) U#6 (Target: 31-03-2023), RIHAND STPS U#1 (Target: 31-10-2025), RIHAND STPS U#2 (Target: 30-06-2026), RIHAND STPS U#3 (Target: 31-12-2024), RIHAND STPS U#4 (Target: 31-03-2025), RIHAND STPS U#5 (Target: 30-06-2025), RIHAND STPS U#6 (Target: 31-10-2025), SINGRAULI STPS U#1 (Target: 31-12-2024), SINGRAULI STPS U#2 (Target: 31-12-2024), SINGRAULI STPS U#3 (Target: 31-12-2024), SINGRAULI STPS U#4 (Target: 31-12-2024), SINGRAULI STPS U#5 (Target: 31-03-2025), SINGRAULI STPS U#6 (Target: 31-06-2024), SINGRAULI STPS U#7 (Target: 31-03-2024), UNCHAHAR TPS U#1 (Target: 31-12-2023), UNCHAHAR TPS U#2 (Target: 31-12-2023), UNCHAHAR TPS U#3 (Target: 30-09-2023), UNCHAHAR TPS U#4 (Target: 30-09-2023), UNCHAHAR TPS U#5 (Target: 30-09-2023), UNCHAHAR TPS U#6 (Target: 31-08-2022), MEJA Stage-I U#1 (Target: 31-10-2023), MEJA Stage-I U#2 (Target: 30-06-2023), TANDA Stage-I U#3 (Target:), TANDA Stage-I U#4 (Target:), TANDA Stage-II U#3 (Target: 31-03-2023), TANDA Stage-II U#4 (Target: 30-09-2023)

L&T Power Development Ltd (Nabha)	Nabha TPP (Rajpura TPP) U#1 (Target: 30-04-2021), Nabha TPP (Rajpura TPP) U#2 (Target: 28-02-2021)
Lalitpur Power Gen. Company Ltd.	LALITPUR TPS U#1 (Target: 31-12-2026), LALITPUR TPS U#2 (Target: 30-09-2026), LALITPUR TPS U#3 (Target: 30-06-2026)
Lanco Anpara Power Ltd.	ANPARA C TPS U#1 (Target: 31-12-2025), ANPARA C TPS U#2 (Target: 31-12-2025)
Prayagraj Power Generation Company Ltd.	PRAYAGRAJ TPP U#1 (Target: 31-12-2026), PRAYAGRAJ TPP U#2 (Target: 31-12-2026), PRAYAGRAJ TPP U#3 (Target: 31-12-2026)
PSPCL	GH TPS (LEH.MOH.) U#1 (Target: 31-12-2026), GH TPS (LEH.MOH.) U#2 (Target: 31-12-2026), GH TPS (LEH.MOH.) U#3 (Target: 31-12-2026), GH TPS (LEH.MOH.) U#4 (Target: 31-12-2026), GGSSTP, Ropar U#3 (Target: 31-12-2026), GGSSTP, Ropar U#4 (Target: 31-12-2026), GGSSTP, Ropar U#5 (Target: 31-12-2026), GGSSTP, Ropar U#6 (Target: 30-12-2026)

Rosa Power Supply Company	ROSA TPP Ph-I U#1 (Target: 31-12-2026), ROSA TPP Ph-I U#2 (Target: 31-12-2026), ROSA TPP Ph-I U#3 (Target: 31-12-2026), ROSA TPP Ph-I U#4 (Target: 31-12-2026)
RRVUNL	KOTA TPS U#5 (Target: 31-08-2024), KOTA TPS U#6 (Target: 31-08-2024), KOTA TPS U#7 (Target: 31-08-2024), SURATGARH TPS U#1 (Target: 31-12-2026), SURATGARH TPS U#2 (Target: 31-12-2026), SURATGARH TPS U#3 (Target: 31-12-2026), SURATGARH TPS U#4 (Target: 31-12-2026), SURATGARH TPS U#5 (Target: 31-12-2026), SURATGARH TPS U#6 (Target: 31-12-2026), SURATGARH SCTPS U#7 (Target: 28-02-2025), SURATGARH SCTPS U#8 (Target: 28-02-2025), CHHABRA TPP U#1 (Target: 31-12-2026), CHHABRA TPP U#2 (Target: 31-12-2026), CHHABRA TPP U#3 (Target: 31-12-2026), CHHABRA TPP U#4 (Target: 31-12-2026), CHHABRA SCPP U#5 (Target: 28-02-2025), CHHABRA SCPP U#6 (Target: 28-02-2025), KALISINDH TPS U#1 (Target: 28-02-2025), KALISINDH TPS U#2 (Target: 28-02-2025)
Talwandi Sabo Power Ltd.	TALWANDI SABO TPP U#1 (Target: 28-02-2021), TALWANDI SABO TPP U#2 (Target: 31-12-2020), TALWANDI SABO TPP U#3 (Target: 31-10-2020)
UPRVUNL	ANPARA TPS U#1 (Target: 31-12-2025), ANPARA TPS U#2 (Target: 31-12-2025), ANPARA TPS U#3 (Target: 31-12-2025), ANPARA TPS U#4 (Target: 31-12-2025), ANPARA TPS U#5 (Target: 31-12-2025), ANPARA TPS U#6 (Target: 31-12-2025), ANPARA TPS U#7 (Target: 31-12-2025), HARDUAGANJ TPS U#8 (Target: 31-12-2026), HARDUAGANJ TPS U#9 (Target: 31-12-2026), OBRA TPS U#9 (Target: 31-12-2026), OBRA TPS U#10 (Target: 31-12-2026), OBRA TPS U#11 (Target: 31-12-2026), OBRA TPS U#12 (Target: 31-12-2026), OBRA TPS U#13 (Target: 31-12-2026), PARICHHA TPS U#3 (Target: 31-12-2026), PARICHHA TPS U#4 (Target: 31-12-2026), PARICHHA TPS U#5 (Target: 31-12-2026), PARICHHA TPS U#6 (Target: 31-12-2026)

Status of availability of ERS towers in NR

Sl. No.	Transmission Utility	Voltage Level (220kV/400kV/765kV/ 500 kV HVDC etc.)	Length of the transmission lines owned by the Utility (Ckt. Kms.)	Number of ERS Sets (towers) available (Nos.)	ERS Set (towers) required as per the Govt. norms.	Location	Remarks
1	PTCUL	400kV	418.394	NIL	1		Tender has been opened and contract activities under process
		220kV	1045.135	NIL	1		
2	Powergrid NR-1	220 KV	1842.88	NIL	1		
		400 KV	11074.26	12 Towers	3	All 400kV ERS at Ballabgarh	make-Lindsey
		765 KV	4721.85	15 Towers	1	All 765kV ERS at Meerut	Make-SBB
		500 KV HVDC	653.88	NIL	1		
		800 KV HVDC	416.58	NIL	1		
3	Powergrid NR-2	66 KV	37.56	Nil	1		ERS tower available for 400KV rating can be used in place of lower as well as higher voltage Towers. In case used for 765KV Line, No of towers can be erected will reduce due to increase in Tower Hight.
		132 KV	262.7	Nil	1		
		220 KV	2152	Nil	1		
		400 KV	8097.3	02 Set (32 Towers)	2	Kishenpur & Jalandhar	
		765 KV	337.5	Nil	1		
4	Powergrid NR-3	800KV HVDC	2205	NIL	1		400KV ERS will be also be used in other voltage level lines
		500KV HVDC	2566	NIL	1		
		765KV	4396	NIL	1		
		400KV	12254	26 Towers	3	Kanpur	
		220KV	1541	NIL	1		
132KV	207	NIL	1				
5	PARBATI KOLDAM TRANSMISSION COMPANY LIMITED	400kV	457	NIL	1		Procurement under process.
6	PATRAN TRANSMISSION COMPANY LTD	400kV	0.4	NIL	1	It is kept in Bhopal and on need basis is moved across region	Not available, will tie up based on the requirements in future. However the parent company IndiGrid owns one set of ERS for all five regions.
7	NRSS-XXIX TRANSMISSION LTD	400kV	853	NIL	1		
8	GURGAON PALWAL TRANSMISSION LTD	400kV	272	NIL	1		
9	RAPP Transmission Company Limited.	400kV	402	NIL	1		
10	NRSS XXXVI Transmission Limited	400kV	301.924	NIL	1		Element I - Operational comprising of 3 kms. Element II - Work Under Progress comprising of 221.924 kms. Element II - Work Under Progress comprising of 77 kms.
11	HPPTCL	220 kV	659	NIL	1		
		400 kV	75.7	NIL	1		
12	RVPN	132 kV	18969.958	1	4	01 No. ERS available at 220 kV GSS Heerapura, Jaipur	ERS proposed : 01 Set at 400 kV GSS, Jodhpur. 01 set at 400 kV GSS Bikaner
		220 kV	16227.979		3		
		400 kV	6899.386		2		
		765 kV	425.498		1		

Sl. No.	Transmission Utility	Voltage Level (220kV/400kV/765kV/ 500 kV HVDC etc.)	Length of the transmission lines owned by the Utility (Ckt. Kms.)	Number of ERS Sets (towers) available (Nos.)	ERS Set (towers) required as per the Govt. norms.	Location	Remarks
13	DTL	220kV	915.498	NIL	1	400kV Bamnauli Sub station	ERS tower available for 400KV rating can also be used for lower voltage lines as well
		400kV	249.19	02 Sets (32 towers)	1		
14	JKPTCL						JKPTCL, Jammu: being procured JKPTCL, Kashmir:10 tower procured (out of which 3 on loan to JKPTCL, Jammu)
15	HVPN						
16	PSTCL	400 kV	1666.43	2	2		
		220 kV	7921.991				
17	UPPTCL 1- Meerut	132KV	27508.321	24 Nos(15 Running+9 Angle)		400 kV S/s Gr. Noida	ERS will be also be used in other voltage level lines.
		220KV	14973.453				
		400KV	6922.828				
	UPPTCL 2-Prayagraj	765KV	839.37	24 Towers		220 kv S/s phulpur	ERS will also be used in other voltage lines.
		400KV	1804.257				
		220KV	2578.932				
		132KV	4714.768				
18	POWERLINK						
19	POWERGRID HIMACHAL TRANSMISSION LTD						
20	Powergrid Ajmer Phagi Transmission Limited						
21	Powergrid Fatehgarh Transmission Limited						
22	POWERGRID KALA AMB TRANSMISSION LTD						
23	Powergrid Unchahar Transmission Ltd						
24	Powergrid Khetri Transmission Limited						
25	POWERGRID VARANASI TRANSMISSION SYSTEM LTD						
26	ADANI TRANSMISSION INDIA LIMITED			2090	1 Set (12 towers)	Sami (Gujarat)	Make-Lindsey ERS set available for 400KV & 500KV rating can be used for lower as well as higher voltage Towers. In case used for 765KV Line, No of towers can reduce due to increase in Tower Height & nos of conductors.
27	BIKANER KHETRI TRANSMISSION LIMITED		482				
28	FATEHGARH BHADLA TRANSMISSION LIMITED	500 kV HVDC 400 kV HVAC	291				
29	NRSS-XXXI(B) TRANSMISSION LTD	400 kV	577.74	Not Available	Not Available		In the advance stage of process of finalising arrangement for providing ERS on need basis with other transmission utility (M/s INDIGRID).
30	ARAVALI POWER COMPANY PVT LTD	765 kv HVAC					

*The transmission Utility with line length less than 500 ckt kms (of 400 KV lines) may be given option either to procure ERS or have agreement with other transmission utilities for providing ERS on mutually agreed terms, when need arises. (As per MoP directions)

Capacity (MW) 30-11-2023	Name of Station	UNIT_NM	STN_TYP E_ID	SECTOR	REGION_NM	ST_NM	SH_NM	IPP	FUEL_NM	Capacity (MW) 31-03-2025	LGBR Approved Outage			Actual Planned Outage-1		
											Start Date	End Date	Reason	Start Date	End Date	Reason for any deviation
220	RAJASTHAN A.P.S.	3	N	CENTRAL SECTOR	Northern	Rajasthan	NPCIL	FALSE	NUCLEAR	220	1-Apr-24	24-May-24	EMCCR	27-Oct-22	25-Jul-24	Reactor startup initiated on 17 July 2024. unit will be synchronised by 25 July 2024.
250	CHHABRA TPP	4	T	STATE SECTOR	Northern	Rajasthan	RRVUNL	FALSE	COAL	250	1-Apr-24	14-Apr-24	COH	5-Mar-24	28-Mar-24	Preponned due to problem in GT as Bucholz relay Alarm continuously persists
130.19	DADRI CCPP	2	T	CENTRAL SECTOR	Northern	Uttar Pradesh	NTPC Ltd.	FALSE	NATURAL GAS	130.19	1-Apr-24	8-May-24	Major Overhauling			Not taken, as EOH not completed
154.51	DADRI CCPP	5	T	CENTRAL SECTOR	Northern	Uttar Pradesh	NTPC Ltd.	FALSE	NATURAL GAS	154.51	1-Apr-24	2-Apr-24	Major Overhauling			Not taken, as EOH not completed
250	SURATGARH TPS	3	T	STATE SECTOR	Northern	Rajasthan	RRVUNL	FALSE	COAL	250	15-Apr-24	5-May-24	AOH			Deferred due to Power Crisis
200	RAJASTHAN A.P.S.	2	N	CENTRAL SECTOR	Northern	Rajasthan	NPCIL	FALSE	NUCLEAR	200	1-May-24	31-May-24	Binennial Shutdown	1-Jan-25	30-Apr-25	Reactor feeder refurbishment and Enmasse thermowell replacement. Material supply is expected by 01 Jan 2025.
220	NARORA A.P.S.	1	N	CENTRAL SECTOR	Northern	Uttar Pradesh	NPCIL	FALSE	NUCLEAR	220	1-May-24	4-Jul-24	Binennial Shutdown	15-Mar-25	15-Jun-25	
250	SURATGARH TPS	4	T	STATE SECTOR	Northern	Rajasthan	RRVUNL	FALSE	COAL	250	11-May-24	31-May-24	AOH			Deferred due to Power Crisis
111.19	AURAIYA CCPP	2	T	CENTRAL SECTOR	Northern	Uttar Pradesh	NTPC Ltd.	FALSE	NATURAL GAS	111.19	31-May-24	31-May-24	Boiler License Renewal	31-May-24	31-May-24	Availed. No deviation
225	KASHIPUR CCPP	1	T	IPP SECTOR	Northern	Uttarakhand	SrEPL	FALSE	NATURAL GAS	225	1-Jun-24	3-Jun-24	Offline Waterwash	16-Jun-24	16-Jun-24	To meet UPCL load requirement
111.19	AURAIYA CCPP	3	T	CENTRAL SECTOR	Northern	Uttar Pradesh	NTPC Ltd.	FALSE	NATURAL GAS	111.19	4-Jun-24	18-Jun-24	Filter Replacement	1-Jul-24	20-Jul-24	EOH completed later. Currently under OH
250	SURATGARH TPS	1	T	STATE SECTOR	Northern	Rajasthan	RRVUNL	FALSE	COAL	250	5-Jun-24	25-Jun-24	AOH	22-Sep-24	16-Oct-24	Postponed as U#5 taken earlier
195	KOTA TPS	6	T	STATE SECTOR	Northern	Rajasthan	RRVUNL	FALSE	COAL	195	10-Jun-24	30-Jun-24	AOH	1-Mar-25	21-Mar-25	Deferred due to Power Crisis
660	CHHABRA TPP	5	T	STATE SECTOR	Northern	Rajasthan	RRVUNL	FALSE	COAL	660	27-Jun-24	31-Jul-24	AOH	27-Jun-24	Continue	
250	SURATGARH TPS	5	T	STATE SECTOR	Northern	Rajasthan	RRVUNL	FALSE	COAL	250				2-May-24	30-May-24	Earlier proposed in FY 23-24 but deferred due to power crisis and further taken w.e.f 02.05.24

STATUS OF SUBMISSION OF DATA BY NORTHERN REGION PLANTS

Sr. No.	State	Plant-Not providing data	Remarks
1	Delhi	RITHALA (Unit#1 to 3)	Status of the plant whether it is generating power or not is to be confirmed. If there is generation, online submission of data is required.
2	J & K	PAMPORE GPS(Liq.)(Unit #1 to 7)	
3	J & K	BAGLIHAR II HPS	


Sr. No		Units providing data but offline	Remarks
1	Delhi	I.P. CCPP (unit #1 to 9)	Online data submission required.
2	Delhi	PRAGATI CCGT-III(#1-6)	Online data submission required.
3	Rajasthan	JALIPA KAPURDI TPP(Unit#1 to 8)	sometimes online/sometimes offline, not consistent in online.
4	U. P	JAWAHAR STPP(Unit#1)	Online data submission required.
5	Uttarakhand	GAMA CCPP	new nodal person user id allotted in 1st week of June, fed data online only once. No more data submission after that.
6	Uttarakhand	SRAVANTHI CCPP(Unit#1,2)	Online data submission required.
7	Punjab	ANANDPUR SAHIB-I	Online data submission required.
	Punjab	ANANDPUR SAHIB-II	Online data submission required.
8	Uttarakhand	MUKERIAN-I	Sends only consolidated data offline. Unit wise online data submission is required.
	Uttarakhand	MUKERIAN-II	
	Uttarakhand	MUKERIAN-III	
	Uttarakhand	MUKERIAN-IV	
9	Uttarakhand	KHATIMA HPS (Unit#1,2,3)	Online data submission required.
10	Uttarakhand	MANERI RHALI-II HPS	Online data submission required.
11	Uttarakhand	SHRI NAGAR HPS	Online data submission required.
12	Uttarakhand	VYASI HPS	Online data submission required.




**प्रचालन समन्वय उपसमिति की बैठक
जून- 2024**

आवृत्ति की स्थिति: जून -2023 से 2024

आवृत्ति की स्थिति: जून' 23 से जून' 24



जून-2024 के दौरान आवृत्ति की स्थिति (As per 5 Minute SCADA data)



पिछले एक साल में आवृत्ति की स्थिति

आवृत्ति बैंड	जून 2023	जुलाई 2023	अगस्त 2023	सितम्बर 2023	अक्टूबर 2023	नवम्बर 2023	दिसंबर 2023	जनवरी 2024	फ़रवरी 2024	मार्च 2024	अप्रैल 2024	मई 2024	जून 2024
< 49.7 Hz(%)	0.22	0.09	0.47	0.11	0.53	0.10	0.17	0.12	0.095	0.065	0.030	0.000	0.02
<49.8 Hz(%)	0.86	0.66	1.63	0.57	1.99	0.96	1.40	0.92	0.797	0.479	0.432	0.059	0.31
<49.9 Hz(%)	8.42	4.60	7.11	5.21	8.87	6.83	7.83	6.80	6.239	6.022	5.254	2.490	4.50
49.90-50.05 Hz(%)	67.83	74.96	77.25	77.86	74.42	74.36	75.21	75.83	74.06	77.51	78.56	80.045	79.177
50.05-50.10 Hz(%)	15.59	15.64	13.28	13.32	13.53	13.74	10.47	11.91	14.118	12.262	11.178	13.839	13.34
>50.10 Hz(%)	8.15	4.79	2.35	3.61	3.18	5.06	6.49	5.47	5.581	4.204	5.010	3.627	2.99
>50.20 Hz(%)	1.09	0.80	0.23	0.32	0.14	0.66	0.53	0.41	0.565	0.657	0.539	0.285	0.12
औसत आवृत्ति	50.01	50.01	50.00	50.00	49.99	50.00	49.99	49.99	50.00	50.00	50.00	50.00	50.002


जून-2024 के दौरान अधिकतम मांग (Demand Met), अधिकतम ऊर्जा खपत (Energy consumption) और अब तक का कीर्तिमान (राज्यों द्वारा जमा आंकड़ों के अनुसार)



राज्य	अधिकतम मांग (MW) (in Jun'24)	दिनांक / समय	रिकॉर्ड अधिकतम मांग (in MW) (upto May'24)	दिनांक / समय	अधिकतम ऊर्जा खपत (MU) (in Jun'24)	दिनांक	रिकॉर्ड अधिकतम ऊर्जा खपत (MU) (Upto May'24)	दिनांक
पंजाब	16089	29.06.24 at 12:45	15293	24.06.23 को 11:45 बजे	345	25.06.2024	344.1	24.06.2023
हरियाणा	14469	19.06.24 at 15:00	12768	28.06.22 को 11:56 बजे	273	25.06.2024	273.1	18.08.2023
राजस्थान	17774	18.06.24 at 11:45	17949	20.01.24 को 11:00 बजे	378.8	19.06.2024	379.1	30.05.2024
दिल्ली	8656	19.06.24 at 15:06	8302	29.05.24 को 15:36 बजे	177.7	18.06.2024	163.8	31.05.2024
उत्तर प्रदेश	30618	13.06.24 at 22:00	29727	31.05.24 को 21:45 बजे	658.7	17.06.2024	642.3	27.05.2024
उत्तराखंड	2863	14.06.24 at 22:00	2781	29.05.24 को 21:00 बजे	62.1	14.06.2024	60.7	31.05.2024
हिमाचल प्रदेश	1919	26.06.24 at 11:00	2235	20.01.24 को 07:00 बजे	40.3	25.06.2024	39.29	24.01.2024
जम्मू और कश्मीर (UT) तथा लद्दाख (UT)	2902	17.06.24 at 05:00	3107	12.01.24 को 20:00 बजे	58.4	17.06.2024	66.8	26.01.2024
चंडीगढ़	482	18.06.24 at 15:28	432	30.05.24 को 14:00 बजे	9.1	18.06.2024	8.6	30.05.2024
उत्तरी क्षेत्र #	91234	19.06.24 at 14:37	86773	30.05.24 को 14:13 बजे	1990.4	18.06.2024	1882.1	29.05.2024

उत्तरी क्षेत्र अधिकतम मांग (Demand Met) as per SCADA Data

क्षेत्रीय विद्युत आपूर्ति (Demand) जून 2023 बनाम जून 2024 (As per 5 Minute SCADA data)




जून -2023 की तुलना में जून -2024 की औसत विद्युत आपूर्ति में 23.1% (~14161 MW) वृद्धि हुई

उत्तरी क्षेत्र की औसत ऊर्जा खपत में वृद्धि(% में) जून -2024/ जून -2023
/ जून -2022

राज्य	जून -2022	जून -2023	जून -2024	% वृद्धि (जून -2023 vs जून -2022)	% वृद्धि (जून -2024 vs जून -2023)
पंजाब	251.1	235.9	293.2	-6.0%	24.3%
हरियाणा	211.7	204.6	259.6	-3.4%	26.9%
राजस्थान	290.8	271.1	344.8	-6.8%	27.2%
दिल्ली	130.1	122.2	151.8	-6.1%	24.2%
उत्तर प्रदेश	495.2	503.9	601.9	1.7%	19.5%
उत्तराखंड	49.3	49.7	56.8	0.8%	14.3%
चंडीगढ़	6.6	6.1	7.9	-7.7%	30.2%
हिमाचल प्रदेश	34.3	31.1	38.3	-9.3%	23.1%
जम्मू और कश्मीर (UT) तथा लद्दाख (UT)	50.8	52.0	54.5	2.3%	4.8%
उत्तरी क्षेत्र	1520.1	1480.5	1813.3	-2.6%	22.5%

उत्तरी क्षेत्र की औसत ऊर्जा खपत में वृद्धि(% में) जून-2024/ जून-2023 / जून-2022

औसत ऊर्जा खपत में वृद्धि(% में)




उत्तरी क्षेत्र की ऊर्जा खपत(MUs)

Northern Region Energy Consumption Pattern




जून-2023 की तुलना में जून-2024 की औसत ऊर्जा खपत 22.0% (~333 एमयू / दिन) की वृद्धि हुई

उत्तरी क्षेत्र की तापीय (Thermal) उत्पादन की स्थिति (MUs/Day)




उत्तरी क्षेत्र की जलीय (हाइड्रो) उत्पादन की स्थिति (MU_s/Day)

Northern Regional Hydro Generation




उत्तरी क्षेत्र की अक्षय (Renewable) उत्पादन की स्थिति (MUs/Day)

NR Renewable Generation



अंतर-क्षेत्रीय आयात(MUs/Day) की स्थिति



वास्तविक सारांश -
जून-2023 बनाम जून-2024

	जून-2023 (मि.यु. /दिन)	जून-2024 (मि.यु. /दिन)	जून माह में वृद्धि (मि.यु./दिन)
तापीय (Thermal) उत्पादन	755.07	844.21	89.13
जलीय (Hydro) उत्पादन	319.34	323.89	4.56
नाभिकीय (Nuclear) उत्पादन	26.31	26.39	0.08
अंतर-क्षेत्रीय (Inter- Regional) कुल आयात	222.22	410.33	188.11
अक्षय (Renewable) उत्पादन	168.065	202.397	34.33

RE Penetration

Maximum Daily MU Penetration

	June '2024		Record upto May '2024	
	Max % Penetration	Date	Max % Penetration	Date
Punjab	4.27	06-06-2024	12.28	01-04-2020
Rajasthan	23.70	05-06-2024	36.47	22-10-2021
UP	2.57	07-06-2024	5.50	05-03-2024
NR	14.67	05-06-2024	20.69	02-04-2023

Outage Summary For June 2024

CONSTITUENTS	PLANNED (A)	FORCED OUTAGES (B=C+D)	EMERGENCY SHUTDOWNS (C)	TRIPPING	% PLANNED SHUTDOWNS (A/(A+C))	% EMERGENCY SHUTDOWNS(C/(A+C))	% ESD SHUTDOWNS(C/B)	% TRIPPING	TOTAL OUTAGES (A+B)
				(D)				(D/B)	
POWERGRID	168	429	239	190	41.3%	58.7%	55.7%	44.3%	597
UPPTCL	80	220	89	131	47.3%	52.7%	40.5%	59.5%	300
RRVPNL	71	128	71	57	50.0%	50.0%	55.5%	44.5%	199
BBMB	15	109	47	62	24.2%	75.8%	43.1%	56.9%	124
HVPNL	36	83	38	45	48.6%	51.4%	45.8%	54.2%	119
DTL	5	49	17	32	22.7%	77.3%	34.7%	65.3%	54
PSTCL	14	36	12	24	53.8%	46.2%	33.3%	66.7%	50
PTCUL	5	16	3	13	62.5%	37.5%	18.8%	81.3%	21
HPPTCL	2	15	6	9	25.0%	75.0%	40.0%	60.0%	17
PDD JK	1	16	4	12	20.0%	80.0%	25.0%	75.0%	17
NTPC	5	8	3	5	62.5%	37.5%	37.5%	62.5%	13
GTL	4	7	0	7	100.0%	0.0%	0.0%	100.0%	11
ESUCRL	8	2	1	1	88.9%	11.1%	50.0%	50.0%	10
RENEW SURYARAVI (RSRPL)	10	0	0	0	100.0%	0.0%	NA	NA	10
THDC	1	9	6	3	14.3%	85.7%	66.7%	33.3%	10
ATIL	0	9	3	6	0.0%	100.0%	33.3%	66.7%	9
PKATL	0	8	2	6	0.0%	100.0%	25.0%	75.0%	8
Cleansolar_Jodhpur	3	4	1	3	75.0%	25.0%	25.0%	75.0%	7
RSEJ3PL	4	2	1	1	80.0%	20.0%	50.0%	50.0%	6
SBSRPC-11	4	1	0	1	100.0%	0.0%	0.0%	100.0%	5
Tata Power	4	1	1	0	80.0%	20.0%	100.0%	0.0%	5
Sekura	1	3	1	2	50.0%	50.0%	33.3%	66.7%	4
AHEJ4L	2	1	1	0	66.7%	33.3%	100.0%	0.0%	3
Renew Power	3	0	0	0	100.0%	0.0%	NA	NA	3
RENEW SUN WAVE (RSWPL)	2	1	0	1	100.0%	0.0%	0.0%	100.0%	3
AREPRL	0	2	1	1	0.0%	100.0%	50.0%	50.0%	2
NHPC	0	2	1	1	0.0%	100.0%	50.0%	50.0%	2
NRSS XXIX	0	2	2	0	0.0%	100.0%	100.0%	0.0%	2
Total	448	1163	550	613	44.9%	55.1%	47.3%	52.7%	1611

OUTAGE SUMMARY OF LAST THREE MONTHS

MONTH	PLANNED	FORCED OUTAGES	EMERGENCY SHUTDOWNS	TRIPPING	% PLANNED as of TOTAL S/D	% EMERGENCY SHUTDOWNS	TOTAL OUTAGES (A+B)
	(A)	(B=C+D)	(C)	(D)	(A/(A+C))	(C/(A+C))	
Mar-24	927	788	380	408	70.9%	29.1%	1715
Apr-24	838	724	366	358	69.6%	30.4%	1562
May-24	812	1113	469	634	62.9%	37.1%	1925
June-24	448	1163	550	613	44.9%	55.1%	1611

New Elements First Time Charged During June 2024

S. No.	Type of transmission element	Total No
1	ICTs/GTs/Transformers	02
2	LILO Line Charging	02
3	Capacitor Bank	03
4	BUS REACTOR	01
5	AC Transmission line Shifting	01
Total New Elements charged		09

ICTs/GTs/Transformers

S.No	Name of element	Owner	Voltage Level (HV/LV/Tertiary)	MVA Capacity	Transformer Details	OLD MVA Capacity	Actual date of charging
1	400/220/33kV, 500 MVA, 3-Phase, BHEL, ICT - 2 at Gorakhpur(UP)	UPPTCL	400/220/33kV	500	Augmentation	240	20-Jun-2024
2	400/220/33kV, 315 MVA, 3-Phase, CGL, ICT - 3 at Bhinmal(PG)	POWERGRID	400/220/33kV	315	New	NA	27-Jun-2024

LILO Line Charging

S.No	Name of element	Voltage Level (in kV)	Name of Line to be LILOed	Line Length of New Line after LILO (In Km)	LILO Portion Line Length (In Km)	Conductor Type	Agency/Owner	Actual date of charging
1	220kV Patran(PATR)-Mansa(PSTCL) - 1(After LILO of 220 KV Mansa - Sunam at 400 KV PTCL Patran (Banwala))	220kV	220 KV Mansa - Sunam	78.169	42.737	ZEBRA	PSTCL	28-Jun-2024
2	220kV Patran(PATR)-Sunam(PSTCL)-1(After LILO of 220 KV Sunam - Mansa at 400 KV PTCL Patran (Banwala))	220kV	220 KV Sunam - Mansa	44.647	42.737	ZEBRA	PSTCL	28-Jun-2024

Capacitor Bank

S.No	Name of element	Owner	Capacitor Bank No	Capacitor MVAR Rating	Actual date of charging
1	33kV, CHDB- F880, 55 MVAR(1X10 MVAR and 3x15 MVAR) Capacitor bank no-Capacitor Bank-3 (55 MVAR) at Nokhra SL_BHD2 (NTPC)	NTPC_NOKHRA	Capacitor Bank-3(55 MVAR)	55	12-Jun-2024
2	33kV, CHDB- F880, 55 MVAR(1x10 MVAR and 3x15 MVAR) Capacitor bank no-Capacitor Bank-2 (55 MVAR) at Nokhra SL_BHD2 (NTPC)	NTPC_NOKHRA	Capacitor Bank-2(55 MVAR)	55	17-Jun-2024
3	33kV, CHDB- F880, 55 MVAR(1x10 MVAR and 3x15 MVAR) Capacitor bank no-Capacitor Bank-1 (55 MVAR) at Nokhra SL_BHD2 (NTPC)	NTPC_NOKHRA	Capacitor Bank-1(55 MVAR)	55	17-Jun-2024

BUS REACTOR

S.No	Name of element	Owner	Voltage Level	MVAR Capacity	Actual date of charging
1	400kV, 125MVA Bus Reactor 1 at Sahupuri (UP)	UPPTCL	400kV	125	15-Jun-2024

AC Transmission line Shifting

S.No	Name of element	Owner	Voltage Level (in kV)	Circuit No	Line Length(Km)	Conductor Type	Actual date of charging
1	220kV Shahjahanpur(PG)-Hardoi(UP)- 1 (JUMPERING OF 220 KV SHAHJAHANPUR(PG)- MALLAWAN LINE AND 220 KV MALLAWAN - HARDOI LINE AT TOWER NO-201 AND 202)	UPPTCL	220kV	1	60	ZEBRA	08-Jun-2024



धन्यवाद