



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
उत्तर क्षेत्रीय विद्युत समिति
Northern Regional Power Committee

विषय: प्रचालन समन्वय उप-समिति की 225^{वीं} बैठक की कार्यसूची।

Subject: Agenda of the 225th OCC meeting.

प्रचालन समन्वय उप-समिति की 225^{वीं} बैठक का आयोजन वीडियो कॉन्फ्रेंसिंग के माध्यम से दिनांक **12.11.2024** को **10:30** बजे से किया जायेगा। उक्त बैठक की कार्यसूची उत्तर क्षेत्रीय विद्युत् समिति की वेबसाइट <http://164.100.60.165> पर उपलब्ध है।

बैठक में सम्मिलित होने के लिए लिंक व पासवर्ड सभी सदस्यों को ई-मेल द्वारा प्रदान किया जाएगा।

कृपया बैठक में उपस्थित होने की सुविधा प्रदान करें।

The **225th** meeting of the Operation Co-ordination sub-committee will be conducted through Video Conferencing on **12.11.2024** from **10:30 Hrs**. The agenda of this meeting has been uploaded on the NRPC web-site <http://164.100.60.165>.

The link and password for joining the meeting will be e-mailed to respective e-mail IDs in due course.

Kindly make it convenient to attend the meeting.

(डी. के. मीना)
अधीक्षण अभियंता (प्रचालन)

सेवा में : प्रचालन समन्वय उप समिति के सभी सदस्य।

To : All Members of OCC

Signed by Dhamendra
Kumar Meena

Date: 08-11-2024 18:57:15

List of addressee (via mail)

OCC Members for FY 2024-25			
S. No	OCC Member	Category	E-mail
1	NLDC	National Load Despatch Centre	nomination awaited rk.porwal@grid-india.in
2	NRLDC	Northern Regional Load Despatch Centre	somara.lakra@grid-india.in
3	CTUIL	Central Transmission Utility	kashish@powergrid.in
4	PGCIL	Central Government owned Transmission Company	rtamc.nr1@powergrid.in rtamcjammu@powergrid.in cpcc.nr3@powergrid.in
5	NTPC	Central Generating Company	hastogi@ntpc.co.in
6	BBMB		powerc@bbmb.nic.in
7	THDC		ravindrasrana@thdc.co.in
8	SJVN		sjvn.cso@sjvn.nic.in
9	NHPC		surendramishra@nhpc.nic.in
10	NPCIL		df@npcil.co.in
11	Delhi SLDC	State Load Despatch Centre	gmsldc@delhisldc.org
12	Haryana SLDC		cesocomml@hvpn.org.in
13	Rajasthan SLDC		ce.ld@rvpn.co.in
14	Uttar Pradesh SLDC		ceps@upsldc.org
15	Uttarakhand SLDC		se_sldc@ptcul.org
16	Punjab SLDC		ce-slhc@pstcl.org
17	Himachal Pradesh SLDC		cehpsldc@gmail.com
18	DTL	State Transmission Utility	bl.gujar@dtl.gov.in
19	HVPNL		cetspkl@hvpn.org.in
20	RRVNL		ce.ppm@rvpn.co.in
21	UPPTCL		smart.saxena@gmail.com
22	PTCUL		ce_oandmk@ptcul.org
23	PSTCL		ce-tl@pstcl.org
24	HPPTCL		gmprojects.tcl@hpmail.in
25	IPGCL		ncsharma@ipgcl-ppcl.nic.in
26	HPGCL	State Generating Company	seom2.rgtpp@hpgcl.org.in
27	RRVUNL		ce.ppmcit@rrvun.com
28	UPRVUNL		cgm.to@uprvunl.org
29	UJVNL		gm_engg_ujvn@yahoo.co.in
30	HPPCL		gm_generation@hppcl.in
31	PSPCL		State Generating Company & State owned Distribution Company
32	UHBVN	State owned Distribution Company (alphabetical rotaional basis/nominated by state govt.)	nomination awaited md@uhbvn.org.in
33	Jodhpur Vidyut Vitran Nigam Ltd.		addlcehqjdvvn@gmail.com
34	Paschimanchal Vidyut Vitaran Nigam Ltd.		nomination awaited md@pvvnl.org
35	UPCL		cgmupcl@yahoo.com
36	HPSEB	cesysophpsebl@gmail.com	
37	Prayagraj Power Generation Co. Ltd.	IPP having more than 1000 MW installed capacity	sanjay.bhargava@tatapower.com

38	Aravali Power Company Pvt. Ltd		amit.hooda01@gmail.com
39	Apraave Energy Ltd.,		rajneesh.setia@apraava.com
40	Talwandi Sabo Power Ltd.		ravinder.thakur@vedanta.co.in
41	Nabha Power Limited		Durvesh.Yadav@larsentoubro.com
42	MEIL Anpara Energy Limited		arun.tholia@meilanparapower.com
43	Rosa Power Supply Company Ltd		Suvendu.Dey@relianceada.com
44	Lalitpur Power Generation Company Ltd		avinashkumar.ltp@lpgcl.com
45	MEJA Urja Nigam Ltd.		rsjuneja@ntpc.co.in
46	Adani Power Rajasthan Limited		manoj.taunk@adani.com
47	JSW Energy Ltd. (KWHEP)		roshan.zipta@jsw.in
48	TATA POWER RENEWABLE	IPP having less than 1000 MW installed capacity (alphabetical rotational basis)	nomination awaited (dhmahabale@tatapower.com)
49	UT of J&K	From each of the Union Territories in the region, a representative nominated by the administration of the Union Territory concerned out of the entities engaged in generation/ transmission/ distribution of electricity in the Union Territory.	sojppdd@gmail.com
50	UT of Ladakh		cepdladakh@gmail.com
51	UT of Chandigarh		elop2-chd@nic.in
52	Noida Power Company limited	Private Distribution Company in region (alphabetical rotational basis)	nomination awaited (ssrivastava@noidapower.com)
53	Fatehgarh Bhadla Transmission Limited	Private transmission licensee (nominated by central govt.)	nomination awaited (nitesh.ranjan@adani.com)
54	NTPC Vidyut Vyapar Nigam Ltd.	Electricity Trader (nominated by central govt.)	nomination awaited (ceonvvn@ntpc.co.in)

Contents

A.1. Confirmation of Minutes.....	5
A.2. Status of action taken on decisions of 224 th OCC meeting of NRPC.....	5
A.3. Review of Grid operations.....	5
A.4. Maintenance Programme of Generating Units and Transmission Lines.....	6
A.5. Planning of Grid Operation.....	6
A.6. Follow-up of issues from previous OCC Meetings- Status update.....	7
A.7. NR Islanding scheme.....	8
A.8. Coal Supply Position of Thermal Plants in Northern Region.....	8
A.9. Status of availability of ERS towers in Northern Region (Agenda by NRPC Sectt.)	9
A.10. Updating outage Details by Generating Station/utilities (Agenda by CEA)....	9
A.11. Installation of Co2 injection (seeding) system in HVDC Mundra and Mahendragarh Terminal system (agenda by ATIL).....	10
A.12. Procurement of cold spare transformers and reactor for Northern Region (Agenda by POWERGRID).....	11
A.13. Review of availability for power line crossing & OPGW diamond formation by upcoming new Transmission line projects (Agenda by POWERGRID NR-1).....	16
B.1. NR Grid Highlights for October 2024.....	16
B.2. Demand forecasting and resource adequacy related.....	19
B.3. Critical operation of Rajasthan Grid during upcoming winter season:.....	28
B.4. Mock testing of islanding scheme and simulation studies.....	30
B.5. Winter preparedness 2024-25.....	31
B.6. Reactive power performance of generators.....	35
B.7. Sharing of ATC/TTC assessment and basecase with NRLDC.....	38

खण्ड-क: उ.क्षे.वि.स.

Part-A: NRPC

A.1. Confirmation of Minutes

224th OCC meeting was held on 18.10.2024. Minutes of the meeting were issued vide letter dt. 07.11.2024.

Decision required from Forum:

Forum may approve the minutes of 224th OCC meeting.

A.2. Status of action taken on decisions of 224th OCC meeting of NRPC

A.2.1. Status of action taken on decisions of 224th NRPC meeting is attached as **Annexure- A.0.**

A.3. Review of Grid operations**A.3.1. Power Supply Position (Provisional) for October 2024**

Anticipated Power Supply Position v/s Actual Power Supply Position (Provisional) of Northern Region during the month of October-2024 is as under:

State / UT	Req. / Avl.	Energy (MU)			Peak (MW)		
		Anticipated	Actual	% Variation	Anticipated	Actual	% Variation
CHANDIGARH	(Avl)	130	145	11.6%	310	298	-3.9%
	(Req)	142	145	2.2%	304	298	-2.1%
DELHI	(Avl)	3423	3243	-5.2%	5650	6161	9.0%
	(Req)	2700	3244	20.1%	5650	6161	9.0%
HARYANA	(Avl)	6126	6161	0.6%	10263	11087	8.0%
	(Req)	5601	6161	10.0%	10602	11087	4.6%
HIMACHAL PRADESH	(Avl)	1069	1065	-0.4%	1935	1947	0.6%
	(Req)	1084	1066	-1.7%	1915	1947	1.7%
J&K and LADAKH	(Avl)	1390	1546	11.2%	3090	2742	-11.3%
	(Req)	1872	1558	-16.8%	3235	3068	-5.2%
PUNJAB	(Avl)	6150	6268	1.9%	10080	14311	42.0%
	(Req)	6499	6268	-3.6%	12748	14311	12.3%
RAJASTHAN	(Avl)	8330	9846	18.2%	17860	16206	-9.3%
	(Req)	9461	9846	4.1%	15300	16206	5.9%
UTTAR PRADESH	(Avl)	13020	14226	9.3%	25500	26756	4.9%
	(Req)	12710	14227	11.9%	25500	26756	4.9%
UTTARAKHAND	(Avl)	1287	1349	4.9%	2260	2412	6.7%
	(Req)	1271	1355	6.6%	2200	2412	9.6%
NORTHERN REGION	(Avl)	40924	43849	7.1%	76900	73700	-4.2%
	(Req)	41340	43869	6.1%	70500	73700	4.5%

As per above, negative / significant variation ($\geq 5\%$) in Actual Power Supply Position (Provisional) vis-à-vis Anticipated figures is observed for the month of October-2024 in terms of Energy Requirement for Delhi, Haryana, HP, UTs of J&K and Ladakh, Punjab, UP, and Uttarakhand and in terms of Peak Demand similar variation is noted

for Chandigarh, Delhi, UTs of J&K and Ladakh, Punjab, Rajasthan, and Uttarakhand. These states/UTs are requested to submit reason for such variations so that the same can be deliberated in the meeting.

All SLDCs are requested to furnish provisional and revised power supply position in prescribed formats on NRPC website portal by 2nd and 15th day of the month respectively for the compliance of Central Electricity Authority (Furnishing of Statistics, Returns and Information) Regulations, 2007.

A.4. Maintenance Programme of Generating Units and Transmission Lines

A.4.1. Maintenance Programme for Generating Units

The meeting on proposed maintenance programme for Generating Units for the month of December-2024 is scheduled on 11-November-2024 via Video Conferencing.

A.4.2. Outage Programme for Transmission Elements

The meeting on proposed outage programme of Transmission elements for the month of December-2024 is scheduled on 11-November-2024 via Video conferencing.

A.5. Planning of Grid Operation

A.5.1. Anticipated Power Supply Position in Northern Region for December 2024

The Anticipated Power Supply Position in Northern Region for December 2024 is as under:

State / UT	Availability / Requirement	Revised Energy (MU)	Revised Peak (MW)	Date of revision
CHANDIGARH	Availability	120	290	No Revision submitted
	Requirement	123	307	
	Surplus / Shortfall	-3	-17	
	% Surplus / Shortfall	-2.4%	-5.4%	
DELHI	Availability	3320	6070	No Revision submitted
	Requirement	2174	5508	
	Surplus / Shortfall	1146	562	
	% Surplus / Shortfall	52.7%	10.2%	
HARYANA	Availability	5800	10450	No Revision submitted
	Requirement	4250	8954	
	Surplus / Shortfall	1550	1496	
	% Surplus / Shortfall	36.5%	16.7%	

State / UT	Availability / Requirement	Revised Energy (MU)	Revised Peak (MW)	Date of revision
	Availability	620	2250	
HIMACHAL PRADESH	Requirement	1145	2146	No Revision submitted
	Surplus / Shortfall	-525	104	
	% Surplus / Shortfall	-45.9%	4.8%	
J&K and LADAKH	Availability	1240	3130	No Revision submitted
	Requirement	2062	3245	
	Surplus / Shortfall	-822	-115	
	% Surplus / Shortfall	-39.9%	-3.5%	
PUNJAB	Availability	6100	10100	No Revision submitted
	Requirement	4531	8991	
	Surplus / Shortfall	1569	1109	
	% Surplus / Shortfall	34.6%	12.3%	
RAJASTHAN	Availability	9060	18360	No Revision submitted
	Requirement	10886	19278	
	Surplus / Shortfall	-1826	-918	
	% Surplus / Shortfall	-16.8%	-4.8%	
UTTAR PRADESH	Availability	14290	27530	No Revision submitted
	Requirement	10378	22277	
	Surplus / Shortfall	3912	5253	
	% Surplus / Shortfall	37.7%	23.6%	
UTTARAKHAND	Availability	1333	2450	05-Nov-24
	Requirement	1380	2490	
	Surplus / Shortfall	-47	-40	
	% Surplus / Shortfall	-3.4%	-1.6%	
NORTHERN REGION	Availability	41883	73500	
	Requirement	36929	66700	
	Surplus / Shortfall	4955	6800	
	% Surplus / Shortfall	13.4%	10.2%	

SLDCs are requested to update the anticipated power supply position of their respective state / UT for the month of December-2024 and submit the measures proposed to be taken to bridge the gap between demand & availability, as well to dispose-off the surplus, if any, in the prescribed format.

A.6. Follow-up of issues from previous OCC Meetings- Status update.

The updated status of agenda items is enclosed at **Annexure-A.I.**

All utilities are requested to update the status.

A.7. NR Islanding scheme

Latest status of Islanding Scheme of NR is attached as **Annexure-A.II.**

Members may kindly deliberate.

A.8. Coal Supply Position of Thermal Plants in Northern Region

A.8.1 In 186th OCC meeting, it was agreed that coal stock position of generating stations in northern region may be reviewed in the OCC meetings on the monthly basis.

A.8.2 Accordingly, coal stock position of generating stations in northern region during current month (till 05th November 2024) is as follows:

Station	Capacity (MW)	PLF % (prev. months)	Normative Stock Req'd (Days)	Actual Stock (Days)
ANPARA C TPS	1200	0.59	14	9.1
ANPARA TPS	2630	0.83	14	7.5
BARKHERA TPS	90	0.43	22	8.8
DADRI (NCTPP)	1820	0.23	22	10.0
GH TPS (LEH.MOH.)	920	0.13	22	22.3
GOINDWAL SAHIB TPP	540	0.35	22	18.5
HARDUAGANJ TPS	1265	0.43	22	16.1
INDIRA GANDHI STPP	1500	0.61	22	28.8
KAWAI TPS	1320	0.60	22	22.6
KHAMBARKHERA TPS	90	0.49	22	13.2
KOTA TPS	1240	0.55	22	13.3
KUNDARKI TPS	90	0.41	22	12.3
LALITPUR TPS	1980	0.58	22	9.9
MAHATMA GANDHI TPS	1320	0.61	22	24.1
MAQSOODPUR TPS	90	0.43	22	12.5
MEJA STPP	1320	0.54	22	12.7
OBRA TPS	1094	0.56	22	6.9
PANIPAT TPS	710	0.43	22	27.4
PARICHA TPS	1140	0.52	22	12.6
PRAYAGRAJ TPP	1980	0.59	22	15.6
RAJIV GANDHI TPS	1200	0.34	22	22.9
RAJPURA TPP	1400	0.51	22	12.9
RIHAND STPS	3000	0.74	14	10.2
ROPAR TPS	840	0.19	22	28.9

कार्यसूची: उ.क्षे.वि.स.की प्रचालन समन्वय उप-समिति की 225^{वीं} बैठक

Station	Capacity (MW)	PLF % (prev. months)	Normative Stock Req'd (Days)	Actual Stock (Days)
ROSA TPP Ph-I	1200	0.56	22	15.3
SINGRAULI STPS	2000	0.66	14	8.5
SURATGARH TPS	1500	0.24	22	8.8
TALWANDI SABO TPP	1980	0.46	22	9.2
TANDA TPS	1760	0.55	22	10.9
UNCHAHAHAR TPS	1550	0.48	22	9.4
UTRAULA TPS	90	0.44	22	15.4
YAMUNA NAGAR TPS	600	0.25	22	13.8
CHHABRA-I PH-1 TPP	500	0.76	22	8.4
KALISINDH TPS	1200	0.33	22	9.8
SURATGARH STPS	1320	0.61	22	4.1
CHHABRA-I PH-2 TPP	500	0.76	22	8.8
CHHABRA-II TPP	1320	0.74	22	4.3

A.9. Status of availability of ERS towers in Northern Region (Agenda by NRPC Sectt.)

A.9.1 In the 68th meeting of NRPC issues arising due to non-availability of sufficient ERS were discussed and it was decided that ERS availability monitoring shall be taken as rolling/follow-up agenda in OCC meetings for regular monitoring of ERS under different utilities in Northern region.

A.9.2 Subsequently matter was deliberated in 211th OCC meeting wherein NRLDC representative briefed about the Requirement of ERS, recent experience in Northern Region, CEA Regulation on ERS, Govt. Guidelines and Present situation on ERS.

A.9.3 NRPC Sectt. vide letter dated 26.09.2023 requested all transmission utilities of NR to furnish the length of transmission line (ckt-kms) and number of ERS towers available with them at different voltage levels (e.g. 220 kV, 400 KV 765 KV and + - 500 kV HVDC via email at seo-nrpc@nic.in.

A.9.4 In this regard, inputs received from utilities are attached as **Annexure-A.III.**

Transmission utilities of NR to update status.

A.10. Updating outage Details by Generating Station/utilities (Agenda by CEA)

A.10.1. To enhance the monitoring of approved Planned Maintenance schedules, Member (GO&D), CEA has directed that actual maintenance availed against approved planned maintenance is to be updated on priority by respective RPCs regularly on monthly basis.

A.10.2. In the 221st OCC meeting of NRPC, forum asked generating stations of NR to update the status of Planned Maintenance schedules versus actual maintenance availed for the previous month before every OCC meeting and it was decided that

to enhance the monitoring of approved Planned Maintenance schedules the said agenda item shall be taken as rolling/follow-up agenda in OCC meetings.

A.10.3. In this regard, list of Planned Maintenance schedules versus actual maintenance availed for the year 2024-25 for the month of October 2024 is attached as **Annexure-A.IV.**


A.10.4. In this, regard, Generating Station/utilities of NR are requested to submit each month the details of the maintenance activities that transpired against the originally planned schedule. Further, any deviations from the planned schedule shall be explained by the concerned generating entities.

Generating utilities of NR to update status.

A.11. Installation of Co2 injection (seeding) system in HVDC Mundra and Mahendragarh Terminal system (agenda by ATIL)

A.11.1. ± 500 kV HVDC Mundra Mahendragarh Transmission system is a critical interconnection between the western region and the Northern Region. The system is in service since the last 12 years. Every year, the system is taken into outage for 6-8 days majorly to check the valve cooling system with checks of deposition of the electrode cooling tubes. The reason of deposition is during circulation of DM water for cooling of thyristor, it meets aluminum alloy heat sinks of the thyristor. Very slow chemical process happens which releases aluminum in DM water while circulation within thyristor heat sink. Released aluminum particles in microns circulate inside water tubes of valve hall. Siemens has provided electrodes on colling tubes of valve hall. Aluminum particles with other impurities deposit on electrodes provided on colling tubes of valve hall. It is very critical to check these electrodes every year so that electrodes with high deposition can be replaced.

A.11.2. Some images of the deposition formed are:



A.11.3. While this electrode deposition and replacement activity had been carried out once a year, we have observed increased deposition in electrodes in the past 5 years. Below is the trend of deposition observed:

	Location	2019	2020	2021	2022	2023	Grand Total
REPLACEMENT OF GRADING ELECTRODE	Mundra	15	20	32	44	47	158
	Mahendragarh	7	9	18	25	28	87

- A.11.4. Moreover, ATIL has had 5 nos. of emergency outages availed in the past 2 years due to deposition and water leakage in the valve hall. The problem is aggravating and it is required that ATIL would have to check the deposition on electrodes on 6 monthly basis i.e. 16 days outage of HVDC system.
- A.11.5. ATIL had approached OEM (M/S Siemens) to provide a solution for such deposition. M/S Siemens has proposed installation of Co2 dosing (injection) system. The purpose of the CO2-dosing system is to inject gaseous CO2 in the cooling system in order to modify the conditions of the cooling water. According to the CO2 amount the pH-value of the cooling water and the conductivity changes. Through the conductivity value the injected CO2 amount is controlled. The CO2-dosing system is needed to reduce/stop the formation of aluminum coating on the grading electrodes used inside the converter. Thus, the injection system maintains the pH of DM water to 7 which prevents such scaling.
- A.11.6. ATIL has submitted that the above-mentioned solution is proven and globally recommended. Enclosed (**Annexure-V**) is a technical paper published by "Internal Journal of electrochemical science" on the subject with Siemens' experience on the same. In India, Power grid has installed the same in its Talcher and Kolar HVDC terminals and the results are very good. Co2 injection system has reduced impurity deposition which has resulted in long maintenance and emergency outages.
- A.11.7. The estimate cost of supply and installation is Rs 10 crore/pole/terminal (total Rs 40 crore for both Mundra and Mahendragarh). The installation would require an outage of 6-8 days outage/pole.
- A.11.8. ATIL seeks approval of the forum to install the Co2 injection system as an additional capitalization for technical upgradation project and requests approval of the outage duration for installation of the same as deemed available to ATIL.
- A.11.9. The cited subject was also discussed in the 51st TCC and 76th NRPC meeting wherein NRPC Board referred matter to OCC forum for detailed technical deliberation on this agenda.

Members may kindly deliberate.

A.12. Procurement of cold spare transformers and reactor for Northern Region (Agenda by POWERGRID)

- A.12.1 Hon'ble CERC had set up a committee on dated 15.03.2018 consisting of representatives from CERC, NLDC, CEA & POWERGRID under the Chairmanship of the Chief (Engineering) of the CERC to assess the requirement of regional spares including bus reactors, line reactors, ICTs, etc. This would ensure reliability of the grid and reduce downtime in case of any failure/outage.

A.12.2 In As per CERC Committee recommendation, the following spares transformers & reactors are required to be kept as spare for Northern Region as per POWERGRID assets base:

i) Transformer:

S I N o	State/ UT	MVA Rating and Phase	Volt	Total installed unit	Spare Required as per CERC report	RPC Approved Spares	Qty Proposed for procurement	Approx Cost (Rs. In Crore)	Availability of RPC Spare	Remarks
1	DELHI	3Ø-500 MVA	400/220	10	1	1	0		Tughlakabad	
2	DELHI	3Ø-315 MVA	400/220	3	1	0	1	20.24		Maharajpur/Bawana
3	HARYANA	3Ø-500 MVA	400/220	17	2	2	0		Manesar GIS Panchkula (Given to PSTCL)	
4	HARYANA	3Ø-315 MVA	400/220	22	2	1	0			
5	HIMACHAL PRADESH	3Ø-315 MVA	400/220	3	1	0	1	20.24		Required at Nallagarh
6	JAMMU & KASHMIR	3Ø-315 MVA	400/220	3	1	0	1	20.24		Required at Sambha
7	PUNJAB	3Ø-500 MVA	400/220	12	1	1	0		Moga	
8	PUNJAB	3Ø-315 MVA	400/220	10	1	2	0		01no. under procurement Ludhiana - Given to DTL	
9	RAJASTHAN	3Ø-500 MVA	400/220	32	2	1	0			
10	RAJASTHAN	3Ø-315 MVA	400/220	18	1	1	0		Bhiwadi - Given to	

									RVPNL	
1 1	UTTAR PRADESH	3Ø- 500 MVA	400/ 220	15	1	1	0		Lucknow	
1 2	UTTAR PRADESH	3Ø- 315 MVA	400/ 220	21	2	2	0		02nos. under procurement	
1 3	UTTAR PRADESH	3Ø- 200 MVA	400/ 132	1	1	0	1	13.2 7		Required at Ballia
1 4	UTTAR PRADESH	3Ø- 200 MVA	220/ 132	2	1	1	0		Raibareilly	
1 5	UTTARA KHAND	3Ø- 500 MVA	400/ 220	1	1	0	1	26.8 1		Required at Roorkee
1 6	UTTARA KHAND	3Ø- 315 MVA	400/ 220	4	1	0	1	20.2 4		Required at Dehradun
1 7	CHANDI GARH	3Ø- 160 MVA	220/ 66	2	1	0	1	11.7		Required at Chandigarh
Total								132. 74		

Special type of Transformer

S I N o	Location	MVA Rating and Phase	Volta ge	Tota l insta lled unit	Spar e Requ ired as per CER C repo rt	RPC Appr oved Spar es	Qty Propos ed for procu rement	App rox Cost (Rs. In Cror e)	Availa bility of RPC Spare	Remark s
1	GIS Maharani Bagh	3Ø- 500 MVA	400/ 220	2	1	0	1	30		HV bushing s: Oil to GIS IV Bushing s: Oil to Oil
2	GIS Baghpat	3Ø- 500 MVA	400/ 220	2	1	0	1	30		
Total								60		

ii) **Reactors:**

Sl. No.	State	Voltage Rating	Capacity in MVA	Total installed Unit	Spare required as per CERC Committee report	RPC Approved Spares	Qty Proposed for procurement	Approx Cost (Rs. In Crore)	Availability of RPC Spare	Remarks
1	Delhi	420 kV	125	3	1	0	1	13.00		
2	Haryana	220 kV	25	2	1	0	1	5.00		
3	Haryana	420 kV	50	12	1	0	1	9.26		
4	Haryana	420 kV	80	7	1	0	1	11.25		
5	Haryana	420 kV	125	11	1	0	1	13.00		
6	HP	420 kV	50	4	1	0	0			
7	HP	420 kV	63	2	1	0	1	9.56		
8	HP	420 kV	80	4	1	0	1	11.25		
9	HP	420 kV	125	1	1	0	1	13.00		
10	J&K	420 kV	50	5	1	0	0			
11	J&K	420 kV	63	3	1	0	1	9.56		
12	J&K	420 kV	80	2	1	0	1	11.25		
13	J&K	420 kV	125	2	1	0	1	13.00		
14	J&K	220 kV	25	1	1	0	1	5.00		
15	LADAKH	220 kV	25	2	1	0	1	5.00		
16	Punjab	420 kV	50	8	1	0	0			
17	Punjab	420 kV	63	4	1	0	1	9.56		
18	Punjab	420 kV	80	2	1	0	1	11.25		
19	Punjab	420 kV	125	7	1	0	1	13.00		
20	Punjab	220 kV	25	3	1	0	1	5.00		
21	Rajasthan	420 kV	50	22	2	0	0			
22	Rajasthan	420 kV	63	2	1	0	1	9.56		
23	Rajasthan	420 kV	80	7	1	0	1	11.25		
24	Rajasthan	420 kV	125	12	1	0	1	13.00		
25	UP	420 kV	50	36	2	0	1	9.26		

26	UP	420 kV	63	11	1	0	1	9.56		
27	UP	420 kV	80	16	1	0	1	11.25		
28	UP	420 kV	125	21	2	0	1	13.00		
29	UP	220 kV	25	1	1	0	1	5.00		
30	Uttrakh and	220 kV	25	2	1	0	1	5.00		
31	Uttrakh and	420 kV	50	0	0	0	1	9.26		
32	Uttrakh and	420 kV	80	1	1	0	1	11.25		
33	Uttrakh and	420 kV	125	2	1	0	1	13.00		
Total								288.33		

Special Type of Reactors

SI . No.	Location	Voltage Rating	Capacity in MVA R	Total installed Unit	Spare required as per CERC Committee report	RPC Approved Spares	Qty Proposed for procurement	Approx Cost (Rs. In Cror e)	Availability of RPC Spare	Remarks
1	GIS Manesar	420 kV	125	2	1	0	1	14.00		HV bushings: Oil to GIS
2	GIS Baghpat	420 kV	125	1	1	0	1	14.00		
Total								28		

Grand Total: 509.07 Cr.

A.12.3 In view of the above, Powergrid has requested for approval for procurement of cold spare transformers & reactors of various ratings as per CERC committee recommendation as mentioned above. The Tariff for the investment made is to be shared by constituents as per CERC notification.

A.12.4 The cited subject matter was also discussed in the 51st TCC and 76th NRPC meeting wherein NRPC Board referred matter to OCC forum for detailed technical deliberation on this agenda.

A.12.5 In the 51st TCC and 76th NRPC meeting MS, NRPC also conveyed that the status of availability/requirements of ICTs/Reactors may be taken as agenda in the OCC meetings regularly to know the present scenario of these assets.

Members may kindly deliberate.

A.13. Review of availability for power line crossing & OPGW diamond formation by upcoming new Transmission line projects (Agenda by POWERGRID NR-1)

A.13.1. This is in reference to the NRTS Availability and the classification of outages required for power line crossings and OPGW diamond formations associated with upcoming transmission line projects. Powergrid NR-1 has mentioned that these outages are not currently being considered under the "LCSD" category (Line Shutdowns for Construction Activities of New Systems Executed by Licensee) on availability certification, which accurately reflects the purpose of these shutdowns as they support essential construction activities for new system integrations.

A.13.2. The construction of the 765kV Bhadla-2 to Sikar-2 transmission line, as approved in the 6th NCT meeting held on 30.09.2019 (MoM point no-4.3.5, pages 11-12 copy attached as **Annexure-A.VI**), is progressing steadily. Additionally, the commissioning of the Fatehgarh-2 to Bhadla-2 Circuits 3 & 4 is underway as per the approved 6th NCT scheme. Both these critical transmission lines require planned shutdowns at multiple locations where they cross existing 765kV and 400kV lines. These planned shutdowns, intended for power line crossings and OPGW diamond formations, have been discussed and formally approved in the outage meeting of OCC.

A.13.3. Powergrid NR-1 has requested that total outage period (mentioned in attached **Annexure-A.VII**) may be reviewed and considered deemed available for power line crossing & OPGW diamond formation by upcoming new Transmission line projects.

Members may kindly deliberate.

खण्ड-ख: उ.क्षे.भा.प्रे.के.

Part-B: NRLDC

B.1. NR Grid Highlights for October 2024

S.No	Constituents	Max Demand met (in MW)	Date & Time of Max Demand met	Max Consumption (in MUs)	Date of Max Consumption	Average Demand met (in Mus)
1	Chandigarh	298	01.10.24 at 19:00	6.0	31.10.24	4.7
2	Delhi	6161	03.10.24 at 15:30	128.3	31.10.24	104.8
3	Haryana	11087	04.10.24 at 19:00	235.2	31.10.24	198.8
4	H.P.	1947	25.10.24 at	36.8	31.10.24	34.4

			07:45			
5	J&K	2742	03.10.24 4 at 19:00	53.7	06.10.24	49.9
6	Punjab	14311	04.10.24 4 at 15:15	289.5	31.10.24	204.4
7	Rajasthan	16206	29.10.24 4 at 12:00	343.8	13.10.24	317.6
8	U.P	26756	04.10.24 4 at 19:20	524.5	27.10.24	459.0
9	Uttarakhand	2412	09.10.24 4 at 19:00	48.4	31.10.24	44.2
10	Northern Region	73686	04.10.24 4 at 20:00	1665.7	31.10.24	1417.8

*As per SCADA


- In Oct'24, the Maximum energy consumption of Northern Region was **1666 MUs** on 31st Oct'24 and it was 17 % higher than Oct'23 (1422 MU 10th Oct'23)
- In Oct'24, the Average energy consumption per day of Northern Region was **1418 MUs** and it was 14 % higher than Oct'23 (1248 MUs/day)
- In Oct'24, the Maximum Demand met of Northern Region was 73686 **MW** on 04th Oct'24 @20:00 hours (as per scada data) as compared to 67829 MW on 10th Oct'23 @12:47hours.

Comparison of Average Energy Consumption (MUs/Day) of NR States for the Oct'23 vs Oct'24

क्षेत्र/राज्य	अक्टूबर- 2023	अक्टूबर- 2024	% अंतर
चंडीगढ़	4.1	4.7	14.6%
दिल्ली	90.5	104.8	15.9%
हिमाचल प्रदेश	32.6	34.4	5.6%

हरियाणा	172.4	198.8	15.3%
जम्मू और कश्मीर	48.5	49.9	2.8%
पंजाब	173.9	204.4	17.6%
राजस्थान	294.5	317.6	7.8%
उत्तराखंड	40.0	44.2	10.4%
उत्तर प्रदेश	391.1	459.0	17.4%
उत्तरी क्षेत्र	1247.6	1417.8	13.6%


Energy Consumptions



Frequency profile

Month	Avg. Freq. (Hz)	Max. Freq. (Hz)	Min. Freq. (Hz)	<49.90 (% time)	49.90 – 50.05 (% time)	>50.05 (% time)
Oct'24	50.00	50.388 (25.10.24 at 13:03:30 hrs)	49.585 (16.10.24 at 17:58:20 hrs)	4.9	80.3	14.8
Oct'23	49.99	50.30 27.10.23 at 16:03:50 hrs	49.47 16.10.23 at 14:56:40 hrs	8.9	74.4	16.7

Reservoir Level and Generation on Last Day of Month



Reservoir Level comparison w.r.t. last year as on 31.10.2024:

RESERVOIR	Parameters			Present Parameters		LAST YEAR	
	MDDL (Mts)	FRL (Mts)	Energy Content at FRL	Level (Mts)	Energy (MU)	Level (Mts)	Energy (MU)
Bhakra	445.62	513.59	1,728.8	499.18	1,065	506.14	1,367
Chamera-I	748.75	760	753.95	758.7	2	-	-
Gandhisagar	381	399.9	725	-	-	-	-
Jawahar Sagar	295.96	298.7	2.01	-	-	-	-
Koteswar	598.5	612.5	610.73	611.65	5	611.78	5
Pong	384.05	426.72	1,084	411.83	556	420.02	889
RPS	343.81	352.81	175.66	-	-	-	-
RSD	487.91	527.91	390.3	501.27	113	514.15	259
Rihand	252.98	268.22	860.5	263.93	540	259.32	268
Tehri	740.04	830	1,164.11	827.99	1,122	824.89	1,057
TOTAL	-	-	-	-	3,403	-	3,845

Detailed presentation on grid highlights of Oct'2024 will be shared by NRLDC in OCC meeting.

B.2. Demand forecasting and resource adequacy related

Hon'ble CERC In the matter of Planning for safe, secure, and reliable integrated operation of the power system during critical periods arising on account of seasonal variations wherein the electricity demand increases rapidly by undertaking specific measures to mitigate the risks on the power system, under clause (h) of sub-section (1) of Section 79 of the Electricity Act, 2003 and the Regulation 31 of the Central Electricity Regulatory Commission (Indian Electricity Grid Code) Regulations, 2023 has issued suo-motto order 9/SM/2024 dated 07.10.2024. Order is available at **Annexure-B.I.**

Commission has issued the following directions to NLDC, RLDCs, and SLDCs in connection with the implementation of Regulations 31 and 33 of the Grid Code to

address the anticipated surge in demand of electricity during October 2024 on account of seasonal variations:

- a) All the State Load Despatch Centres and RLDCs shall furnish the details of operational planning undertaken by them in terms of Regulation 31(4) (a) of the Grid Code especially for October 2024. RLDC shall validate the adequacy of resources in terms of Regulation 31(4)(b) of the Grid Code.
- b) All State Load Despatch Centres and Regional Load Despatch Centres shall prepare the worst-case scenario due to possible surge in demand during the period 1.10.2024 to 31.10.2024 in their respective control area and submit within seven days to the Commission with a copy to National Load Despatch Centre.
- c) The State Load Despatch Centres or Regional Load Despatch Centres, as the case may be, should assess their demand-generation scenario in the upcoming months, ensure the optimum generation, avoid undesirable planned outages, and advise the generating company to offer their availability. The State Load Despatch Centre or Regional Load Despatch Centre shall ensure the optimum scheduling during the shortage period and surplus power to get despatched during the deficit period.
- d) The Distribution Companies, in case of a shortage scenario, can procure the power from surplus or requisitioned capacity of other states so that optimum despatch can be ensured for safe and reliable power system operations. The State Load Despatch Centre shall monitor the generation-demand deficit of the respective distribution companies.
- e) The generating companies operating their plant with capacity less than its installed capacity due to technical issues, i.e., capacity under partial outage or forced outage, are advised to fix the issues to ensure the maximum generation capacity on-bar.
- f) The draw schedule of the respective control area needs to adhere to prevent the reduction of system frequency. The State Load Despatch Centre or Regional Load Despatch Centre, as the case may be, shall monitor the deviation of the key system parameters.
- g) The State Load Despatch Centres or Regional Load Despatch Centres, as the case may be, shall issue the system alerts to their respective grid-connected entities for the possible deficit during the likely surge in demand

The Regional Load Despatch Centres and State Load Despatch Centres shall submit the report on the implementation of the above measures, a load-generation scenario in their respective control areas, and any other measures taken to address the deficit of power supply during the period 1.10.2024 to 31.10.2024.

NLDC, RLDCs, and SLDCs were directed to submit their responses to the measures contained in para 9 of this order by 16.10.2024.

As per the information available with NRLDC, only HP & Uttarakhand have submitted their formal reply to CERC.

Punjab and J&K have shared some information with NRLDC, but formal communication to CERC from their side is yet to be done.

Whereas other states have neither submitted their response to CERC nor NRLDC with regard to order 9/SM/2024 dated 07.10.2024.

It is requested that Delhi, UP, Haryana, Rajasthan and Chandigarh may provide update in this regard. Punjab and J&K are also requested to provide update whether they have submitted the information to CERC.

With reference to the Clause 31(2) of Central Electricity Regulatory Commission-IEGC Regulations, 2023 and the Operating Procedure of NRLDC prepared in accordance with the same, each SLDC has to furnish the demand estimation for day ahead, week ahead, month ahead (with time block wise granularity) and demand estimation for year ahead (with hour granularity). The sub-clause 31(2) (h) of IEGC-2023 states the following timeline for the submission of demand estimate data to RLDC.

Type of Demand Estimation	Timeline
Daily	10:00 hours of previous day
Weekly	First working day of previous week
Monthly	Fifth day of previous month
Yearly	30th September of previous year

Status of Day Ahead Forecasting & generation adequacy submission status for October-2024 as per Clause 31(4) (a) & (b) of IEGC-2023 is shown below:

S.no	State	01-Oct	02-Oct	03-Oct	04-Oct	05-Oct	06-Oct	07-Oct	08-Oct	09-Oct	10-Oct	11-Oct	12-Oct	13-Oct	14-Oct	15-Oct	16-Oct	17-Oct	18-Oct	19-Oct	20-Oct	21-Oct	22-Oct	23-Oct	24-Oct	25-Oct	26-Oct	27-Oct	28-Oct	29-Oct	30-Oct	31-Oct			
1	JK & Ladakh(UT)	N	N	N	N	N	N	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	N		
2	Punjab	Y	N	N	N	N	N	Y	Y	Y	Y	Y	N	N	N	N	N	N	N	N	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
3	UP	Y	N	Y	Y	Y	N	Y	Y	Y	Y	N	N	N	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
4	Uttarakhand	Y	Y	Y	Y	Y	N	Y	Y	Y	Y	N	N	N	Y	Y	Y	Y	Y	N	Y	Y	Y	N	Y	Y	Y	Y	N	Y	Y	N	N	N	
5	Chandigarh	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	
6	Rajasthan	Y	N	Y	N	N	Y	N	Y	N	N	N	N	N	N	N	N	N	N	Y	N	Y	N	N	Y	Y	Y	Y	N	N	N	N	N	N	N
7	Delhi	N	Y	N	N	Y	Y	Y	Y	N	Y	Y	Y	N	N	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
8	Haryana	N	N	Y	N	Y	Y	N	N	Y	N	N	Y	N	Y	Y	Y	Y	Y	Y	Y	Y	N	Y	N	Y	N	Y	Y	Y	Y	N	Y	Y	Y
9	HP	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	N	Y	Y	Y	Y	Y	Y	Y	Y	Y

Status of Week Ahead Forecasting data Submission status for the month of October 2024 is shown below:

S.no	State	07-10-2024 to 13-10-2024	14-10-2024 to 20-10-2024	21-10-2024 to 27-10-2024	28-10-2024 to 03-11-2024	04-11-2024 to 10-11-2024
1	JK & Ladakh(UT)	N	N	N	N	N
2	Punjab	N	N	N	N	N
3	UP	N	N	N	Y	Y
4	Uttarakhand	N	N	N	N	N
5	Chandigarh	N	N	N	N	N
6	Rajasthan	N	N	N	N	N
7	Delhi	N	N	N	N	N
8	Haryana	N	N	N	N	N
9	HP	Y	Y	Y	Y	Y

Status of Month Ahead (October'2024) and Year Ahead Demand forecasting submission status:

Region	State		
		Monthly	Yearly
		Data submission	Data submission
		(Y/N)	(Y/N)
NR	Punjab	N	N
	Haryana	N	N
	Rajasthan	N	N
	Delhi	N	Y
	UP	Y	Y
	Uttarakhand	N	N
	HP	Y	Y
	J&K	N	N
	Chandigarh	N	N
	Railways_NR	N	N

In accordance with above, all SLDCs are requested to timely furnish the demand estimation data along with generation adequacy data as per the formats available at https://drive.google.com/drive/folders/1KWY4G9gTBLV5wTJkhGEleRptKP-QbhjL?usp=drive_link to NRLDC through mail (nrldcmis@grid-india.in) and FTP as per above timeline.

The relevant clauses from IEGC 2023 related to demand forecasting exercise and resource adequacy exercise are tabulated below:

Clause No.	Responsible Entity	Compliance Assignment
5.2(i)	Each distribution licensee within a State	Estimate the demand in its control area including the demand of open access consumers and factoring in captive generating plants, energy efficiency measures, distributed generation, demand response, in

		different time horizons, namely long-term, medium term and short-term.
5.2(ii)	STU (on behalf of distribution licensee)/other designated agency	Estimate the demand for the entire State duly considering the diversity in different time horizons, namely long-term, medium term and short-term.
5.3(a)	Each distribution licensee	(i) assess the existing generation resources and identify the additional generation resource requirement to meet the estimated demand in different time horizons, (ii) prepare generation resource procurement plan.
5.3(c)	Each distribution licensee	Generation resource procurement planning (specifying procurement from resources under State control area and regional control area) shall be undertaken in different time horizons, namely long-term, medium term and short-term to ensure (i) adequacy of generation resources and (ii) planning reserve margin (PRM) taking into account loss of load probability and energy not served as specified by CEA.
5.3(d)	STU (on behalf of distribution licensee)/other designated agency	STU or other designated agency by state commission shall provide to NLDC, •the details regarding demand forecasting, •assessment of existing generation resources •such other details as may be required for carrying out a national level simulation for generation resource adequacy for States.
5.3(e)	NLDC	Based on the information received, NLDC shall carry out a simulation to assist the States in drawing their optimal generation resource adequacy plan.
5.3(f)	Each distribution licensee	Each distribution licensee shall ensure demonstrable generation resource adequacy for such period as specified by the respective SERC
31.1(a)	NLDC/RLDC/SLDC	Operational planning in advance by NLDC, RLDCs and SLDCs within their respective control areas: Monthly and Yearly time horizons in co-ordination with CTU, RPCs or STUs, as applicable.
31.1(b)	NLDC/RLDC/SLDC	Operational planning shall be carried out in advance by NLDC, RLDCs and SLDCs within their respective control areas on Intra-day, Day Ahead, Weekly time horizons.
31.1(c)	NLDC/RLDC	Procedure and data format by NLDC/RLDC for following activity •Operational planning analysis •Real-time monitoring, •Real-time assessments. Format is available at https://posoco.in/wp-

		content/uploads/2024/03/Final-NLDC-Operating-Procedure_as-submitted-to-CERC-dated-290923.pdf
31.1(d)	SLDC	SLDC may also issue procedures and formats for data collection for the above purposes.
31.2(a)	SLDC	Each SLDC shall carry out demand estimation (active & reactive) as part of operational planning after duly factoring in the demand estimation done by STU as part of resource adequacy planning referred to in Chapter 2 of these regulations.
31.2(b)	SLDC	Each SLDC shall develop methodology for daily, weekly, monthly, yearly demand estimation in MW and MWh for operational analysis as well as resource adequacy purposes
31.2(c)	SLDC	The demand estimation by each SLDC shall be done on day ahead basis with time block wise granularity for the daily operation and scheduling . Revision in real-time demand estimate by SLDC if major change is observed and sharing with RLDC
31.2(d)	SLDC	Each SLDC shall submit node-wise morning peak, evening peak, day shoulder and night off-peak estimated demand in MW and MVA on a monthly and quarterly basis for the nodes 110 kV and above
31.2(e)	SLDC	SLDC shall also estimate peak and off-peak demand (active as well as reactive power) on a weekly and monthly basis for load - generation balance planning as well as for operational planning analysis
31.2(f)	ISTS connected bulk consumers or distribution licensees	The entities such as bulk consumers or distribution licensees that are directly connected to ISTS shall estimate and furnish such a demand estimate to the concerned RLDC
31.2(g)	RLDC/NLDC	Based on the demand estimate furnished by the SLDCs and other entities directly connected to ISTS, each RLDC shall prepare the regional demand estimate and submit it to the NLDC. NLDC, based on regional demand estimates furnished by RLDCs, shall prepare national demand estimate
31.2(h)	SLDC	Submission of demand estimate data by SLDCs or other entities directly connected to ISTS, as applicable, to the respective RLDC and RPC as per below timeline : - Daily: 10:00 hrs of previous day - Weekly: First workinh day of previus week - Monthly: Fifth day of previous month - Yearly: 30th September of the previous year
31.2(i)	SLDC/RLDC/NLDC	Compute forecasting error for intra-day, dayahead, weekly, monthly and yearly forecasts and analyse the same in order to

		reduce forecasting error in the future. The computed forecasting errors shall be made available by SLDCs, RLDCs and NLDC on their respective websites.
31.3(a)	SLDC	The generation estimation by each SLDC shall be done on day ahead basis with time block wise granularity for the daily operation and scheduling . Revision in real-time generation estimate by SLDC if major change is observed and sharing with RLDC
31.3(b)	RLDC	RLDC shall forecast generation from wind, solar, ESS and Renewable Energy hybrid generating stations that are regional entities and SLDC shall forecast generation from such sources that are intra-state entities, for different time horizons as referred to in clause (1) of Regulation 31 of these regulations for the purpose of operational planning
31.4(a)	SLDC	SLDCs estimate and ensure the adequacy of resources, identify generation reserves, demand response capacity and generation flexibility requirements with due regard to the resource adequacy framework as specified under Chapter 2 of these regulations
31.4(b)	SLDC	Furnishing time block-wise information for the following day in SLDC respect of all intra-state entities to the concerned RLDC who shall validate the adequacy of resources with due regard to the following: (i) Demand forecast aggregated for the control area; (ii) Renewable energy generation forecast for the control area; (iii) Injection schedule for intra-State entity generating station; (iv) Requisition from regional entity generating stations (v) Secondary and planned procurement through Tertiary reserve requirement; (vi) Planned procurement of power through other bilateral or collective transactions, if any.
33.1	NLDC, RLDC, SLDC & (RPC: Monthly & Yearly)	Based on the operational planning analysis data, operational planning study shall be carried out by various agencies for time horizons such as Real time, Intra Day , Weekly , Monthly & Yearly
33.2	SLDC, RLDCs and NLDC	SLDCs, RLDCs and NLDC shall utilize network estimation tool integrated in their EMS and SCADA systems for the real time operational planning study.
33.3	SLDC	SLDCs shall perform day-ahead, weekly, monthly and yearly operational studies for the

		concerned State for: (a) assessment and declaration of total transfer capability (TTC) and available transfer capability (ATC) for the import or export of electricity by the State. TTC and ATC shall be revised from time to time based on the commissioning of new elements and other grid conditions and shall be published on SLDC website with all the assumptions and limiting constraints; (b) planned outage assessment; (c) special scenario assessment; (d) system protection scheme assessment; (e) natural disaster assessment; and (f) any other study relevant in operational scenario.
33.4	RLDCs and NLDC	RLDCs and NLDC shall perform day-ahead, weekly, monthly and yearly operational studies for: (a) assessment of TTC and ATC at inter-regional, intra-regional, and inter-state levels; (b) planned outage assessment; (c) special scenario assessment; (d) system protection scheme assessment; (e) natural disaster assessment; and (f) any other study relevant to operational scenarios
33.5	RLDCs	RLDC shall assess intra-regional and inter-state level TTC and ATC and submit them to NLDC. NLDC shall declare TTC and ATC for import or export of electricity between regions including simultaneous import or export capability for a region, and crossborder interconnections 11 (Eleven) months in advance for each month on a rolling basis.
33.6	RLDCs	Operational planning study shall be done to assess whether the planned operations shall result in deviations from any of the system operational limits defined under these regulations and applicable CEA Standards. The deviations, if any, shall be reviewed in the monthly operational meeting of RPC and significant deviations shall be monitored by RPC for early resolution.
33.7	NLDC, RLDCs, RPCs and SLDCs	NLDC, RLDCs, RPCs and SLDCs shall maintain records of the completed operational planning study, including date specific power flow study results, the operational plan and minutes of meetings on operational study.
33.8	NLDC, RLDCs, RPCs and SLDCs	NLDC, RLDCs, RPCs and SLDCs shall have operating plans to address potential deviations from system operational limit identified as a result of the operational planning study.
33.9	SLDCs	Each SLDC shall undertake a study on the

		impact of new elements to be commissioned in the intra-state system in the next six (6) months on the TTC and ATC for the State and share the results of the studies with RLDC
33.10	RLDCs	Each RLDC shall undertake a study on the impact of new elements to be commissioned in the next six (6) months in (a) the ISTS of the region and (b) the intrastate system on the inter-state system and share the results of the studies with NLDC
33.11	NLDC	NLDC shall undertake study on the impact of new elements to be commissioned in the next six (6) months in (a) inter-regional system, (b) cross-border link and (c) intraregional system on the inter-regional system.
33.12	NLDC, RLDCs and SLDCs	NLDC, RLDCs and SLDCs shall compare the results of the studies of the impact of new elements on the system and transfer capability addition with those of the interconnection and planning studies by CTU and STUs
33.13	concerned user or SLDC or RLDC or NLDC	Defense mechanisms like system protection scheme, load-rejection scheme, generation run-back, islanding scheme or any other scheme for system security shall be proposed by the concerned user or SLDC or RLDC or NLDC and shall be deployed as finalized by the respective RPC

All SLDCs need to take actions at their end for timely submission of demand forecasting and resource adequacy data on day-ahead, week-ahead, month ahead and year ahead basis. It is also requested to share actions being taken at your end to ensure compliance of above listed clauses of IEGC 2023.

Members may please discuss.

B.3. Critical operation of Rajasthan Grid during upcoming winter season:

Issues related to grid operation in Rajasthan state control area have been highlighted from NRLDC side in last several OCC/TCC/NRPC meetings. It is to be noted that such issues get aggravated during winter months when agricultural demand in state is on the higher side. Several issues were encountered in Rajasthan control area during last winter season. Issues were discussed in detail in 224 OCC meeting held on 18.10.2024 and separate meeting organised on 19.10.2024. Some of the actions that were agreed are listed below:

1. SLDC to take up the matter with DISCOMs for shifting of non-essential demand being provided in day-time till transmission network capacity augmentation takes place

2. Additional ICT at Hindaun 400 KV to be commissioned in December 2024. Voltage will improve but not much considering voltages are reaching critical low of approx. 300 KV.
3. As Dholpur Gas plant has also been run in the recent past and significant improvement in Voltages and grid parameters have been observed, RVUNL to ensure the running of Dholpur units as ultimate solution in present condition.
4. RE plants installed in state control area should also provide MVAR support to RE plants as per the CEA standards as being implemented in ISGS RE plants.
5. For safely meeting 18000 MW load of Rajasthan with voltage in IEGC band, 4000 MVAR support additionally is required. After installing 2500 MVAR of capacitor banks in the study files the base case is converging with voltages at low of 360 KV at 400 KV sub-stations being observed. The base cases were simulated using the real time data. Hence, there was urgent requirement of installation of capacitor banks to prevent system collapse.
6. DISCOMs are requested to approach MoP with complete proposal for installation of Capacitor banks through RDSS fund. It was also stated that the detailed proposal was already made for all the 04 power companies of Rajasthan when funding through PSDF fund was envisaged earlier.
7. It was again reiterated that low voltages in Rajasthan network was a major area of concern it has to be flagged at the highest level. If PSDF/RDSS fund is not available, funding through other routes/schemes to be taken up for installation of Capacitor banks.
8. Expediting capacity augmentation at substations and coordinate with PGCIL/CTU to ensure N-1 compliance to prevent major grid disturbances.

Location wise constraints presented by NRLDC representative and RRVPNL Comments is summarised as below:

C

Name of Substation	MVA Capacity	Total Loading (MW) (variations throughout day during Dec'23- Jan'24)	SPS Status as available with NRLDC	RRVNL comment in the meeting
Bhiwadi(PG)	3*315=945	300-700	Not implemented	
Neemrana(PG)	315+500=815	200-450	Not implemented	
Bassi(PG)	2*315+500=1130	300-1000	Not implemented	
Sikar(PG)	2*315+500=1130	150-750	Not implemented	
Jaipur South(PG)	2*500=1000	150-650	Not implemented	
Kankroli(PG)	3*315=945	250-650	Not implemented	
Kotputli(PG)	2*315=630	150-500	Not implemented	
Hindaun (RVPN)	2*315 =630	250-550	Implemented	Additional ICT to be commissioned by Nov'24
Chittorgarh (RVPN)	3*315 =945	200-700	Implemented	SPS is under revision. 4th ICT is proposed
Ajmer (RVPN)	2*315 =630	200-600	Implemented	Additional 500 MVA ICT to be commissioned by 06.09.2025
Merta (RVPN)	2*315 =630	250-550	Implemented	
Bikaner (RVPN)	2*315 =630	100-550	Implemented	
Jodhpur (RVPN)	2*315 =630	200-500	Implemented	
Heerapura(RVPN)	3*250+315=1065	300-900	Not implemented	3rd ICT by 12.09.2025 SPS to be proposed. Additional ICT is proposed.
Bhilwara (RVPN)	1*500+1*315 =815	300-550	Under Implementation	SPS implemented, additional ICT proposed
Ratangarh(RVPN)	3*315=945	300-750	Implemented	4th ICT proposed
Deedwana(RVPN)	2*315=630	150-500	Not implemented	Under study presently no SPS proposed
Suratgarh(RVPN)	2*315=630	100-500	Implemented	Space constraint

CTUIL/RRVNL is requested to provide update regarding ICT capacity augmentation at 400/220kV POWERGRID substations:

- (i) 400/220kV Neemrana
- (ii) 400/220kV Sikar
- (iii) 400/220kV Jaipur South
- (iv) 400/220kV Kotputli

It is to be noted that new 500MVA ICT capacity augmentation has already been approved for 400/220kV Bhiwadi, 400/220kV Bassi and 400/220kV Kankroli substations and under implementation.

Rajasthan SLDC and RRVNL(STU) are requested to provide update on all the above points.

B.4. Mock testing of islanding scheme and simulation studies

Following four islanding schemes are operational in the Northern Region: NAPP Islanding Scheme (Uttar Pradesh), RAPP Islanding Scheme (Rajasthan), Bawana Islanding Scheme (Delhi), and Pathankot-RSD Islanding Scheme (Punjab). As per the SOP for mock islanding schemes approved in the recently concluded OCC 223, SLDCs are requested to prepare and share their plans for conducting mock testing of islanding schemes in their control areas.

None of the four utilities have yet created a SCADA network map for their island areas. However, Uttar Pradesh and Rajasthan have developed SCADA displays with partial island summaries, although telemetry issues still need resolution.

RAPP A & B ISLANDING SCHEME (RAJASTHAN)

13.9.24 11:3:17

INSTANTANEOUS FREQ. 50.06 HZ				ISLANDING FREQ. 50.06 HZ	
NAME OF FEEDER	LOAD	STATUS (Up/Down)	STATUS (Up/Down)	RAAPP-A GENERATION	RAAPP-B GENERATION
RAAPP-A Gen					
220 KV RAPP A (SUT)	72	BLOCKED	0		183
220 KV RAPP A (SUT)	1	OPERATIVE	0		
220 KV RAPP A (SUT)	1	OPERATIVE	0		
220 KV RAPP A (SUT)	14	BLOCKED	0		
RAAPP-B Gen					
220 KV RAPP B (SUT)	5	OPERATIVE	0		
220 KV RAPP B (SUT)	0	BLOCKED	0		
220 KV RAPP B (SUT)	25	BLOCKED	0		
				TOTAL GENERATION	170
				TOTAL BLOCKED/ISLANDED LOAD	0
				TOTAL OPERATIVE LOAD	0

RAJWEST (JSW) ISLANDING SCHEME (RAJASTHAN)

13.9.24 11:8:49

INSTANTANEOUS FREQ. 50.04 HZ				ISLANDING FREQ. 50.04 HZ	
NAME OF FEEDER	LOAD	STATUS (Up/Down)	STATUS (Up/Down)	TOTAL GENERATION	EX BUS GENERATION
ARVEST BARBER	313	BLOCKED			
ARVEST KODPAR	368	BLOCKED			
ARVEST KANWAR	335	BLOCKED			
ARVEST BARBER	77	BLOCKED			
ARVEST SHAKURBHANA		BLOCKED			
ARVEST JASALMER	412	OPERATIVE			
ARVEST JASALMER (SUT)	20	OPERATIVE			
ARVEST SIMBOLI		OPERATIVE			
ARVEST SHAKURBHANA	82	BLOCKED			
				TOTAL GENERATION	632
				EX BUS GENERATION	567
				TOTAL BLOCKED/ISLANDED LOAD	0
				TOTAL OPERATIVE LOAD	196

STPS ISLANDING SCHEME (RAJASTHAN)

13.9.24 11:9:29

NEOUS FREQ. 50.04 HZ				ISLANDING FREQ. 50.04 HZ	
NAME OF FEEDER	LOAD	STATUS (Up/Down)	STATUS (Up/Down)	TOTAL GENERATION	EX BUS GENERATION
KANER	54	OPERATIVE			
SHANER	138	OPERATIVE			
SONA	108	BLOCKED			
SHANGARH	299	OPERATIVE			
SPSI	654	OPERATIVE			
JHU	15	BLOCKED			
JHU	136	BLOCKED			
				TOTAL GENERATION	1543
				EX BUS GENERATION	1398
				TOTAL BLOCKED/ISLANDED LOAD	0
				TOTAL OPERATIVE LOAD	499

NAPS ISLANDING LOAD DISPLAY

FREQUENCY (HZ) 50.06 HZ 13.9.24 11:1:17

NAME OF SUBSTATION	ELEMENT NAME	LOADING	
		WHEN ONE MACHINE IS RUNNING	WHEN BOTH THE MACHINES ARE RUNNING
220KV NAPP	SUT-1	11.23	11.23
	SUT-2	9.43	9.43
	6.3 MVA ICT-1	0.02	0.02
220KV SIMBOLI	6.3 MVA ICT-2		
	40 MVA ICT-3	3.17	3.17
	132KV GARHMUKTESHWAR	-0.00	-0.00
	132KV SUGAR MILL	1.48	1.48
220KV KHURJA	332 KV ANOOPSHAHAR	N / APP	6.66
	332 KV KHURJA-II	N / APP	0.00
	6.3 MVA ICT-1	N / APP	9.85
	40 MVA ICT-2	N / APP	9.23
	40 MVA ICT-3	N / APP	10.12
TOTAL LOAD		37.99	104.6
RANGE OF REQUIRED LOAD		70-90 MW	150-280 MW

220KV NAPP-GENERATION		
UNIT-I	GENERATION(MW)	G/L RATIO(%)
UNIT-I	199.1	5.26
UNIT-II	9.43	4.47
TOTAL	407.5	3.82

Erroneous values

Rajasthan SLDC was asked to include G/L ratio of island in their displays and also check for missing load values so that correct total island load data is available.

During 224 OCC meeting, NRLDC representative mentioned that only the NAPS Islanding Scheme of UP has incorporated the G/L ratio in its SCADA display according to the shared format. UP representative added that due to a recent fire incident at Khurja S/S, the telemetry from the 220kV Khurja S/S is currently unavailable, and they promised to share an update on the restoration of telemetry from Khurja as soon as possible.

NRLDC representative also requested that all concerned utilities provide updated islanding base cases for different load-generation balance scenarios (Summer: Peak/Off-peak and Winter: Peak/Off-peak) along with dynamic data of the generators in the island for conducting dynamic simulation studies. He reiterated that the Islanding SCADA display should be made available at NRLDC as per the format shared in previous OCC meetings.

UP, Rajasthan, Punjab and Delhi SLDC are requested to provide update.

B.5. Winter preparedness 2024-25

Winter in Northern region is likely to start from mid of October till February end, and the challenges faced during these months are well known to all the utilities. During winter,

demand of NR states except Rajasthan and hilly states is on the lower side. With decreasing temperatures and festivals, onset of winter also brings some severe challenges to NR grid operators. Moreover, there is possibility for severe winter during this season due to the impact of LA-NINA. IMD in their press release dated 05.09.2024, Extended range Forecast for next two weeks (5- 18 Sept, 2024) mentioned that “*The latest MMCFS forecast indicates higher likelihood of La Niña conditions are likely to develop during end of monsoon season*”. Accordingly, number of measures were discussed and implemented for better grid operation during winter months:

Based on the detailed discussion held in last OCC meeting, following actions were suggested:

- Transmission utilities to prepare plan for measures to be taken by them for carrying out pre-winter maintenance activities. It was agreed that same may be shared by utilities via mail with NRPC/NRLDC before next OCC meeting. Plan has been received from POWERGRID NR-2.
- To carry out tap change exercise at 220kV and below voltage level. NRLDC will also be studying voltage profile of 400/220kV substations in NR for the month of Oct 2024. Accordingly, tap changes at following 400/220kV substations are being proposed based on present tap positions, study at NRLDC end and previous year experiences:
 - (i) 400/220kV Bhiwani PG) (increase by 2 steps)
 - (ii) 400/220kV Sonapat PG) (increase by 2 steps)
 - (iii) 400/220kV Dehar (BBMB) (increase by 2 steps)
 - (iv) 400/220kV Daultabad (increase by 2 steps)
 - (v) 400/220kV Bamnauli (increase by 2 steps)
 - (vi) 400/220kV Allahabad(PG) (reduction by 2 steps)
 - (vii) 400/220kV Amritsar(PG) (reduction by 1 step)
 - (viii) 400/220kV Jalandhar(PG) (reduction by 1 step)
 - (ix) 400/220kV Kaithal(PG) (reduction by 1 step)
- With low temperature across Northern region and with high humidity in the air, fog starts to appear across the Northern region. This problem is generally most severe from 15Dec- 15Feb period & more prominent in areas having high pollution. During this time, additional care need to be taken by system operator as many multiple element tripping events have been reported in the past especially in Punjab, Rajasthan, Haryana and Eastern UP. Such tripping are more severe if the lines are tripping from generation complex.

To furnish details of Progress on cleaning and replacement of porcelain insulator with polymer insulator. NRLDC has already requested vide emails dated 26.09.2024, 30.09.2024 & 07.11.2024, all transmission utilities to furnish the utility-wise latest status of the replacement of porcelain insulators with polymer insulators so that crucial lines for which such works are pending may be identified & prioritized. List is also attached as **Annexure-B.II** of agenda.

List of line that reported tripping on 4 or more instances last year during Dec-Jan months during fog-prone time of 21:00-10:00hrs along with their insulator status is shown below:

S. No.	Line Name	Tripping instances	Owner	Insulator status
1	220 KV RAPS_A(NP)-Sakatpura(RS) Ckt-2	12	RRVNL	N/A
2	220 KV RAPS_B(NP)-Sakatpura(RS) Ckt-1	10	RRVNL	N/A
3	220 KV RAPS_A(NP)-Sakatpura(RS) Ckt-1	9	RRVNL	N/A
4	400 KV Agra-Unnao Ckt-1	8	UPPTCL	Partial polymer (25%)
5	220 KV Debari(RS)-RAPS_A(NP) Ckt-1	6	RRVNL	N/A
6	220 KV Nara(UP)-Roorkee(UK) Ckt-1	5	UPPTCL	N/A
7	220 KV Ratangarh(RS)-Sikar(PG) Ckt-1	5	POWERGRID	N/A
8	220 KV Panipat(BB)-Chajpur(HV) Ckt-2	5	HVNL	N/A
9	400 KV Muktsar-Makhu Ckt-2	5	PSTCL	Porcelain
10	400 KV Suratgarh(RVUN)-Ratangarh(RS) Ckt-1	4	RRVNL	Porcelain
11	220 KV Shahjahanpur(PG)-Lakhimpur(Gola) Ckt-2	4	UPPTCL	N/A
12	220 KV Ratangarh(RS)-Sikar(PG) Ckt-2	4	POWERGRID	N/A
13	400 KV Shree Cement(SCL)-Kota(PG) Ckt-1	4	POWERGRID	Polymer
14	400 KV Muradnagar_2-Mathura Ckt-1	4	UPPTCL	N/A

- To ensure that all over flux setting of transformers and overvoltage settings of transmission lines are as per approved protection philosophy of NRPC.

On number of occasions, it is seen that utilities are correcting their protection settings after tripping events. It is important all the protection settings are as approved by NRPC. Utilities are requested to confirm the same from field and ensure that protection settings are only as approved by NRPC.

- OCC expressed concern on the lack of progress of DTL reactors and asked them to expedite their works. Status of reactors under commissioning in Delhi control area in Northern region as per discussion in 223 OCC MoM is shown below:

Substation	Reactor	Status as per 222 OCC MoM
Mundka	1x125 MVAR at 400 kV & 1x25 MVAR at 220 kV	Bay work completed on 25.03.2023. Reactor part tender is dropped and at present same is under revision.
Bamnauli	2x25 MVAR at 220 kV	Bay work completed on 25.03.2023. Reactor part tender is dropped and at present same is under revision.
Electric Lane	1x50 MVAR at 220 kV	Under Re-tendering due to Single Bid
Indraprastha	2x25 MVAR at 220 kV	Bay work completed on 07.11.2023. Reactor part tender is dropped and at present same is under revision.

NRLDC representative also presented the voltage profile of these substations for last winter season in the meeting and emphasized on urgent requirement of these reactors. It is requested to expedite the commissioning of these reactors apart from the measures listed above.

- Some of the generators have already been tested (Tehri, Chamera, Pong, RSD etc.) and shall be available for condenser mode of operation as and when required. States/SLDCs are also advised to explore synchronous condenser operation of Hydro & Gas units in their state control area. It is requested that all other utilities may explore possibility of running units as synchronous condenser. Since reactive energy charges are now payable to generators also therefore, it would also be providing them financial support in case units are supporting through synchronous condenser mode of operation.

During 224 OCC meeting,

NHPC representative agreed to make Chamera-II available to operate as a synchronous condenser this winter season, as needed for grid stability. He noted that the unit had not been run as a synchronous condenser since 2018 due to maintenance issues, which have now been addressed.

Punjab representative informed the forum that currently only one machine at RSD can operate as a synchronous condenser. For the other three machines, they have engaged ABB to install additional equipment to enable synchronous condenser functionality.

The BBMB representative mentioned that they would provide an update on their synchronous condenser capabilities to the forum shortly.

- Utilities to submit feedback on NRLDC reactive power document including for line reactors which can be used as bus reactors as per requirement.


Ramping support requirement from states during winter season:

Off-peak to peak demand ratio of NR falls to around 0.5 to 0.6 during winter, morning and evening load ramp is quite steep together with limited hydro resources etc. This increases the importance of Portfolio management as per load forecast especially during high ramp up and ramp down periods.

Generation planning becomes very important especially with the in-surge of renewable integration with the grid, generation resources should be optimally planned, taking care to maintain adequate reserves.


Hydro generation resource which becomes all the more important due to ramping requirement; it starts depleting due to limited inflow of water (most of the hydro stations of NR are snow fed). With increasing solar generation during the day-time, the ramping requirements during evening hours are rising and posing serious challenge to the system operators to maintain frequency within the band.

Demand pattern for last 3 days (05.11.2024, 06.11.2024, 07.11.2024) is shown below:




As can be seen there is high ramp in demand during 0400-0800 hrs and also during 1700-1830 hrs. It is requested that all intrastate generating resources are also scheduled optimally to support this ramp in demand.

Further, from demand pattern of Haryana for last few days it is seen that there is sudden decline in demand at 06:00hrs. Haryana SLDC is requested to provide the reasons for the same.



Further from the demand pattern of UP state it is seen that there is sharp rise in demand from 1700-1830 hrs. This rise of 4000MW in demand is observed when the solar generation in the grid is declining. This is leading to extra pressure on the grid resources to meet this ramp in demand.



Utilities are requested to prepare plan for measures to be taken by them for carrying out pre-winter maintenance activities. Same may be shared by utilities via mail with NRPC/NRLDC before OCC meeting. Members may please discuss.

B.6. Reactive power performance of generators

During winter season, demand of Northern region is low and high voltages are a common phenomenon predominantly in Punjab, Haryana and Delhi area. Even after several actions being taken by control centers, it is seen that there is persistent high voltage in Northern region. The reactive power absorption by generators becomes an important resource that helps in managing high voltages in the grid. However, even after continuous follow up in OCC meetings, it is seen that MVAR data telemetry is poor/ inaccurate from most of the generating stations. For some of the generators it is seen that there is inadequate reactive power absorption based on their capability curve especially during night hours. The performance of generators in absorption of reactive power for last 7 days (01 Nov 2024 – 07 Nov 2024) is shown below:

S.No.	Station	Unit No.	Capacity	Geographical location	MVAR capacity as per capability curve (on LV side)	MVAR performance (-) Absorption (+) Generation (HV side data)	Voltage absorption above (in KV)
1	Dadri NTPC	1	490	Delhi-NCR	-147 to 294	-150 to 110	Data freeze
		2	490		-147 to 294	-150 to 110	
2	Singrauli NTPC	1	200	UP	-60 to 120	0 to 20	404
		2	200		-60 to 120	0 to 20	402
		3	200		-60 to 120	-5 to 20	402
		4	200		-60 to 120	-25 to 0	394
		5	200		-60 to 120	-10 to 5	398
		6	500		-150 to 300	5 to 50	404
		7	500		-150 to	10 to 40	402

					300		
3	Rihand NTPC	1	500	UP	-150 to 300	-50 to 0	394
		2	500		-150 to 300	-20 to 20	396
		3	500		-150 to 300	-50 to 0	394
		4	500		-150 to 300	-60 to -10	394
4	Kalisindh RS	1	600	Rajasthan	-180 to 360	-	-
		2	600		-180 to 360	-150 to 50	400
5	Anpara C UP	1	600	UP	-180 to 360	-110 to 0	770
		2	600		-180 to 360	-120 to -20	768
6	Talwandi Saboo PB	1	660	Punjab	-198 to 396	-200 to 0	410
		2	660		-198 to 396	-200 to 0	410
		3	660		-198 to 396	-	-
7	Kawai RS	1	660	Rajasthan	-198 to 396	-100 to 50	402
		2	660		-198 to 396	-70 to 20	404
8	IGSTPP Jhajjar	1	500	Haryana	-150 to 300	-80 to 50	410
		2	500		-150 to 300	-90 to 150	412
		3	500		-150 to 300	-110 to 50	409
9	Rajpura (NPL)	1	700	Punjab	-210 to 420	-250 to 0	405
		2	700		-210 to 420	-250 to 0	402
10	MGTPS	1	660	Haryana	-198 to 396	-120 to 120	412
		2	660		-198 to 396	-130 to 100	408
11	Bawana	1	216	Delhi-NCR	-65 to 130	-70 to 10	406
		2	216		-65 to 130	-	-
		3	216		-65 to 130	-	-
		4	216		-65 to 130	-	-
		5	253		-65 to 130	-50 to 50	408
		6	253		-65 to 130	-	-
12	Bara PPGCL	1	660	UP	-198 to 396	0 to 80	775
		2	660		-198 to 396	0 to 100	775
		3	660		-198 to 396	-70 to 20	765

13	Lalitpur TPS	1	660	UP	-198 to 396	-50 to 50	765
		2	660		-198 to 396	-50 to 50	765
		3	660		-198 to 396	-100 to 50	760
14	Anpara D UP	1	500	UP	-150 to 300	-200 to -100	-
		2	500		-150 to 300	-150 to -100	-
15	Chhabra TPS	1	250	Rajasthan	-75 to 150	-40 to 40	410
		2	250		-75 to 150	-70 to 20	408
		3	250		-75 to 150	-60 to 40	410
		4	250		-75 to 150	-	-
	5	660	-198 to 396	-50 to 150	412		
	6	660	-198 to 396	-50 to 150	410		

All generating stations are requested to resolve any issues related to telemetry and make sure that MVAR absorption is as per grid requirement and capability curve of machine.

Since with IEGC 2023 implementation, reactive energy performance also has financial impact, it is desirable that all generating stations continue to support grid voltages by having reactive power performance as per their capability curve and grid requirement.

Some of the generating units such IGSTPP Jhajjar, MGTPS Jhajjar, Bara need to explore possibility of further MVAR absorption. Further, intrastate generators in Rajasthan control area may be asked to support through adequate reactive power generation during day-time when Rajasthan grid experiences low voltage.

Following was discussed in 224 OCC meeting:

Singrauli representative informed that they would look into the issue of Unit 4 and Unit 5.

IGSTPP Jhajjar representative informed the forum that their machine is capable of absorbing reactive power as per its capability curve. However, they have manually set a voltage threshold of 408kV for Unit-3, and they plan to adjust the voltage threshold of 412kV in Unit-2 by making suitable tap changes to align it with Unit-3.

Regarding Talwandi Sabo, Punjab representative stated that they have consulted PSPCL, which confirmed that the settings were configured as per the OEM's specifications and have not been adjusted since. Punjab representative requested guidance on any standard settings or documents that could be shared with the OEM for tuning the system.

The forum advised that the settings could be aligned with the unit's capability curve. Subsequently, Punjab SLDC representative proposed inviting a PSPCL representative to the upcoming Northern Region protection meeting to resolve the issue.

Representative from Bara also agreed to rectify the issue and same has been taken up with their protection team.

CGM(NRLDC) informed all such plants to take suitable actions at their end so that the reactive power performance of generators aligns with the requirement of the grid.

Following are few observations based on data of 01Nov-07Nov 2024 analysed at NRLDC end:

- Some of the machines at NTPC Singrauli are generating MVAR whereas some are absorbing MVAR
- Data of Dadri Stage-II was not available for analysis.
- IGSTPP Jhajjar performance needs improvement.
- Performance of Unit-2 at MGTPS Jhajjar was better than for Unit-1
- Performance of Unit03 at Bara is as required, whereas Unit-1 and Unit-2 performance needs improvement/ data check.
- Rajasthan SLDC to monitor performance of intrastate thermal units to obtain better voltage support during low voltage conditions in the grid.

All generating stations are requested to resolve any issues related to telemetry and make sure that MVAR absorption is as per grid requirement and capability curve of machine. Generators may also set their Vsch (voltage set point) such that units are absorbing MVAR as per their capability and grid requirement with intimation to RLDC/SLDC.

B.7. Sharing of ATC/TTC assessment and basecase with NRLDC

All NR states except Chandigarh UT are sharing basecase and ATC/TTC assessment with NRLDC. OCC has advised all states to timely declare TTC/ATC for prospective months and revise the figures as per requirement.

CERC vide their order dated 29.09.2023 has granted approval of “Detailed Procedure for Allocation of Transmission Corridor for Scheduling of General Network Access and Temporary General Network Access under Central Electricity Regulatory Commission (Connectivity and General Network Access to the inter-State Transmission System) Regulations, 2022”.

Detailed roles and responsibilities for State Load Dispatch Centers in various timelines of the approved procedure are provided in the table below.

Purpose	S No	Action of Stakeholder	Responsibility	Submission to	Data/ Information on Submission Time line
1. Revision 0 TTC/ATC Declaration for Month 'M'	1(a)	<i>Submission of node wise Load and generation data along with envisaged</i>	SLDC	RLDC	10 th Day of 'M-12' month
		<i>scenarios for assessment of transfer capability</i>			
		<i>Assessment of TTC/ATC of the import/export capability of the state and intra-state system and</i>			

		<i>sharing of updated network simulation models</i>			
	1(b)	<i>Declaration of TTC/ATC of the intra- state system by SLDC in consultation with RLDC</i>			<i>26th Day of 'M-12' month</i>
2. Interconnection Studies for elements to be integrated in the month 'M'	2(a)	<i>Submission of node-wise load and generation data & sharing of network simulation models for intra-state elements coming in the next six months</i>	SLDC	RLDC	<i>8th Day of 'M- 6' month</i>
	2(b)	<i>Sharing of inter-connection study results</i>			<i>21st Day of 'M-6' month</i>
3. Month Ahead TTC/ATC Declaration & Base case for Operational Studies for Month 'M'	3(a)	<i>Submission of node wise Load and generation data along with envisaged scenarios for assessment of transfer capability</i>	SLDC	RLDC	<i>8th Day of 'M- 1' month</i>
		<i>Assessment of TTC/ATC of the intra- state system and sharing of updated network simulation models</i>			
	3(b)	<i>Declaration of TTC/ATC of the intra- state system in consultation with RLDC</i>	SLDC	RLDC	<i>22nd Day of 'M-1' month</i>

To encourage participation from SLDCs regarding basecase preparation and ATC/TTC assessment, two workshops have been conducted from Grid-India/NRLDC side. One workshop was conducted 31.08.2023 before the finalization of the procedure and another on 10.01.2024 recently to involve further participation from SLDCs.

Although all SLDCs are now involved in preparation of basecase & ATC/TTC assessment, it is seen that the timelines as per CERC approved procedure are not being followed and number of times basecases are not received from SLDC side.

B.7.1 ATC/TTC assessment sharing 11 months in advance

The procedure mentions that:

“SLDCs in consultation with RLDCs shall declare the import and export TTC, ATC, and TRM of the individual control/bid areas within the region in accordance with Regulation 44 (3) of the Grid Code 2023. RLDCs shall assess the import and export TTC, TRM and ATC for the group of control/bid areas within the region (if required). The computed TTC, TRM and ATC figures shall be published on the website of respective SLDCs and RLDCs, along with the details of the basis of calculations, including assumptions, if any, **at least eleven (11) months in advance**. The specific constraints indicated in the system study shall also be published on the website.”

Accordingly, SLDCs are requested to send the PSSE cases for four scenarios for Oct'25 i.e. Afternoon Peak, Solar Peak, Evening Peak & Off-Peak hours as communicated from NRLDC side. It is requested that the basecases as well as ATC/TTC assessments may be shared with NRLDC as per CERC approved procedure. Further, the above exercise needs to be carried out regularly monthly.

It was discussed in last several OCC meetings & all states were requested to share basecase as well as ATC/TTC assessments for M-12 scenarios on monthly basis with NRLDC as per CERC approved procedure. Accordingly, it is requested to submit the basecase as well as ATC/TTC assessments.

B.7.2 Sharing of Data and study results for interconnection studies

As per **Regulation 33 of IEGC 2023**,

(9) Each SLDC shall undertake a study on the impact of new elements to be commissioned in the intra-state system in the next six (6) months on the TTC and ATC for the State and share the results of the studies with RLDC.

(10) Each RLDC shall undertake a study on the impact of new elements to be commissioned in the next six (6) months in (a) the ISTS of the region and (b) the intra-state system on the inter-state system and share the results of the studies with NLDC.

(11) NLDC shall undertake study on the impact of new elements to be commissioned in the next six (6) months in (a) inter-regional system, (b) cross-border link and (c) intra-regional system on the inter-regional system.

In line with above, utilities are requested to share the list of elements/LGB data/interconnection study results etc as per the approved procedure which are expected to be commissioned within next six months. This needs to be practised as monthly exercise on regular basis.

The agenda was discussed in last several OCC meetings & all utilities were requested to share list of elements/LGB data/interconnection study results etc as per the approved procedure on monthly basis.

B.7.3 TTC/ATC of state control areas for monsoon 2024 (M-1)

As discussed in previous OCC meetings, most of the NR states except Ladakh and Chandigarh U/Ts are sharing basecase and ATC/TTC assessment with NRLDC.

Based on simulation studies and discussions between SLDCs and NRLDC, ATC/TTC limits for NR states for the month of Dec'2024 are attached as **Annexure-B.III**.

OCC has advised all states to timely declare TTC/ATC for prospective months and revise the figures as per requirement.

The agenda was also discussed in last several OCC meetings wherein all states agreed to send the data as well as PSSE basecases on time for all three (M-1, M-6, M-11) scenarios.

In 224 OCC meeting,

- NRLDC representative stated that the agenda was also discussed in last several OCC meeting wherein all states agreed to send the data as well as PSSE basecases on time for all three (M-1, M-6, M-11) scenarios. CGM

Status of action taken on decision of 224th OCC meeting of NRPC

S.N.	Agenda	Decision of 224 th OCC meeting of NRPC	Status of action taken
1	A.15. N-1 contingency violation in 400/220/33KV 315MVA ICT-I at BBMB Dehar (Agenda by Powergrid NR-2)	Forum asked BBMB, PSTCL and HPPTCL to jointly have a meeting and explore the technical modalities for implementation of SPS at Dehar and same may be presented in next OCC meeting	BBMB, PSTCL and HPPTCL to update the status.
2	A.16. Regarding installation of CSD in 400KV Kalaamb Wangtoo and 400KV Kalaamb Sorang to control switching surges (Agenda by Powergrid NR-2)	<p><i>Forum recommended that CTU to do a study and submit its observations to NRLDC on the following</i></p> <ul style="list-style-type: none"> <i>a. Whether the reactor currently installed at the Karcham end could be relocated to either Wangtoo or Sorang, or alternatively, a new reactor could be installed.</i> <i>b. Determine whether to install a reactor at Wangtoo or Sorang, or alternatively, to install a Capacitor Switching Device (CSD) on the 400 kV Wangtoo and 400 kV Sorang lines at Kalaamb substation to manage switching surges.</i> 	CTU to update the status.
3	A.17. Power flow congestion to Delhi Ring Main unit through 400 kV Switchyard at 765/400KV Jhatikra substation (Agenda by Powergrid NR-1)	<i>Forum asked CTU to provide detailed study report in consultation with NRLDC on load congestion relieving measures at Jhatikra S/S including provision for upcoming ICTs at Jhatikra S/S and Narela S/s.</i>	CTU to update the status.

Status of action taken on decision of 224th OCC meeting of NRPC

4	A.21 Requirement of complete 400 kV Bus-1 &2 shutdown at Mandola & Ballabgarh SS for replacement of damaged sections 400 kV jack buses (Agenda by Powergrid NR-1)	<i>Forum asked DTL and HVPN to submit before OCC meeting how they will manage their load during the complete shutdown of 400 kV Bus-1 and Bus-2 at Mandola and Ballabgarh substation, respectively.</i>	DTL and HVPN to update the status.
---	---	---	------------------------------------

Follow up issues from previous OCC meetings

Annexure-A. I

1	Down Stream network by State utilities from ISTS Station	Augmentation of transformation capacity in various existing substations, addition of new substations along with line bays as well as requirement of line bays by STUs for downstream network are under implementation at various locations in Northern Region. Further, 220kV bays have already been commissioned at various substations in NR. For its utilization, downstream 220kV system needs to be commissioned.	List of downstream networks is enclosed in Annexure-A. I. I.																																				
2	Progress of installing new capacitors and repair of defective capacitors	Information regarding installation of new capacitors and repair of defective capacitors is to be submitted to NRPC Secretariat.	<p>Data upto following months, received from various states / UTs:</p> <table border="1" data-bbox="971 825 1580 1108"> <tr><td>⊙ CHANDIGARH</td><td>Sep-2019</td></tr> <tr><td>⊙ DELHI</td><td>Jul-2024</td></tr> <tr><td>⊙ HARYANA</td><td>Aug-2024</td></tr> <tr><td>⊙ HP</td><td>Sep-2024</td></tr> <tr><td>⊙ J&K and LADAKH</td><td>Not Available</td></tr> <tr><td>⊙ PUNJAB</td><td>Sep-2024</td></tr> <tr><td>⊙ RAJASTHAN</td><td>Sep-2024</td></tr> <tr><td>⊙ UP</td><td>Sep-2024</td></tr> <tr><td>⊙ UTTARAKHAND</td><td>Oct-2024</td></tr> </table> <p>All States/UTs are requested to update status on monthly basis.</p>	⊙ CHANDIGARH	Sep-2019	⊙ DELHI	Jul-2024	⊙ HARYANA	Aug-2024	⊙ HP	Sep-2024	⊙ J&K and LADAKH	Not Available	⊙ PUNJAB	Sep-2024	⊙ RAJASTHAN	Sep-2024	⊙ UP	Sep-2024	⊙ UTTARAKHAND	Oct-2024																		
⊙ CHANDIGARH	Sep-2019																																						
⊙ DELHI	Jul-2024																																						
⊙ HARYANA	Aug-2024																																						
⊙ HP	Sep-2024																																						
⊙ J&K and LADAKH	Not Available																																						
⊙ PUNJAB	Sep-2024																																						
⊙ RAJASTHAN	Sep-2024																																						
⊙ UP	Sep-2024																																						
⊙ UTTARAKHAND	Oct-2024																																						
3	Healthiness of defence mechanism: Self-certification	<p>Report of mock exercise for healthiness of UFRs carried out by utilities themselves on quarterly basis is to be submitted to NRPC Secretariat and NRLDC. All utilities were advised to certify specifically, in the report that “All the UFRs are checked and found functional” .</p> <p>In compliance of NPC decision, NR states/constituents agreed to raise the AUFR settings by 0.2 Hz in 47th TCC/49th NRPC meetings.</p>	<p>Data upto following months, received from various states / UTs:</p> <table border="1" data-bbox="971 1297 1580 1612"> <tr><td>⊙ CHANDIGARH</td><td>Not Available</td></tr> <tr><td>⊙ DELHI</td><td>Sep-2024</td></tr> <tr><td>⊙ HARYANA</td><td>Sep-2024</td></tr> <tr><td>⊙ HP</td><td>Aug-2024</td></tr> <tr><td>⊙ J&K and LADAKH</td><td>Not Available</td></tr> <tr><td>⊙ PUNJAB</td><td>Sep-2024</td></tr> <tr><td>⊙ RAJASTHAN</td><td>Jun-2024</td></tr> <tr><td>⊙ UP</td><td>Sep-2024</td></tr> <tr><td>⊙ UTTARAKHAND</td><td>Sep-2024</td></tr> <tr><td>⊙ BBMB</td><td>Jun-2024</td></tr> </table> <p>All States/UTs are requested to update status for healthiness of UFRs on monthly basis for islanding schemes and on quartely basis for the rest .</p> <p>Status:</p> <table border="1" data-bbox="971 1833 1580 2072"> <tr><td>⊙ CHANDIGARH</td><td>Not Available</td></tr> <tr><td>⊙ DELHI</td><td>Increased</td></tr> <tr><td>⊙ HARYANA</td><td>Increased</td></tr> <tr><td>⊙ HP</td><td>Increased</td></tr> <tr><td>⊙ J&K and LADAKH</td><td>Increased</td></tr> <tr><td>⊙ PUNJAB</td><td>Increased</td></tr> <tr><td>⊙ RAJASTHAN</td><td>Increased</td></tr> <tr><td>⊙ UP</td><td>Increased</td></tr> </table>	⊙ CHANDIGARH	Not Available	⊙ DELHI	Sep-2024	⊙ HARYANA	Sep-2024	⊙ HP	Aug-2024	⊙ J&K and LADAKH	Not Available	⊙ PUNJAB	Sep-2024	⊙ RAJASTHAN	Jun-2024	⊙ UP	Sep-2024	⊙ UTTARAKHAND	Sep-2024	⊙ BBMB	Jun-2024	⊙ CHANDIGARH	Not Available	⊙ DELHI	Increased	⊙ HARYANA	Increased	⊙ HP	Increased	⊙ J&K and LADAKH	Increased	⊙ PUNJAB	Increased	⊙ RAJASTHAN	Increased	⊙ UP	Increased
⊙ CHANDIGARH	Not Available																																						
⊙ DELHI	Sep-2024																																						
⊙ HARYANA	Sep-2024																																						
⊙ HP	Aug-2024																																						
⊙ J&K and LADAKH	Not Available																																						
⊙ PUNJAB	Sep-2024																																						
⊙ RAJASTHAN	Jun-2024																																						
⊙ UP	Sep-2024																																						
⊙ UTTARAKHAND	Sep-2024																																						
⊙ BBMB	Jun-2024																																						
⊙ CHANDIGARH	Not Available																																						
⊙ DELHI	Increased																																						
⊙ HARYANA	Increased																																						
⊙ HP	Increased																																						
⊙ J&K and LADAKH	Increased																																						
⊙ PUNJAB	Increased																																						
⊙ RAJASTHAN	Increased																																						
⊙ UP	Increased																																						

									<table border="1"> <tr><td>⊙</td><td>UTTARAKHAND</td><td>Increased</td></tr> <tr><td>⊙</td><td>BBMB</td><td>Increased</td></tr> </table>	⊙	UTTARAKHAND	Increased	⊙	BBMB	Increased																																				
⊙	UTTARAKHAND	Increased																																																	
⊙	BBMB	Increased																																																	
4	Status of FGD installation vis-à-vis installation plan at identified TPS	<p>List of FGDs to be installed in NR was finalized in the 36th TCC (special) meeting dt. 14.09.2017. All SLDCs were regularly requested since 144th OCC meeting to take up with the concerned generators where FGD was required to be installed.</p> <p>Further, progress of FGD installation work on monthly basis is monitored in OCC meetings.</p>							<p>Status of the information submission (month) from states / utilities is as under:</p> <table border="1"> <tr><td>⊙</td><td>HARYANA</td><td>Jun-2024</td></tr> <tr><td>⊙</td><td>PUNJAB</td><td>Jun-2024</td></tr> <tr><td>⊙</td><td>RAJASTHAN</td><td>Jul-2024</td></tr> <tr><td>⊙</td><td>UP</td><td>Jan-2024</td></tr> <tr><td>⊙</td><td>NTPC</td><td>Feb-2023</td></tr> </table> <p>FGD status details are enclosed as Annexure-A. I. II.</p> <p>All States/utilities are requested to update status of FGD installation progress on monthly basis.</p>	⊙	HARYANA	Jun-2024	⊙	PUNJAB	Jun-2024	⊙	RAJASTHAN	Jul-2024	⊙	UP	Jan-2024	⊙	NTPC	Feb-2023																											
⊙	HARYANA	Jun-2024																																																	
⊙	PUNJAB	Jun-2024																																																	
⊙	RAJASTHAN	Jul-2024																																																	
⊙	UP	Jan-2024																																																	
⊙	NTPC	Feb-2023																																																	
5	Submission of breakup of Energy Consumption by the states	<p>All states/UTs are requested to submit the requisite data as per the billed data information in the format given as under:</p> <table border="1"> <thead> <tr> <th>Category→</th> <th>Consumption by Domestic Loads</th> <th>Consumption by Commercial Loads</th> <th>Consumption by Agricultural Loads</th> <th>Consumption by Industrial Loads</th> <th>Traction supply load</th> <th>Miscellaneous / Others</th> </tr> </thead> <tbody> <tr> <td><Month></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>	Category→	Consumption by Domestic Loads	Consumption by Commercial Loads	Consumption by Agricultural Loads	Consumption by Industrial Loads	Traction supply load	Miscellaneous / Others	<Month>												<p>Status of the information submission (month) from states / utilities is as under:</p> <table border="1"> <thead> <tr> <th>State / UT</th> <th>Upto</th> </tr> </thead> <tbody> <tr><td>⊙</td><td>CHANDIGARH</td><td>Not Submitted</td></tr> <tr><td>⊙</td><td>DELHI</td><td>Jun-24</td></tr> <tr><td>⊙</td><td>HARYANA</td><td>Sep-24</td></tr> <tr><td>⊙</td><td>HP</td><td>Aug-24</td></tr> <tr><td>⊙</td><td>J&K and LADAKH</td><td>JPDCCL- Mar' 24 KPDCL- Not Submitted</td></tr> <tr><td>⊙</td><td>PUNJAB</td><td>Aug-24</td></tr> <tr><td>⊙</td><td>RAJASTHAN</td><td>Jul-24</td></tr> <tr><td>⊙</td><td>UP</td><td>Jun-24</td></tr> <tr><td>⊙</td><td>UTTARAKHAND</td><td>Jun-24</td></tr> </tbody> </table> <p>Chandigarh is requested to submit the requisite data w.e.f. April 2018 as per the billed data information in the given format</p>	State / UT	Upto	⊙	CHANDIGARH	Not Submitted	⊙	DELHI	Jun-24	⊙	HARYANA	Sep-24	⊙	HP	Aug-24	⊙	J&K and LADAKH	JPDCCL- Mar' 24 KPDCL- Not Submitted	⊙	PUNJAB	Aug-24	⊙	RAJASTHAN	Jul-24	⊙	UP	Jun-24	⊙	UTTARAKHAND	Jun-24
Category→	Consumption by Domestic Loads	Consumption by Commercial Loads	Consumption by Agricultural Loads	Consumption by Industrial Loads	Traction supply load	Miscellaneous / Others																																													
<Month>																																																			
State / UT	Upto																																																		
⊙	CHANDIGARH	Not Submitted																																																	
⊙	DELHI	Jun-24																																																	
⊙	HARYANA	Sep-24																																																	
⊙	HP	Aug-24																																																	
⊙	J&K and LADAKH	JPDCCL- Mar' 24 KPDCL- Not Submitted																																																	
⊙	PUNJAB	Aug-24																																																	
⊙	RAJASTHAN	Jul-24																																																	
⊙	UP	Jun-24																																																	
⊙	UTTARAKHAND	Jun-24																																																	
6	Information about variable charges of all generating units in the Region	<p>The variable charges detail for different generating units are available on the MERIT Order Portal.</p>							<p>All states/UTs are requested to submit daily data on MERIT Order Portal timely.</p>																																										
7	Status of Automatic Demand Management System in NR states/UT's	<p>The status of ADMS implementation in NR, which is mandated in clause 5.4.2 (d) of IEGC by SLDC/SEB/DISCOMs is presented in the following table:</p>							<p>The status of ADMS implementation in NR is enclosed in Annexure-A. I. II.</p> <table border="1"> <tr><td>⊙</td><td>DELHI</td><td>Scheme Implemented but operated in manual mode.</td></tr> <tr><td>⊙</td><td>HARYANA</td><td>Scheme not implemented</td></tr> <tr><td>⊙</td><td>HP</td><td>Scheme not implemented</td></tr> <tr><td>⊙</td><td>PUNJAB</td><td>Scheme not implemented</td></tr> <tr><td>⊙</td><td>RAJASTHAN</td><td>Under implementation.</td></tr> <tr><td>⊙</td><td>UP</td><td>Scheme implemented by NPCIL only</td></tr> </table>	⊙	DELHI	Scheme Implemented but operated in manual mode.	⊙	HARYANA	Scheme not implemented	⊙	HP	Scheme not implemented	⊙	PUNJAB	Scheme not implemented	⊙	RAJASTHAN	Under implementation.	⊙	UP	Scheme implemented by NPCIL only																								
⊙	DELHI	Scheme Implemented but operated in manual mode.																																																	
⊙	HARYANA	Scheme not implemented																																																	
⊙	HP	Scheme not implemented																																																	
⊙	PUNJAB	Scheme not implemented																																																	
⊙	RAJASTHAN	Under implementation.																																																	
⊙	UP	Scheme implemented by NPCIL only																																																	

©	UTTARAKHAND	Scheme not implemented
---	-------------	------------------------

8	Reactive compensation at 220 kV/ 400 kV level at 8 substations			
	State / Utility	Substation	Reactor	Status
i	DTL	Peeragarhi	1x50 MVAR at 220 kV	1x50 MVAR Reactor at Peeragarhi has been commissioned on dated 18.09.2023
ii	DTL	Harsh Vihar	2x50 MVAR at 220 kV	2x50 MVAR Reactor at Harsh Vihar has been commissioned on dated 31th March 2023.
iii	DTL	Mundka	1x125 MVAR at 400 kV & 1x25 MVAR at 220 kV	Bay work completed on 25.03.2023. Reactor part tender is dropped and at present same is under revision.
iv	DTL	Bamnauli	2x25 MVAR at 220 kV	Bay work completed on 25.03.2023. Reactor part tender is dropped and at present same is under revision.
v	DTL	Indraprastha	2x25 MVAR at 220 kV	Bay work completed on 07.11.2023. Reactor part tender is dropped and at present same is under revision.
vi	DTL	Electric Lane	1x50 MVAR at 220 kV	Under Re-tendering due to Single Bid
vii	PTCUL	Kashipur	1x125 MVAR at 400 kV	SLDC informed that PTCUL has intimated that bid extension has been done till 18.07.2024. In 220th OCC meeting, PTCUL was suggested to seek assistance from Powergrid in
viii	RAJASTHAN	Jodhpur	1x125 MVAR	Agreement signed on dt. 22.06.2020. Grant of Ist Instalment received on dt.19.02.21 & work order placed on dt. 07.04.2022 to M/s Kanohar Electricals Ltd. Schedule time is 18 months. 01 No. of 125 MVAR reactor is under testing which is expected to done by end of May 2024. Tentative charging plan is to be intimated by Rajasthan SLDC.

1. Down Stream network by State utilities from ISTS Station:

Sl. No.	Substation	Downstream network bays	Status of bays	Planned 220 kV system and Implementation status	Revised Target	Remarks
1	400/220kV, 3x315 MVA Samba	Commissioned: 8 Total: 8	Utilized: 6 Unutilized: 2	• Network to be planned for 2 bays.	Mar'25	02 No. of bays shall be utilized for LILO-II of 220kV Jatwal-Bishnah Transmission Line, the work of which is delayed due to persisting RoW issues. expected date of completion is Mar 2025 subject to availability of funds and resolving of RoW issues), Updated in 220th OCC by JKPTCL.
2	400/220kV, 2x315 MVA New Wanpoh	Commissioned: 6 Total: 6	Utilized: 2 Unutilized: 4	• 220 kV New Wanpoh - Alusteng D/c Line	Mar'25	02 No. of bays are to be utilized for connecting 220kV New Wanpoh-Alusteng D/c Line. RoW issues persisting; At present new-wampoh-mirbazar 5km and harwan-alstung 16km have been completed, expected date of completion is Mar 2025 subject to availability of funds and resolving of RoW issues), Updated in 214th OCC by JKPTCL.
				• 220 kV New Wanpoh - Mattan D/c Line	End of 2024	02 No. of bays are to be utilized for connecting 220kV New Wanpoh-Mattan D/c Line. The funding source for the project is being identified and the project is expected to be completed by ending 2024. Updated in 204th OCC by JKPTCL.
3	400/220kV, 2x315 MVA Amargarh	Commissioned: 6 Total: 6	Utilized: 4 Unutilized: 2	• 220kV D/C line from 400/220kV Kunzar - 220/33kV Sheeri	End of 2024	02 No. of bays are proposed to be utilized for connecting 220/132 kV GSS Loolipora. The funding source for the project is being identified and the project is expected to be completed by ending 2024. Updated in 204th OCC by JKPTCL.
4	400/220kV, 2x500 MVA Kurukshetra (GIS)	Commissioned: 8 Total: 8	Utilized: 6 Unutilized: 2	• 220kV Bhadson (Kurukshetra) – Ramana Ramani D/c line	Mar'25	Under construction.Updated in 222nd OCC by HVPNL
5	400/220 kV, 2x315 MVA Dehradun	Commissioned: 6 Total: 6	Utilized: 2 Unutilized: 4	• Network to be planned for 4 bays	-	PTCUL to update the status.
6	Shahjahanpur, 2x315 MVA 400/220 kV	Commissioned: 6 Approved/Under Implementation:1	Utilized: 7	• 220 kV D/C Shahjahanpur (PG) - Gola line	Commissioned	Energization date: 26.10.2023 updated by UPPTCL in 215th OCC
				• LILO of Sitapur – Shahjahanpur 220 kV SC line at Shahjahanpur (PG)	Commissioned	Energization date: 25.02.2022 updated by UPPTCL in 196th OCC
7	Hamirpur 400/220 kV Sub-station	Commissioned: 8 Total: 8	Utilized: 4 Unutilized: 4	• 220 kV Hamirpur-Dehan D/c line	Commissioned	HPPTCL has commissioned the Planned 220kV Dehan-Hamirpur TL utilizing 2 No. 220kV Bays. Commissioned date: 09.06.2022. Updated in 198th OCC by HPPTCL
				• Network to be planned for 4 bays	-	HPPTCL to update the status.
8	Sikar 400/220kV, 1x 315 MVA S/s	Commissioned: 8 Total: 8	Utilized: 6 Unutilized: 2	• LILO of 220 kV Sikar (220 kV GSS)-Dhod S/c line at Sikar (PG)	Commissioned	LILO of 220 kV S/C Sikar-Dhod line at 400 kV GSS PGCIL, Sikar has been charged on dt. 31.03.2022
				• Network to be planned for 2 bays.	-	Against the 3rd ICT at 400 kV GSS Sikar, only 2 bays were constructed and same has been utilized by RVPN by constructing LILO of 220 kV S/C Sikar – Dhod line as updated by RVPNL in 195th OCC
9	Bhiwani 400/220kV S/s	Commissioned: 6 Total: 6	Utilized: 2 Unutilized: 4	• 220 kV D/C line Bhiwani (PG) – Bhiwani (HVPNL) line	Commissioned	Updated in 202nd OCC by HVPNL
				• 220 kV Bhiwani (PG) - Isherwal (HVPNL) D/c line.	Dec'24	Issue related to ROW as intimated in 218th OCC by HVPNL. Status: Work was stalled since 29.07.2021 due to ROW issues and farmers agitation and further restarted on 9.10.2023 with the help of district administration. Now, work was again stalled since 30.11.2023 due to severe ROW issues. Expected to be completed by 31.12.2024. Foundation 209/212. Erection 193/212. Stinging 37.8/50.3 km
				• 220 kV Bhiwani (PG) - Dadhibana (HVPNL) D/c line.	Oct'25	Line work awarded to M/s R S Infra Projects Pvt. Ltd. Noida, Uttar Pradesh on dated 09.03.2024. Work of route plan and route alignment has been started by the firm as intimated in 218th OCC by HVPNL.
10	Jind 400/220kV S/s	Commissioned: 4 Approved:4 Total: 8	Utilized: 4 Unutilized: 0	• LILO of both circuits of 220 kV Jind HVPNL to PTPS D/C line at 400 kV substation PGCIL Khatkar (Jind) with 0.5 sq inch ACSR conductor	Dec'24	Work in progress. Updated in 220th OCC by HVPNL.
11	400/220kV Tughlakabad GIS	Commissioned: 6 Under Implementation: 4	Utilized: 6 Unutilized: 0	• RK Puram – Tughlakabad (UG Cable) 220kV D/c line – March 2023.	Commissioned	Updated in 216th OCC by DTL
				• Masjid Mor – Tughlakabad 220kV D/c line.	Commissioned	Updated in 216th OCC by DTL

Sl. No.	Substation	Downstream network bays	Status of bays	Planned 220 kV system and Implementation status	Revised Target	Remarks
12	400/220kV Kala Amb GIS (TBCB)	Commissioned: 6 Total: 6	Utilized: 2	• HPPTCL has planned one no. of 220kV D/c line from Kala Amb 400/220kV S/s to 220/132kV Kala Amb S/s	Commissioned	Energization date: 31.05.2024 updated by HPPTCL in 220th OCC
			Unutilized: 2	• HPPTCL has planned one no. of 220kV D/c line from Kala Amb 400/220kV S/s to 220/132kV Giri S/s	-	Tendering process is yet to be started.Updated in 219th OCC by HPPTCL
			Under Implementation:2	• Network to be planned for 2 bays	-	HPPTCL to update the status.
13	400/220kV Kadarpur Sub-station	Commissioned: 8 Total: 8	Utilized: 0	• D/C line Kadarpur - Sec-56 Gurugram.	Not awarded yet	Initial proposal of LILO of 220kV Pali-Sector 56 Line and Pali-Sector 52 line was descope due to forest issue. Proposal to evacuate power from 220kV D/C Pali-Sector 56 line to Sector 56 and 52 with bunching of lines is under consideration. Updated in 218th OCC by HVPNL
			Unutilized: 8	• S/C line Kadarpur - Sec-52 Gurugram	Not awarded yet	Initial proposal of LILO of 220kV Pali-Sector 56 Line and Pali-Sector 52 line was descope due to forest issue. Propost to evacuate power from 220kV D/C Pali-Sector 56 line to Sector 56 and 52 with bunching of lines is under consideration. Updated in 218th OCC by HVPNL
				• S/C line Kadarpur - Pali	Not awarded yet	Initial proposal of LILO of 220kV Pali-Sector 56 Line and Pali-Sector 52 line was descope due to forest issue. Propost to evacuate power from 220kV D/C Pali-Sector 56 line to Sector 56 and 52 with bunching of lines is under consideration. Updated in 218th OCC by HVPNL
14	400/220kV Sohna Road Sub-station	Commissioned: 8 Total: 8	Utilized: 4	• LILO of both circuits of 220kV D/c Sohna-Rangla Rajpur at Roj Ka Meo line at 400kV Sohna Road	Dec'24	Updated in 216th OCC by HVPNL
			Unutilized: 4	• LILO of both circuits of 220kV D/c Badshahpur-Sec77 line at 400kV Sohna Road	-	The matter is subjudice in Hon'ble Punjab & Haryana High court, Chandigarh Updated in 205th OCC by HVPNL. Status:- Earlier 02 nos 220 kV line bays were to be utilized for the 220 kV GIS S/Stn. Sec-77, Gurugram but due to denotification of land of the 220 kV GIS S/Stn. Sec-77 the said substation is now going to be dismantled and a new substation is proposed at Sec-75A, Gurugram. Now, these 02 no. 220 kV line bays may be utilized at 220 kV GIS S/Stn Sec-75A, Gurugram.
15	400/220kV Prithla Sub-station	Commissioned: 8 Approved: 2 Total: 10	Utilized: 4	• 220kV D/C line from Prithla to Harfali with LILO of one circuit at 220kV Meerpur Kurali	Mar'25	Contract awarded on 08.08.23 to M/s Skipper with completion in March 25.Updated in 218th OCC by HVPNL
			Unutilized: 4	• LILO of both ckt of 220kV D/c Ranga Rajpur – Palwal line	Commissioned	Energization date: 31.12.2021. Updated in 198th OCC by HVPNL
			Under Implementation:2	• 220kV D/C for Sector78, Faridabad	31.01.2025	Issue related to ROW and Pending crossing approval from Northern Railways and DFCCIL. as intimated in 223rd OCC by HVPNL.
				• Prithla - Sector 89 Faridabad 220kV D/c line	Jul'25	Work awarded to M/s Man Structural Pvt Ltd. JV M/s Aquarian Enterprises on 09.01.2024. Contractual date: 06.05.2025 and Tentative date of completion :06.05.2025 Route has been approved and further work is in progress.Updated in 218th OCC by HVPNL
16	400/220kV Sonapat Sub-station	Commissioned: 6 Under Implementation:2 Total: 8	Utilized: 2	• LILO of both circuits of 220kV Samalkha - Mohana line at Sonapat	31.12.2024	Updated in 224th OCC by HVPNL. Status: The stringing work between TL No. 19 & 20, TL No. 22 & 23 and TL No. 22 & 24 is pending for want of necessary consent from the forest department. The case has already been uploaded on Parivesh portal and is currently pending at the O/o AIGF, Forest Dept. Panchkula.
			Unutilized: 4	• Sonapat - HSIISC Rai 220kV D/c line	Commissioned	Energization date: 31.05.2024 updated by HVPNL in 220th OCC
			Under Implementation:2	• Sonapat - Kharkhoda Pocket A 220kV D/c line	08.03.2025	Updated in 212th OCC by HVPNL. Status: Work order has been issued to M/s R.S Infra on dated 09.08.2023 by O/o CE/PD&C, Panchkula for construction of line. Both bays are under construction and erection of electrical equipment is under progress. Tetative date of completion of both bays at PGCIL end is end of July 2024.
17	400/220kV Neemrana Sub-station	Commissioned: 6 Total: 6	Utilized: 4 Unutilized: 2	• LILO of Bhiwadi - Neemrana 220kV S/c line at Neemrana (PG)	-	Work is under progres. Stub Setting: 14/2017. Permission for Highway is awaited from concerned department as updated in 218th OCC by RVPNL.
18	400/220kV Kotputli Sub-station	Commissioned: 6 Total: 6	Utilized: 4 Unutilized: 2	• Kotputli - Pathreda 220kV D/c line	-	Date of bid opening has been extended up to 30.04.2024 as updated in 218th OCC by RVPNL.
19	400/220kV Jalandhar Sub-station	Commissioned: 10 Total: 10	Utilized: 8 Unutilized: 2	• Network to be planned for 2 bays	Nov'24	LILO of 220 kV BBMB Jalandhar - Butari line at 400 kV PGCIL Jalandhar being planned. Work expected to be completed by May 2024. Updated in 198th OCC by PSTCL. 6 months more are needed due to ROW issues as updated by PSTCL in 220th OCC

Sl. No.	Substation	Downstream network bays	Status of bays	Planned 220 kV system and Implementation status	Revised Target	Remarks
20	400/220kV Roorkee Sub-station	Commissioned: 6 Total: 6	Utilized: 4 Unutilized: 2	• Roorkee (PG)-Pirankaliyar 220kV D/c line	Commissioned	Roorkee (PG)-Pirankaliyar 220kV D/c line commissioned in 2020 as intimated by PTCUL in 197th OCC
21	400/220kV Lucknow Sub-station	Commissioned: 8 Total: 8	Utilized: 4 Unutilized: 4	• Network to be planned for 2 bays	Commissioned	• Lucknow -Kanduni, 220 kV D/C line work energized on 05.10.2023. Updated in 212th OCC by UPPTCL. • No planning for 2 no. of bays upated by UPPTCL in 196th OCC. The same has been communicated to Powergrid.
22	400/220kV Gorakhpur Sub-station	Commissioned: 6 Total: 6	Utilized: 4 Unutilized: 2	• Network to be planned for 2 bays	Commissioned	• Gorakhpur(PG)- Maharajanaj, 220 kV D/C line energized on 27.09.2023 updated by UPPTCL in 212th OCC
23	400/220kV Fatehpur Sub-station	Commissioned: 8 Under Implementation:2 Total: 10	Utilized: 6 Unutilized: 2 Under Implementation:2	• Network to be planned for 2 bays	-	• UPPTCL intimated that 02 no. of bays under finalization stage. In 201st OCC, UPPTCL intimated that it is finalized that Khaga s/s will be connected (tentative time 1.5 years). • No planning for 2 no. of bays updated by UPPTCL in 196th OCC. The same has been communicated to Powergrid.
24	400/220kV Abdullapur Sub-station	Commissioned: 10 Under Implementation:2 Total: 12	Utilized: 10 Unutilized: 0 Under Implementation:2	• Abdullapur – Rajokheri 220kV D/c line	Commissioned	Ckt-1 commissioned at 16:13hrs on dated 06.08.24 & Ckt-2 commissioned at 20:10 hrs on dated 05.08.24. Updated in 223rd OCC by HVPNL
25	400/220kV Pachkula Sub-station	Commissioned: 8 Under tender:2 Total: 10 Out of these 10 nos. 220kV	Utilized: 2 Unutilized: 4 Under Implementation:2	• Panchkula – Pinjore 220kV D/c line	Commissioned	Updated in 218th OCC by HVPNL
				• Panchkula – Sector-32 220kV D/c line	Commissioned	Energization date: 24.05.2024 updated by HVPNL in 220th OCC
				• Panchkula – Raiwali 220kV D/c line	Commissioned	Updated in 194th OCC by HVPNL
				• Panchkula – Sadhaura 220kV D/c line: Sep'23	Mar'25	Updated in 222nd OCC by HVPNL
26	400/220kV Amritsar S/s	Commissioned:7 Approved in 50th NRPC- 1 no. Total: 8	Utilized: 6 Under Implementation:2	• Amritsar – Patti 220kV S/c line	31.08.2024	Issue in connectivity agreement with CTU. PSTCL has taken up the issue with CTU and accordingly CTU has been asked by OCC forum to plan a meeting with PSTCL and CEA at the earliest. Updated in 224th OCC by PSTCL.
				• Amritsar – Rashiana 220kV S/c line (2 bays shall be required for above lines. However, 1 unutilized bay shall be used for Patti and requirement of one additional bay approved for Rashiana by NRPC)	31.08.2024	Issue in connectivity agreement with CTU. PSTCL has taken up the issue with CTU and accordingly CTU has been asked by OCC forum to plan a meeting with PSTCL and CEA at the earliest. Updated in 224th OCC by PSTCL.
27	400/220kV Bagpat S/s	Commissioned: 8 Total: 8	Utilized:6 Unutilized: 2	• Bagpat - Modipuram 220kV D/c line	Commissioned	Updated in 201st OCC by UPPTCL
28	400/220kV Bahadurgarh S/s	Commissioned: 4 Approved: 4 Total: 8	Utilized:2 Unutilized: 2	• LILO of 220 kV Nunamajra- Daultabad S/c line at 400 kV Bahadurgarh PGCIL	Mar'25	Updated in 220th OCC by HVPNL. Status: NIT has been floated vide NIT No. EPC-D-96 dated 15.10.23 to be opened on 22.12.23. • Now, the tender has been dropped and likely to be refloated by 31.07.2024.
				• Bahadurgarh - METL 220kV D/c line (Deposit work of M/s METL)	Mar'25	Updated in 220th OCC by HVPNL. Status: • Revised BOQ forwarded from Design wing to contract wing. • Tender has floated vide NIT No. EPC-D-100 dated 04.01.2024 with tender opening date of 26.02.2024. • Tender has been opened on 26.03.24 and 03 nos. bids has been received. The work is likely to be awarded by the 31.07.2024.
				• Bahadurgarh - Kharkhoda Pocket B 220kV D/c line	08.03.2025	Updated in 220th OCC by HVPNL. Status: Contract awarded on 09.08.23 to M/s R S Infra Noida. Work has been started.
29	400/220kV Jaipur (South) S/s	Commissioned: 4 Total: 4	Utilized:2 Unutilized: 2	• LILO of 220 kV S/C Dausa – Sawai Madhopur line at 400 kV GSS Jaipur South (PG)	06.10.2025	Work order has been issued on 06.10.2023, work under progress as updated by RVPNL in 215th OCC
30	400/220kV Sohawal S/s	Commissioned: 8 Total: 8	Utilized: 8	• Sohawal - Barabanki 220kV D/c line	Commissioned	Energization date: 14.04.2018 updated by UPPTCL in 196th OCC
				• Sohawal - New Tanda 220kV D/c line	Commissioned	Energization date: 28.05.2019 updated by UPPTCL in 196th OCC
				• Network to be planned for 2 bays	Commissioned	• Sohawal - Gonda 220kV S/c line (Energization date: 27.04.2020) updated by UPPTCL in 196th OCC • Sohawal - Bahraich 220kV S/c line (Energization date: 15.02.2021) updated by UPPTCL in 196th OCC
31	400/220kV, Kankroli	Commissioned: 6 Total: 6	Utilized: 4 Unutilized: 2	• 220 kV D/C Kankroli(PG) - Nathdwara line	-	Standard bid document has been finalized on 13.08.2024 and bid is under preparation as updated by RVPNL in 222nd OCC.

Sl. No.	Substation	Downstream network bays	Status of bays	Planned 220 kV system and Implementation status	Revised Target	Remarks
32	400/220kV, Manesar	Commissioned: 8 Total: 8	Utilized: 4 Unutilized: 4	• Network to be planned for 2 bays	-	Status:- 2nos bays are being utilised for 220 kV D/C Panchgaon (PGCIL)-Panchgaon Ckt-I & 220 kV D/C Panchgaon (PGCIL)-Panchgaon Ckt-II, charged on dated 05.09.2022 & 20.10.2022 respectively. The 2nos bays may be utilised by HVPNL in future.
33	400/220kV, Saharanpur	Commissioned: 6 Under Implementation:2 Total: 8	Utilized: 6 Unutilized: 0 Under Implementation:2	• Network to be planned for 2 bays	Commissioned	Saharanpur(PG)-Devband D/c line (Energization date: 20.04.2023) updated by UPPTCL in 207th OCC
34	400/220kV, Wagoora	Commissioned: 10 Total: 10	Utilized: 6 Unutilized: 4	• Network to be planned for 4 bays	-	PDD, J&K to update the status.
35	400/220kV, Ludhiana	Commissioned: 9 Total: 9	Utilized: 8 Unutilized: 1	• Network to be planned for 1 bay	Commissioned	Direct circuit from 220 kV Lalton Kalan to Dhandari Kalan to be diverted to 400 kV PGCIL Ludhiana. Work completed , final agrrement is expected to be signed by May'24. Updated in 218th OCC by PSTCL.
36	400/220kV, Chamba (Chamera Pool)	Commissioned: 3 Under tender:1 Total: 4	Utilized:3 Unutilized: 0 Under tender:1	• Stringing of 2nd ckt of Chamera Pool – Karian 220kV D/c line	Commissioned	Stringing of 2nd Circuit of Chamera Pool-Karian Tansmission line has been completed & terminal bay at 400/220 kV chamera pooling substation (PGCIL) is commissioned on 20.01.2024. Updated in 217th OCC by HPPTCL.
37	400/220kV, Mainpuri	Commissioned: 6 Under Implementation:2 Total: 8	Utilized: 6 Unutilized: 0 Under Implementation:2	• Network to be planned for 2 bays	-	• 02 no. of bays under finalization stage updated by UPPTCL in 196th OCC. Mainpuri S/s planned. Land is not finalized, therefore timeline not available as intimated by UPPTCL in 201st OCC.
38	400/220kV, Patiala	Commissioned: 8 Total: 8	Utilized: 6 Unutilized: 2	• Network to be planned for 2 bays	May'25	2 Nos. bays for 400 kV PGCIL Patiala - 220 kV Bhadson (D/C) line being planned. Tender is yet to be awarded. Timeline one year communicated by PSTCL in 220th OCC meeting

FGD Status

Updated status of FGD related data submission

NTPC (27.02.2023)

MEJA Stage-I

RIHAND STPS

SINGRAULI STPS

TANDA Stage-I

TANDA Stage-II

UNCHA HAR TPS

UPRVUNL (10.01.2024)

ANPARA TPS

HARDUAGANJ TPS

OBRA TPS

PARICHHA TPS

PSPCL (18.06.2024)

GGSSSTP, Ropar

GH TPS (LEH.MOH.)

RRVUNL (09.07.2023)

CHHABRA SCPP

CHHABRA TPP

KALISINDH TPS

KOTA TPS

SURATGARH SCTPS

SURATGARH TPS

Updated status of FGD related data submission

**Lalitpur Power Gen. Co. Ltd.
(10.01.2024)**

Lalitpur TPS

**Lanco Anpara Power Ltd.
(01.01.2024)**

ANPARA-C TPS

HGPCL (14.06.2024)

PANIPAT TPS

RAJIV GANDHI TPS

YAMUNA NAGAR TPS

Adani Power Ltd. (18.02.2022)

KAWAI TPS

**Rosa Power Supply Company
(01.01.2024)**

Rosa TPP Phase-I

**Prayagraj Power Generation
Company Ltd. (05.01.2024)**

Prayagraj TPP

APCPL (01.05.2024)

INDIRA GANDHI STPP

Pending submissions

GVK Power Ltd.

GOINDWAL SAHIB

NTPC

DADRI (NCTPP)

Talwandi Sabo Power Ltd.

TALWANDI SABO TPP

L&T Power Development Ltd.

Nabha TPP (Rajpura TPP)

Target Dates for FGD Commissioning (Utility-wise)

Adani Power Ltd.	KAWAI TPS U#1 (Target: 31-12-2024), KAWAI TPS U#2 (Target: 31-12-2024)
APCPL	INDIRA GANDHI STPP U#2 (Target: 30-09-2023), INDIRA GANDHI STPP U#3 (Target: 30-06-2023)
GVK Power Ltd.	GOINDWAL SAHIB U#1 (Target: 30-04-2020), GOINDWAL SAHIB U#2 (Target: 29-02-2020)
HGPCL	PANIPAT TPS U#6 (Target: 31-12-2026), PANIPAT TPS U#7 (Target: 31-12-2026), PANIPAT TPS U#8 (Target: 31-12-2026), RAJIV GANDHI TPS U#1 (Target: 31-12-2024), RAJIV GANDHI TPS U#2 (Target: 31-12-2024), YAMUNA NAGAR TPS U#1 (Target: 31-12-2024), YAMUNA NAGAR TPS U#2 (Target: 31-12-2024)

NTPC

DADRI (NCTPP) U#1 (Target: 31-12-2020), DADRI (NCTPP) U#2 (Target: 31-10-2020), DADRI (NCTPP) U#3 (Target: 31-08-2020), DADRI (NCTPP) U#4 (Target: 30-06-2020), DADRI (NCTPP) U#5 (Target: 30-06-2022), DADRI (NCTPP) U#6 (Target: 31-03-2023), RIHAND STPS U#1 (Target: 31-10-2025), RIHAND STPS U#2 (Target: 30-06-2026), RIHAND STPS U#3 (Target: 31-12-2024), RIHAND STPS U#4 (Target: 31-03-2025), RIHAND STPS U#5 (Target: 30-06-2025), RIHAND STPS U#6 (Target: 31-10-2025), SINGRAULI STPS U#1 (Target: 31-12-2024), SINGRAULI STPS U#2 (Target: 31-12-2024), SINGRAULI STPS U#3 (Target: 31-12-2024), SINGRAULI STPS U#4 (Target: 31-12-2024), SINGRAULI STPS U#5 (Target: 31-03-2025), SINGRAULI STPS U#6 (Target: 31-06-2024), SINGRAULI STPS U#7 (Target: 31-03-2024), UNCHAHAR TPS U#1 (Target: 31-12-2023), UNCHAHAR TPS U#2 (Target: 31-12-2023), UNCHAHAR TPS U#3 (Target: 30-09-2023), UNCHAHAR TPS U#4 (Target: 30-09-2023), UNCHAHAR TPS U#5 (Target: 30-09-2023), UNCHAHAR TPS U#6 (Target: 31-08-2022), MEJA Stage-I U#1 (Target: 31-10-2023), MEJA Stage-I U#2 (Target: 30-06-2023), TANDA Stage-I U#3 (Target:), TANDA Stage-I U#4 (Target:), TANDA Stage-II U#3 (Target: 31-03-2023), TANDA Stage-II U#4 (Target: 30-09-2023)

L&T Power Development Ltd (Nabha)	Nabha TPP (Rajpura TPP) U#1 (Target: 30-04-2021), Nabha TPP (Rajpura TPP) U#2 (Target: 28-02-2021)
Lalitpur Power Gen. Company Ltd.	LALITPUR TPS U#1 (Target: 31-12-2026), LALITPUR TPS U#2 (Target: 30-09-2026), LALITPUR TPS U#3 (Target: 30-06-2026)
Lanco Anpara Power Ltd.	ANPARA C TPS U#1 (Target: 31-12-2025), ANPARA C TPS U#2 (Target: 31-12-2025)
Prayagraj Power Generation Company Ltd.	PRAYAGRAJ TPP U#1 (Target: 31-12-2026), PRAYAGRAJ TPP U#2 (Target: 31-12-2026), PRAYAGRAJ TPP U#3 (Target: 31-12-2026)
PSPCL	GH TPS (LEH.MOH.) U#1 (Target: 31-12-2026), GH TPS (LEH.MOH.) U#2 (Target: 31-12-2026), GH TPS (LEH.MOH.) U#3 (Target: 31-12-2026), GH TPS (LEH.MOH.) U#4 (Target: 31-12-2026), GGSSTP, Ropar U#3 (Target: 31-12-2026), GGSSTP, Ropar U#4 (Target: 31-12-2026), GGSSTP, Ropar U#5 (Target: 31-12-2026), GGSSTP, Ropar U#6 (Target: 30-12-2026)

Rosa Power Supply Company	ROSA TPP Ph-I U#1 (Target: 31-12-2026), ROSA TPP Ph-I U#2 (Target: 31-12-2026), ROSA TPP Ph-I U#3 (Target: 31-12-2026), ROSA TPP Ph-I U#4 (Target: 31-12-2026)
RRVUNL	KOTA TPS U#5 (Target: 31-08-2024), KOTA TPS U#6 (Target: 31-08-2024), KOTA TPS U#7 (Target: 31-08-2024), SURATGARH TPS U#1 (Target: 31-12-2026), SURATGARH TPS U#2 (Target: 31-12-2026), SURATGARH TPS U#3 (Target: 31-12-2026), SURATGARH TPS U#4 (Target: 31-12-2026), SURATGARH TPS U#5 (Target: 31-12-2026), SURATGARH TPS U#6 (Target: 31-12-2026), SURATGARH SCTPS U#7 (Target: 28-02-2025), SURATGARH SCTPS U#8 (Target: 28-02-2025), CHHABRA TPP U#1 (Target: 31-12-2026), CHHABRA TPP U#2 (Target: 31-12-2026), CHHABRA TPP U#3 (Target: 31-12-2026), CHHABRA TPP U#4 (Target: 31-12-2026), CHHABRA SCPP U#5 (Target: 28-02-2025), CHHABRA SCPP U#6 (Target: 28-02-2025), KALISINDH TPS U#1 (Target: 28-02-2025), KALISINDH TPS U#2 (Target: 28-02-2025)
Talwandi Sabo Power Ltd.	TALWANDI SABO TPP U#1 (Target: 28-02-2021), TALWANDI SABO TPP U#2 (Target: 31-12-2020), TALWANDI SABO TPP U#3 (Target: 31-10-2020)
UPRVUNL	ANPARA TPS U#1 (Target: 31-12-2025), ANPARA TPS U#2 (Target: 31-12-2025), ANPARA TPS U#3 (Target: 31-12-2025), ANPARA TPS U#4 (Target: 31-12-2025), ANPARA TPS U#5 (Target: 31-12-2025), ANPARA TPS U#6 (Target: 31-12-2025), ANPARA TPS U#7 (Target: 31-12-2025), HARDUAGANJ TPS U#8 (Target: 31-12-2026), HARDUAGANJ TPS U#9 (Target: 31-12-2026), OBRA TPS U#9 (Target: 31-12-2026), OBRA TPS U#10 (Target: 31-12-2026), OBRA TPS U#11 (Target: 31-12-2026), OBRA TPS U#12 (Target: 31-12-2026), OBRA TPS U#13 (Target: 31-12-2026), PARICHHA TPS U#3 (Target: 31-12-2026), PARICHHA TPS U#4 (Target: 31-12-2026), PARICHHA TPS U#5 (Target: 31-12-2026), PARICHHA TPS U#6 (Target: 31-12-2026)

Status of availability of ERS towers in NR

Sl. No.	Transmission Utility	Voltage Level (220kV/400kV/765kV/ 500 kV HVDC etc.)	Length of the transmission lines owned by the Utility (Ckt. Kms.)	Number of ERS Sets (towers) available (Nos.)	ERS Set (towers) required as per the Govt. norms.	Location	Remarks
1	PTCUL	400kV	418.394	NIL	1		Tender has been opened and contract activities under process
		220kV	1045.135	NIL	1		
2	Powergrid NR-1	220 KV	1842.88	NIL	1		
		400 KV	11074.26	12 Towers	3	All 400kV ERS at Ballabgarh	make-Lindsey
		765 KV	4721.85	15 Towers	1	All 765kV ERS at Meerut	Make-SBB
		500 KV HVDC	653.88	NIL	1		
3	Powergrid NR-2	800 KV HVDC	416.58	NIL	1		
		66 KV	37.56	Nil	1		ERS tower available for 400KV rating can be used in place of lower as well as higher voltage Towers. In case used for 765KV Line, No of towers can be erected will reduce due to increase in Tower Hight.
		132 KV	262.7	Nil	1		
		220 KV	2152	Nil	1		
		400 KV	8097.3	02 Set (32 Towers)	2	Kishenpur & Jalandhar	
765 KV	337.5	Nil	1				
4	Powergrid NR-3	800KV HVDC	2205	NIL	1		400KV ERS will be also be used in other voltage level lines
		500KV HVDC	2566	NIL	1		
		765KV	4396	NIL	1		
		400KV	12254	26 Towers	3	Kanpur	
		220KV	1541	NIL	1		
		132KV	207	NIL	1		
5	PARBATI KOLDAM TRANSMISSION COMPANY LIMITED	400kV	457	NIL	1		Procurement under process.
6	PATRAN TRANSMISSION COMPANY LTD	400kV	0.4	NIL	1	It is kept in Bhopal and on need basis is moved across region	Not available, will tie up based on the requirements in future. However the parent company IndiGrid owns one set of ERS for all five regions.
7	NRSS-XXIX TRANSMISSION LTD	400kV	853	NIL	1		
8	GURGAON PALWAL TRANSMISSION LTD	400kV	272	NIL	1		
9	RAPP Transmission Company Limited.	400kV	402	NIL	1		
10	NRSS XXXVI Transmission Limited	400kV	301.924	NIL	1		Element I - Operational comprising of 3 kms. Element II - Work Under Progress comprising of 221.924 kms. Element II - Work Under Progress comprising of 77 kms.
11	HPPTCL	220 kV	659	NIL	1		
		400 kV	75.7	NIL	1		
12	RVPN	132 kV	18969.958	1	4	01 No. ERS available at 220 kV GSS Heerapura, Jaipur	ERS proposed : 01 Set at 400 kV GSS, Jodhpur. 01 set at 400 kV GSS Bikaner
		220 kV	16227.979		3		
		400 kV	6899.386		2		
		765 kV	425.498		1		
13	DTL	220kV	915.498	NIL	1	400kV Bamnauli Sub station	ERS tower available for 400KV rating can also be used for lower voltage lines as well
		400kV	249.19	02 Sets (32 towers)	1		
14	JKPTCL						JKPTCL, Jammu: being procured
15	HVPN						JKPTCL, Kashmir:10 tower procured (out of which 3 on loan to JKPTCL, Jammu)

Sl. No.	Transmission Utility	Voltage Level (220kV/400kV/765kV/ 500 kV HVDC etc.)	Length of the transmission lines owned by the Utility (Ckt. Kms.)	Number of ERS Sets (towers) available (Nos.)	ERS Set (towers) required as per the Govt. norms.	Location	Remarks
16	PSTCL	400 kV 220 kV	1666.43 7921.991	2	2		
17	UPPTCL 1- Meerut	132KV	27508.321	24 Nos(15 Running+9 Angle)		400 kV S/s Gr. Noida	ERS will be also be used in other voltage level lines.
		220KV	14973.453				
		400KV	6922.828				
	UPPTCL 2-Prayagraj	765KV	839.37	24 Towers		220 kv S/s phulpur	ERS will also be used in other voltage lines.
		400KV	1804.257				
		220KV	2578.932				
		132KV	4714.768				
18	POWERLINK						
19	POWERGRID HIMACHAL TRANSMISSION LTD						
20	Powergrid Ajmer Phagi Transmission Limited						
21	Powergrid Fatehgarh Transmission Limited						
22	POWERGRID KALA AMB TRANSMISSION LTD						
23	Powergrid Unchahar Transmission Ltd						
24	Powergrid Khetri Transmission Limited						
25	POWERGRID VARANASI TRANSMISSION SYSTEM LTD						
26	ADANI TRANSMISSION INDIA LIMITED		2090	1 Set (12 towers)	1 set (12 towers)	Sami (Gujarat)	Make-Lindsey ERS set available for 400KV & 500KV rating can be used for lower as well as higher voltage Towers. In case used for 765KV Line, No of towers can reduce due to increase in Tower Height & nos of conductors.
27	BIKANER KHETRI TRANSMISSION LIMITED		482				
28	FATEHGARH BHADLA TRANSMISSION LIMITED	500 kV HVDC 400 kV HVAC	291				
29	NRSS-XXXI(B) TRANSMISSION LTD	400 kV	577.74	Not Available	Not Available		In the advance stage of process of finalising arrangement for providing ERS on need basis with other transmission utility (M/s INDIGRID).
30	ARAVALI POWER COMPANY PVT LTD	765 kv HVAC					

*The transmission Utility with line length less than 500 ckt kms (of 400 KV lines) may be given option either to procure ERS or have agreement with other transmission utilities for providing ERS on mutually agreed terms, when need arises. (As per MoP directions)

Capacity (MW) 30-11-2023	Name of Station	UNIT_NM	STN_TYP E_ID	SECTOR	REGION_NM	ST_NM	SH_NM	IPP	FUEL_NM	Capacity (MW) 31-03-2025	Approved Planned Outage-1			Actual Planned Outage-1		
											Start Date	End Date	Reason	Start Date	End Date	Reason for any deviation
660	TALWANDI SABO TPP	3	T	IPP SECTOR	Northern	Punjab	TSPL	FALSE	COAL	660	7-Oct-24	31-Oct-24	AOH			
135	JALIPA KAPURDI TPP	7	T	IPP SECTOR	Northern	Rajasthan	JSWBL	FALSE	LIGNITE	135	23-Oct-24	30-Oct-24	AOH			
135	JALIPA KAPURDI TPP	5	T	IPP SECTOR	Northern	Rajasthan	JSWBL	FALSE	LIGNITE	135	15-Oct-24	22-Oct-24	AOH			
135	JALIPA KAPURDI TPP	6	T	IPP SECTOR	Northern	Rajasthan	JSWBL	FALSE	LIGNITE	135	5-Oct-24	12-Oct-24	AOH			
250	CHHABRA TPP	3	T	STATE SECTOR	Northern	Rajasthan	RRVUNL	FALSE	COAL	250	1-Oct-24	20-Oct-24	AOH			
660	CHHABRA TPP	6	T	STATE SECTOR	Northern	Rajasthan	RRVUNL	FALSE	COAL	660	1-Sep-24	5-Oct-24	AOH			
110	TANDA TPS	3	T	CENTRAL SECTOR	Northern	Uttar Pradesh	NTPC Ltd.	FALSE	COAL	110	1-Oct-24	30-Oct-24	AOH			
225	KASHIPUR CCPP	1	T	IPP SECTOR	Northern	Uttarakhand	SrEPL	FALSE	NATURAL GAS	225	30-Sep-24	2-Oct-24	Offline Waterwash			
214	KASHIPUR CCPP	2	T	IPP SECTOR	Northern	Uttarakhand	SrEPL	FALSE	NATURAL GAS	214	6-Oct-24	8-Oct-24	Offline Waterwash			
214	KASHIPUR CCPP	2	T	IPP SECTOR	Northern	Uttarakhand	SrEPL	FALSE	NATURAL GAS	214	21-Oct-24	23-Oct-24	Offline Waterwash			

Analysis of corrosion and scaling in high-voltage direct-current valve cooling water system

X W Li¹ and D Ding^{2,*}, L Wang² and L W Sun²

¹ State Grid Shaanxi Electric Power Company, Xi'an, China.

² State Grid Shaanxi Electric Power Research Institute, Xi'an, China.

*E-mail: dingde5160@163.com

Abstract. In this paper, the problems of corrosion and scaling in the converter valve tower cooling water system based on the ± 500 kV Baode HVDC transmission project with Siemens light-triggered thyristor HVDC transmission technology are analyzed in detail. The corrosion and scaling phenomenon can cause the closure or emergency shutdown of converter valves and bring potential dangers to the safe and stable operation of power grid. So far, there is no fundamental solution to this problem. Based on the investigation of scaling phenomenon of grading electrode and corrosion of thyristor aluminum alloy heat sinks, the scaling law of the grading electrode is proposed and the cause of scaling is put forward and analyzed. Some suggestions are given.

1. Introduction

Converter valve is the core equipment of a high-voltage, direct current (HVDC) electric power transmission system. Considering the valve loss, which inevitably exists, the heat generated by valve loss could largely harm the performance of converter valve. Thus, the internal water cooling system, which effectively helps dissipating the heat out of valve, is of great significance to ensure the normal operation of the converter valve [1]. Unfortunately, operating experiences show that the problem of corrosion and scaling is very common in inner cooling water system of converter valves [2-12]. Despite the use of mixed ion exchange resin for desalination and purification of the internal cooling water of the converter valve, corrosion and scaling still exist in the internal cooling water system of the converter valve, leading to an unsatisfied performance of the heat dissipation and insulation of the converter valve. Accordingly, the safe and stable operation of the thyristor, reactor, damper capacitor and water pipe of the converter valve could be negatively affected.

In this paper, the scaling problem of bipolar grading electrodes in the ± 500 kV Baode HVDC power transmission project is taken as the research object and the corrosion and scaling issues of the internal cooling water system of the converter valve are analyzed and the relevant recommendations and solutions are proposed.

2. Valve cooling water path and grading electrode

2.1. HVDC transmission system

The HVDC transmission technology is one of the most advanced and energy-saving power transmission and transformation technologies in the world, and it is also the key developing technology in Chinese technical equipment field. It has the advantages of asynchronous operation between two AC systems,

fast response, precise adjustment, convenient operation, stable voltage distribution along the line and low operation loss. Moreover, the investment and operation cost of HVDC transmission line are less than that of AC transmission system [13]. HVDC transmission system usually consists of rectifier station, inverter station and HVDC transmission line. Its wiring principle is shown in figure 1.




Figure 1. HVDC transmission system

2.2. Valve cooling water system

Converter valve is one of the most important equipment in HVDC transmission system. Under normal operation, the thyristor generates high heat with high current flowing, which causes the temperature of the thyristor to rise sharply. The thyristor must be cooled effectively, or it will be burnt out. The temperature of the thyristor of the converter valve is generally less than 90°C. The heat dissipation of thyristor is realized by the aluminum alloy heat sinks which is closely contacted with thyristor by internal cooling water cooling. The system flow chart is shown in figure 2.




Figure 2. Air cooling water system

2.3. Valve assembly waterway

The valve hall of the converter valve is divided into three phases, namely A, B and C. Each phase is subdivided into left (L) and right (R) sides, each side being split into six layers. Each valve assembly is composed of series thyristors. The thyristors are separated by aluminum alloy heat sinks. The heat sinks are connected by waterways, and the heat of the heat sinks is derived by cooling water.

The connection modes of cooling water pipeline of valve assembly could be segmented to series type, parallel type and series-parallel type. The series type of connection mode is mainly based on ABB technology route. The flow rate in series type is large, but the temperature difference between the head and the tail is huge too. The parallel type is mainly based on SIEMENS technology route. The series-parallel type, mainly based on Zhonglian Puri technology route, combines the advantages of ABB and SIEMENS given water route arrangement of flow and temperature.

SIEMENS technology route was adopted in ± 500 kV converter station. Its valve assembly waterway was parallel, A is thyristor, B is heat sinks, C is connecting water pipe. The schematic diagram is shown in figure 3, and the valve assembly is shown in figure 4.




Figure 3. Parallel connection water line




Figure 4. SIEMENS Valve assembly

2.4. Grading electrode position

In order to avoid discharging unevenly on the inner and outer wall of cooling water pipeline in the converter valve due to uneven voltage distribution, and leakage current caused by the contact between metal equipment and water pipeline in the valve assembly, grading electrodes were installed on the main cooling water pipe of the valve tower and the water distribution and catchment pipes in the valve assembly. The appearance of the grading electrodes is shown in Figure 5. For the grading electrode, the effective part presented is platinum, of 23.8 mm in length and 2 mm in diameter; the remaining part is stainless steel. The installation of grading electrodes could help realizing even voltage distribution on the inner and outer wall of the main water cooling pipeline and help releasing leakage current, which now transfer from thyristor aluminum alloy heat sinks to inert platinum electrode. By doing this, the corrosion phenomenon of electrical equipment could be avoided [14].




Figure 5. Grading electrodes

There were 432 grading electrodes installed in the single pole of Baoji Converter Station, including 24 zero potential electrodes. The number of grading electrodes installed on the T-type connection part of valve assemblies and main water pipe was 144, the number of grading electrodes installed on the anode side of thyristor valve assemblies was 288 and the number of grading electrodes installed on the cathode side was 288. The rest were electrode valve tower interlayer electrodes. The installation positions of grading electrodes could be divided into the following categories, as shown in table 1, L: left side, R: right side, L1: on the left and level 1, R1: on the right and level 1, R2\L3\L4\R4\R5\L6 and so on.

Table 1. Grading electrode positions in the valve tower

Valve tower electrode location (A phase, B phase, C phase)		Number of electrodes
Top part tube	L sides	2
	R sides	2
	L1 and R1 upper part	4
	R2 upper part	2
S-shape tube	L3 upper part	2
	L4 and R4 upper part	4
	R5 upper part	2
	L6 upper part	2
T-type tube	L and R sides	12
Water distribution pipe and confluence pipe	Cathode sides.	24
	Anode sides	24
Bottom part tube	L and R side	2

3. Scaling on Grading Electrodes

Based on the investigation of several HVDC transmission projects in China, it is found that the scaling phenomenon of grading electrodes exists in different degrees. Figure 6 (a) and (b) illustrate the difference in scaling for grading electrodes of ABB technical route and grading electrode of Siemens technical route, respectively. In addition, figure 6(c) shows a third type of grading electrode of Zhonglian Puri technical route with some scaling presented.




Figure 6. Three types of electrode scaling

3.1. Scaling phenomenon in Inverter station

The scaling phenomena in Baoji Converter Station were as following: the scaling of the grading electrodes on the anode side of thyristor on the valve assembly was slight and loose; the scaling of the grading electrodes on the cathode side was serious and firm; the zero potential point of the main water pipe of the valve tower was not scaling. The scaling of the grading electrode at the T-type connection between the water distributing pipe of the valve assembly and the main water pipe was moderate, but scaling was very firm.

The scaling on the anode side was slight. The thickness of the scaling of electrode could be calculated as the following: the diameter of the electrode with scaling minus the diameter of the electrode without scaling, and then divide the result by 2. The average thickness of scaling was 0.1-0.2 mm. The scaling distributed evenly, the scaling was crisp and easy to fall off. The scaling on the upstream side was slightly thicker than that on the back side. Only the root part was not covered by scaling, as shown in figure 7.




Figure 7. Deposit on grading electrodes at anode side of valve assembly of Invert station

The scaling of the grading electrodes on the cathode side is serious. Generally, the scaling thickness is 0.6-0.8 mm, the end is thick, the tail is thin, the scaling is firm, and it is not easy to fall off. There is no difference between the scaling on the front and back surfaces. Only the root is not covered by scaling, as illustrated in figure 8.




Figure 8. Deposition of grading electrodes at cathode side of valve assembly of Invert station

Observing the grading electrode at the T-type connection of valve assembly distributing pipeline and main water pipe, general scale thickness is 0.6-0.8 mm, scaling distributed evenly, scaling is very firm, firmly attached to the electrode surface. The scaling is no difference between water front side and back side. Only half of length of the platinum electrode part is covered by scaling, as seen in figure 9.




Figure 9. Deposition of grading electrodes at T-junction of the valve assembly and the main water pipe of Invert station

3.2. *Scaling phenomenon in Rectifier station*

Deyang converter station basically operates as a rectifier, and the scaling of anode side grading electrodes on valve assembly was serious, as shown in Figure 10, which was basically consistent with the scaling of cathode side of valve assembly in rectifier station. The scaling of grading electrodes on cathode side was slight, as shown in figure 11, which was basically consistent with the scaling of anode side of valve assembly in rectifier station; the zero potential point of main water pipe in valve tower was not scaling. The scaling degree of grading electrodes installed on T-type connection of water distributing pipe and main water pipe was at intermediate level, as seen in figure 12.



Figure 10. Deposit on grading electrodes at anode side of valve assembly of rectifier station




Figure 11. Deposit on grading electrodes at cathode side of valve assembly of rectifier station




Figure 12. Deposit on grading electrodes at T-junction of the valve assembly and the main water pipe of rectifier station

4. Scale distribution principle

4.1. Distribution characteristics of scaling

According to the electrode scaling thickness, that is, the diameter of the electrode after scaling minus the diameter of the electrode without scaling, and then divided by 2, and position of grading electrodes scaling, the 864 branch electrodes of bipolar at the BAOJI converter station were all sampled for detection. The electrodes scaling were divided into 6 classes: valve assembly cathode side with serious scaling; anode side with slight scaling; valve assembly T-type tube electrodes with scaling in the middle; S-shape tube electrodes, top part electrodes, pole II bottom screen electrodes with scaling situation in agreement with those at anode side; and pole I bottom screen electrode with scaling situation in agreement with those at cathode side, as seen in tables 2 and 3, the diameter of the electrode after scaling is listed. note: The pole I converter valve has been operating for 44 months, the bottom voltage of the valve tower is -500 kV, the pole II has been operating for 39 months, and the bottom voltage of the valve tower is +500 kV. CL:CL represents the left side of the valve tower of the C phase converter valve, CR\BL\BR\AL\AR and so on.

Table 2. Pole I grading electrode with deposits' data analysis (unit: mm)

Average value	CL	CR	BL	BR	AL	AR
Top part	2.04	2.04	2.02	2.02	2.03	2.05
Mid-upper part	2.11	2.02	2.00	2.01	2.01	2.02
S-type tube	2.05	2.04	2.07	2.05	2.03	2.03
Cathode side	2.63	2.94	2.96	2.95	2.94	2.94
Anode side	2.13	2.23	2.23	2.23	2.23	2.23
T-shape tube	2.04	2.16	2.13	2.08	2.12	2.09
Bottom part	2.88	2.72	2.73	2.65	2.68	2.83

Table 3. Pole II grading electrode with deposits' data analysis (unit: mm)

Average value	CL	CR	BL	BR	AL	AR
Top part	2.04	2.05	2.04	2.04	2.04	2.04
Mid-upper part	2.45	2.52	2.49	2.72	2.62	2.02
S-shape tube	2.06	2.04	2.06	2.06	2.05	2.08
Cathode side	2.34	2.28	2.30	2.28	2.31	2.29
Anode side	2.99	2.93	3.09	2.89	2.95	3.05
T-type tube	2.24	2.10	2.23	2.14	2.19	2.07
Bottom part	2.01	2.01	2.02	2.01	2.02	2.03

4.2. Distribution and treatment of scaling

Baoji converter station functions as an inverter station, therefore, the scale distribution of 432 grading

electrodes of pole I and pole II were basically identical. Thus, the scaling regularity of grading electrodes of Inverter station could be obtained: scaling on the cathode side of thyristor is serious and sturdy, the scaling on the anode side is slight and loose, while scaling degree at the T-type connection is moderate and very firmly attached.

As a rectifier station, the scale distribution of 432 grading electrodes of pole I and pole II in Deyang converter station were the same, but it was different from that in Baoji converter station. Therefore, the scaling regularity of grading electrodes could be concluded that: scaling on the anode side of thyristor is serious, scaling on the cathode side is slight and scaling on the T-type connection is moderate.

Therefore, according to the scaling distribution law of grading electrodes, scaling removal could be carried out purposefully. Inverter station could aim at removing scaling on the cathode side of thyristor of valve assembly, while rectifier station could only focus on scaling on the anode side of thyristor of valve assembly [15].

5. Related detection analysis and treatment recommendations

5.1. Scale analysis

The scales of all grading electrodes were broken and dissolved in hot dilute sulfuric acid with 35% mass concentration. By doing this, the content of metal elements was detected by ICP emission spectrometer. Aluminum elements accounted for 90-96%, iron elements 5-8%, calcium elements 0.1-0.5%, magnesium elements 0.1-0.5%, sodium elements 0.05-0.1%. Detecting the resistance values of the extreme and tail parts of the grading electrode after scaling, the resistance values were found to be 280-350 k Ω . This indicates that the main harm of the scaling of the electrode lies in the gradual loss of the original function of grading voltage and transferring leakage current.

5.2. Water quality inspection

The main metal element found in scaling was aluminum. Analyzing the mass concentration of metal elements in inner cooling water and makeup water of pole I and pole II, seen in Table 4. It was found that the mass concentration of aluminum was very low, only 1.1-1.3 $\mu\text{g/L}$. This indicates that the medium aluminum in scaling of grading electrode may come from the makeup water of valve tower. Therefore, the concentration of Mg^{2+} and Ca^{2+} and the mass concentration of aluminum in the makeup water should be reduced.

Table 4. Water sample analysis of data on cation ion contents ($\mu\text{g/L}$)

Sample name	Na^+	NH_4^+	K^+	Mg^{2+}	Ca^{2+}	Al
Pole I de-gas jar	2.6	0.2	1.5	0.3	5.9	1.3
Pole II de-gas jar	1.1	0.2	0.8	0.2	3.6	1.1
makeup water	1105.8	0.2	389.5	10.3	75.8	1.5

5.3. Structure of aluminum alloy heat sinks

The aluminum alloy material directly contacting the internal cooling water system is only the aluminum alloy heat sinks of the thyristor. Unfolding a piece of aluminum alloy heat sinks running for 3 years, it could be found that there were many black corrosion points in the water inlet and outlet. As shown in figure 13, the water inlet channel (the so-called “double mosquito perfume water path” section) was bright and clean, while the outlet channel had black corrosion spots, as shown in figure 14. The results show that the corrosion products of aluminum alloy may come from the scaling of the grading electrodes, and the corrosion effect exerts no obvious harm to the aluminum alloy heat sinks.



Figure 13. Inlet and outlet section of the heat sink




Figure 14. "Double mosquito perfume water path" section inside of the heat sink

5.4. Waterway voltage analysis

Since grading electrodes connect with heat sink, grading electrodes potentiality varies with the heat sink potentiality, the voltage difference among the grading electrodes is the sum of several heat sink voltage difference, the results listed in table 5.

Table 5. Voltage in the water circuit

Title	Voltage at two ends(V)	Valve condition	Current direction
Two electrodes	26	turn-on	Anode to Cathode
Neighboring heat sinks	2	turn-on	Anode to Cathode
Head-tail heat sinks	26	turn-on	Anode to Cathode
Two electrodes	41665	turn-off	Cathode to Anode
Neighboring heat sinks	3205	turn-off	Cathode to Anode
Head-tail heat sinks	41665	turn-off	Cathode to Anode


5.5. Electrolytic corrosion and scaling analysis

Based on the aluminum-hydroelectric potential-pH chart [16], the following patterns are possible. If the potential exceeds 1.35V above zone with oxygen reaction, the electrolytic water product is oxygen, see Eg.(1). If the potential is below 0.12V zone with the hydrogen reaction, see Equation (2). If the potential

is between 0.12-1.35V, the absorption oxygen corrosion will take place, see Equation (3). If the potential is over -1.676V, aluminum loses electrons and is electrolyzed, see Equation (4).



Through the calculation of $\text{Al}(\text{OH})_3$ pks=32.89 and H_3AlO_3 pK1=11.2, at 18~25°C, the pH value is 5.6~5.8, the oxide film of alumina has the minimum solubility, that is, the aluminum alloy protective film is the best. When the pH value is less than 4.6 or more than 8.3, the protective film begins to dissolve, see Equations (5) and (6):



Therefore, the aluminum alloy heat sink is subject to electrolytic corrosion. The production of hydrogen or oxygen will generate $\text{Al}(\text{OH})_4^-$. So, in the cooling water system, when the valve is turned on, the aluminum hydroxide is absorbed by the electrode surface of valve anode side. When the valve is turned off, the aluminum hydroxide is absorbed by the electrode surface of valve cathode side. In addition, the electrode at the positive potential can produce oxygen, with its volume being about 50% of that at the negative potential, and the electrolysis gas can remove the scaling. Therefore, both rectifier and invert stations have more severe scaling in the electrode at the positive potential than at the negative one.

6. Conclusions

Corrosion in HVDC valves cooling water system was analyzed. The chemical composition of the scaling on the electrodes revealed a large amount of aluminum. Further investigation showed that the aluminum detected was a corrosion product coming from the makeup water of internal cooling water and aluminum alloy heat sinks. It could be found that the surface conductive resistance of the grading electrode increased significantly and the function of grading voltage and transferring leakage current were lost after scaling. Observing the internal of the heat sinks of aluminum alloy, corrosion spots were found. But they are not enough to harm its safe operation. The experiments illustrated that the scaling at the positive potential was higher than that at the negative potential. The scaling principle was different in the rectifier and inverter stations. In the rectifier station, the scaling of grading electrodes at the anode side of valve is serious, while the scaling of grading electrodes at the cathode side is more severe in the inverter station. Based on these regularities of the distribution of the scaling on grading electrodes, targeted scale removal measurements could be carried out. On account of the corrosion of aluminum alloy heat sinks caused by leakage current electrolysis, the conductivity of the internal cooling water system should be lowered as far as possible, and the pH value should be adjusted to a reasonable range.

References

- [1] Liu Z Y 2013 UHV AC/DC Power Grid (Beijing: China Power Press) pp 479-80
- [2] Arinde S Dhaliwal and Fu Y 2008 Special Report for Group B4 (Cigre. Question 1.1-1.5) p 110
- [3] Tian X W, Yang J M and Zhang W P 2010 *Modern Science* **8** pp 68-70
- [4] Wang Y Y, Hao Z J and Lin R 2006 *Southern Power System Technology* **32** pp 80-3
- [5] Li Y 2009 *Journal of Guizhou Electric Power Technology* **115** pp 5-6
- [6] Zhang P D, Hao Z J and Liu H T 2008 *Journal of Electrical Engineering Technology* **12** pp 1-2
- [7] Qian Y H, Zhou Y Y and Xu C W 2012 *Advanced Materials Research* **354-355** pp 1157-60
- [8] Deng B F, Sun H M and Cao J F 2008 *Southern Power System Technology* **2** pp 73-6
- [9] Wang C, Liu X, Wang X, Liu N and Jiao X Y 2015 *Electrical Insulation Conf. (EIC) (Seattle*

- Washington USA*) pp 7-10
- [10] Neubert and Holweg 2007 *Siemens Investigation Report of Scaling Phenomenon on Grading Electrodes in Thyristor Valve Cooling Circuit* (Erlangen, Siemens Technical Note) p 7
 - [11] Lips H P 2002 *IEEE Transactions on Power Delivery* **9** (4) pp 1830-1837
 - [12] Jackson P O, Abrahamsson B, Gustavsson D and Igetoft L 1997 *IEEE Transactions on Power Delivery* **12** (2) pp1049-1052
 - [13] Zhao W J 2011 *HVDC Transmission Engineering* (Second edition) (Beijing: China Power Press) pp 26-27
 - [14] Zhang J W, Wang M H, Deng W B, Luo B and Zhu J 2012 *High Voltage Apparatus* **51**(32) pp 22-25
 - [15] Fu J H, Li Q Y, Gu Y G, Sun H T, Jiao Y F and Zuo K 2014 *Shaanxi Electric Power* **42**(10) pp 72-75
 - [16] Yang Z H, Xu N and Qiu Z X 2000 *Journal of Northeast University (Natural Science Edition)* **21**(4) pp 401-3

Short Communication

Corrosion Behavior of Aluminum in Carbon Dioxide Aqueous Solution at 50 °C

Daoyu Li¹, Zhen Shi², Huaping Xu¹, Yi Chen³, Wenxin Feng¹, Zhiyuan Qiu¹, Hao Liu¹, Gang Lv¹, Shengping Wang^{2,*}, Youping Fan⁴

¹ Guiyang Bureau, Extra High Voltage Power Transmission Company, China Southern Power Grid (CSG), Guiyang 550081, China

² Faculty of Material Science and Chemistry, China University of Geosciences, Wuhan 430074, China

³ Operational Technology Department, Extra High Voltage Power Transmission Company, China Southern Power Grid (CSG), Guangzhou 510663, China

⁴ School of Electrical Engineering, Wuhan University, Wuhan 430072, China

*E-mail: spwang@cug.edu.cn

Received: 15 January 2019 / Accepted: 14 February 2019 / Published: 10 March 2019

In this work, the corrosion behavior of aluminum in carbon dioxide solutions with different concentrations at high temperature (50 °C) was studied. The corrosion of aluminum in the carbon dioxide solutions was inhibited to a certain extent compared to the corrosion in deionized water. It was found that an aluminum electrode in 0.84 $\mu\text{mol L}^{-1}$ carbon dioxide solution with pH 4.35 had the lowest corrosion rate as observed from its lowest corrosion current, the most positive corrosion potential, and the maximum charge transfer impedance. The mechanism for aluminum corrosion inhibition was that HCO_3^- generated by carbon dioxide ionization developed an ordered charge field on the aluminum surface, shielding the diffusion of aluminum ions and inhibiting the dissolution of the oxide film on the aluminum surface. SEM, EDS and XRD confirmed that the corrosion products covering the surface of the aluminum electrode were $\text{Al}(\text{OH})_3$ and/or Al_2O_3 . Based on the above, it was elucidated that the Pt grading electrodes of the high voltage direct current (HVDC) valve cooling system lower the scaling rate in solutions with a certain concentration of carbon dioxide, and it was shown that the concentration of aluminum ions in the inner cooling water is a crucial factor affecting the scaling of grading electrodes. Therefore, reducing the concentration of aluminum ions in the inner cooling water, in other words, inhibiting the corrosion of aluminum, is the fundamental means for solving the scaling problem of the grading electrode. This paper will contribute to the research on production improvement techniques used for HVDC valve cooling systems.

Keywords: Aluminum, Corrosion, Carbon dioxide solution, Bicarbonate radical, Radiator, Thyristor, High voltage direct current

1. INTRODUCTION

High voltage direct current (HVDC) transmission systems have become the preferred resource allocation and long distance power transportation method due to their narrow transmission corridor, high transmission efficiency, and low power consumption [1, 2]. Unfortunately, the scaling of grading electrodes in deionized water cooling circuits of HVDC power transmission modules is a long-known and unsolved problem that has a great impact on the safe operation of the HVDC transmission system. Deionized water is used as the cooling water circulating in the in-valve cooling system, and its working temperature is in the range of 48-52 °C. Grading electrodes are cylindrical bright platinum electrodes with deposition of mixed aluminum oxides and hydroxides (alumina) [3, 4]. The aluminum element in the deposition is derived from corrosion of the aluminum radiator and is precipitated on the surface of the grading electrodes under appropriate conditions. To solve the scaling problem of the grading electrode, it is necessary to suppress the corrosion behavior of the aluminum radiator in the in-valve cooling water system [5]. Previous reports have focused on the corrosion characteristics of aluminum in weak acid media (hydrochloric acid, sulfuric acid) [6, 7], aqueous alkaline solutions [8, 9] and neutral dilute salt solutions (for instance, halide media [10, 11] and sodium sulfate solution [12]).

According to the studies by Weber [13] and Siemen [14], the introduction of a certain concentration of carbon dioxide in the deionized water at 25 °C lowered the scaling rate of grading electrodes. However, they did not identify the origin for the lowering of the grading electrode scaling rate. The scaling on the surface of the grading electrode is due to aluminum deposition, indicating that the corrosion behavior of the aluminum radiator in the inner cooling water system was suppressed when the scaling rate was lowered. This paper discusses the electrochemical corrosion behavior of aluminum in different concentrations of carbon dioxide aqueous solution at 50 °C in order to elucidate the corrosion mechanisms, providing guidance for solving the scaling problem of the grading electrode in the HVDC valve cooling system.

2. EXPERIMENTAL SECTION

2.1. Electrochemical system

An electrochemical system for testing consisted of a working electrode, a reference electrode, a counter electrode and an electrolyte. Platinum black electrodes were used as the counter electrodes, and saturated calomel electrodes (SCE) were used as the reference electrodes. The SCE potential at 50 °C is 0.228 V (relative to the standard hydrogen electrode (SHE)). The working electrodes were cut from the aluminum radiator with a 1 cm × 1 cm working surface. The model 3003 aluminum electrode was used [15] that was composed of Si (0.57 wt%), Fe (0.63 wt%), Cu (0.14 wt%), Mn (1.27 wt%), Zn (0.09 wt%), Li (0.03 wt%) and Al (97.31 wt%). All of the surfaces other than the 1 cm² working surface were coated with epoxy resin. Prior to testing, the working electrodes were polished with diamond paper and nano-alumina powder, cleaned with deionized water and absolute ethanol, and dried and immersed in the testing electrolytes for 24 h.

Different concentrations of carbon dioxide electrolyte were prepared by the aeration method, and the concentration was controlled by different ventilation times. First, N₂ was injected into deionized water (100 mL) for 5 min (excluding the dissolved air in deionized water), and then CO₂ was injected into deionized water for 0, 10, 20, 30, 40, 50 and 60 min. Finally, all electrolytes were closed and left standing for 12 h. The concentrations of the carbon dioxide solutions were tested according to the ISO 925-1997 standard [16]. An S470 pH meter was used to test the pH of the electrolytes.

2.2. Electrochemical Test

Steady state polarization curves and electrochemical impedance spectroscopy (EIS) spectra were obtained using a CHI660D electrochemical workstation. The potential scan rate was 1 mV s⁻¹, and the potential range was 0.8 V (ranging from the potential 0.4 V lower than the stable potential to the potential 0.4 V higher than the stable potential). The corrosion potential and corrosion current density were obtained from the polarization curves.

The corrosion characteristics of the aluminum surface were determined from the results of EIS analysis that was performed over a frequency range from 1 Hz to 10⁵ Hz with an amplitude of 5 mV. The electrolyte temperatures for all tests were between 48 and 52 °C. During the testing, the electrochemical systems were kept in a shielding box.

2.3. Characterization



All of the SEM, EDS, and XRD test samples underwent accelerated corrosion by potentiostatic anodic oxidation for a more clear observation and analysis of the corrosion surface and corrosion products of aluminum. The anodization process used a two-electrode system with platinum as the cathode and an aluminum electrode after pre-treatment (polished, washed) as the anode. The stable potential (open circuit potential) at various concentrations was tested prior to the anodization. Based on the stable potential, the oxidation overpotential of 30 mV was increased to conduct accelerated corrosion experiments. The compositions of corrosion products were determined using a D8-Focus X-ray powder diffraction instrument with a Cu target. The scanning angle range was from 5 to 80 degrees, and the scan rate was 8° min⁻¹. SEM was performed using an SU8010 ultrahigh resolution field emission scanning electron microscope equipped with high performance X-ray energy dispersive spectroscopy (EDS).

3. RESULTS AND DISCUSSION

3.1. Different concentrations and pH of carbon dioxide solutions

The concentrations and pH of the carbon dioxide solution at different ventilation times are shown in Table 1. For 0-30 min, as the ventilation time increased, the concentration of the carbon dioxide solution gradually increased and the pH gradually decreased. Until the ventilation time of 40 min, the concentration and pH of the carbon dioxide solution tended to be stable, indicating that the prepared

carbon dioxide solution was near saturation. The concentration of HCO_3^- in the carbon dioxide solution was calculated according to formula (3), and the concentration of HCO_3^- showed the same trend as the concentration of the carbon dioxide solution.



$$C(\text{H}^+) = C(\text{HCO}_3^{2-}) = \sqrt{C(\text{CO}_2)K_{a1}} \quad (3)$$




Table 1. Concentration and pH of the carbon dioxide solution at different ventilation times

Ventilation time of carbon dioxide solution (min)	Concentration of carbon dioxide solution ($\mu\text{mol L}^{-1}$)	pH	Calculated concentration of HCO_3^- in electrolytes ($\mu\text{mol L}^{-1}$)
0	0	6.12	0.76
10	345	5.76	1.74
20	535	5.37	4.27
30	750	4.67	21.38
40	850	4.36	43.65
50	886	4.35	44.67
60	876	4.35	44.67

According to the ionization reactions (1), (2) and (4) of carbon dioxide in water, CO_2 , H_2CO_3 molecules, and HCO_3^- and CO_3^{2-} ions are present in the carbon dioxide solution. For the study of the corrosion mechanisms of aluminum in the carbon dioxide solution, the CO_2 and H_2CO_3 molecules and the HCO_3^- and CO_3^{2-} ions in the carbon dioxide solution should be analyzed. Examination of the equilibrium ionization constants shows that the second-order ionization constant ($K_{a2} = 4.7 \times 10^{-11}$) of carbonic acid is far weaker than the first-order ionization constant ($K_{a1} = 4.7 \times 10^{-7}$). Thus, there are more HCO_3^- ions in the solution. Therefore, it is speculated that HCO_3^- ions play a major role in inhibiting aluminum corrosion in the carbon dioxide solution.

3.2. Polarization curves

The polarization curves of the aluminum electrodes are shown in Fig. 1. It is well known that the more positive the corrosion potential and the lower the corrosion current, the lower the aluminum corrosion rate [17, 18]. As the concentration of the carbon dioxide solution increased to $850 \mu\text{mol L}^{-1}$, the corrosion potential of aluminum was gradually positively shifted, indicating that the corrosion of aluminum in the carbon dioxide solution was inhibited.

The data for the corrosion potential and the corrosion current density of the aluminum electrodes in the electrolytes are shown in Table 2. The corrosion current of aluminum in the carbon dioxide solution was lower than that in deionized water, indicating that the corrosion resistance of aluminum in the carbon dioxide solution was better than that in deionized water. The lowest corrosion current density and the

most positive corrosion potential of aluminum were measured in the $850 \mu\text{mol L}^{-1}$ carbon dioxide solution, indicating that the lowest corrosion rate of aluminum was obtained in the $850 \mu\text{mol L}^{-1}$ carbon dioxide solution. Thus, injection of CO_2 into deionized water can reduce the corrosion of aluminum.




Figure 1. Polarization curves of aluminum in the carbon dioxide solution.

Table 2. Corrosion potential and current densities of aluminum in carbon dioxide solution at $50 \text{ }^\circ\text{C}$.

Concentration of carbon dioxide solution ($\mu\text{mol L}^{-1}$)	Corrosion potential (V)	Corrosion current density (nA cm^{-2})	Anodic Tafel slope (V dec^{-1})	Cathodic Tafel slope (V dec^{-1})
0	-0.884	248.9	0.209	-0.124
345	-0.814	237.4	0.214	-0.145
535	-0.748	219.9	0.217	-0.221
750	-0.719	167.1	0.220	-0.272
850	-0.692	122.6	0.226	-0.195

3.3. EIS curves

According to the analysis of the surface state of the aluminum electrode, contributions from charge transfer impedance due to the oxidation of aluminum, diffusion impedance of ions in the electrolyte, impedance of the electric double layer capacitor, and impedance of the cladding layer should be present. The EIS curves of the aluminum electrode in carbon dioxide solutions with different concentrations are shown in Fig. 2a. The Nyquist diagrams of aluminum corrosion in carbon dioxide solutions with different concentrations show similar plots consisting of a semicircle and a straight line.

The physical meaning of the semicircle diameter in the high-frequency region is the charge transfer impedance (R_{ct}) during the etching process, and the charge transfer impedance reflects the corrosion resistance of the aluminum in the solution. The lower the charge transfer impedance, the lower the aluminum corrosion resistance [19-21]. The equivalent circuit diagram of the electrochemical impedance spectrum is shown in Fig. 2c.




Figure 2. EIS curves (a), partially enlarged view of the curves (b), and their equivalent circuit model (c) for the aluminum electrodes in the carbon dioxide solutions at stable potential. The original data curves and the fitting curves are indicated by dotted and solid lines, respectively.

R_1 represents the resistance of the solution between the aluminum electrode and the reference electrode, R_2 represents the impedance of the electrolyte through the deposition layer, R_3 represents the charge transfer impedance for aluminum oxidation, C_1 represents the capacitance of the cladding layer, C_2 represents the capacitance of the double layer, and W represents the diffusion impedance of the ions in the electrolyte [22, 23].

Table 3. EIS parameters obtained by fitting the data to equivalent circuit model.

Concentration ($\mu\text{mol L}^{-1}$)	R_1 (Ω)	R_2 (Ω)	R_3 ($10^{-6}\Omega$)	C_1 (10^{-9}F)	C_2 (10^{-6}F)
0	753.0	1773	25.82	1.709	4.346
345	706.5	2064	30.26	1.464	4.865
535	639.9	2615	33.83	1.233	9.418
750	552.2	2825	38.79	1.168	2.249
850	273.3	3068	39.93	1.449	5.173

The data for the corresponding numerical simulations of the equivalent circuit are shown in Table 3. As the concentration of the carbon dioxide solution increased to $850 \mu\text{mol L}^{-1}$, the charge transfer resistance gradually increases, indicating that the corrosion resistance of aluminum gradually increases and that the corrosion resistance of aluminum in the carbon dioxide solution was better than that in the deionized water. The highest charge transfer impedance was observed for the oxidation of aluminum in the $850 \mu\text{mol L}^{-1}$ carbon dioxide solution. This result was consistent with the results of the polarization curves shown in Fig. 1.

3.4. SEM and EDS

The surface morphologies of the aluminum electrode after corrosion in carbon dioxide solutions with different concentrations are shown in Fig. 3. Fig. 3b shows the presence of significant corrosion on the aluminum electrode surface in deionized water, with gullies, pores, and corrosion products observed. However, the corrosion of aluminum in the carbon dioxide solutions was relatively mild. Fig. 3c and 3d show that only small corrosion holes appeared on the electrode surface for the carbon dioxide solutions at the lower concentrations ($345, 535 \mu\text{mol L}^{-1}$). In Fig. 3e, and 3f, it is observed that the electrode surfaces were very smooth in the carbon dioxide solutions with higher concentrations ($750, 850 \mu\text{mol L}^{-1}$), and no obvious corrosion occurred.




Figure 3. SEM images of the original aluminum (a) and the aluminum electrode surface in $0 \mu\text{mol L}^{-1}$ (b), $345 \mu\text{mol L}^{-1}$ (c), $535 \mu\text{mol L}^{-1}$ (d), $750 \mu\text{mol L}^{-1}$ (e), and $850 \mu\text{mol L}^{-1}$ (f) carbon dioxide solution.

The SEM and EDS of the corrosion products of the aluminum electrode in deionized water and in the $850 \mu\text{mol L}^{-1}$ carbon dioxide solution are shown in Fig. 4. It is observed from Figs. 4a and 4e that the corrosion of aluminum in deionized water was more severe and that more holes appeared. According to the EDS elemental diagram, the distributions of elements for the corrosion products in deionized water and in the $850 \mu\text{mol L}^{-1}$ carbon dioxide solution were similar. Aluminum was uniformly distributed on the electrode surface, while oxygen was mainly concentrated in the corrosion products. The elemental contents of the corrosion products of the aluminum electrode in deionized water and in the $850 \mu\text{mol L}^{-1}$ carbon dioxide solution are shown in Table 4. It was found that the corrosion products consisted mainly of aluminum and oxygen. The corrosion products of the aluminum electrode in deionized water and in the carbon dioxide solution should be consistent. The corrosion product of the aluminum electrode in the carbon dioxide solution did not develop either aluminum carbonate or aluminum hydrogen carbonate.





Figure 4. SEM images (a) and Al (b), O (c) and C (d) of EDS elemental analysis for corrosion products of aluminum in 0 μmol L⁻¹ carbon dioxide solution, and SEM images (e) and Al (f), O (g) and C (h) of EDS elemental analysis for the corrosion products of aluminum in the 850 μmol L⁻¹ carbon dioxide solution.

Table 4. Elemental contents obtained from the EDS analysis results presented in Figure 4.

Concentration of carbon dioxide solution ($\mu\text{mol L}^{-1}$)	Al-K		O-K		C-K	
	Wt %	At%	Wt %	At%	Wt %	At%
0	84.51	75.35	12.63	18.90	2.86	5.72
850	86.36	77.10	11.53	18.31	2.11	4.59

3.5. XRD

The XRD spectra of the corrosion products of the aluminum electrodes in carbon dioxide solutions with different concentrations are shown in Fig. 5. For all of the samples, four strong peaks are observed at 39° , 45° , 65° , and 78° that match well to Al (PDF#040-708). Two strong peaks observed at 25° and 63° also correspond well to $\text{Al}(\text{OH})_3$ (PDF#26-0025) and Al_2O_3 (PDF#33-0018), respectively. This indicates that the corrosion products of aluminum electrodes in the carbon dioxide solutions and the deionized water contained $\text{Al}(\text{OH})_3$ and Al_2O_3 . This was consistent with the corrosion products of aluminum in moist air [24, 25]. As the concentration of the carbon dioxide solution increased, the peaks of the $\text{Al}(\text{OH})_3$ and Al_2O_3 corrosion products at 25° and 63° gradually weakened. The peak of the corrosion product in the $850 \mu\text{mol L}^{-1}$ carbon dioxide solution almost disappeared. This indicated that the corrosion resistance of aluminum in the carbon dioxide solution was better than that in deionized water and that the lowest corrosion rate of aluminum was obtained in the $850 \mu\text{mol L}^{-1}$ carbon dioxide solution.

**Figure 5.** XRD spectrum of the corrosion products on the aluminum surface in the carbon dioxide solution.

3.6. Corrosion mechanism

It is speculated that HCO_3^- ions play a major role in inhibiting aluminum corrosion in carbon dioxide solutions. This paper mainly explores the origin for the inhibition of aluminum corrosion by HCO_3^- ions.

According to the work of Lashgari [26], the following processes are involved in the aluminum corrosion phenomena: damage of oxide/passive film (hydroxylation process) [27, 28], anodic metallic dissolution, and proton reduction. The oxide films are often chemically unstable in aqueous media and dissolve gradually through the interaction with water molecules, corresponding to the so-called hydroxylation process. At the interface region, some particular anions such as Cl^- [29, 30] can facilitate the hydroxylation process at the high energy surface active sites. However, HCO_3^- anion is relatively large and is adsorbed at a long distance and brings fewer water molecules onto the surface-active sites. Therefore, HCO_3^- ions inhibit aluminum corrosion based on suppressing the dissolution of the oxide film on the aluminum surface.

In the carbon dioxide electrolyte, HCO_3^- generated by carbon dioxide ionization adsorbed on the aluminum surface, eliminating the electric field on the original Al surface. The layer of bicarbonate HCO_3^- becomes electrostatically repulsive, reversing the charge in the oxide film layer for OH^- , which will suppress the deposition of aluminum on the surface. HCO_3^- continuously gathers on the surface of the electrode to form a shielding layer, shielding the diffusion of aluminum ions in solution. The Al^{3+} of the Helmholtz layer and the aluminum electrodes reach equilibrium of dissolution-precipitation. Because the continuous dissolution of aluminum is suppressed, aluminum corrosion is also suppressed.

4. CONCLUSIONS

The corrosion behavior of aluminum in weakly acidic carbon dioxide solution was studied. The electrolyte was simulated according to the working conditions of HVDC. The corrosion environment of aluminium was also special, such as high temperature, low conductivity and so on. Aluminum corrosion under these specific conditions was rarely reported. The results showed that compared to deionized water, the corrosion of aluminum in the carbon dioxide solution was suppressed. It was found that an aluminum electrode in the $0.84 \mu\text{mol L}^{-1}$ carbon dioxide solution with pH 4.35 had the lowest corrosion rate as observed from its lowest corrosion current, the most positive corrosion potential, and the maximum charge transfer impedance. It was confirmed that HCO_3^- plays a major role in inhibiting aluminum corrosion in carbon dioxide solutions. HCO_3^- inhibited aluminum corrosion by inhibiting the dissolution of the oxide film on the aluminum surface and by electrostatic repulsion of OH^- in solution.

This report focused on the primary reason for the grading electrodes scaling in HVDC valve cooling systems. It was elucidated that reducing the concentration of aluminum ions in the inner cooling water, in other words, inhibiting the corrosion of aluminum, is the fundamental means for solving the scaling problem of the grading electrode. This paper will provide guidance for the future application of aluminum in HVDC systems.

ACKNOWLEDGMENTS

This work was supported by the Programs of the China Southern Power Grid (CGYKJXM20180394, CGYKJXM20160094).

References

1. A. Kalair, N. Abas and N. Khan, *Renew. Sust. Energ. Rev.*, 59 (2016) 1653.
2. B.V. Eeckhout, D.V. Hertem and M.Reza, *Int. T. Electr. Energ.*, 20 (2010) 661.
3. H.Y. Qian, Y.Y. Zhou and W.C. Xu, *Adv. Mater. Res.*, 354 (2012) 1157.
4. Y. Wang, Z. Hao and R. Lin, *High. Voltage. Eng.*, 32 (2006) 80.
5. D.Y. Li, Y.X. Shi, H.P. Xu, Y. Chen, P. Zhou, X.W. Li, W.X. Feng and S.P. Wang, *Int. J. Electrochem. Sci.*, 13 (2018) 9346.
6. J.P. Dasquet, D. Caillard and E. Conforto, *Thin Solid Films*, 371 (2000) 183.
7. I.V. Aoki, M.C. Bernard and C.D. Torresi, *Electrochim. Acta*, 46 (2002) 1871.
8. J. Zhang, M. Klasky and B.C. Letellier, *J. Nucl. Mater.*, 384 (2009) 175.
9. M. Lashgari and A.M. Malek, *Electrochim. Acta*, 55 (2010) 5253.
10. Z. Bo, L. Ying and F. Wang, *Corros. Sci.*, 51 (2009) 268.
11. E. Mccafferty, *Corros. Sci.*, 45 (2003) 1421.
12. S.G. Wang, H.J. Huang, M. Sun, K. Long and Z.D. Zhang, *J. Phy. Chem. C*, 119 (2015).
13. I. Weber, B. Mallick, M. Schild, S. Kareth, R. Puchta and E.R. Van, *Chem. Eur. J.*, 20 (2015) 12091.
14. P.O. Jackson, B. Abrahamsson and D. Gustavsson, *IEEE. T. Power. Deli.*, 12 (1997) 1049.
15. C.Y. Kong, R.C. Soar and P.M. Dickens, *J. Mater. Process. Technol.*, 146 (2004) 181.
16. Solid mineral fuels determination of carbonate carbon content gravimetric method, *ISO 925-1997*.
17. S.M. Moon and S.I. Pyun, *Corros. Sci.*, 39 (1997) 399.
18. M.A. Amin, S.S. Abd El Rehim and A.S. El Lithy, *Corros. Sci.*, 52 (2010) 3099.
19. S.I. Pyun and S.M. Moon, *J. Solid. State. Electrochem.*, 4 (2000) 267.
20. N.D. Nam, W.C. Kim and J.G. Kim, *Mater. Corros.*, 63 (2012) 1004.
21. B. Zhang, Y. Li and F.H. Wang, *Corros. Sci.*, 49 (2007) 2071.
22. M. Trueba, S.P. Trasatti and D.O. Flamini, *Corros. Sci.*, 63 (2012) 59.
23. J. Wysocka, S. Krakowiak and J. Ryl, *J. Electroanal. Chem.*, 778 (2016) 126.
24. G.S. Frankel, *J. Electrochem. Soc.*, 29 (1998) 2186.
25. T.H. Nguyen and R.T. Foley, *J. Electrochem. Soc.*, 129 (1982) 27.
26. M. Lashgari, E. Kianpour and E. Mohammadi, *J. Mater. Eng. Perform*, 22 (2013) 3620.
27. P.J. Eng, T.P. Trainor, G.E. Brown, G.A. Waychunas, M. Newville, S.R. Sutton and M.L. Rivers, *Science*, 288 (2000) 1029.
28. E.J. Lee and S.I. Pyun, *Corros. Sci.*, 37 (1995) 157.
29. M. Lashgari, *Electrochim. Acta*, 56 (2011) 3322.
30. W.M. Carroll, M. Murphy and C.B. Berslin, *Corros. Sci.*, 34 (1993) 1495.

© 2019 The Authors. Published by ESG (www.electrochemsci.org). This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution license (<http://creativecommons.org/licenses/by/4.0/>).

I/7249/2019



Annexure-A.VI

भारत सरकार
 Government of India
 विद्युत मंत्रालय
 Ministry of Power
 केन्द्रीय विद्युत प्राधिकरण
 Central Electricity Authority
 विद्युत प्रणाली योजना एवं मूल्यांकन - I प्रभाग
 Power System Planning & Appraisal - I Division

सेवा में/ To

1.	Chairperson, Central Electricity Authority Sewa Bhawan, R.K. Puram, New Delhi – 110 066.	2.	Member (Power System), Central Electricity Authority Sewa Bhawan, R.K. Puram, New Delhi – 110 066.
3.	Member (Economic & Commercial), Central Electricity Authority Sewa Bhawan, R.K. Puram, New Delhi – 110 066.	4.	Director (Trans) Ministry of Power Shram Shakti Bhawan, New Delhi-110001.
5.	Chief Operating Officer, Central Transmission Utility POWERGRID, Saudamini, Plot No. 2, Sector-29, Gurgaon – 122 001.	6.	Manoj Kumar Upadhyay Deputy Adviser NITI Aayog, Parliament Street, New Delhi – 110 001.
7.	Shri P. K. Pahwa, Ex. Member (GO&D), CEA 428 C, Pocket -2, Mayur Vihar, Phase -1, Delhi – 110091.	8.	Shri Prabhakar Singh, Ex. Director (Projects), POWERGRID D 904, Tulip Ivory, Sector-70, Gurgaon – 122 001.

Subject: 6th meeting of "National Committee on Transmission" (NCT) held on 30th September, 2019 – Minutes of Meeting

Sir/Madam,

6th meeting of the "National Committee on Transmission" (NCT) was held on 30th September, 2019 at 3:30 pm under the chairmanship of Shri P. S. Mhaske, Chairperson, CEA in conference Room of CEA (Chintan), 2nd Floor, Sewa Bhawan, R.K. Puram, New Delhi. Minutes of the meeting are available on CEA website <http://www.cea.nic.in>. (path to access: Home Page-Wing-Power System-PSPA I-National Committee on Transmission)

Yours faithfully,

(Goutam Roy)

Chief Engineer(PSPA-I) & Member Secretary (NCT)

I/7249/2019

MVAr MSC, 2x125 MVAr MSR at both Fatehgarh-II and Bhadla-II S/s for voltage stability.

4.3.4.2 NCT agreed with the proposal and recommended the following:

- (a) Transmission scheme “Transmission system strengthening scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under phase II –Part B1 (765/400/220 ICT augmentation at Fatehgarh II and Bhadla-II)” **may be considered for implementation through RTM route as it involves upgradation of substation /addition of transformation capacity in under implementation substation.**
- (b) The completion schedule for scheme would be same as the completion schedule of the scheme “Transmission system strengthening for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under phase II –Part B”
- (c) SECI to invite bids for setting up of Solar RE projects for the entire potential of 2.2 GW in Fatehgarh and 1.05 GW in Bhadla in similar time frame and ensure that entire capacity is bid out to avoid non-utilization of ISTS scheme.

4.3.5 Name of the Scheme: Transmission system strengthening scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under phase-II- Part C

Sl. No.	Scope of the Transmission Scheme	Capacity /km	Estimated Cost (in Rs Cr)
1.	Establishment of 765/400 kV, 2x1500 MVA at Sikar – II with 400kV (1x125 MVAr) and 765 kV (2x330 MVAr) bus reactor <i>Future provisions: Space for- 765/400kV ICT along with bays -2 765 kV line bays along with switchable line reactors – 10 400 kV line bays along with switchable line reactor –6 400/220kV ICT along with bays -4 220kV bays -8 400kV bus reactor -2</i>	765/400 kV, 1500 MVA ICT – 2 765/400 kV, 500 MVA spare single phase ICT-1 765 kV ICT bays – 2 400 kV ICT bays – 2 765 kV line bays –2 400 kV line bays-2 125 MVAr, 420 kV bus reactor-1 420 kV reactor bay – 1 330 MVAr, 765 kV bus reactor- 2 765 kV reactor bay- 2 110 MVAr, 765 kV, 1 ph Reactor (spare unit) -1	322
2.	Bhadla-II PS – Sikar-II 765kV D/c line	Length- 310 km	1452
3.	2 no. of 765 kV line bays at Bhadla- II for Bhadla-II PS	765 kV line bays –2	40

I/7249/2019

	– Sikar-II 765kV D/c line		
4.	1x330 MVAR switchable line reactor for each circuit at Sikar-II end of Bhadla-II PS – Sikar-II 765kV D/c line	330MVAR, 765 kV reactor- 2 Switching equipment for 765 kV reactor - 2	62
5.	1x240MVAR switchable line reactor for each circuit at Bhadla-II end of Bhadla-II PS – Sikar-II 765kV D/c line	240MVAR, 765 kV reactor- 2 Switching equipment for 765 kV reactor - 2	50
6.	Sikar-II – Neemrana 400kV D/c line (Twin HTLS*)	Length-140	238
7.	2 no. of 400 kV line bays at Neemrana for Sikar-II – Neemrana 400kV D/c line (Twin HTLS*)	400 kV line bays- 2	18
		Total	2182

**with minimum capacity of 2200 MVA on each circuit at nominal voltage*

Note:

- i. Powergrid to provide space for 2 no of 765 kV bays at Bhadla II and space for 2 no of switchable line reactors at Bhadla II substation
- ii. Powergrid to provide space for 2 no of 400 kV bays each at Neemrana
- iii. The line lengths mentioned above are approximate as the exact length shall be obtained after the detailed survey

4.3.5.1 CEA stated that the scheme “Transmission system strengthening scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under phase II –Part C” has been planned to enable the evacuation of RE power from Ramgarh, Fatehgarh and Bhadla SEZs under phase II.

4.3.5.2 NCT agreed with the proposal and recommended the following:

- (a) Transmission scheme “Transmission system strengthening scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under phase II –Part C” **may be considered for implementation through TBCB route**
- (b) SECI to invite bids for setting up of Solar RE projects for the entire potential of 1.9 GW in Ramgarh, 2.2 GW in Fatehgarh and 1.05 GW in Bhadla in similar time frame and ensure that entire capacity is awarded.
- (e) The implementation time-frame of the transmission schemes associated with Ph-II of 66.5 GW RE integration is December’ 2021. However, the implementation time-frame of the transmission scheme associated with solar RE projects in

DIAMOND CROSSING CASE UPTO OCTOBER

CODE	EVENT NO.	ELEMENT NAME	OUTAGE		Classification/ Category Code	REASON OF OUTAGE
			DATE TIME	DATE TIME		
1	2	3	4	5	6	7
N1PFTL1	TBCB108 24022	765KV FATEHGARH_2-BHADLA_2 Ckt-I (PFTL)	09-08-2024 18:19	10-08-2024 02:11	LCSD	Shutdown for diamond arrangement of Earthwire and OPGW of ckt -1 & Ckt -2 with upcoming Ckt -3 & ckt -4. Approved in 6th NCT meeting dated 30.09.2019 vide MOM point no-4.3.3(1,2,3) on page no 09.
N1PFTL1	TBCB108 24030	765KV FATEHGARH_2-BHADLA_2 Ckt-I (PFTL)	10-08-2024 17:33	12-08-2024 00:55	LCSD	Shutdown for diamond arrangement of Earthwire and OPGW of ckt -1 & Ckt -2 with upcoming Ckt -3 & ckt -4. Approved in 6th NCT meeting dated 30.09.2019 vide MOM point no-4.3.3(1,2,3) on page no 09.
N1PFTL2	TBCB108 24023	765KV FATEHGARH_2-BHADLA_2 Ckt-II (PFTL)	09-08-2024 18:19	10-08-2024 03:12	LCSD	Shutdown for diamond arrangement of Earthwire and OPGW of ckt -1 & Ckt -2 with upcoming Ckt -3 & ckt -4. Approved in 6th NCT meeting dated 30.09.2019 vide MOM point no-4.3.3(1,2,3) on page no 09.
N1PFTL2	TBCB108 24031	765KV FATEHGARH_2-BHADLA_2 Ckt-II (PFTL)	10-08-2024 17:34	12-08-2024 00:56	LCSD	Shutdown for diamond arrangement of Earthwire and OPGW of ckt -1 & Ckt -2 with upcoming Ckt -3 & ckt -4. Approved in 6th NCT meeting dated 30.09.2019 vide MOM point no-4.3.3(1,2,3) on page no 09.
N1PFTL1		765 KV BHADLA_2 (PG)-FATEHGARH_II(PG) (PFTL) CKT-1 (PFTL)	10-10-2024 17:00	10-10-2024 23:00	LCSD	for Diamond crossing of OPGW between AP 2/0-3/0 to complete the commissioning work of upcoming 765 KV D/C Bhadla-II-Sikar-II line. Approved in 6th NCT meeting dated 30.09.2019 vide MOM point no-4.3.5 on page no 11-12.
N1PFTL2		765 KV BHADLA_2 (PG)-FATEHGARH_II(PG) (PFTL) CKT-2 (PFTL)	10-10-2024 17:00	10-10-2024 23:00	LCSD	for Diamond crossing of OPGW between AP 2/0-3/0 to complete the commissioning work of upcoming 765 KV D/C Bhadla-II-Sikar-II line. Approved in 6th NCT meeting dated 30.09.2019 vide MOM point no-4.3.5 on page no 11-12.
N1PBTL1		765 KV BHADLA_2 (PG)-FATEHGARH_II(PG) (PBTL) CKT-3 (PBTL)	10-10-2024 17:00	10-10-2024 23:00	LCSD	for Diamond crossing of OPGW between AP 2/0-3/0 to complete the commissioning work of upcoming 765 KV D/C Bhadla-II-Sikar-II line. Approved in 6th NCT meeting dated 30.09.2019 vide MOM point no-4.3.5 on page no 11-12.
N1PBTL2		765 KV BHADLA_2 (PG)-FATEHGARH_II(PG) (PBTL) CKT-4 (PBTL)	10-10-2024 17:00	10-10-2024 23:00	LCSD	for Diamond crossing of OPGW between AP 2/0-3/0 to complete the commissioning work of upcoming 765 KV D/C Bhadla-II-Sikar-II line. Approved in 6th NCT meeting dated 30.09.2019 vide MOM point no-4.3.5 on page no 11-12.
NR176528		765 KV AJMER-BHADLA_2 (PG) CKT-1 (RTM)	21-10-2024 17:33	22-10-2024 04:49	LCSD	for Diamond crossing of Earth wire as well as OPGW of 765kV D/C Ajmer- Bhadla 2 T/L at Tower number 218-219. Approved in 2nd NRSC meeting dated 13.11.2018 vide MOM no.-2.3(v) & 2.3(xxi) on page no. 108 & 109.

DIAMOND CROSSING CASE UPTO OCTOBER

CODE	EVENT NO.	ELEMENT NAME	OUTAGE		Classification/ Category Code	REASON OF OUTAGE
			DATE TIME	DATE TIME		
1	2	3	4	5	6	7
NR176528		765 KV AJMER-BHADLA_2 (PG) CKT-1 (RTM)	22-10-2024 17:09	23-10-2024 05:33	LCSD	for Diamond crossing of Earth wire as well as OPGW of 765kV D/C Ajmer- Bhadla 2 T/L at Tower number 218-219. Approved in 2nd NR SCT meeting dated 13.11.2018 vide MOM no.-2.3(v) & 2.3(XXI) on page no. 108 & 109.
NR176528		765 KV AJMER-BHADLA_2 (PG) CKT-1 (RTM)	23-10-2024 17:23	24-10-2024 00:51	LCSD	for Diamond crossing of Earth wire as well as OPGW of 765kV D/C Ajmer- Bhadla 2 T/L at Tower number 218-219. Approved in 2nd NR SCT meeting dated 13.11.2018 vide MOM no.-2.3(v) & 2.3(XXI) on page no. 108 & 109.
NR176528		765 KV AJMER-BHADLA_2 (PG) CKT-1 (RTM)	24-10-2024 17:26	24-10-2024 23:04	LCSD	for Diamond crossing of Earth wire as well as OPGW of 765kV D/C Ajmer- Bhadla 2 T/L at Tower number 218-219. Approved in 2nd NR SCT meeting dated 13.11.2018 vide MOM no.-2.3(v) & 2.3(XXI) on page no. 108 & 109.
NR176529		765 KV AJMER-BHADLA_2 (PG) CKT-2 (RTM)	21-10-2024 17:33	22-10-2024 03:06	LCSD	for Diamond crossing of Earth wire as well as OPGW of 765kV D/C Ajmer- Bhadla 2 T/L at Tower number 218-219. Approved in 2nd NR SCT meeting dated 13.11.2018 vide MOM no.-2.3(v) & 2.3(XXI) on page no. 108 & 109.
NR176529		765 KV AJMER-BHADLA_2 (PG) CKT-2 (RTM)	22-10-2024 17:10	23-10-2024 05:10	LCSD	for Diamond crossing of Earth wire as well as OPGW of 765kV D/C Ajmer- Bhadla 2 T/L at Tower number 218-219. Approved in 2nd NR SCT meeting dated 13.11.2018 vide MOM no.-2.3(v) & 2.3(XXI) on page no. 108 & 109.
NR176529		765 KV AJMER-BHADLA_2 (PG) CKT-2 (RTM)	23-10-2024 17:25	24-10-2024 01:02	LCSD	for Diamond crossing of Earth wire as well as OPGW of 765kV D/C Ajmer- Bhadla 2 T/L at Tower number 218-219. Approved in 2nd NR SCT meeting dated 13.11.2018 vide MOM no.-2.3(v) & 2.3(XXI) on page no. 108 & 109.
NR176529		765 KV AJMER-BHADLA_2 (PG) CKT-2 (RTM)	24-10-2024 17:26	24-10-2024 23:10	LCSD	for Diamond crossing of Earth wire as well as OPGW of 765kV D/C Ajmer- Bhadla 2 T/L at Tower number 218-219. Approved in 2nd NR SCT meeting dated 13.11.2018 vide MOM no.-2.3(v) & 2.3(XXI) on page no. 108 & 109.
NR176530		400 KV BASSI-SIKAR (PG) CKT-1	26-10-2024 13:23	26-10-2024 21:04	LCSD	for Power Line overhead crossing work of upcoming Sikar II Bhadla II ckt 1 & 2.
NR176530		400 KV BASSI-SIKAR (PG) CKT-1	27-10-2024 08:27	27-10-2024 20:15	LCSD	for Power Line overhead crossing work of upcoming Sikar II Bhadla II ckt 1 & 2.
NR176530		400 KV BASSI-SIKAR (PG) CKT-1	28-10-2024 14:22	28-10-2024 20:24	LCSD	for Power Line overhead crossing work of upcoming Sikar II Bhadla II ckt 1 & 2.

DIAMOND CROSSING CASE UPTO OCTOBER

CODE	EVENT NO.	ELEMENT NAME	OUTAGE		Classification/ Category Code	REASON OF OUTAGE
			DATE TIME	DATE TIME		
1	2	3	4	5	6	7
NR176530		400 KV BASSI-SIKAR (PG) CKT-2	26-10-2024 13:28	26-10-2024 21:05	LCSD	for Power Line overhead crossing work of upcoming Sikar II Bhadla II ckt 1 & 2.
NR176530		400 KV BASSI-SIKAR (PG) CKT-2	27-10-2024 08:27	27-10-2024 20:17	LCSD	for Power Line overhead crossing work of upcoming Sikar II Bhadla II ckt 1 & 2.
NR176530		400 KV BASSI-SIKAR (PG) CKT-2	28-10-2024 14:23	28-10-2024 20:25	LCSD	for Power Line overhead crossing work of upcoming Sikar II Bhadla II ckt 1 & 2.

S.No.	Voltage Level	Name of Line	Circuit ID	Tower Configura	Line Length	O&M by	Agency at		Type of conductor	Remarks	Replaced with Polymer Insulator (As a % of Total Line)	Remarks
							End-I	End-II				
1. HVDC lines												
ISTS LINES												
A. POWERGRID												
1	± 800kV	Agra-Bishwanath Chariali Pole-I	1	Bi-pole	1728	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing	HVDC capacity 6000 MW, only two physical lines	Partial (11%)	
2	± 800kV	Agra-Bishwanath Chariali Pole-II	2	Bi-pole	1728	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing		Partial (11%)	
3	± 800kV	Agra-Alipurduar Pole-I	1	Bi-pole	1296*	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing		Partial (11%)	
4	± 800kV	Agra-Alipurduar Pole-II	2	Bi-pole	1296*	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing	HVDC capacity 6000 MW, only two physical lines	Partial (11%)	
5	± 800kV	Kurukshetra-Champa Pole-I	1	Bi-pole	1305	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing		Partial (11%)	
6	± 800kV	Kurukshetra-Champa Pole-II	2	Bi-pole	1305	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing		Partial (11%)	
7	± 800kV	Kurukshetra-Champa Pole-III	3	Bi-pole	1305	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing	HVDC capacity 2500 MW	Partial (11%)	
8	± 800kV	Kurukshetra-Champa Pole-IV	4	Bi-pole	1305	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing		Partial (11%)	
9	± 500kV	Balia-Bhiwadi Pole-I	1	Bi-pole	790	POWERGRID	POWERGRID	POWERGRID	ACSR Quad Bersimis		Partial (15%)	
10	± 500kV	Balia-Bhiwadi Pole-II	2	Bi-pole	790	POWERGRID	POWERGRID	POWERGRID	ACSR Quad Bersimis	HVDC capacity 1500 MW	Partial (15%)	
11	± 500kV	Rihand-Dadri Pole-I	1	Bi-pole	815	POWERGRID	POWERGRID	POWERGRID	ACSR Quad Bersimis		Partial (62%)	
12	± 500kV	Rihand-Dadri Pole-II	2	Bi-pole	815	POWERGRID	POWERGRID	POWERGRID	ACSR Quad Bersimis		Partial (43%)	
B. Adani Power Ltd (Adani Transmission India Ltd.)												
1	± 500kV	Adani Mundra - Mahindergarh Pole-I	1	Bi-pole	990	ATIL	APL Mundra	ATIL	ACSR Quad Bersimis	HVDC capacity 2500 MW	Partial (43%)	
2	± 500kV	Adani Mundra - Mahindergarh Pole-II	2	Bi-pole	990	ATIL	APL Mundra	ATIL			Partial (43%)	
2. 765kV Transmission Line												
ISTS LINES												
A. POWERGRID												
1	765kV	Agra-Aligarh	1	D/C	123	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis	LILO of Agra-Gr. Noida at Aligarh (LILO portion)	Polymer Insulator	
2	765kV	Aligarh-Gr.Noida	1	D/C	51	POWERGRID	POWERGRID	WUPPTCL	Quad Bersimis		Polymer Insulator	
3	765kV	Agra-Fatehpur	1	S/C	335	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Conventional	
4	765kV	Agra-Fatehpur	2	S/C	334	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Conventional	
5	765kV	Agra-Jhatikara	1	S/C	252	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Polymer Insulator	
6	765kV	Ajmer-Chittorgarh	1	D/C	211	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available	
7	765kV	Ajmer-Chittorgarh	2	D/C	211	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available	
8	765kV	Ajmer-Bhadla II	1	D/C	326	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra	LILO of 765kV D/C Ajmer-Bikaner-1 at Bhadla II(PG)	Not Available	
9	765kV	Ajmer-Bhadla II	2	D/C	326	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra	LILO of 765kV D/C Ajmer-Bikaner-2 at Bhadla II(PG)	Not Available	
10	765kV	Balia - Lucknow765 (N)	1	S/C	319	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Conventional	
11	765kV	Bikaner - Bhadla	1	D/C	167	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available	
12	765kV	Bikaner - Bhadla	2	D/C	167	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available	
13	765kV	Bikaner- Moga	1	D/C	367	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available	
14	765kV	Bikaner- Moga	2	D/C	367	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available	
15	765kV	Bikaner-Bhadla II	1	D/C	197	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra	LILO of 765kV D/C Ajmer-Bikaner-1 at Bhadla II(PG)	Not Available	
16	765kV	Bikaner-Bhadla II	2	D/C	197	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra	LILO of 765kV D/C Ajmer-Bikaner-2 at Bhadla II(PG)	Not Available	
17	765kV	Kanpur(GIS)-Aligarh	1	D/C	322	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis	LILO of Kanpur-Jhatikara at Aligarh	Polymer Insulator	
18	765kV	Aligarh-Jhatikara	1	D/C	158	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Polymer Insulator	
19	765kV	Jhatikara-Bhiwani (PG)	1	S/C	85	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Polymer Insulator	
20	765kV	Koteshwar(PG)-Meerut	1	S/C	176	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis	Earlier charged at 400kV	Not Available	
21	765kV	Koteshwar(PG)-Meerut	2	S/C	176	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Not Available	
22	765kV	Lucknow-Bareilly	1	S/C	252	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Conventional	
23	765kV	Meerut-Bhiwani(PG)	1	S/C	174	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Partial (99%)	

24	765kV	Meerut-Gr.Noida	1	S/C	119	POWERGRID	POWERGRID	WUPPTCL	Quad Bersimis	Agra-Meerut LILOed at G. Noida by UPPTCL	Polymer Insulator
25	765kV	Moga- Bhiwani (PG)	1	S/C	273	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Partial (96%)
26	765kV	Moga-Meerut	1	S/C	338	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Polymer Insulator
27	765kV	Orai-Aligarh	1	D/C	331	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available
28	765kV	Orai-Aligarh	2	D/C	331	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available
29	765kV	Phagi-Bhiwani(PG)	1	S/C	272	POWERGRID	RRVPNL	POWERGRID	Quad Bersimis		Partial (18%)
30	765kV	Phagi-Bhiwani(PG)	2	S/C	277	POWERGRID	RRVPNL	POWERGRID	Quad Bersimis		Partial (16%)
31	765kV	Varanasi-Balia	1	S/C	166	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Conventional
32	765kV	Varanasi-Fatehpur	1	S/C	223	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis	LILO of Gaya (ER)- Fatehpur at Varanasi	Conventional
33	765kV	Varanasi-Kanpur(GIS)	1	S/C	326	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Polymer Insulator
34	765kV	Varanasi-Kanpur(GIS)	2	S/C	326	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Polymer Insulator
B. PKTSL											
1	765kV	Khetri-Jhatikara	1	D/C	146	PKTSL	PKTSL	POWERGRID	Hexa Zebra		Not Available
2	765kV	Khetri-Jhatikara	2	D/C	146	PKTSL	PKTSL	POWERGRID	Hexa Zebra		Not Available
C. PFTL											
1	765kV	Fatehgarh II-Bhadla II	1	D/C	186	PFTL	POWERGRID	POWERGRID	Hexa Zebra		Not Available
2	765kV	Fatehgarh II-Bhadla II	2	D/C	186	PFTL	POWERGRID	POWERGRID	Hexa Zebra		Not Available
D. FBTL											
1	765kV	Fatehgarh II-Bhadla	1	D/C	175	FBTL	POWERGRID	POWERGRID	Hexa Zebra	Loop in of 400kV Fatehgarh (FBTL)-	Polymer Insulator
2	765kV	Fatehgarh II-Bhadla	2	D/C	175	FBTL	POWERGRID	POWERGRID	Hexa Zebra		Polymer Insulator
E. BKTL											
1	765kV	Bikaner-Khetri	1	D/C	241	BKTL	POWERGRID	PKTSL	Hexa Zebra		Polymer Insulator
2	765kV	Bikaner-Khetri	2	D/C	241	BKTL	POWERGRID	PKTSL	Hexa Zebra		Polymer Insulator
F. PAPTL											
1	765kV	Ajmer-Phagi	1	D/C	134	PAPTL	POWERGRID	RRVPNL	Hexa Zebra		Not Available
2	765kV	Ajmer-Phagi	2	D/C	134	PAPTL	POWERGRID	RRVPNL	Hexa Zebra		Not Available
G. PASTL											
1	765kV	Aligarh(PG)-SIKAR_2	1	D/C	265	PASTL	PSTL	POWERGRID	Hexa Zebra	Anti theft charged	Not Available
2	765kV	Aligarh(PG)-SIKAR_2	2	D/C	265	PASTL	PSTL	POWERGRID	Hexa Zebra	from Aligarh(PG) Upto	Not Available
STATE LINES											
A. UPPTCL											
1	765kV	Agra Fatehabad-Ghatampur	1	S/C	229	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis		Not Available
2	765kV	Agra Fatehabad-Gr. Noida	1	S/C	159	UPPTCL	UPPTCL	UPPTCL	ACSR Quad Bersimis		Not Available
3	765kV	Agra(Fatehbad)-Lalitpur	1	S/C	337	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis		Not Available
4	765kV	Agra(Fatehbad)-Lalitpur	2	S/C	335	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis		Not Available
5	765kV	AnparaC-AnparaD	1	S/C	3	UPPTCL	LANCO	UPRVUNL	Quad Bersimis		Not Available
6	765kV	AnparaC-Unnao	1	S/C	409	UPPTCL	LANCO	UPPTCL	Quad Bersimis		Conventional
7	765kV	AnparaD-Obra_C	1	D/C	53	UPPTCL	UPRVUNL	UPPTCL	Quad Bersimis	After LILO of 765 KV	Not Available
8	765kV	Obra_C-Unnao	1	D/C	390	UPPTCL	UPRVUNL	UPPTCL	Quad Bersimis	ANPARA D-UNNAO LINE	Not Available
9	765kV	Bara-Mainpuri	1	S/C	377	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis		Not Available
10	765kV	Gr. Noida-Meerut_PMSTL	1	S/C	100	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis	After LILO of 765 KV	Not Available
11	765kV	Meerut_PMSTL-Hapur	1	S/C	37	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis	GREATER NOIDA	Not Available
12	765kV	Gr. Noida-Jawaharpur	1	D/C	162	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis	After LILO of 765 KV	Not Available
13	765kV	Jawaharpur-Mainpuri	1	D/C	40	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis	MAINPURI(SEUPPTCL)-	Not Available
14	765kV	Hapur(UP)-Rampur_PRSTL (UP)	1	S/C	230	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis	LILO of 765KV Hapur-Ghatampur at Rampur. LILO portion is on D/C tower 2.5km 5towers	Not Available

AnparaB-Unnao shifted to AnparaC and charged at 765kV

15	765kV	Mainpuri(UP)-Hapur(UP)	1	S/C	217	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis		Not Available	
B. RRVPNL												
1	765kV	Anta-Phagi	1	S/C	214	RRVPNL	RRVPNL	RRVPNL	Quad Bersimis		Not Available	
2	765kV	Anta-Phagi	2	S/C	212	RRVPNL	RRVPNL	RRVPNL	Quad Bersimis		Not Available	
3. 765kV Transmission Line charged at 400kV												
ISTS LINES												
A. POWERGRID												
1	765kV charged at 400kV	Kishenpur-Moga	1	S/C	275	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Partial (1%)	
2		Kishenpur-Moga	2	S/C	287	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Partial (1%)	
3		Tehri-Koteshwar(PG)	1	S/C	15	POWERGRID	THDC	POWERGRID	Quad Bersimis		Conventional	
4		Tehri-Koteshwar(PG)	2	S/C	17	POWERGRID	THDC	POWERGRID	Quad Bersimis		Conventional	
5		Rihand-Vindhyachal Pool	1	S/C	31	POWERGRID	NTPC	POWERGRID	Quad Bersimis		Not Available	
6		Rihand-Vindhyachal Pool	2	S/C	31	POWERGRID	NTPC	POWERGRID	Quad Bersimis		Not Available	
4. 400kV HVAC Transmission Line												
ISTS LINES												
A. POWERGRID												
1	400kV	Abdullapur- Bawana	1	D/C	167	POWERGRID	POWERGRID	DTL	Triple Snowbird		Partial (99%)	
2	400kV	Abdullapur- Deepalpur	1	D/C	141	POWERGRID	POWERGRID	KT Jhajjar	Triple Snowbird	LILO of Abdullapur-Bawana one ckt at Deepalpur by Jhajjar KT	Partial (99%)	LILO of Abdullapur-Bawana one ckt at Deepalpur
3	400kV	Abdullapur-Kurukshetra	1	D/C	52	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird+Twin HTLS for LILO	LILO of Abdullapur-Sonapat line at Kurukshetra	Polymer Insulator	LILO of Abdullapur-Sonepat ckts at Kurukshetra
4	400kV	Abdullapur-Kurukshetra	2	D/C	52	POWERGRID	POWERGRID	POWERGRID		LILO of Abdullapur-Sonapat line at Kurukshetra	Polymer Insulator	
5	400kV	Agra-Agra(Fatehabad)	1	S/C	45	POWERGRID	POWERGRID	UPPTCL	Twin Moose	LILO of Agra(PG)-Agra(UP) ckt-2 at Fatehabad (765kV Agra UP)	Polymer Insulator	
6	400kV	Agra(UP)-Agra(Fatehabad)	1	S/C	56	POWERGRID	UPPTCL	UPPTCL	Twin Moose		Polymer Insulator	
7	400kV	Agra-Agra(UP)	1	D/C	30	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Polymer Insulator	
8	400kV	Agra-Ballabgarh	1	S/C	181	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
9	400kV	Agra-Bassi	1	S/C	211	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	Planned for insulator replacement in 321nos towers under NR3
10	400kV	Agra-Bhiwadi	1	D/C	209	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
11	400kV	Agra-Bhiwadi	2	D/C	209	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
12	400kV	Agra-Jaipur South	1	D/C	254	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Agra-Bassi D/C at Jaipur South	Partial (4%)	LILO of Agra-Bassi D/C at Jaipur South
13	400kV	Agra-Jaipur South	2	D/C	254	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Agra-Bassi D/C at Jaipur South	Partial (4%)	
14	400kV	Agra-Sikar	1	D/C	386	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (3%)	
15	400kV	Agra-Sikar	2	D/C	386	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (3%)	
16	400kV	Ajmer-Ajmer(PG)	1	D/C	66	POWERGRID	RRVPNL	POWERGRID	Quad Moose		Not Available	
17	400kV	Ajmer-Ajmer(PG)	2	D/C	66	POWERGRID	RRVPNL	POWERGRID	Quad Moose		Not Available	
18	400kV	Allahabad-Fatehpur	3	S/C	154	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Allahabad-Kanpur one ckt at Fatehpur	Polymer Insulator	
19	400kV	Allahabad-Fatehpur	1	D/C	140	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Lilo of Allahabad-Mainpuri (PG) D/C at Fatehpur	Conventional	
20	400kV	Allahabad-Fatehpur	2	D/C	140	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Lilo of Allahabad-Mainpuri (PG) D/C at Fatehpur	Conventional	
21	400kV	Allahabad-Varanasi	1	D/C	99	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Allahabad-Sarnath shifted from Sarnath to varanasi	Conventional	
22	400kV	Allahabad-Kanpur	1	S/C	225	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
23	400kV	Allahabad-Kanpur(New 765)	1	D/C	240	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
24	400kV	Allahabad-Kanpur(New 765)	2	D/C	240	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
25	400kV	Allahabad-Meja(NTPC)	1	D/C	28	POWERGRID	POWERGRID	MUNPL	Twin Moose		Polymer Insulator	MUNPL is joint venture between NTPC and UPPCL
26	400kV	Allahabad-Meja(NTPC)	2	D/C	28	POWERGRID	POWERGRID	MUNPL	Twin Moose		Polymer Insulator	

27	400kV	Amritsar-Jalandhar	1	S/C	60	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
28	400kV	Amritsar-Jalandhar	2	D/C	71	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	LILO of 400kV Amritsar-Hamirpur at Jalandhar
29	400kV	Amritsar-Parbati Pooling (Banala)	1	D/C	251	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (49%)	
30	400kV	Auraiya-Agra	1	D/C	166	POWERGRID	NTPC	POWERGRID	Twin Moose		Partial (86%)	
31	400kV	Auraiya-Agra	2	D/C	166	POWERGRID	NTPC	POWERGRID	Twin Moose		Partial (90%)	
32	400kV	Baglihar II-Kishenpur	1	S/C	130	POWERGRID	JKSPDCL	POWERGRID	Twin Moose	LILO of 400kV Kishenpur-New Wanpoh ckt-2 at Baglihar. LILO portion is of JK PDD	Conventional	
33	400kV	Baglihar II-New Wanpoh	1	S/C	130	POWERGRID	JKSPDCL	POWERGRID	Twin Moose		Not Available	
34	400kV	Bagpat-Kaithal	1	D/C	154	POWERGRID	POWERGRID	POWERGRID	Quad Moose	LILO of Meerut-Kaithal DC at Bagpat	Polymer Insulator	
35	400kV	Bagpat-Kaithal	2	D/C	154	POWERGRID	POWERGRID	POWERGRID	Quad Moose	LILO of Meerut-Kaithal DC at Bagpat	Polymer Insulator	
36	400kV	Bagpat-Saharanpur	1	D/C	121	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Partial (41%)	
37	400kV	Bagpat-Dehradun	1	D/C	165	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Partial (40%)	
38	400kV	Bahadurgarh-Kabulpur	1	S/C	42	POWERGRID	POWERGRID	HVPNL	Twin Moose		Polymer Insulator	LILO of Bahadurgarh-Bhiwani at Kabulpur
39	400kV	Bahadurgarh-Sonepat	1	D/C	53	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		Polymer Insulator	
40	400kV	Bahadurgarh-Sonepat	2	D/C	53	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		Polymer Insulator	
41	400kV	Balia-Mau	1	D/C	9	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Conventional	
42	400kV	Balia-Sohawal	1	D/C	229	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Balia-LUCKNOW D/C at Sohawal	Conventional	LILO of Balia-Lucknow (316 KM) D/C at Sohawal
43	400kV	Balia-Sohawal	2	D/C	229	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Balia-LUCKNOW D/C at Sohawal	Conventional	LILO of Balia-Lucknow (316 KM) D/C at Sohawal
44	400kV	Ballabgarh-Tughlakabad	1	M/C	40	DTL	POWERGRID	POWERGRID	HTLS INVAR (LILO portion) & Bersimis (before LILO)	Tower is quad circuit tower	Polymer	
45	400kV	Ballabgarh-Tughlakabad	2	M/C	40	DTL	POWERGRID	POWERGRID	HTLS INVAR (LILO portion) & Bersimis (before LILO)	Tower is quad circuit tower	Polymer	
46	400kV	Ballabgarh-Gurgaon	1	S/C	43	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
47	400kV	Ballabgarh-Maharanibagh	1	D/C	61	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis	Bypassed at Maharanibagh to form Dadri-Ballabgarh	Polymer Insulator	
48	400kV	Ballabgarh-Nawada	1	D/C	13	POWERGRID	POWERGRID	HVPNL	Quad Bersimis		Polymer Insulator	Ballabgarh-Gnoida LILOed at Nawada (Faridabad, Haryana)
49	400kV	Bareilly PG-Moradabad	1	D/C	93	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Partial (3%)	
50	400kV	Bareilly PG-Rampur_PRSTL	1	S/C	40	POWERGRID	POWERGRID	UPPTCL	Twin Moose	After LILO of 400 KV BAREILLY(PG)-MORADABAD(UPPTCL) CIRCUIT-II at RAMPUR(PRSTL)	Not Available	
51	400kV	Rampur_PRSTL-Moradabad	1	S/C	57	POWERGRID	UPPTCL	UPPTCL	Twin Moose	After LILO of 400 KV BAREILLY(PG)-MORADABAD(UPPTCL) CIRCUIT-II at RAMPUR(PRSTL)	Not Available	
52	400kV	Bareilly PG-Bareilly (765kV)	1	D/C	2	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Conventional	
53	400kV	Bareilly PG-Bareilly (765kV)	2	D/C	2	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Conventional	

54	400kV	Bareilly PG(765kV)-Kashipur	1	D/C	101	POWERGRID	POWERGRID	PTCUL	Quad Moose		Partial (90%)	
55	400kV	Bareilly PG(765kV)-Kashipur	2	D/C	101	POWERGRID	POWERGRID	PTCUL	Quad Moose		Partial (90%)	
56	400kV	Bassi-Bhiwadi	2	S/C	220	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
57	400kV	Bassi-Heerapura	1	D/C	48	POWERGRID	POWERGRID	RRVNL	Twin Moose		Polymer Insulator	
58	400kV	Bassi-Heerapura	2	D/C	49	POWERGRID	POWERGRID	RRVNL	Twin Moose		Polymer Insulator	
59	400kV	Bassi-Kotputli	1	S/C	106	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
60	400kV	Bassi-Phagi	1	D/C	48	POWERGRID	POWERGRID	RRVNL	Quad Moose		Partial (26%)	
61	400kV	Bassi-Phagi	2	D/C	48	POWERGRID	POWERGRID	RRVNL	Quad Moose		Partial (26%)	
62	400kV	Bassi-Sikar	1	D/C	170	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (16%)	
63	400kV	Bassi-Sikar	2	D/C	170	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (17%)	
64	400kV	Bawana(CCGT)-Bahadurgarh	1	D/C	49	POWERGRID	DTL/Pragati CCGT	POWERGRID	Twin Moose		Polymer Insulator	
65	400kV	Bhadla-Bhadla(PG)	1	D/C	27	POWERGRID	RRVNL	POWERGRID	Quad Moose		Not Available	
66	400kV	Bhadla-Bhadla(PG)	2	D/C	27	POWERGRID	RRVNL	POWERGRID	Quad Moose		Not Available	
67	400kV	Bhadla-Bhadla II	1	D/C	52	POWERGRID	POWERGRID	POWERGRID	Twin HTLS+Hexa Zebra	48.309KM Twin HTLS conductor of POWERGRID and 3.73 KM HEXA Zebra of FBTL	Not Available	
68	400kV	Bhadla-Bhadla II	2	D/C	52	POWERGRID	POWERGRID	POWERGRID	Twin HTLS+Hexa Zebra		Not Available	
69	400kV	Bhinmal-Kankroli	1	D/C	202	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Bypassed at Bhinmal to form 400kV Kankroli Zerda ckt-2	Polymer Insulator	
70	400kV	Bhiwadi-Gurgaon	1	S/C	83	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
71	400kV	Bhiwadi-Hissar	1	S/C	212	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
72	400kV	Bhiwadi-Hissar	2	D/C	144	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	LILo of Bhiwadi-Moga both ckts at Hisar
73	400kV	Bhiwadi-Hissar	3	D/C	144	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
74	400kV	Bhiwadi-NeemranaPG	1	D/C	48	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
75	400kV	Bhiwadi-NeemranaPG	2	D/C	48	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
76	400kV	Bhiwani BBMB - Hissar	1	S/C	35	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Bypassed at Hissar to form Bhiwani BBMB-Fatehabad	Polymer Insulator	
77	400kV	Bhiwani (PG) - Hissar	1	S/C	64	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Bypassed at Hissar to form Moga-Bhiwani(PG) bypassed at Mahendergarh(ATL)	Polymer Insulator	LILo of Bawana-Hisar (132KM) at Bhiwani PG
78	400kV	Bhiwani (PG) - Hissar	2	D/C	57	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
79	400kV	Bhiwani (PG) - Hissar	3	D/C	57	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
80	400kV	Bhiwani PG - Jind	1	D/C	82	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
81	400kV	Bhiwani PG - Jind	2	D/C	82	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
82	400kV	Bhiwani PG- BawanaCCGT	1	D/C	97	POWERGRID	POWERGRID	DTL/ CCGT	Twin Moose		Polymer Insulator	LILo of Bawana-Hisar (132KM) at Bhiwani PG
83	400kV	Bhiwani PG- Bhiwani BBMB	1	S/C	34	POWERGRID	POWERGRID	BBMB	Twin Moose		Polymer Insulator	LILo of Bhiwani (BBMB)- Bahadurgarh (84km) at Bhiwani (PG)
84	400kV	Bhiwani PG-Kabulpur	1	S/C	48	POWERGRID	POWERGRID	HVPNL	Twin Moose		Polymer Insulator	LILo of Bahadurgarh-Bhiwani at Kabulpur
85	400kV	Bikaner_2 (PBTSL)-Bikaner(PG)	1	D/C	43	POWERGRID	PBTSL	POWERGRID	Quad Moose		Not Available	
86	400kV	Bikaner_2 (PBTSL)-Bikaner(PG)	2	D/C	43	POWERGRID	PBTSL	POWERGRID	Quad Moose		Not Available	
87	400kV	Chamba pool - Jalandhar	1	D/C	162	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (48%)	
88	400kV	Chamba pool - Jalandhar	2	D/C	162	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (48%)	
89	400kV	Chamera-II - Chamba Pool	1	S/C	0.38	POWERGRID	NHPC	POWERGRID	Twin Moose		Conventional	Two tower is S/C and one tower is D/C
90	400kV	Chamera-II-Chamera-I	1	S/C	36	POWERGRID	NHPC	NHPC	Twin Moose		Conventional	
91	400kV	Chamera-II-Kishenpur	1	S/C	135	POWERGRID	NHPC	POWERGRID	Twin Moose		Conventional	

92	400kV	Chamera-I-Jalandhar	1	D/C	152	POWERGRID	NHPC	POWERGRID	Twin ACAR		Partial (43%)	
93	400kV	Chamera-I-Jalandhar	2	D/C	152	POWERGRID	NHPC	POWERGRID	Twin ACAR		Partial (43%)	
94	400kV	Chittorgarh-Chittorgarh(PG)	1	D/C	49	POWERGRID	RRVPL	POWERGRID	Quad Moose		Not Available	
95	400kV	Chittorgarh-Chittorgarh(PG)	2	D/C	49	POWERGRID	RRVPL	POWERGRID	Quad Moose		Not Available	
96	400kV	Chittorgarh-Kankroli	1	D/C	71	POWERGRID	RRVPL	POWERGRID	Twin Moose		Polymer Insulator	LILO of 400 kV Rapp C-Kankroli at Chittorgarh
97	400kV	Dadri NCTPP-G. Noida	1	D/C	13	POWERGRID	NTPC	UPPCL	Quad Bersimis		Polymer Insulator	
98	400kV	Dadri NCTPP-Maharanibagh	1	D/C	54	POWERGRID	NTPC	POWERGRID	Quad Bersimis	Bypassed at Maharanibagh to form Dadri-Ballabgarh	Polymer Insulator	
99	400kV	Dadri NCTPP-Kaithal	1	S/C	213	POWERGRID	NTPC	POWERGRID	Twin Moose	LILO of Dadri-Malerkotla at Kaithal	Polymer Insulator	
100	400kV	Dadri NCTPP-Mandola	1	D/C	46	POWERGRID	NTPC	POWERGRID	Quad Bersimis		Polymer Insulator	
101	400kV	Dadri NCTPP-Mandola	2	D/C	46	POWERGRID	NTPC	POWERGRID	Quad Bersimis		Polymer Insulator	
102	400kV	Dadri NCTPP-Muradnagar New	1	S/C	33	POWERGRID	NTPC	UPPTCL	Twin Moose		Polymer Insulator	Line shifted from Muradnagar to Muradnagar New (UPPTCL)
103	400kV	Dadri NCTPP-Panipat	1	S/C	112	POWERGRID	NTPC	BBMB	Twin Moose		Polymer Insulator	
104	400kV	Dadri NCTPP-Panipat	2	S/C	117	POWERGRID	NTPC	BBMB	Twin Moose		Polymer Insulator	
105	400kV	Deepalpur-Bawana	1	D/C	26	POWERGRID	KT-Jhajjar	DTL	Triple Snowbird	LILO of 400kV Bawana-Abdullapur one circuit at Deepalpur by Jhajjar KT	Polymer Insulator	
106	400kV	Dehradun-Abdullapur	1	D/C	89	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Not Available	
107	400kV	Dehradun-Abdullapur	2	D/C	89	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Not Available	
108	400kV	Dulhasti-Kishenpur	1	S/C	120	POWERGRID	NHPC	POWERGRID	Quad Moose		Conventional	
109	400kV	Dulhasti-Kishenpur	2	S/C	120	POWERGRID	NHPC	POWERGRID	Quad Moose		Conventional	
110	400kV	Dwarka-Jhatikara	1	S/C	18	POWERGRID	POWERGRID	POWERGRID	Twin HTLS	After LILO of 400kV Jhatikara-Bamnoli-I at Dwarka(DC)	Not Available	
111	400kV	Dwarka-Bamnauli	1	S/C	10	POWERGRID	POWERGRID	DTL	Twin HTLS		Not Available	
112	400kV	Fatehabad PG-Hissar	1	D/C	89	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Bypassed at Hissar to form Bhiwani BBMB-Fatehabad	Polymer Insulator	
113	400kV	Fatehpur-Kanpur	1	S/C	100	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	LILO of Singrauli-Kanpur at Fatehpur
114	400kV	Fatehpur-Kanpur	2	S/C	107	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Bypassed at Kanpur to form Fatehpur-Panki	Partial (64%)	LILO of Allahabad-Kanpur one ckt at Fatehpur
115	400kV	Kanpur-Panki	1	S/C	6	POWERGRID	POWERGRID	UPPTCL	Twin Moose	Bypassed at Kanpur to form Fatehpur-Panki	Polymer Insulator	
116	400kV	Kanpur-Panki	2	S/C	6	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Polymer Insulator	
117	400kV	Fatehpur-Mainpuri	1	D/C	260	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	LILO of Allahabad-Mainpuri (363 KM) D/C at Fatehpur Series compensated line (Degree of comp. - 40%)
118	400kV	Fatehpur-Mainpuri	2	D/C	260	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
119	400kV	G.Noida-Nawada	1	D/C	30	POWERGRID	UPPTCL	HVPL	Quad Bersimis	Lilo of Ballabgarh-G.Noida at Nawada	Polymer Insulator	Ballabgarh-G.Noida LILoed at Nawada (Faridabad,Haryana)
120	400kV	Gorakhpur PG-Gorakhpur UP	1	D/C	46	POWERGRID	POWERGRID	UPPCL	Twin Moose		Polymer Insulator	Partial Planning has been completed
121	400kV	Gorakhpur PG-Gorakhpur UP	2	D/C	46	POWERGRID	POWERGRID	UPPCL	Twin Moose		Polymer Insulator	Partial Planning has been completed

122	400kV	Gorakhpur PG-Lucknow PG	1	D/C	264	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (3%)	At crossing
123	400kV	Gorakhpur PG-Lucknow PG	2	D/C	264	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (3%)	At crossing
124	400kV	Gorakhpur PG-Basti (UP)	1	D/C	117	POWERGRID	POWERGRID	UPPTCL	Twin Moose	LILO of 400kV Gorakhpur PG-Lucknow PG ckt-4 at Basti (UP). LILO portion is of UP	Not Available	
125	400kV	Gorakhpur PG-Basti (UP)	2	D/C	108	POWERGRID	POWERGRID	UPPTCL	Twin Moose	LILO of 400kV Lucknow Gorakhpur-3 at Basti. LILO portion is of UP	Not Available	
126	400kV	Basti (UP)-Lucknow PG	1	D/C	204	POWERGRID	UPPTCL	POWERGRID	Twin Moose		Not Available	
127	400kV	Gurgaon-Sohna Road	1	D/C	7	POWERGRID	POWERGRID	GPTL	Quad Moose	LILO of 400kV Gurgaon	Not Available	
128	400kV	Gurgaon-Sohna Road	2	D/C	7	POWERGRID	POWERGRID	GPTL	Quad Moose	Manesar D/C at Sohna Road by GPTL	Not Available	
129	400kV	Hamirpur-Parbati Pooling (Banala)	1	D/C	77	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	LILO of Amritsar-Banala-1 at Hamirpur
130	400kV	Jaipur South-Bassi	1	D/C	37	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Agra-Bassi D/C at Jaipur South	Polymer Insulator	LILO of Agra-Bassi D/C at Jaipur South
131	400kV	Jaipur South-Bassi	2	D/C	37	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Agra-Bassi D/C at Jaipur South	Polymer Insulator	
132	400kV	Jaipur South-Kota	1	D/C	180	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
133	400kV	Jaipur South-RAPP D	1	D/C	228	POWERGRID	POWERGRID	NPCIL	Twin Moose		Not Available	
134	400kV	Jalandhar-Nakodar	1	D/C	42	POWERGRID	POWERGRID	PSTCL	Quad Moose		Polymer Insulator	
135	400kV	Jalandhar-Hamirpur	1	D/C	135	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (43%)	LILO of 400kV Amritsar-Hamirpur at Jalandhar
136	400kV	Kaithal-Hissar	1	D/C	113	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		LILO of Patiala-Hissar at Kaithal	
137	400kV	Kaithal-Hissar	2	D/C	113	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		LILO of Patiala-Hissar at Kaithal	
138	400kV	Kaithal-Malerkotla	1	S/C	135	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
139	400kV	Kankroli-Jodhpur	1	S/C	188	POWERGRID	POWERGRID	RRVNL	Twin HTLS		Conventional	
140	400kV	Kanpur-Agra	1	S/C	240	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
141	400kV	Kanpur-Auraiya	1	D/C	73	POWERGRID	POWERGRID	NTPC	Twin Moose		Conventional	
142	400kV	Kanpur-Auraiya	2	D/C	73	POWERGRID	POWERGRID	NTPC	Twin Moose		Conventional	
143	400kV	Kanpur-Ballabgarh	1	S/C	386	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	*Series Compensated, Ckt 1-35%, Ckt-2 & 3-40%
144	400kV	Kanpur-Ballabgarh	2	D/C	371	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	*Series Compensated, Ckt 1-35%, Ckt-2 & 3-40%
145	400kV	Kanpur-Ballabgarh	3	D/C	371	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	*Series Compensated, Ckt 1-35%, Ckt-2 & 3-40%
146	400kV	Kanpur-Kanpur(GIS)	1	D/C	21	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Polymer Insulator	
147	400kV	Kanpur-Kanpur(GIS)	2	D/C	21	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Polymer Insulator	
148	400kV	Kanpur(GIS)-Lucknow(765)	1	D/C	160	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
149	400kV	Kanpur(GIS)-Lucknow(765)	2	D/C	160	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
150	400kV	Kishenpur-NewWanpoh	1	D/C	130	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
151	400kV	Kishenpur-NewWanpoh	3	D/C	135	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
152	400kV	Kishenpur-NewWanpoh	4	D/C	135	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
153	400kV	Kishenpur-Samba	1	D/C	35	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
154	400kV	Kishenpur-Samba	2	D/C	35	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
155	400kV	Kota-Merta	1	D/C	256	POWERGRID	POWERGRID	RRVNL	Twin Moose		Conventional	

156	400kV	Kotputli-Bhiwadi	1	S/C	132	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	LILO of Bassi-Bhiwadi-2 at Kotputli	
157	400kV	Kurukshetra-Jind	1	D/C	103	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Not Available		
158	400kV	Kurukshetra-Jind	2	D/C	103	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Not Available		
159	400kV	Kurukshetra-Sonipat	1	D/C	125	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird (Twin HTLS for LILO portion)	LILO of Abudhapur-Sonipat line at 400kV	Partial (99%)	LILO of Abudhapur-Sonipat at	
160	400kV	Kurukshetra-Sonipat	2	D/C	125	POWERGRID	POWERGRID	POWERGRID				Partial (99%)	
161	400kV	Kurukshetra(PG)-Dhanansu(PS)	1	D/C	165	POWERGRID	POWERGRID	PSTCL	Quad Moose	Kurukshetra-Jalandhar (LILO portion is of	Polymer Insulator	LILO portion to be checked	
162	400kV	Dhanansu(PS)-Jalandhar(PG)	1	D/C	106	POWERGRID	PSTCL	POWERGRID	Quad Moose				Polymer Insulator
163	400kV	Kurukshetra-Nakodar	1	D/C	234	POWERGRID	POWERGRID	PSTCL	Quad Moose		Polymer Insulator		
164	400kV	Lucknow-Basti	1	D/C	203	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Not Available		
165	400kV	Lucknow-Basti	2	D/C	203	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Not Available		
166	400kV	Lucknow PG-Lucknow UP	1	S/C	63	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Conventional		
167	400kV	Lucknow PG-Unnao	1	D/C	74	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Conventional		
168	400kV	Lucknow PG-Unnao	2	D/C	74	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Conventional		
169	400kV	Lucknow UP-Bareilly PG	1	S/C	279	POWERGRID	UPPTCL	POWERGRID	Twin Moose		Conventional		
170	400kV	765 Lucknow (PG) - Lucknow (PG)	1	D/C	3	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Polymer Insulator		
171	400kV	765 Lucknow (PG) - Lucknow (PG)	2	D/C	3	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Polymer Insulator		
172	400kV	LucknowPG-Sohawal	1	D/C	98	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	LILO of Balia-Lucknow (316 KM) D/C at Sohawal	
173	400kV	LucknowPG-Sohawal	2	D/C	98	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional		
174	400kV	Lucknow PG-Shahjahanpur	1	D/C	170	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (10%)		
175	400kV	Lucknow PG-Shahjahanpur	2	D/C	170	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (10%)		
176	400kV	Lucknow-Jehta	1	D/C	32	POWERGRID	POWERGRID	UPPTCL	Twin Moose	LILO of 400kV Lucknow Unnao DC at Jehta (UP). LILO portion is of	Not Available		
177	400kV	Lucknow-Jehta	2	D/C	32	POWERGRID	POWERGRID	UPPTCL	Twin Moose			Not Available	
178	400kV	Ludhiana-Jalandhar	1	S/C	85	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
179	400kV	Ludhiana-Malerkotla	1	S/C	36	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
180	400kV	Ludhiana-Patiala	1	D/C	76	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
181	400kV	Ludhiana-Patiala	2	D/C	76	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
182	400kV	Mainpuri-Ballabgarh	1	D/C	236	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
183	400kV	Mainpuri-Ballabgarh	2	D/C	236	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
184	400kV	Malerkotla-Patiala	1	S/C	62	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
185	400kV	Manesar- Sohna Road	1	D/C	17	POWERGRID	POWERGRID	GPTL	Quad Moose	LILO of 400kV Gurgaon Manesar D/C at Sohna Road by GPTL	Not Available		
186	400kV	Manesar- Sohna Road	2	D/C	17	POWERGRID	POWERGRID	GPTL	Quad Moose			Not Available	
187	400kV	Mandola-Maharanibagh	1	D/C (LILO towers are M/C)	29	POWERGRID	POWERGRID	POWERGRID	Twin HTLS	After LILO of 400KV Mandola-Bawana D/C Lines at 400KV Maharanibagh(PG)	Not Available		
188	400kV	Mandola-Maharanibagh	2	D/C (LILO towers are M/C)	29	POWERGRID	POWERGRID	POWERGRID	Twin HTLS			Not Available	
189	400kV	Maharanibagh-Bawana	1	D/C	29	POWERGRID	POWERGRID	DTL	Twin HTLS			Not Available	
190	400kV	Maharanibagh-Bawana	2	D/C	29	POWERGRID	POWERGRID	DTL	Twin HTLS			Not Available	
191	400kV	Meerut-Bagpat	1	D/C	71	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Meerut-Kaithal DC at Baghpat	Polymer Insulator		
192	400kV	Meerut-Bagpat	2	D/C	71	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Meerut-Kaithal DC at Baghpat	Polymer Insulator		
193	400kV	Meerut-Mandola	1	D/C	60	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
194	400kV	Meerut-Mandola	2	D/C	60	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
195	400kV	Meerut-Muzzafarnagar	1	S/C	37	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Polymer Insulator		
196	400kV	Moga-Fatehabad	1	D/C	179	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
197	400kV	Moga-Hissar	1	D/C	209	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Bypassed at Hissar to form Moga-Bhiwani(PG)	Polymer Insulator		

198	400kV	Moga-Hissar	2	D/C	206	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	LILO of Bhiwadi-Moga both ckts at Hisar
199	400kV	Moga-Hissar	3	D/C	206	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
200	400kV	Moga-Jalandhar	1	D/C	85	POWERGRID	POWERGRID	POWERGRID	Twin ACAR		Polymer Insulator	
201	400kV	Moga-Jalandhar	2	D/C	85	POWERGRID	POWERGRID	POWERGRID	Twin ACAR		Polymer Insulator	
202	400kV	Muradnagar-Hapur	1	S/C	28	POWERGRID	UPPTCL	UPPTCL	Twin Moose	Moradabad- Muradnagar LILoed at Hapur LILo portion of	Not Available	
203	400kV	Moradabad-Hapur	2	S/C	109	POWERGRID	UPPTCL	UPPTCL	Twin Moose		Not Available	
204	400kV	Nallagarh-Koldam	1	D/C	46	POWERGRID	POWERGRID	NTPC	Quad Moose		Conventional	Koldam to Parbati near section is of
205	400kV	Nallagarh-Patiala	1	D/C	94	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		Polymer Insulator	
206	400kV	Nallagarh-Patiala	2	D/C	94	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		Polymer Insulator	
207	400kV	Nathpa Jhakri-Gumma	1	D/C	55	POWERGRID	SJVNL	HPPTCL	Triple Snowbird	LILo of DC Jhakri- Panchkula line at Gumma	Not Available	
208	400kV	Nathpa Jhakri-Gumma	2	D/C	55	POWERGRID	SJVNL	HPPTCL	Triple Snowbird		Not Available	
209	400kV	Gumma-Panchkula	1	D/C	112	POWERGRID	HPPTCL	POWERGRID	Triple Snowbird		Not Available	
210	400kV	Gumma-Panchkula	2	D/C	112	POWERGRID	HPPTCL	POWERGRID	Triple Snowbird		Not Available	
211	400kV	Nathpa Jhakri-RampurHEP	1	D/C	21	POWERGRID	SJVNL	SJVNL	Triple Snowbird	Nathpa Jhakri- Nallagarh LILoed at Rampur HEP	Conventional	LILo of Jhakri-Nallagarh 1 at Rampur HEP
212	400kV	Nathpa Jhakri-RampurHEP	2	D/C	21	POWERGRID	SJVNL	SJVNL	Triple Snowbird		Conventional	
213	400kV	NeemranaPG-Manesar	1	D/C	67	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
214	400kV	NeemranaPG-Manesar	2	D/C	67	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
215	400kV	NeemranaPG-Babai	1	D/C	85	POWERGRID	POWERGRID	RRVNL	Twin Moose	LILo PORTION IF OF NRSS36(B), LILo of 400kV Neemrana-Sikar 1 at Babai	Not Available	LILo of 400kV Neemrana-Sikar at Babai by NRSSXXXVI (Essel group): Earlier 29% of Neemrana- Sikar PG
216	400kV	NeemranaPG-Sikar	2	D/C	176	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
217	400kV	NewWanpoh-Wagoora	1	D/C	57	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
218	400kV	NewWanpoh-Wagoora	2	D/C	57	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
219	400kV	Orai(PG)-Orai	1	D/C	42	POWERGRID	POWERGRID	UPPTCL	Quad Moose		Not Available	
220	400kV	Orai(PG)-Orai	2	D/C	42	POWERGRID	POWERGRID	UPPTCL	Quad Moose		Not Available	
221	400kV	Panchkula -Abdullapur	1	D/C	63	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		Polymer Insulator	LILo of Jhakri- Abdullapur at Panchkula
222	400kV	Panchkula -Abdullapur	2	D/C	63	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		Polymer Insulator	LILo of Jhakri- Abdullapur at
223	400kV	Patiala-Panchkula	1	D/C	65	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
224	400kV	Patiala-Panchkula	2	D/C	65	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
225	400kV	Patiala-Patran	1	D/C	79	POWERGRID	POWERGRID	PTCL	Triple Snowbird	LILo of 400kV D/C Patiala – Kaithal Line at Patran SS under the ownership of PTCL.	Polymer Insulator	LILo of 400 kV Kaithal-
226	400kV	Patiala-Patran	2	D/C	79	POWERGRID	POWERGRID	PTCL	Triple Snowbird		Polymer Insulator	
227	400kV	Patran-Kaithal	1	D/C	47	POWERGRID	PTCL	POWERGRID	Triple Snowbird		Polymer Insulator	
228	400kV	Patran-Kaithal	2	D/C	47	POWERGRID	PTCL	POWERGRID	Triple Snowbird		Polymer Insulator	
229	400kV	RampurHEP-Nallagarh	1	D/C	128	POWERGRID	SJVNL	POWERGRID	Triple Snowbird	Nathpa Jhakri- Nallagarh LILoed at Rampur HEP	Conventional	LILo of Jhakri-Nallagarh 1 at Rampur HEP
230	400kV	RampurHEP-Nallagarh	2	D/C	128	POWERGRID	SJVNL	POWERGRID	Triple Snowbird		Conventional	
231	400kV	RAPS-C-Chittorgarh	1	D/C	155	POWERGRID	NPCIL	RRVNL	Twin Moose		Partial (38%)	LILo of 400 kV Rapp C- Kankroli at Chhitorgarh
232	400kV	RAPS-C-Kankroli	1	D/C	199	POWERGRID	NPCIL	POWERGRID	Twin Moose		Partial (51%)	

233	400kV	RAPS-C-Kota	1	S/C	51	POWERGRID	NPCIL	POWERGRID	Twin Moose		Partial (55%)	400kV RAPS-Jaipur line whose work was completed till Kota section is connected with 400kV Raps-Kota#2 (for antitheft purpose) and hence 400kV RapsC-Kota #2 is now two twin moose lines connected in parallel paths
234	400kV	RAPS-C-Kota	2	D/C	55	POWERGRID	NPCIL	POWERGRID	Twin Moose	D/C with 400kV Jaipur-RAPP D line	Not Available	
235	400kV	Rasra-Balia	1	S/C	46	POWERGRID	UPPTCL	POWERGRID	Twin Moose	LILO OF 400kV Bata-Mau-II at Rasara. LILO portion is of UP	Not Available	
236	400kV	Rasra-Mau	1	S/C	38	POWERGRID	UPPTCL	UPPTCL	Twin Moose		Not Available	
237	400kV	Rihand-Allahabad	1	D/C	279	POWERGRID	NTPC	POWERGRID	Twin Moose		Conventional	
238	400kV	Rihand-Allahabad	2	D/C	279	POWERGRID	NTPC	POWERGRID	Twin Moose		Conventional	
239	400kV	Roorkee-Kashipur	1	D/C	151	POWERGRID	POWERGRID	PTCUL	Quad Moose		Partial (72%)	
240	400kV	Roorkee-Kashipur	2	D/C	151	POWERGRID	POWERGRID	PTCUL	Quad Moose		Partial (72%)	
241	400kV	Roorkee-Saharanpur	1	D/C	36	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Polymer Insulator	
242	400kV	Roorkee-Dehradun	1	D/C	80	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Partial (50%)	
243	400kV	Sarnath-Varanasi	1	D/C	70	POWERGRID	UPPTCL	POWERGRID	Quad Moose		Partial (52%)	LILO of Sarnath-Allahabad (144 KM) at 765/400kV Varanasi
244	400kV	Sarnath-Varanasi	2	D/C	107	POWERGRID	UPPTCL	POWERGRID	Quad Moose		Partial (52%)	
245	400kV	Shahjahanpur-Bareilly PG	1	D/C	116	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
246	400kV	Shahjahanpur-Bareilly PG	2	D/C	116	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
247	400kV	Shahjahanpur-Rosa	1	D/C	8	POWERGRID	POWERGRID	UPPCL	Twin Moose		Not Available	
248	400kV	Shahjahanpur-Rosa	2	D/C	8	POWERGRID	POWERGRID	UPPCL	Twin Moose		Not Available	
249	400kV	Shree Cement-Kota	1	D/C	208	POWERGRID	Sh. Cement	POWERGRID	Twin Moose		Polymer Insulator	
250	400kV	Shree Cement-Merta	2	D/C	103	POWERGRID	Sh. Cement	RRVPLN	Twin Moose		Polymer Insulator	
251	400kV	Sikar-Babai	1	D/C	95	POWERGRID	POWERGRID	RRVPLN	Twin Moose	LILO PORTION IF OF NRSS36(B), LILO of 400kV Neemrana-Sikar 1 at Babai	Not Available	
252	400kV	Sikar-Ratangarh	1	D/C	76	POWERGRID	POWERGRID	RRVPLN	Twin Moose		Conventional	
253	400kV	Sikar-Ratangarh	2	D/C	76	POWERGRID	POWERGRID	RRVPLN	Twin Moose		Conventional	
254	400kV	Singrauli-Allahabad	1	S/C	224	POWERGRID	NTPC	POWERGRID	Twin Moose		Conventional	
255	400kV	Singrauli-Allahabad	2	S/C	202	POWERGRID	NTPC	POWERGRID	Twin Moose		Conventional	
256	400kV	Singrauli-Allahabad	3	S/C	215	POWERGRID	NTPC	POWERGRID	Twin Moose		Not Available	
257	400kV	Singrauli-Anpara	1	S/C	25	POWERGRID	NTPC	UPPTCL	Twin Moose		Partial (91%)	
258	400kV	Singrauli-Fatehpur	1	S/C	331	POWERGRID	NTPC	POWERGRID	Twin Moose		Conventional	LILO of Singrauli-Kanpur at Fatehpur
259	400kV	Singrauli-LucknowUP	1	S/C	409	POWERGRID	NTPC	UPPTCL	Twin Moose		Conventional	
260	400kV	Singrauli-Rihand	1	S/C	42	POWERGRID	NTPC	NTPC	Twin Moose		Conventional	
261	400kV	Singrauli-Rihand	2	S/C	44	POWERGRID	NTPC	NTPC	Twin Moose		Conventional	
262	400kV	Singrauli-Vindhyachal	1	S/C	3	POWERGRID	NTPC	POWERGRID	Twin Moose		Conventional	
263	400kV	Singrauli-Vindhyachal	2	S/C	5	POWERGRID	NTPC	POWERGRID	Twin Moose		Conventional	
264	400kV	Koteswar(PG)-Koteswar(THDC)	1	D/C	3	POWERGRID	POWERGRID	THDC	Twin Moose		Conventional	
265	400kV	Koteswar(PG)-Koteswar(THDC)	2	D/C	3	POWERGRID	POWERGRID	THDC	Twin Moose		Conventional	
266	400kV	Tehri-Koteswar(PG)	3	S/C	14	POWERGRID	THDC	POWERGRID	Quad Moose		Not Available	

267	400kV	Unnao-Jehta	1	D/C	70	POWERGRID	UPPTCL	UPPTCL	Twin Moose	LILO of 400kV Lucknow Unnao DC at Jehta (UP). LILO portion is of UP	Not Available		
268	400kV	Unnao-Jehta	2	D/C	70	POWERGRID	UPPTCL	UPPTCL	Twin Moose	LILO of 400kV Lucknow Unnao DC at Jehta (UP). LILO portion is of UP	Not Available		
269	400kV	Uri-II - Uri-I	1	S/C	10	POWERGRID	NHPC	NHPC	Twin Moose		Conventional	LILO of 400kV Uri-I - Wagoora D/C at Amargarh	
270	400kV	Uri-II - Wagoora	1	S/C	105	POWERGRID	NHPC	POWERGRID	Twin Moose		Conventional		
271	400kV	Jauljivi-Bareilly_2	1	D/C	205	POWERGRID	POWERGRID	POWERGRID	Twin Moose	After LILO of 400kV Dhauliganga - Bareilly(UP) Double circuit line(Initially LILOed at Pithoragarh and charged at 220kV level) at Jauljivi(PG)	Not Available		
272	400kV	Jauljivi-Bareilly_2	2	D/C	205	POWERGRID	POWERGRID	POWERGRID	Twin Moose	After LILO of 400kV Dhauliganga - Bareilly(UP) Double circuit line(Initially LILOed at Pithoragarh and charged at 220kV level) at Jauljivi(PG)	Not Available		
B. POWERLINK Transmission Ltd													
1	400kV	Bareilly PG-Meerut	1	D/C	250	POWERLINK	POWERGRID	POWERGRID	Twin Moose		Conventional	LILO of Bareilly PG-Mandola-1 (241 Km) at	
2	400kV	Bareilly PG-Meerut	2	D/C	250	POWERLINK	POWERGRID	POWERGRID	Twin Moose		Conventional		
3	400kV	Bareilly UP-Bareilly PG	1	D/C	14	POWERLINK	UPPTCL	POWERGRID	Twin Moose		Polymer Insulator		
4	400kV	Bareilly UP-Bareilly PG	2	D/C	14	POWERLINK	UPPTCL	POWERGRID	Twin Moose		Polymer Insulator		
5	400kV	Gorakhpur PG-Lucknow PG	1	D/C	246	POWERLINK	POWERGRID	POWERGRID	Twin Moose		Conventional	*Series compensated line	
6	400kV	Gorakhpur PG-Lucknow PG	2	D/C	246	POWERLINK	POWERGRID	POWERGRID	Twin Moose		Conventional		
7	400kV	Meerut-Mandola	3	D/C	102	POWERLINK	POWERGRID	POWERGRID	Twin Moose		Conventional	LILO of Bareilly PG-	
8	400kV	Meerut-Mandola	4	D/C	102	POWERLINK	POWERGRID	POWERGRID	Twin Moose		Conventional	Mandola-1&2 (241 Km)	
C. PKTSL													
1	400kV	Khatri-Sikar	1	D/C	78	PKTSL	PKTSL	POWERGRID	Twin HTLS		Not Available		
2	400kV	Khatri-Sikar	2	D/C	78	PKTSL	PKTSL	POWERGRID	Twin HTLS		Not Available		
D. Adani Transmission India Ltd.													
1	400kV	Mahindergarh (APL)-Bhiwani PG	1	D/C	50	ATIL	APL	POWERGRID	Twin Moose		Conventional		
2	400kV	Mahindergarh (APL)-Bhiwani PG	2	D/C	50	ATIL	APL	POWERGRID	Twin Moose		Conventional		
3	400kV	Mahindergarh (APL)-Bhiwani PG	3	D/C	56	ATIL	APL	POWERGRID	Twin Moose	Bypassed at 400kV Bhiwani to form 400kV	Not Available		
4	400kV	Mahindergarh (APL)-Bhiwani PG	4	D/C	56	ATIL	APL	POWERGRID	Twin Moose			Not Available	
5	400kV	MahindergarhHVDC-Dhanonda	1	D/C	5	ATIL	APL	HVPNL	Quad Moose	Bypassed at Dhanonda to form	Conventional		
6	400kV	MahindergarhHVDC-Dhanonda	2	D/C	5	ATIL	APL	HVPNL	Quad Moose			Conventional	
E. APCPL (Aravali Power Corporation Pvt Ltd.)													
1	400kV	Jhajjar (IGSTPS)-Mundka	1	D/C	66	APCPL	APCPL	DTL	Twin Moose		Polymer		
2	400kV	Jhajjar (IGSTPS)-Mundka	2	D/C	66	APCPL	APCPL	DTL	Twin Moose		Polymer		
F. PHTL (Powergrid Himachal Transmission Limited)													
1	400kV	Abdullapur-Kala Amb	1	D/C	39	PHTL	POWERGRID	PKATL	Quad Moose		Conventional		
2	400kV	Abdullapur-Kala Amb	2	D/C	39	PHTL	POWERGRID	PKATL	Quad Moose		Conventional		
3	400kV	Kala Amb- Wangtoo (HP)	1	D/C	174	PHTL	PKATL	HPPTCL	Quad Moose	Karcham-Kala Amb LILOed at Wangtoo (HP)	Not Available		
4	400kV	Karcham Wangtoo - Wangtoo (HP)	1	D/C	1	PHTL	JSW	HPPTCL	Quad Moose			Not Available	
5	400kV	Karcham Wangtoo - Wangtoo (HP)	2	D/C	1	PHTL	JSW	HPPTCL	Quad Moose			Not Available	
6	400kV	Baspa-Karcham Wangtoo	1	D/C	22	PHTL	JPVL	JSW	Triple snowbird		Conventional		
7	400kV	Baspa-Karcham Wangtoo	2	D/C	22	PHTL	JPVL	JSW	Triple snowbird		Conventional		
8	400kV	Karcham Wangtoo-NJPC	1	D/C	34	PHTL	JSW	SJVN	Triple snowbird		Conventional		

9	400kV	Karcham Wangtoo-NJPC	2	D/C	34	PHTL	JSW	SJVNL	Triple snowbird		Conventional
10	400kV	Sorang-Wangtoo	1	D/C	21	PHTL	SORANG	HPPTCL	Quad Moose		Not Available
11	400kV	Sorang-Kala Amb	1	D/C	160	PHTL	SORANG	PKATL	Quad Moose		Not Available
G. PKTCL (Parbati-Koldam Transmission)											
1	400kV	Koldam-Ludhiana	1	D/C	151	PKTCL	NTPC	POWERGRID	Triple Snowbird		27% Polymer & 73% porcelain
2	400kV	Koldam-Ludhiana	2	D/C	151	PKTCL	NTPC	POWERGRID	Triple Snowbird		27% Polymer & 73% porcelain
3	400kV	Koldam-Banala	1	D/C	67	PKTCL	NTPC	POWERGRID	Quad Moose		100% porcelain
4	400kV	Nallagarh-Banala	1	D/C	62	PKTCL	POWERGRID	POWERGRID	Quad Moose		100% porcelain Powergrid owned 46.38km
5	400kV	Parbati-III- Parbati Pooling (Banala)	1	S/C	13	PKTCL	NHPC	POWERGRID	Quad Moose		100% porcelain Some portion is of Powergrid
6	400kV	Parbati-III- Parbati Pooling (Banala)	1	S/C	4	PKTCL	NHPC	POWERGRID	Quad Moose		100% porcelain
7	400kV	Parbati II- Sainj	1	S/C	1	PKTCL	NHPC	HPPCL	Quad Moose		100% porcelain LILO of 400KV Parbati II
8	400kV	Parbati III- Sainj	1	S/C	9	PKTCL	NHPC	HPPCL	Quad Moose		100% porcelain Parbati III at Sainj
H. INDIGRID:NRSS-29 Transmission Company Limited											
1	400kV	Jalandhar-Samba	1	D/C	135	NRSS-29	POWERGRID	POWERGRID	Twin Moose		Polymer
2	400kV	Jalandhar-Samba	2	D/C	135	NRSS-29	POWERGRID	POWERGRID	Twin Moose		Polymer
3	400kV	Amargarh-Samba	1	D/C	286	NRSS-29	NRSS-29	POWERGRID	Twin Moose		Polymer
4	400kV	Amargarh-Samba	2	D/C	286	NRSS-29	NRSS-29	POWERGRID	Twin Moose		Polymer
5	400kV	Uri-I - Amargarh	1	D/C	62	NRSS-29	NHPC	NRSS-29	Twin Moose	LILO of 400kV D/C Uri-I - Wagoora Line at Amargarh SS under the ownership of NRSS-XXIX	Polymer
6	400kV	Uri-I - Amargarh	2	D/C	62	NRSS-29	NHPC	NRSS-29	Twin Moose		Polymer
7	400kV	Amargarh - Wagoora	1	D/C	36	NRSS-29	NRSS-29	POWERGRID	Twin Moose		Polymer
8	400kV	Amargarh - Wagoora	2	D/C	36	NRSS-29	NRSS-29	POWERGRID	Twin Moose		Polymer
I. Powergrid Unchahar Transmission Ltd.											
1	400kV	Fatehpur-Unchahar	1	D/C	54	PUTL	POWERGRID	NBPPL	Twin Moose		Not Available
2	400kV	Fatehpur-Unchahar	2	D/C	54	PUTL	POWERGRID	NBPPL	Twin Moose		Not Available
J. NRSSXXXI(B) (Sekura Energy)											
1	400kV	Amritsar-Malerkotla	1	D/C	149	NRSSXXXI(B)	POWERGRID	POWERGRID	Twin Moose		Polymer
2	400kV	Amritsar-Malerkotla	2	D/C	149	NRSSXXXI(B)	POWERGRID	POWERGRID	Twin Moose		Polymer
3	400kV	Kurukshetra-Malerkotla	1	D/C	139	NRSSXXXI(B)	POWERGRID	POWERGRID	Twin Moose		Polymer
4	400kV	Kurukshetra-Malerkotla	2	D/C	139	NRSSXXXI(B)	POWERGRID	POWERGRID	Twin Moose		Polymer
K. Gurgaon Palwal Transmission Ltd.											
1	400kV	Dhanoda-Neemrana	1	D/C	47	GPTL	HVPNL	POWERGRID	Twin HTLS	Bypassed at Dhanonda to form	Polymer
2	400kV	Dhanoda-Neemrana	2	D/C	47	GPTL	HVPNL	POWERGRID	Twin HTLS		Polymer
3	400kV	Prithala-Kadarpur	1	D/C	29	GPTL	GPTL	GPTL	Twin HTLS		Polymer
4	400kV	Prithala-Kadarpur	2	D/C	29	GPTL	GPTL	GPTL	Twin HTLS		Polymer
5	400kV	Prithala(GPTL)-Aligarh(PG)	1	D/C	49	GPTL	GPTL	POWERGRID	Twin HTLS		Polymer
6	400kV	Prithala(GPTL)-Aligarh(PG)	2	D/C	49	GPTL	GPTL	POWERGRID	Twin HTLS		Polymer
7	400kV	Kadarpur-Sohna Road	1	D/C	10	GPTL	GPTL	GPTL	Twin HTLS		Polymer
8	400kV	Kadarpur-Sohna Road	2	D/C	10	GPTL	GPTL	GPTL	Twin HTLS		Polymer
L. FBTL											
1	400kV	AREPRL-Fatehgarh Pooling	1	D/C	1	FBTL	FBTL	FBTL	Quad moose		Not Available
2	400kV	AREPRL-Fatehgarh Pooling	2	D/C	1	FBTL	FBTL	FBTL	Quad moose		Not Available
3	400kV	Fatehgarh II-Fatehgarh Pooling	1	D/C	45	FBTL	POWERGRID	FBTL	Hexa Zebra+ Twin HTLS	LILO of 400kV Fatehgarh I-Bhadla-1 at Fatehgarh II. LILO Portion is of Powergrid	Not Available
4	400kV	Fatehgarh II-Fatehgarh Pooling	2	D/C	45	FBTL	POWERGRID	FBTL	Hexa Zebra+ Twin HTLS		Not Available
M. PBTSL											
1	400kV	Bikaner_2 (PBTSL)-Khetri (PKTSL)	1	D/C (some towers M/C)	275	PBTSL	PBTSL	PKTSL	Twin HTLS		Not Available

2	400kV	Bikaner_2 (PBTSL)-Khetri (PKTSL)	2	D/C (some towers M/C)	275	PBTSL	PBTSL	PKTSL	Twin HTLS	Not Available
3	400kV	Bikaner_2 (PBTSL)-Khetri (PKTSL)	3	D/C (some towers M/C)	275	PBTSL	PBTSL	PKTSL	Twin HTLS	Not Available
4	400kV	Bikaner_2 (PBTSL)-Khetri (PKTSL)	4	D/C (some towers M/C)	275	PBTSL	PBTSL	PKTSL	Twin HTLS	Not Available
5	400kV	Khetri (PKTSL)-Bhiwadi(PG)	1	D/C	126	PBTSL	PKTSL	POWERGRID	Twin HTLS	Not Available
6	400kV	Khetri (PKTSL)-Bhiwadi(PG)	2	D/C	126	PBTSL	PKTSL	POWERGRID	Twin HTLS	Not Available
N. PRTL										
1	400kV	Jaisalmer(RS)-Fatehgarh_III(PG)	1	D/C	50	PRTL	RAJASTHAN	PRTL	Twin HTLS	Not Available
2	400kV	Jaisalmer(RS)-Fatehgarh_III(PG)	2	D/C	50	PRTL	RAJASTHAN	PRTL	Twin HTLS	Not Available
3	400kV	Fatehgarh_III(PG)- Fatehgarh_II(PG)	1	D/C	44	PRTL	PRTL	POWERGRID	Twin HTLS	Not Available
4	400kV	Fatehgarh_III(PG)- Fatehgarh_II(PG)	2	D/C	44	PRTL	PRTL	POWERGRID	Twin HTLS	Not Available
O. NRSS-36										
1	400kV	Babai(RS)-Bhiwani(PG)	1	D/C	111	NRSS-36	NRSS-36	POWERGRID	Twin Moose	Not Available
2	400kV	Babai(RS)-Bhiwani(PG)	2	D/C	111	NRSS-36	NRSS-36	POWERGRID	Twin Moose	Not Available
RE Connected at ISTS Dedicated Lines										
A. RENEW										
1	400kV	Bikaner(PG) - Bikaner (Renew)	1	S/C	5	RENEW	POWERGRID	RENEW	Twin Moose	Not Available
B. Avaada										
1	400kV	Bikaner(PG)-Avaada	1	S/C	14	AEPL	POWERGRID	AEPL	Twin Moose	Not Available
C. ARPOPL										
1	400kV	Bikaner(PG)-Ayana	1	S/C	12	ARPOPL	PGCIL	Ayana	ACSR Twin Moose+AL 59	Not Available
D. Azure										
1	400kV	Bikaner(PG)-Azure 43 PSS	1	S/C	9	Azure	POWERGRID	Azure 43 PSS	Twin Moose	Not Available
2	400kV	Azure43(RSS)-Azure 43 PSS	1	S/C	3	Azure	Azure 43 PSS	Azure 43 RSS	Twin Moose	Not Available
E. RSRPL										
1	400kV	Bikaner(RENEW) - Renew Surya Ravi	1	S/C	13	RSRPL	RENEW	RSRPL	Twin Moose	Not Available
F. NTPC										
1	400kV	Bhadla II - Kolayat	1	D/C	29	NTPC	POWERGRID	NTPC	Quad Moose	Not Available
2	400kV	Kolayat - Kolayat_2	1	D/C	2	NTPC	NTPC	NTPC	Quad Moose	Not Available
STATE LINES										
A. DTL										
1	400kV	Bamnauli-Tughlakabad	1	M/C	68	DTL	DTL	POWERGRID	Tower is quad circuit tower	Polymer Insulator
2	400kV	Bamnauli-Tughlakabad	2	M/C	68	DTL	DTL	POWERGRID	Tower is quad circuit tower	Polymer Insulator
3	400kV	Bamnoli-Jhatikara	1	D/C	12	DTL	DTL	POWERGRID	Quad bersimis	Polymer Insulator
4	400kV	Bamnoli-Jhatikara	2	D/C	12	DTL	DTL	POWERGRID	Quad bersimis	Polymer Insulator
5	400kV	Bawana-Mundka	1	D/C	18	DTL	DTL	DTL	Quad bersimis	Polymer Insulator
6	400kV	Bawana-Mundka	2	D/C	18	DTL	DTL	DTL	Quad bersimis	Polymer Insulator
7	400kV	Jhatikara-Mundka	1	D/C	17	DTL	POWERGRID	DTL	Quad bersimis	Polymer Insulator
8	400kV	Jhatikara-Mundka	2	D/C	17	DTL	POWERGRID	DTL	Quad bersimis	Polymer Insulator
B. HVPNL										
1	400kV	CLP Jhajjar -Dhanonda	1	D/C	20	HVPNL	CLP Jhajjar	HVPNL	Twin Moose	Conventional
2	400kV	CLP Jhajjar -Dhanonda	2	D/C	20	HVPNL	CLP Jhajjar	HVPNL	Twin Moose	Conventional
3	400kV	CLP Jhajjar- Kabulpur	1	D/C	35	JKTPL	CLP Jhajjar	HVPNL	Quad Moose	Already had Anti fog
4	400kV	CLP Jhajjar- Kabulpur	2	D/C	35	JKTPL	CLP Jhajjar	HVPNL	Quad Moose	Polymer Insulator
5	400kV	Deepalpur-Kabulpur	1	D/C	67	JKTPL	KT Jhajjar	HVPNL	Quad Moose	Installed on every towers
6	400kV	Deepalpur-Kabulpur	2	D/C	67	JKTPL	KT Jhajjar	HVPNL	Quad Moose	

7	400kV	Dhanoda-Daultabad	1	D/C	73	HVNL	HVNL	HVNL	Quad Moose			
8	400kV	Dhanoda-Daultabad	2	D/C	73	HVNL	HVNL	HVNL	Quad Moose		Already had Polymer Insulator	
9	400kV	Gurgaon-Daultabad	1	D/C	21	HVNL	POWERGRID	HVNL	Quad Moose			Six towers multi-circuit with Bamnauli-
10	400kV	Gurgaon-Daultabad	2	D/C	21	HVNL	POWERGRID	HVNL	Quad Moose			Partial (84%),
11	400kV	Jhajjar-Daulatabad	1	D/C	64	HVNL	APCPL	HVNL	Twin Moose		Polymer Insulator	Remaining pending
12	400kV	Jhajjar-Daulatabad	2	D/C	64	HVNL	APCPL	HVNL	Twin Moose		Polymer Insulator	
13	400kV	Khedar-Fatehabad	1	D/C	40	HVNL	HPGCL	POWERGRID	Twin Moose		Conventional	Presently there is no planning of replacement of Conventio disc Insulator with Polymer Insulators
14	400kV	Jind-Kirori	1	D/C	51	HVNL	POWERGRID	HVNL	Twin Moose		Polymer Insulator	
15	400kV	Jind-Kirori	2	D/C	51	HVNL	POWERGRID	HVNL	Twin Moose		Polymer Insulator	
16	400kV	Khedar-Kirori	1	D/C	6.2	HVNL	HPGCL	HVNL	Twin Moose		Conventional	Presently there is no planning of replacement
17	400kV	Khedar-Kirori	2	D/C	6	HVNL	HPGCL	HVNL	Twin Moose		Conventional	Existing disc insulator are of Porcelain
18	400kV	Khedar-Nuhiawali	1	D/C	114	HVNL	HPGCL	HVNL	Twin Moose		Conventional	
19	400kV	Nuhiawali-Fatehabad	1	D/C	78	HVNL	HVNL	POWERGRID	Twin Moose		Conventional	
C. PDD (Jammu & Kashmir)												
1	400kV	Baglihar(stage 1)-Kishenpur	1	D/C	68	JK PDD	JKSPDCL	POWERGRID	Twin Moose		Conventional	
2	400kV	Baglihar(stage 1)-Kishenpur	2	D/C	68	JK PDD	JKSPDCL	POWERGRID	Twin Moose		Not Available	
D. PSTCL												
1	400kV	Behman Jassa- HMEL	1	D/C	17	PSTCL	PSTCL	PSTCL	Twin Moose		Not Available	
2	400kV	Behman Jassa- HMEL	2	D/C	17	PSTCL	PSTCL	PSTCL	Twin Moose		Not Available	
3	400kV	Behman Jassa- Moga	1	S/C	113	PSTCL	PSTCL	PSTCL	Twin Moose	After LILO of 400 KV TSPL to 400 KV Moga at 400 KV Behman Jassa Singh	Not Available	
4	400kV	Makhu-Amritsar	1	D/C	64	PSTCL	PSTCL	PSTCL	Twin Moose		Partial (10%)	
5	400kV	Makhu-Amritsar	2	D/C	64	PSTCL	PSTCL	PSTCL	Twin Moose		Partial (10%)	
6	400kV	Muktsar-Makhu	1	D/C	96	PSTCL	PSTCL	PSTCL	Twin Moose		Conventional	
7	400kV	Muktsar-Makhu	2	D/C	96	PSTCL	PSTCL	PSTCL	Twin Moose		Conventional	
8	400kV	Nakodar-Makhu	1	D/C	52	PSTCL	PSTCL	PSTCL	Twin Moose		Conventional	
9	400kV	Nakodar-Makhu	2	D/C	52	PSTCL	PSTCL	PSTCL	Twin Moose		Conventional	
10	400kV	Nakodar-Moga	1	S/C	78	PSTCL	PSPCL	POWERGRID	Twin Moose		Not Available	LILO of 400kV Talwandi sabo-Nakodar at Moga
11	400kV	Rajpura-Dhuri	1	D/C	86	PSTCL	PSTCL	PSTCL	Twin Moose		Conventional	Lilo of Rajpura th-Dhuri
12	400kV	Rajpura TPS- Rajpura	1	D/C	9	PSTCL	PSPCL	PSTCL	Twin Moose		Conventional	1 at 400kV Rajpura
13	400kV	Rajpura-Dhuri	2	D/C	86	PSTCL	PSTCL	PSTCL	Twin Moose		Conventional	Lilo of Rajpura th-Dhuri
14	400kV	Rajpura TPS- Rajpura	2	D/C	9	PSTCL	PSPCL	PSTCL	Twin Moose		Not Available	2 at 400kV Rajpura
15	400kV	Rajpura TPS-Nakodar	1	D/C	139	PSTCL	PSPCL	PSTCL	Twin Moose		Conventional	
16	400kV	Rajpura TPS-Nakodar	2	D/C	139	PSTCL	PSPCL	PSTCL	Twin Moose		Conventional	
17	400kV	Talwandi Saboo- Dhuri	1	D/C	175	PSTCL	PSPCL	PSTCL	Twin Moose		Partial (22%)	
18	400kV	Talwandi Saboo- Dhuri	2	D/C	175	PSTCL	PSPCL	PSTCL	Twin Moose		Partial (22%)	
19	400kV	Talwandi Saboo- Behman Jassa	1	D/C	20	PSTCL	PSPCL	PSTCL	Twin Moose	After LILO of 400 KV TSPL to 400 KV Moga at 400 KV Behman Jassa Singh	Not Available	
20	400kV	Talwandi Saboo- Nakodar	1	D/C	180	PSTCL	PSPCL	PSTCL	Twin Moose		Conventional	
21	400kV	Talwandi Saboo- Muktsar	1	D/C	100	PSTCL	PSPCL	PSTCL	Twin Moose		Conventional	
22	400kV	Talwandi Saboo- Muktsar	2	D/C	100	PSTCL	PSPCL	PSTCL	Twin Moose		Conventional	
E. PTCUL												
1	400kV	Alaknanda(GVK)-Srinagar(PTCUL)	1	D/C	14	PTCUL	GVKPIL	PTCUL	Twin Moose		Conventional	
2	400kV	Alaknanda(GVK)-Srinagar(PTCUL)	2	D/C	14	PTCUL	GVKPIL	PTCUL	Twin Moose		Conventional	
3	400kV	Muradabad-Kashipur	1	S/C	108	PTCUL	UPPTCL	PTCUL	Twin Moose		Conventional	
4	400kV	Rishikesh-Nehtaur	1	D/C	124	PTCUL	PTCUL	UPPTCL	Twin Moose		Not Available	LILO of 400kV

5	400kV	Nehtaur-Kashipur	2	D/C	80	PTCUL	UPPTCL	PTCUL	Twin Moose		Not Available	Rishikesh-Kashipur	
6	400kV	Roorkee-Rishikesh	1	S/C	50	PTCUL	POWERGRID	PTCUL	Twin Moose	LILO portion is of POWERGRID	Not Available		
7	400kV	Roorkee-Muzaffarnagar	1	S/C	71	PTCUL	POWERGRID	UPPTCL	Twin Moose		Not Available		
F. RRVPNL													
1	400kV	Ajmer-Bhilwara	1	D/C	160	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
2	400kV	Ajmer-Bhilwara	2	D/C	160	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
3	400kV	Akal-Barmer	1	S/C	124	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Conventional		
4	400kV	Akal-Jodhpur	1	S/C	225	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Conventional		
5	400kV	Akal-Ramgarh	1	D/C	99	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
6	400kV	Akal-Ramgarh	2	D/C	99	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
7	400kV	Anta-Chhabra	1	S/C	90	RRVPNL	RRVPNL	RVUNL	Quad Moose	Bypassed at Anta to form Chhabra-Kota(PG)	Not Available		
8	400kV	Anta-Chhabra SC	1	D/C	89	RRVPNL	RRVPNL	RVUNL	Quad Moose		Not Available		
9	400kV	Anta-Chhabra SC	2	D/C	89	RRVPNL	RRVPNL	RVUNL	Quad Moose		Not Available		
10	400kV	Anta-Kalisindh	1	D/C	80	RRVPNL	RRVPNL	RVUNL	Quad Moose		Not Available		
11	400kV	Anta-Kalisindh	2	D/C	80	RRVPNL	RRVPNL	RVUNL	Quad Moose		Not Available		
12	400kV	Anta-Kawai	1	D/C	50	RRVPNL	RRVPNL	Kawai(Adani)	Quad Moose		Not Available		
13	400kV	Anta-Kawai	2	D/C	50	RRVPNL	RRVPNL	Kawai(Adani)	Quad Moose		Not Available		
14	400kV	Anta-Kota (PG)	1	S/C	91	RRVPNL	RRVPNL	POWERGRID	Twin Moose	Bypassed at Anta to form Chhabra-Kota(PG)	Not Available		
15	400kV	Barmer-Bhinmal	1	D/C	144	RRVPNL	RRVPNL	POWERGRID	Twin Moose		Not Available		
16	400kV	Barmer-Bhinmal	2	D/C	144	RRVPNL	RRVPNL	POWERGRID	Twin Moose		Not Available		
17	400kV	Barmer-Jaisalmer-II (Bhaesada)	1	D/C	117	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
18	400kV	Barmer-Jaisalmer-II (Bhaesada)	2	D/C	117	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
19	400kV	Barmer-Rajwest	1	D/C	15	RRVPNL	RRVPNL	RAJWEST	Twin Moose		Conventional		
20	400kV	Bhadla-Jodhpur	1	D/C	106	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
21	400kV	Bhilwara-Chhabra	1	S/C	303	RRVPNL	RRVPNL	RVUNL	Twin Moose		Conventional		
22	400kV	Bhilwara-Chittorgarh(RRVPNL)	1	D/C	49	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
23	400kV	Bhilwara-Chittorgarh(RRVPNL)	2	D/C	49	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
24	400kV	Bikaner-Bhadla	1	D/C	189	RRVPNL	RRVPNL	RRVPNL	Quad Moose		Not Available		
25	400kV	Bikaner-Bhadla	2	D/C	189	RRVPNL	RRVPNL	RRVPNL	Quad Moose		Not Available		
26	400kV	Bikaner-Merta	1	S/C	172	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
27	400kV	Bikaner-Sikar(PG)	1	D/C	171	RRVPNL	RRVPNL	POWERGRID	Twin Moose		Not Available		
28	400kV	Bikaner-Sikar(PG)	2	D/C	171	RRVPNL	RRVPNL	POWERGRID	Twin Moose		Not Available		
29	400kV	Chhabra - Kawai SCTPS	1	S/C	45	RRVPNL	RVUNL	APRL	Twin Moose		Conventional		
30	400kV	Chhabra-Chhabra SC	1	D/C	2	RRVPNL	RRVPNL	RVUNL	Quad Moose		Not Available		
31	400kV	Chhabra-Chhabra SC	2	D/C	2	RRVPNL	RRVPNL	RVUNL	Quad Moose		Not Available		
32	400kV	Heerapura-Hindaun	1	S/C	192	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Conventional		
33	400kV	Hindaun-Chhabra	1	S/C	305	RRVPNL	RRVPNL	RVUNL	Twin Moose		Conventional		
34	400kV	Kakani (Jodhpur New)-Jodhpur	2	S/C	102	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
35	400kV	Kankani (Jodhpur New)-Akal	1	D/C	223	RRVPNL	RRVPNL	RRVPNL	Quad Moose		Not Available		
36	400kV	Kankani(Jodhpur New)-Jaisalmer-II(Bhainsra)	1	D/C	177	RRVPNL	RRVPNL	RRVPNL	Quad Moose	LILO of 400kV Kankani(Jodhpur New)-Akal ckt-2	Not Available		
37	400kV	Jaisalmer-II(Bhainsra)-Akal	1	D/C	61	RRVPNL	RRVPNL	RRVPNL	Quad Moose		Not Available		
38	400kV	Kankani (Jodhpur New)-Jodhpur	1	S/C	67	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
39	400kV	Kankani (Jodhpur New)-Merta	1	S/C	140	RRVPNL	RRVPNL	RRVPNL	Twin Moose	LILO of 400kV Jodhpur-Merta-1 at Kakani	Not Available		
40	400kV	Merta-Bhadla	1	D/C	175	RRVPNL	RRVPNL	RRVPNL	Twin Moose	LILO of 400kV Jodhpur-Merta-2 at Bhadla	Not Available		
41	400kV	Merta-Heerapura	1	S/C	175	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Conventional		
42	400kV	Merta-Ratangarh	1	S/C	173	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Conventional		

43	400kV	Phagi-Ajmer(RRVPNL)	1	D/C	109	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available	
44	400kV	Phagi-Ajmer(RRVPNL)	2	D/C	109	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available	
45	400kV	Phagi-Heerapura	1	D/C	52	RRVPNL	RRVPNL	RRVPNL	Quad Moose		Not Available	
46	400kV	Phagi-Heerapura	2	D/C	52	RRVPNL	RRVPNL	RRVPNL	Quad Moose		Not Available	
47	400kV	Rajwest - Kankani (Jodhpur New)	1	S/C	209	RRVPNL	RRVPNL	RRVPNL	Twin Moose	LILO of 400kV Jodhpur-Rajwest-I at Kakani	Not Available	
48	400kV	Rajwest-Jodhpur	1	D/C	209	RRVPNL	RWPL	RRVPNL	Twin Moose		Conventional	
49	400kV	Ramgarh-Bhadla	1	D/C	160	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available	
50	400kV	Ramgarh-Bhadla	2	D/C	160	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available	
51	400kV	Suratgarh-Bikaner	1	S/C	146	RRVPNL	RVUNL	RRVPNL	Twin Moose		Conventional	
52	400kV	Suratgarh-Ratangarh	1	S/C	144	RRVPNL	RVUNL	RRVPNL	Twin Moose		Conventional	
53	400kV	Suratgarh-Ratangarh	2	S/C	144	RRVPNL	RVUNL	RRVPNL	Twin Moose		Conventional	
54	400kV	Suratgarh-Suratgarh SC	1	S/C	2	RRVPNL	RVUNL	RVUNL	Quad Moose		Not Available	
55	400kV	Suratgarh SC-Bikaner	1	D/C	140	RRVPNL	RVUNL	RRVPNL	Twin Moose		Not Available	
56	400kV	Suratgarh SC-Bikaner	2	D/C	140	RRVPNL	RVUNL	RRVPNL	Twin Moose		Not Available	
G. UPPTCL												
1	400kV	Agra (Fatehabad)-Agra South	1	D/C	70	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
2	400kV	Agra (UP)-Agra(Fatehabad)	1	S/C	104	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	LILO of 400 kv Agra(UP)- Muradnagar(N) at Fatehabad(UP)
3	400kV	Agra UP-Unnao	1	S/C	279	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (25%)	
4	400kV	Agra(Fatehabad)-Mathura	1	S/C	142	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
5	400kV	Agra(Fatehabad)-Mathura	2	D/C	151	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	LILO of 400 kv Fatehabad(UP)- Muradnagar at Mathura
6	400kV	Alakhnanda-Vishnuprayag	1	D/C	109	UPPTCL	GVKPIL	JPVL	Twin Moose		Not Available	
7	400kV	Aligarh-Mainpuri	1	D/C	93	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
8	400kV	Aligarh-Mainpuri	2	D/C	93	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
9	400kV	Aligarh-Muradnagar	1	S/C	177	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	*Series Compensated line (40%). It would be shifted
10	400kV	Aligarh-Sikandrabad	1	D/C	95	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
11	400kV	Aligarh-Harduaganj	1	S/C	40	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
12	400kV	AnparaB-AnparaC	1	D/C	0.05	UPPTCL	UPRVUNL	LANCO	Quad Moose		Conventional	
13	400kV	AnparaB-AnparaC	2	D/C	0.05	UPPTCL	UPRVUNL	LANCO	Quad Moose		Conventional	
14	400kV	AnparaB-AnparaD	1	D/C	5	UPPTCL	UPRVUNL	UPPTCL	Twin Moose		Not Available	
15	400kV	AnparaB-AnparaD	2	D/C	5	UPPTCL	UPRVUNL	UPPTCL	Twin Moose		Not Available	
16	400kV	AnparaB-Mau	1	S/C	262	UPPTCL	UPRVUNL	UPPTCL	Twin Moose		Partial (13%)	
17	400kV	AnparaB-Obra B	1	S/C	40	UPPTCL	UPRVUNL	UPPTCL	Twin Moose		Partial	
18	400kV	AnparaB-Sarnath	1	D/C	158	UPPTCL	UPRVUNL	UPPTCL	Twin Moose		Partial	
19	400kV	AnparaB-Sarnath	2	D/C	158	UPPTCL	UPRVUNL	UPPTCL	Twin Moose		Conventional	
20	400kV	Ataur-Hapur	1	D/C	52	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
21	400kV	Ataur-Hapur	2	D/C	52	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
22	400kV	Ataur-Indirapuram	1	D/C	15	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
23	400kV	Ataur(UP)-Noida Sec 123(UP)	1	D/C	19	UPPTCL	UPPTCL	UPPTCL	Quad Moose (LILO portion Twin HTLS)	LILO of 400 KVATAUR- INDIRAPURAM CKT-II	Not Available	
24	400kV	Indirapuram(UP)-Noida Sec 123(UP)	1	D/C	17	UPPTCL	UPPTCL	UPPTCL	Quad Moose (LILO portion Twin HTLS)	at 400 KV NOIDA SECTOR 123	Not Available	
25	400kV	Azamgarh-Mau	1	S/C	48	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (79%)	
26	400kV	Azamgarh-Tanda	1	D/C	153	UPPTCL	UPPTCL	NTPC	Twin Moose		Not Available	
27	400kV	Badaun-Sambhal	1	D/C	77	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
28	400kV	Badaun-Sambhal	2	D/C	77	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
29	400kV	Banda-Orai	1	D/C	108	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	

30	400kV	Banda-Orai	2	D/C	108	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
31	400kV	Banda-Rewa road	1	D/C	177	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
32	400kV	Banda-Rewa road	2	D/C	177	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
33	400kV	Bara-Meja	1	D/C	32	UPPTCL	UPPTCL	MUNPL	Quad Moose		LILO of 400kV Bara-Rewa road D/C at Meja	
34	400kV	Bara-Meja	2	D/C	32	UPPTCL	UPPTCL	MUNPL	Quad Moose			
35	400kV	Bareilly UP-Unnao	1	D/C	271	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (15%)	*Series Compensated line (45%)
36	400kV	Bareilly UP-Unnao	2	D/C	271	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (15%)	*Series Compensated line (45%)
37	400kV	Gorakhpur UP-Azamgarh	1	S/C	90	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (76%)	
38	400kV	Gr. Noida(765)-Sector 148	1	D/C	47	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
39	400kV	Gr. Noida(765)-Sector 148	2	D/C	47	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
40	400kV	Gr. Noida-Gr. Noida (765)	1	D/C	45	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
41	400kV	Gr. Noida-Gr. Noida (765)	2	D/C	45	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
42	400kV	Gr.Noida-Sikandrabad	1	D/C	17	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
43	400kV	Gr.Noida-Sikandrabad	2	D/C	17	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
44	400kV	Hapur-Dasna	1	D/C	14	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
45	400kV	Hapur-Dasna	2	D/C	14	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
46	400kV	Hapur-Moradabad	1	S/C	109	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
47	400kV	Hapur-Muradnagar	1	S/C	28	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
48	400kV	Harudaganj-Sikandarabad	1	S/C	115	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
49	400kV	Mainpuri(UP)-Mainpuri(PG)	1	D/C	25	UPPTCL	UPPTCL	POWERGRID	Twin Moose		Not Available	LILO of 400kV Orai-Mainpuri(PG) at Mainpuri(UP)
50	400kV	Mainpuri(UP)-Mainpuri(PG)	2	D/C	26	UPPTCL	UPPTCL	POWERGRID	Twin Moose		Not Available	
51	400kV	Meja-Musauli	1	D/C	65	UPPTCL	MUNPL	UPPTCL	Quad Moose		Not Available	
52	400kV	Meja-Rewa road	1	D/C	45	UPPTCL	MUNPL	UPPTCL	Quad Moose		Not Available	
53	400kV	Muradnagar New- Mathura	1	D/C	246	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	LILO of 400 kV Fatehabad(UP)-Muradnagar at Mathura
54	400kV	Muradnagar-Ataur	2	D/C	18	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
55	400kV	Musauli-Rewa road	1	D/C	34	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
56	400kV	Muzaffarnagar-Alakhnanda	1	D/C	189	UPPTCL	UPPTCL	GVKPIL	Twin Moose		Not Available	
57	400kV	Muzaffarnagar-Ataur	1	D/C	121	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
58	400kV	Muzaffarnagar-Vishnuprayag	1	D/C	280	UPPTCL	UPPTCL	JPVL	Twin Moose		Conventional	
59	400kV	Noida Sec 148 - Noida Sec 123	1	D/C	20	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
60	400kV	Noida Sec 148 - Noida Sec 123	2	D/C	20	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
61	400kV	Noida Sec 148-Noida Sec 123	1	D/C	20	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
62	400kV	Noida Sec 148-Noida Sec 123	2	D/C	20	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
63	400kV	Obra-Rewa road	1	S/C	179	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
64	400kV	Obra-Sultanpur	1	S/C	230	UPPTCL	UPRVUNL	UPPTCL	Twin Moose		Conventional	
65	400kV	Obra B - Obra C	1	S/C	1	UPPTCL	UPRVUNL	UPRVUNL	Twin Moose		Not Available	
66	400kV	Orai-Mainpuri(UP)	1	D/C	176	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
67	400kV	Orai-Mainpuri(UP)	2	D/C	176	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
68	400kV	Orai-Paricha	1	D/C	111	UPPTCL	UPPTCL	UPRVUNL	Twin Moose		Not Available	
69	400kV	Orai-Paricha	2	D/C	111	UPPTCL	UPPTCL	UPRVUNL	Twin Moose		Not Available	

70	400kV	Panki-Aligarh	1	S/C	285	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (24%)	
71	400kV	Rewa road -Panki	1	S/C	210	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	LILO of Bara-Panki at 400kV Rewa Road
72	400kV	Rosa-Badaun	1	D/C	85	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
73	400kV	Rosa-Badaun	2	D/C	85	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
74	400kV	Sarnath-Azamgarh	1	S/C	97	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
75	400kV	Lucknow_1(PG)-Mohanlalganj (PGYTL)	1	S/C	58	UPPTCL	POWERGRID	UPPTCL	Twin Moose	LILO of 400kV LUCKNOW(PG)-	Conventional	
76	400kV	Sultanpur(UP)-Mohanlalganj (PGYTL)	1	S/C	133	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Conventional	
77	400kV	Sultanpur-Tanda	1	D/C	103	UPPTCL	UPPTCL	NTPC	Twin Moose		Not Available	
78	400kV	Tanda-Basti	1	D/C	44	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
79	400kV	Tanda-Basti	2	D/C	44	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
80	400kV	Mohanlalganj (PGYTL)-Unnao(UP)	1	S/C	104	UPPTCL	UPPTCL	UPPTCL	Twin Moose	LILO of 400 KV SAROJANI	Partial (13%)	Status after LILO?
81	400kV	Lucknow(UP)-Mohanlalganj (PGYTL)	1	S/C	89	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (13%)	
82	400kV	Unnao-Panki	1	S/C	49	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (41%)	
83	400kV	Varanasi-Jaunpur	1	D/C	73	UPPTCL	POWERGRID	UPPTCL	Twin Moose		Not Available	
84	400kV	Varanasi-Jaunpur	2	D/C	73	UPPTCL	POWERGRID	UPPTCL	Twin Moose		Not Available	
85	400kV	Jaunpur (UP)-Obra_B(UP)	1	D/C	177	UPPTCL	UPPTCL	UPPTCL	Twin Moose	After LILO of 400 KV OBRA B- OBRA-C CKT-	Not Available	
86	400kV	Obra_C_TPS(UP)-Jaunpur (UP)	1	D/C	176	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
87	400kV	Sambhal-Rampur	1	D/C	74	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
88	400kV	Sambhal-Rampur	2	D/C	74	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
89	400kV	Simbholi-Meerut_PMSTL	1	D/C	29	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
90	400kV	Simbholi-Meerut_PMSTL	2	D/C	29	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
91	400kV	Simbholi_PMSTL (UP)-Muradnagar_2(UP)	1	D/C	71	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
92	400kV	Simbholi_PMSTL (UP)-Muradnagar_2(UP)	2	D/C	71	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
93	400kV	Panki-Panki_TPS	1	S/C	1	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
H. PJFTL												
1	400kV	Firozabad-Jawaharpur	1	D/C	40	PJFTL	PJFTL	UPRVUNL	Quad Moose	Anti-theft charging from Firozabad(PJFTL)	Not Available	
2	400kV	Firozabad-Jawaharpur	2	D/C	40	PJFTL	PJFTL	UPRVUNL	Quad Moose		Not Available	
3	400kV	Agra South-Firozabad PJFTL	1	D/C	79	PJFTL	UPPTCL	PJFTL	Twin Moose	LILO of 400kV Agra South-Agra Fatehabad ckt-2 at Firozabad PJFTL	Not Available	
4	400kV	Agra(Fatehabad)-Firozabad PJFT	1	D/C	79	PJFTL	UPPTCL	PJFTL	Twin Moose		Not Available	
I. GTL												
1	400kV	Kanpur(PG)-Ghatampur_TPS(UP)	1	D/C	49	GTL	POWERGRID	UPPTCL	Twin Moose	Antitheft charging from Kanpur(PG) Upto DEAD	Not Available	
2	400kV	Kanpur(PG)-Ghatampur_TPS(UP)	2	D/C	49	GTL	POWERGRID	UPPTCL	Twin Moose		Not Available	
J. HPPTCL												
1	400kV	Lahal-Chamba	1	D/C	35	HPPTCL	HPPTCL	POWERGRID	Twin Moose		Not Available	
2	400kV	Lahal-Chamba	2	D/C	35	HPPTCL	HPPTCL	POWERGRID	Twin Moose		Not Available	
K. NTPC JV												
1	400kV	Dadri-Loni (Harsh Vihar)	1	D/C	54	NTPC	NTPC	DTL	Twin Moose		Polymer	
2	400kV	Dadri-Loni (Harsh Vihar)	2	D/C	54	NTPC	NTPC	DTL	Twin Moose		Polymer	
L. MTSCl												
1	400kV	Ajmer-Deedwana	1	S/C	110	MTSCL	RRVNL	MTSCL	Twin Moose		Not Available	
2	400kV	Bikaner-Deedwana	1	S/C	129	MTSCL	RRVNL	MTSCL	Twin Moose		Conventional	
M. Aravali Transmission Service Company Ltd (ATSCL)												
1	400kV	Alwar-Hindaun	1	S/C	96	ATSCL	ATSL	RRVNL	Twin Moose		Not Available	Partly owned by Aravali Transmission Services lltd.
N. BBMB												
1	400kV	Dehar-Rajpura	1	S/C	129	BBMB	BBMB	PSTCL	Twin Morkulla+ LILO portion is of twin moose	Dehar-Bhiwani LILOed at Rajpura	Antifog	LILO of Dehar-Bhiwani at Rajpura
2	400kV	Bhiwani(BBMB)-Rajpura	1	S/C	213	BBMB	BBMB	PSTCL		Dehar-Bhiwani LILOed at Rajpura	Antifog	

3	400kV	Dehar-Panchkula	1	S/C	125	BBMB	BBMB	POWERGRID	Twin Morkulla+ LILO portion is of twin moose	POWERGRID owned LILO portion of 9.034Km	Antifog	LILO of Dehar-Panipat at Panchkula
4	400kV	Panchkula-Panipat	1	S/C	155	BBMB	POWERGRID	BBMB			Antifog	
OTHER DEDICATED LINES												
A. THDC												
1	400kV	Aligarh-Khurja	1	D/C	35	THDC	POWERGRID	THDC	Twin Moose		Not Available	
2	400kV	Aligarh-Khurja	2	D/C	35	THDC	POWERGRID	THDC	Twin Moose		Not Available	
5. 400kV Transmission Line charged at 220kV												
STATE LINES												
A. RRVPNL												
1	400kV charged at 220kV	Dholpur-Hindaun	1	S/C	100	RRVPNL	RRVUNL	RRVPNL	Twin Moose		Conventional	
2	400kV charged at 220kV	Kota-KTPS	1	D/C	7	RRVPNL	POWERGRID	RRVUNL	Twin Moose		Conventional	
3	400kV charged at 220kV	Kota-KTPS	2	D/C	7	RRVPNL	POWERGRID	RRVUNL	Twin Moose		Conventional	

* - Fixed series capacitor (FSC) is owned by POWERGRID

National Load Despatch Centre
Import Capability of Punjab for December 2024

\
 Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	10300	500	9800	5497	4303		https://www.punjab.sldc.org/ATC_TTC.aspx
Limiting Constraints		N-1 contingency of 400/220KV ICT at Rajpura, Ludhiana, Jalandhar, Muktsar Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla and Patiala ICTs 220 kV underlying network at Jalandhar, Ludhiana and Amritsar						

National Load Despatch Centre
Import Capability of Uttar Pradesh for December 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	17300	600	16700	10165	6535		https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde
Limiting Constraints		N-1 contingency of 400/220kV Obra, Allahabad(PG), Gorakhpur (UP), Agra(PG), Lucknow (PG) ICTs						

National Load Despatch Centre
Import Capability of Haryana for December 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	10300	300	10000	5418	4582		https://hvpn.org.in/#/atcttc
Limiting Constraints		N-1 contingency of 400/220kV ICT at Deepalpur, Hisar, Kabulpur and Panipat(BBMB)						

**National Load Despatch Centre
Import Capability of Rajasthan for December 2024**

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	7600	600	7000	5755	1245		https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads
Limiting Constraints		N-1 contingency of 400/220kV Heerapura, Jodhpur, Bikaner, Ajmer, Merta, Hindaun and Ratangarh ICTs						

National Load Despatch Centre
Import Capability of Delhi for December 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	7300	300	7000	4810	2190		https://www.delhisldc.org/resources/atcttcreport.pdf
Limiting Constraints		N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs.						

National Load Despatch Centre
Import Capability of Uttarakhand for December 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	1710	100	1610	1402	208		https://uksldc.in/ttc-atc
Limiting Constraints		N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines						

National Load Despatch Centre
Import Capability of HP for December 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	2386	100	2286	1130	1156		https://hpsldc.com/mrm_category/ttc-atc-report/
Limiting Constraints		Overloading of 2*100MVA Giri transformers						

**National Load Despatch Centre
Import Capability of J&K for December 2024**

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	3200	100	3100	1977	1123		
Limiting Constraints		N-1 contingency of 400/220KV ICTs at Amargarh 220 kV underlying network at Amargarh, Wagoora						

National Load Despatch Centre
Import Capability of Chandigarh for December 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	400	20	380	342	38		
Limiting Constraints		N-1 contingency of 220kV Nallagarh-Kishengarh						

**CENTRAL ELECTRICITY REGULATORY COMMISSION
(NEW DELHI)**

Suo-Motu Petition No. 9/SM/2024

Coram:

Shri Jishnu Barua, Chairperson

Shri Ramesh Babu V., Member

Shri Harish Dudani, Member

Date of Order : 7th October, 2024

In the matter of :

Planning for safe, secure, and reliable integrated operation of the power system during critical periods arising on account of seasonal variations wherein the electricity demand increases rapidly by undertaking specific measures to mitigate the risks on the power system, under clause (h) of sub-section (1) of Section 79 of the Electricity Act, 2003 and the Regulation 31 of the Central Electricity Regulatory Commission (Indian Electricity Grid Code) Regulations, 2023.

And in the matter of :

1. National Load Despatch Centre,
Grid Controller of India Ltd. (CIN U40105DL2009GOI188682)
B-9 (1st Floor), Qutab Institutional Area, Katwaria Sarai,
New Delhi -110016
2. Northern Regional Load Despatch Centre,
Grid Controller of India Ltd.
18-A, Shaheed Jeet Singh Sansanwal Marg,
Katwaria Sarai, New Delhi -110016
3. Western Regional Load Despatch Centre, Mumbai
Grid Controller of India Ltd.
F-3, M.I.D.C. Area, Marol Andheri (East),
Mumbai -400093
4. Southern Regional Load Despatch Centre
29, Race Course Cross Road,
Bangalore -560009



5. Eastern Regional Load Despatch Centre, Kolkata
Grid Controller of India Ltd. 14, Golf Club Road, Tollygunge, Kolkata -700 03
6. North Eastern Load Despatch Centre, Shillong
Grid Controller of India Ltd.
Lower, Nongrah, Lapalang, Shillong,
Meghalaya 793006
7. The Chief Engineer,
State Load Dispatch Centre,
SLDC Complex. PSTCL,
Near 220 kV G/Stn,
Ablowal, Patiala- 147001
8. The Chief Engineer (LD),
Electricity Department,
UT Secretariat,
Sector - 9D, UT of Chandigarh-160009
9. The Managing Director,
Himachal Pradesh Power Transmission Corporation Limited,
Barowalias House,
Khalini, Shimla-171002
10. The Executive Director,
State Load Dispatch Centre,
Delhi Transco Ltd, 33kV Substation Building,
Minto Road, New Delhi, 110002
11. The Superintending Engineer
State Load Dispatch Centre.
Rajasthan Rajya Vidya Prasaran Nigam Limited.
Ajmer Road, Heerapur. Jaipur – 302004
12. The Managing Director,
State Load Dispatch Centre,
Haryana,
Behind BBMB Power house,
Sewah, Panipat, Haryana 132103
13. The Chief Engineer
State Load Dispatch Center,
SLDC Complex TOTU,
Shimla, Himachal Pradesh-17 10 1 1
14. The Director,
State Load Dispatch Centre,



Uttar Pradesh Power Transmission Corporation Limited (UPPTCL),
Phase II, Vibhuti Khand, Lucknow- 226001

15. The Chief Engineer,
State Load Dispatch Centre,
Vidyut Bhawan, Saharanpur Road Majra,
Near ISBT Dehradun-248001
Uttarakhand
16. The Chief Engineer,
Maharashtra State Load Dispatch Centre,
Thane-Belapur Road. Airoli
Navi Mumbai-400 708
17. The Chief Engineer,
State Load Dispatch Centre,
Gujrat Energy Transmission Corporation Limited (GETCO),
GSSC Compound Near TB Hospital,
Gotri Road, Gotri, Vadodara - 390 021
18. The Chief Engineer (LD),
State Load Dispatch Centre (SLDC),
Chhattisgarh State Power Transmission Co. Ltd.
Danganiya, Raipur, Chhattisgarh- 492013
19. The Chief Engineer,
State 3 Dispatch Centre,
MP Power Transmission Co. Ltd
Nayagaon, Rampur, Jabalpur-482008
20. The Chief Engineer (Electrical),
State Load Dispatch Centre (SLDC),
Race Course Cross Road, A. R. Circle, Bengaluru-560009
21. The Chief Engineer,
State Load Dispatch Centre (SLDC),
Transmission corporation of Andhra Pradesh Limited (APTRANSCO),
Vidvut Soudha, Gunadala,
Eluru Road Vijayawada, Andhra Pradesh 520004
22. The Chief Engineer/Operation,
State Load Dispatch Centre,
Tamil Nadu Transmission Corporation Limited (TANTRANSCO),
144 Anna Salai, Chennai- 600002
23. The Chief Engineer,



State Load Despatch Centre (SLDC), Transmission Corporation of
Telangana Ltd. (TSTRANSCO),
Vidvut Soudha, Khairatabad. Hyderabad- 500 082

24. The Chief Engineer (Transmission- System Operation),
State Load Despatch Centre (SLDC)
Vaidyuthi Bhavanam, Pottam, Trivandrum- 695 009 Kerala

25. The Chief Engineer (TRANS., O&M),
State Load Despatch Center (SLDC),
Bihar State Power Transmission Company Limited (BSPTCL),
4th Floor, Vidyut Bhawan, Bailey Road, Patna-1

26. The Chief Load Despatcher,
State Load Despatch Centre (SLDC),
SLDC Building. GR1DCO Colony,
P.O. Mancheswar Railway Colony,
Bhubaneswar- 751017

27. The Chief Engineer,
State Load Despatch
Center, Jharkhand Urja Sancharan Nigam Limited,
Engineering Building, H.E.C.,
Dhurwa. Ranchi – 834004

28. The Chief Engineer,
West Bengal State Load Despatch Centre WBSLDC),
Danesh Seikh Lane,
Andul Road, Howrah-711109

29. The Additional Chief Engineer,
State Load Despatch Centre (SLDC),
Power Department, Govt. of Sikkim, Gangtok-737201

30. The Chief Engineer,
State Load Despatch Centre (SLDC), Damodar
Valley Corporation (DVC), Danesh Saikh Lane,
Andul Road, Howrah 711109

31. The Executive Engineer (SLDC),
Department of Power,
Government of Arunachal Pradesh,
National Highway 52A, Vidyut Bhawan, Itanagar-791111

32. The Asst. General Manager,
SLDC Division,
Assam Electricity Grid Corporation Ltd.,



ASEB Colony, Power House Kahilipara,
Guwahati-781 019

33. The Superintending Engineer,
P&E Office Complex, North Block (III Floor)
Electric Veng, Aizawl- 796001, Mizoram.
34. The Superintending Engineer,
Load Despatch Centre
Meghalaya Power Transmission Corporation Limited,
Short Round Road,
Lum Jingshai, Meghalaya, Shillong 793022.
35. The Chief Engineer,
Department of Power Govt. of Nagaland, Kohima-797 001
36. The General Manager, State Load Despatch Centre
Manipur State Power Company Ltd (MSPCL)
Electricity Complex, Keisumphat Junction,
Imphal-795001, Manipur.
37. The Director (Tech.),
Tripura State Electricity Corporation Ltd (TSECL),
Banamalipur, Agartala -799 001
38. Northern Regional Power Committee, New Delhi
Shaheed Jeet Singh Marg,
Qutab Institutional Area,
New Delhi -110016
39. Western Regional Power Committee, Mumbai
M.I.D.C. Central Road,
Krantiveer Lakhuji Salve Marg, Seepz,
Andheri East, Mumbai, Maharashtra-400093
40. Southern Regional Power Committee,
29, Race Course Rd, Nehru Nagar,
Gandhi Nagar, Bengaluru,
Karnataka 560009
41. Eastern Regional Power Committee, Kolkata
14, Golf Club Rd, Golf Gardens,
Tollygunge, Kolkata,
West Bengal- 70003316
42. North Eastern Regional Power Committee,
Jowai Rd, Umpling, Shillong,



Meghalaya-793006

43. Central Electricity Authority,
Sewa Bhawan, R. K. Puram, Sector-1,
New Delhi

...Respondents

ORDER

This Commission, in the exercise of the powers conferred under Section 178 read with Section 79(1)(h) of the Electricity Act, 2003 (hereinafter referred to as “the Act”), has specified CERC (Indian Electricity Grid Code), Regulations 2023 (hereinafter referred to as “the Grid Code”) on 29.05.2023 effective from 1.10.2023. Section 28(2) of the Act provides that the Regional Load Despatch Centre shall comply with such principles, guidelines and methodologies in respect of wheeling and optimum scheduling and despatch of electricity as the Central Commission may specify in the Grid Code. Section 29(1) of the Act provides that the Regional Load Despatch Centre shall issue such directions and exercise such supervision and control as may be required for ensuring the stability of the grid operation and for achieving the maximum economy and efficiency in the operation of the power system in the region under its control. Section 33(3) of the Act provides that the State Load Despatch Centre shall comply with the directions of the Regional Load Despatch Centre (“RLDC”). Section 29(4) of the Act provides that the Regional Power Committee in the region may, from time to time, agree on matters concerning the stability and smooth operation of the integrated grid and the economy and efficiency of the power system within the region. Therefore, the Act envisages and assigns responsibilities to the



Regional Load Despatch Centres and State Load Despatch Centres as apex bodies at the regional level and state level, respectively, to ensure safe, secure, stable, and integrated operation of the power system in the respective region or the state, as the case may be, and to the Regional Power Committees to coordinate among the constituents in their respective regions to achieve agreement with regard to stability and smooth operation of the integrated grid.

2. Regulation 31 of the Grid Code provides for the time horizon for operational planning, demand estimation, generation estimation, and adequacy of resources for the purpose of operational planning in the following manner: -

(a) For operational planning, National Load Despatch Centre, Regional Load Despatch Centres, and State Load Despatch Centres have been assigned the responsibility to carry out operational planning within their respective control areas on Intra-day, Day Ahead, and Weekly time horizons.

(b) For demand estimation, the State Load Despatch Centres are mandated to carry out demand estimation as part of operational planning for both active power and reactive power incidents on the transmission systems based on the details collected from distribution licensees, grid-connected distributed generation resources, captive power plants and other bulk consumers embedded within the State and to estimate the peak and off-peak demand on a weekly and monthly basis for load - generation balance planning as well as for operational planning. Based on the demand estimate furnished by SLDCs and other entities directly connected to the ISTS, RLDCs shall prepare regional

demand estimates based on which NLDC shall prepare national demand estimates.

(c) For generation estimation, RLDCs have been mandated to forecast generation from wind, solar, ESS, and renewable energy hybrid generating stations, which are regional entities, and SLDCs have been mandated to forecast generation from such resources which are intra-State entities for different time horizons, for the purpose of operational planning.

(d) SLDCs are required to estimate and ensure adequacy of resources, identify generation, demand response capacity, and generation flexibility requirements, and furnish time block-wise information for the following day in respect of all intra-State entities to the concerned RLDCs who shall validate the adequacy of resources with due regard to the aggregated demand forecast for the control area, renewable energy generation forecast for the control area, injection schedule of intra-State entity generating stations, requisition from regional entity generating stations, secondary and planned procurement through tertiary reserve requirements, and planned procurement through bilateral or collective transactions.

3. Regulation 33 provides that based on the operational planning analysis data, NLDC, RLDCs, and SLDCs shall carry out operational planning studies in real time, intra-day, day-ahead, and weekly basis, and RPCs shall carry out operational planning studies on monthly/yearly basis. This Regulation further provides that operational studies shall be carried out to assess whether the planned operations would result in



deviations from any of the operational limits defined under the Grid Code and applicable standards issued by the Central Electricity Authority. Regulation 33 further enjoins upon Regional Power Committees to monitor significant deviations for early resolution. NLDCs, RLDCs, RPCs, and SLDCs are required to develop operating plans to address potential deviation from system operational limits identified as a result of the operational planning study and communicate the same to the users in advance for taking corrective measures. The detailed reasons and explanations given by the users shall be discussed in the monthly operation sub-committee of the respective regions, and quarterly reports shall be submitted by RPCs to the Commission and CEA.

4. An extract of Regulations 31 and 33 of the Grid Code is enclosed in this order for the convenience of reference.

5. The Commission sought details of the load-generation scenario for the months of September and October 2024 from NLDC, followed by meetings of the Commission with the officers of NLDC. NLDC has submitted forecast scenarios for the months of September 24 and October 2024. The NLDC has also conducted the meeting of the Forum of Load Despatchers to ensure the proper projection of demand by the State Load Despatch Centre. We have considered the peak demand forecast for the month of October 2024. A summary of these scenarios is as under:-



Table 1: Peak demand forecast and load generation balance during Oct-24
(in GW)

	Oct-24
Demand Forecast	
Peak Demand forecast	230
Peak Demand (including ISTS losses) forecast	232.2
Available generation (other than thermal generation)	59.4
Ex-bus Thermal Requirement (without reserve)	172.8
Gross Thermal Requirement (without reserve)	187.9
Estimated Thermal Generation	
Net available thermal capacity	182.20
Availability of generation required	
Additional generation required	5.7
Additional generation required (with reserve 3% of peak demand)	12.60

It is observed from the above table that the projected load generation balance based on peak demand during October 2024 indicates the requirement for additional generation. The rise in demand during solar generation hours can be met from renewable generation provided the solar generation is as per the past trends. However, during non-solar hours (including evening and morning peaks), there is a requirement of additional requirement of Generation resources of about 12.60 GW with a reserve requirement of 3% to meet contingency.

6. The Grid Code enjoins the responsibility upon all concerned stakeholders to ensure stable and economic operation of power system and resolve the issues of significant deviations, if any. The Commission, taking cognizance of the previous year's record, intends to impress upon all the stakeholders that there is an imperative need for prudent planning of load generation balance and issue of alerts to all the grid-connected user entities of the concerned control areas to make them aware about the

anticipated challenges in the operation of the power system and for undertaking the preventive measures as may be required to maintain load generation balance.

7. The Commission is of the view that there is a need to sensitize all the stakeholders, monitor their actions, and bring about behavioural changes through specific and proactive regulatory interventions. The Commission believes that it is advisable to take preventive *ex-ante* measures instead of the *ex-post* reactive measures of finding instances of violation of the Grid Code, initiating penal proceedings for violation, and imposing penalty under the provisions of the Act. This proactive approach would also help to encourage collective efforts on the part of the National Load Despatch Centre, Regional Load Despatch Centres, State Load Despatch Centres, and the grid connected entities to make concerted efforts to ensure stable and economic operation of the grid.

8. The projected requirement of generation is significantly higher than the annual growth of the electricity demand and the addition of generation capacity. The projected requirement of thermal generation during October, 2024 needs proper operational planning and adequacy of resources in terms of Regulation 31(4) of the Grid Code. Any uncertain variation in the electricity demand arising on account of seasonal variations leading to a rapid increase in demand causes undesirable stress in the power system. The steep rise in electricity demand without adequate generation sources may put the power system operation at risk. It is the statutory responsibility of the RLDCs and SLDCs to carry out the operational planning for the increase in demand due to seasonal variations while discharging their functions under Sections 28



and 32 of the Act, respectively, read with the provisions of Regulations 31 and 33 of the Grid Code. 12. In light of the above, the Commission feels that there is a need to prepare the system operators and the stakeholders to meet the situation arising out of the abrupt increase in demand due to seasonal variations, especially during October 2024. Regulation 60 of the Grid Code empowers the Commission to issue practice directions through suo-moto proceedings with regard to implementation of the provisions of the said Regulations. Regulation 60 of the Grid Code is extracted as under:-

“60. Issue of Suo Motu Orders and Directions

The Commission may from time to time issue suo motu orders and practice directions with regard to implementation of these regulations and matters incidental or ancillary thereto, as the case may be.”

9. In exercise of the powers vested under Regulation 60, read with all relevant provisions of the Grid Code, the Commission issues the following directions to NLDC, RLDCs, and SLDCs in connection with the implementation of Regulations 31 and 33 of the Grid Code to address the anticipated surge in demand of electricity during October 2024 on account of seasonal variations:

- a) All the State Load Despatch Centres and RLDCs shall furnish the details of operational planning undertaken by them in terms of Regulation 31(4) (a) of the Grid Code especially for October 2024. RLDC shall validate the adequacy of resources in terms of Regulation 31(4)(b) of the Grid Code.
- b) All State Load Despatch Centres and Regional Load Despatch Centres shall prepare the worst-case scenario due to possible surge in demand during the



period 1.10.2024 to 31.10.2024 in their respective control area and submit within seven days to the Commission with a copy to National Load Despatch Centre.

- c) The State Load Despatch Centres or Regional Load Despatch Centres, as the case may be, should assess their demand-generation scenario in the upcoming months, ensure the optimum generation, avoid undesirable planned outages, and advise the generating company to offer their availability. The State Load Despatch Centre or Regional Load Despatch Centre shall ensure the optimum scheduling during the shortage period and surplus power to get despatched during the deficit period.
- d) The Distribution Companies, in case of a shortage scenario, can procure the power from surplus or requisitioned capacity of other states so that optimum despatch can be ensured for safe and reliable power system operations. The State Load Despatch Centre shall monitor the generation-demand deficit of the respective distribution companies.
- e) The generating companies operating their plant with capacity less than its installed capacity due to technical issues, i.e., capacity under partial outage or forced outage, are advised to fix the issues to ensure the maximum generation capacity on-bar.
- f) The draw schedule of the respective control area needs to adhere to prevent the reduction of system frequency. The State Load Despatch Centre or Regional Load Despatch Centre, as the case may be, shall monitor the deviation of the key system parameters.

g) The State Load Despatch Centres or Regional Load Despatch Centres, as the case may be, shall issue the system alerts to their respective grid-connected entities for the possible deficit during the likely surge in demand.

10. The Regional Load Despatch Centres and State Load Despatch Centres shall submit the report on the implementation of the above measures, a load-generation scenario in their respective control areas, and any other measures taken to address the deficit of power supply during the period 1.10.2024 to 31.10.2024.

11. The objective of the present proceedings is to prepare the system operators and other stakeholders to meet the challenges and threats to the power system that may arise due to the abrupt increase in demand. The responses of the SLDCs, RLDCs, and NLDC with regard to the implementation of the measures detailed in para 9 of this order shall, in the first instance, be examined in detail by a Single-Member Bench comprising a Member of the Commission. Accordingly, in the exercise of powers under Section 97 of the Electricity Act,2003, the Commission nominates Shri Ramesh Babu V., Member, to conduct the proceedings for this purpose. The Single Member Bench shall provide due opportunity to the parties to make their submissions. The Single Member Bench shall have the authority to direct the parties to submit such further information and to take such remedial measures as may be considered necessary. The Single Member Bench shall submit a report to the Commission with regard to the preparedness of the System Operators and other stakeholders to meet the challenges arising on account of the sudden surge in demand for power and his recommendations with regard to the remedial measures to be taken for the future. The



Commission, after consideration of the report of the Single Member Bench shall issue appropriate directions as may be considered appropriate.

12. NLDC, RLDCs, and SLDCs are directed to submit their responses to the measures contained in para 9 of this order by 16.10.2024.

Sd./-
(Shri Harish Dudani)
Member

Sd./-
(Shri Ramesh Babu V)
Member

Sd./-
(Shri Jishnu Barua)
Chairperson



Extract of Regulation 31 and 33 of the Grid Code

31. OPERATIONAL PLANNING

(1) Time Horizon

- (a) Operational planning shall be carried out in advance by NLDC, RLDCs and SLDCs within their respective control areas with Monthly and Yearly time horizons in co-ordination with CTU, RPCs or STUs, as applicable.
- (b) Operational planning shall be carried out in advance by NLDC, RLDCs and SLDCs within their respective control areas on Intra-day, Day Ahead, Weekly time horizons.
- (c) RLDCs in consultation with NLDC shall issue procedures and formats for data collection to carry out:
 - (i) Operational planning analysis,
 - (ii) Real-time monitoring,
 - (iii) Real-time assessments.
- (d) SLDC may also issue procedures and formats for data collection for the above purposes.

(2) Demand Estimation

- (a) Each SLDC shall carry out demand estimation as part of operational planning after duly factoring in the demand estimation done by STU as part of resource adequacy planning referred to in Chapter 2 of these regulations. Demand estimation by SLDC shall be for both active power and reactive power incidents on the transmission system based on the details collected from distribution licensees, grid-connected distributed generation resources, captive power plants and other bulk consumers embedded within the State.

- (b) Each SLDC shall develop methodology for daily, weekly, monthly, yearly demand estimation in MW and MWh for operational analysis as well as resource adequacy purposes. Each SLDC, while estimating demand may utilize state of the art tools, weather data, historical data and any other data. For this purpose, all distribution licensees shall maintain a historical database of demand.
- (c) The demand estimation by each SLDC shall be done on day ahead basis with time block wise granularity for the daily operation and scheduling. In case SLDC observes a major change in demand in real time for the day, it shall immediately submit the revised demand estimate to the concerned RLDC for demand estimate correction.
- (d) Each SLDC shall submit node-wise morning peak, evening peak, day shoulder and night off-peak estimated demand in MW and MVA on a monthly and quarterly basis for the nodes 110 kV and above for the preparation of scenarios for computation of TTC and ATC by the concerned RLDC and NLDC.
- (e) SLDC shall also estimate peak and off-peak demand (active as well as reactive power) on a weekly and monthly basis for load - generation balance planning as well as for operational planning analysis, which shall be a part of the operational planning data. The demand estimates mentioned above shall have granularity of a time block. The estimate shall cover the load incident on the grid as well as the net load incident taking into account embedded generation in the form of roof-top solar and other distributed generation.
- (f) The entities such as bulk consumers or distribution licensees that are directly connected to ISTS shall estimate and furnish such a demand estimate to the concerned RLDC.
- (g) Based on the demand estimate furnished by the SLDCs and other entities directly connected to ISTS, each RLDC shall prepare the regional demand estimate and submit it to the NLDC. NLDC, based on regional demand estimates furnished by RLDCs, shall prepare national demand estimate.



- (h) Timeline for submission of demand estimate data by SLDCs or other entities directly connected to ISTS, as applicable, to the respective RLDC and RPC shall be as follows:
- (i) SLDCs, RLDCs and NLDC shall compute forecasting error for intra-day, dayahead, weekly, monthly and yearly forecasts and analyse the same in order to reduce forecasting error in the future. The computed forecasting errors shall be made available by SLDCs, RLDCs and NLDC on their respective websites.

(3) Generation Estimation

- (a) The modalities of generation estimation by entities shall be as per the Procedure referred to in sub-clause (c) of clause (1) of Regulation 31 of these regulations.
- (b) RLDC shall forecast generation from wind, solar, ESS and Renewable Energy hybrid generating stations that are regional entities and SLDC shall forecast generation from such sources that are intra-state entities, for different time horizons as referred to in clause (1) of Regulation 31 of these regulations for the purpose of operational planning.

(4) Adequacy of Resources

- (a) SLDCs shall estimate and ensure the adequacy of resources, identify generation reserves, demand response capacity and generation flexibility requirements with due regard to the resource adequacy framework as specified under Chapter 2 of these regulations.
- (b) SLDCs shall furnish time block-wise information for the following day in respect of all intra-state entities to the concerned RLDC who shall validate the adequacy of resources with due regard to the following:
 - (i) Demand forecast aggregated for the control area;
 - (ii) Renewable energy generation forecast for the control area;

- (iii) Injection schedule for intra-State entity generating station;
- (iv) Requisition from regional entity generating stations;
- (v) Secondary and planned procurement through Tertiary reserve requirement;
- (vi) Planned procurement of power through other bilateral or collective transactions, if any.

33. OPERATIONAL PLANNING STUDY

- (1) Based on the operational planning analysis data, operational planning study shall be carried out by various agencies for time horizons as under:
- (2) SLDCs, RLDCs and NLDC shall utilize network estimation tool integrated in their EMS and SCADA systems for the real time operational planning study. All users shall make available at all times real time error free operational data for the successful execution of network analysis using EMS/SCADA. Failure to make available such data shall be immediately reported to the concerned SLDC, the concerned RLDC and NLDC along with a firm timeline for restoration. The performance of online network estimation tools at SLDC and RLDC shall be reviewed in the monthly operational meeting of RPC. Any telemetry related issues impacting the online network estimation tool shall be monitored by RPC for their early resolution.
- (3) SLDCs shall perform day-ahead, weekly, monthly and yearly operational studies for the concerned State for:
 - (a) assessment and declaration of total transfer capability (TTC) and available transfer capability (ATC) for the import or export of electricity by the State. TTC and ATC shall be revised from time to time based on the commissioning of new elements and other grid conditions and shall be published on SLDC website with all the assumptions and limiting constraints;



- (b) planned outage assessment;
 - (c) special scenario assessment;
 - (d) system protection scheme assessment;
 - (e) natural disaster assessment; and
 - (f) any other study relevant in operational scenario.
- (4) RLDCs and NLDC shall perform day-ahead, weekly, monthly and yearly operational studies for:
- (a) assessment of TTC and ATC at inter-regional, intra-regional, and inter-state levels;
 - (b) planned outage assessment;
 - (c) special scenario assessment;
 - (d) system protection scheme assessment;
 - (e) natural disaster assessment; and
 - (f) any other study relevant to operational scenarios
- (5) RLDC shall assess intra-regional and inter-state level TTC and ATC and submit them to NLDC. NLDC shall declare TTC and ATC for import or export of electricity between regions including simultaneous import or export capability for a region, and crossborder interconnections 11 (Eleven) months in advance for each month on a rolling basis. TTC and ATC shall be revised from time to time based on the commissioning of new elements and other grid conditions and shall be published on the websites of the NLDC and respective RLDCs with all the assumptions and limiting constraints
- (6) Operational planning study shall be done to assess whether the planned operations shall result in deviations from any of the system operational limits defined under these regulations and applicable CEA Standards. The deviations, if



any, shall be reviewed in the monthly operational meeting of RPC and significant deviations shall be monitored by RPC for early resolution.

- (7) NLDC, RLDCs, RPCs and SLDCs shall maintain records of the completed operational planning study, including date specific power flow study results, the operational plan and minutes of meetings on operational study.
- (8) NLDC, RLDCs, RPCs and SLDCs shall have operating plans to address potential deviations from system operational limit identified as a result of the operational planning study. These operating plans shall be communicated to users in advance so that they can take corrective measures. In case any user is unable to adhere to such an operating plan, it shall inform the respective SLDC, RLDC and NLDC in advance with detailed reasons and explanations for the non-adherence. These detailed reasons and explanations shall be discussed in the monthly operation sub-committee of the respective region and a quarterly report shall be submitted by the respective RPC to the Commission and CEA.
- (9) Each SLDC shall undertake a study on the impact of new elements to be commissioned in the intra-state system in the next six (6) months on the TTC and ATC for the State and share the results of the studies with RLDC.
- (10) Each RLDC shall undertake a study on the impact of new elements to be commissioned in the next six (6) months in (a) the ISTS of the region and (b) the intrastate system on the inter-state system and share the results of the studies with NLDC
- (11) NLDC shall undertake study on the impact of new elements to be commissioned in the next six (6) months in (a) inter-regional system, (b) cross-border link and (c) intraregional system on the inter-regional system.
- (12) NLDC, RLDCs and SLDCs shall compare the results of the studies of the impact of new elements on the system and transfer capability addition with those of the interconnection and planning studies by CTU and STUs, and any significant

variations observed shall be communicated to CEA, RPCs, CTU and STUs for immediate and long-term mitigation measures.

- (13) Defense mechanisms like system protection scheme, load-rejection scheme, generation run-back, islanding scheme or any other scheme for system security shall be proposed by the concerned user or SLDC or RLDC or NLDC and shall be deployed as finalized by the respective RPC.

**CENTRAL ELECTRICITY REGULATORY COMMISSION
(NEW DELHI)**

Suo-Motu Petition No. 9/SM/2024

Coram:

Shri Jishnu Barua, Chairperson

Shri Ramesh Babu V., Member

Shri Harish Dudani, Member

Date of Order : 7th October, 2024

In the matter of :

Planning for safe, secure, and reliable integrated operation of the power system during critical periods arising on account of seasonal variations wherein the electricity demand increases rapidly by undertaking specific measures to mitigate the risks on the power system, under clause (h) of sub-section (1) of Section 79 of the Electricity Act, 2003 and the Regulation 31 of the Central Electricity Regulatory Commission (Indian Electricity Grid Code) Regulations, 2023.

And in the matter of :

1. National Load Despatch Centre,
Grid Controller of India Ltd. (CIN U40105DL2009GOI188682)
B-9 (1st Floor), Qutab Institutional Area, Katwaria Sarai,
New Delhi -110016
2. Northern Regional Load Despatch Centre,
Grid Controller of India Ltd.
18-A, Shaheed Jeet Singh Sansanwal Marg,
Katwaria Sarai, New Delhi -110016
3. Western Regional Load Despatch Centre, Mumbai
Grid Controller of India Ltd.
F-3, M.I.D.C. Area, Marol Andheri (East),
Mumbai -400093
4. Southern Regional Load Despatch Centre
29, Race Course Cross Road,
Bangalore -560009



5. Eastern Regional Load Despatch Centre, Kolkata
Grid Controller of India Ltd. 14, Golf Club Road, Tollygunge, Kolkata -700 03
6. North Eastern Load Despatch Centre, Shillong
Grid Controller of India Ltd.
Lower, Nongrah, Lapalang, Shillong,
Meghalaya 793006
7. The Chief Engineer,
State Load Dispatch Centre,
SLDC Complex. PSTCL,
Near 220 kV G/Stn,
Ablowal, Patiala- 147001
8. The Chief Engineer (LD),
Electricity Department,
UT Secretariat,
Sector - 9D, UT of Chandigarh-160009
9. The Managing Director,
Himachal Pradesh Power Transmission Corporation Limited,
Barowalias House,
Khalini, Shimla-171002
10. The Executive Director,
State Load Dispatch Centre,
Delhi Transco Ltd, 33kV Substation Building,
Minto Road, New Delhi, 110002
11. The Superintending Engineer
State Load Dispatch Centre.
Rajasthan Rajya Vidya Prasaran Nigam Limited.
Ajmer Road, Heerapur. Jaipur – 302004
12. The Managing Director,
State Load Dispatch Centre,
Haryana,
Behind BBMB Power house,
Sewah, Panipat, Haryana 132103
13. The Chief Engineer
State Load Dispatch Center,
SLDC Complex TOTU,
Shimla, Himachal Pradesh-17 10 1 1
14. The Director,
State Load Dispatch Centre,



Uttar Pradesh Power Transmission Corporation Limited (UPPTCL),
Phase II, Vibhuti Khand, Lucknow- 226001

15. The Chief Engineer,
State Load Dispatch Centre,
Vidyut Bhawan, Saharanpur Road Majra,
Near ISBT Dehradun-248001
Uttarakhand
16. The Chief Engineer,
Maharashtra State Load Dispatch Centre,
Thane-Belapur Road. Airoli
Navi Mumbai-400 708
17. The Chief Engineer,
State Load Dispatch Centre,
Gujrat Energy Transmission Corporation Limited (GETCO),
GSSC Compound Near TB Hospital,
Gotri Road, Gotri, Vadodara - 390 021
18. The Chief Engineer (LD),
State Load Dispatch Centre (SLDC),
Chhattisgarh State Power Transmission Co. Ltd.
Danganiya, Raipur, Chhattisgarh- 492013
19. The Chief Engineer,
State 3 Dispatch Centre,
MP Power Transmission Co. Ltd
Nayagaon, Rampur, Jabalpur-482008
20. The Chief Engineer (Electrical),
State Load Dispatch Centre (SLDC),
Race Course Cross Road, A. R. Circle, Bengaluru-560009
21. The Chief Engineer,
State Load Dispatch Centre (SLDC),
Transmission corporation of Andhra Pradesh Limited (APTRANSCO),
Vidvut Soudha, Gunadala,
Eluru Road Vijayawada, Andhra Pradesh 520004
22. The Chief Engineer/Operation,
State Load Dispatch Centre,
Tamil Nadu Transmission Corporation Limited (TANTRANSCO),
144 Anna Salai, Chennai- 600002
23. The Chief Engineer,



State Load Despatch Centre (SLDC), Transmission Corporation of
Telangana Ltd. (TSTRANSCO),
Vidvut Soudha, Khairatabad. Hyderabad- 500 082

24. The Chief Engineer (Transmission- System Operation),
State Load Despatch Centre (SLDC)
Vaidyuthi Bhavanam, Pottam, Trivandrum- 695 009 Kerala

25. The Chief Engineer (TRANS., O&M),
State Load Despatch Center (SLDC),
Bihar State Power Transmission Company Limited (BSPTCL),
4th Floor, Vidyut Bhawan, Bailey Road, Patna-1

26. The Chief Load Despatcher,
State Load Despatch Centre (SLDC),
SLDC Building. GR1DCO Colony,
P.O. Mancheswar Railway Colony,
Bhubaneswar- 751017

27. The Chief Engineer,
State Load Despatch
Center, Jharkhand Urja Sancharan Nigam Limited,
Engineering Building, H.E.C.,
Dhurwa. Ranchi – 834004

28. The Chief Engineer,
West Bengal State Load Despatch Centre WBSLDC),
Danesh Seikh Lane,
Andul Road, Howrah-711109

29. The Additional Chief Engineer,
State Load Despatch Centre (SLDC),
Power Department, Govt. of Sikkim, Gangtok-737201

30. The Chief Engineer,
State Load Despatch Centre (SLDC), Damodar
Valley Corporation (DVC), Danesh Saikh Lane,
Andul Road, Howrah 711109

31. The Executive Engineer (SLDC),
Department of Power,
Government of Arunachal Pradesh,
National Highway 52A, Vidyut Bhawan, Itanagar-791111

32. The Asst. General Manager,
SLDC Division,
Assam Electricity Grid Corporation Ltd.,



ASEB Colony, Power House Kahilipara,
Guwahati-781 019

33. The Superintending Engineer,
P&E Office Complex, North Block (III Floor)
Electric Veng, Aizawl- 796001, Mizoram.
34. The Superintending Engineer,
Load Despatch Centre
Meghalaya Power Transmission Corporation Limited,
Short Round Road,
Lum Jingshai, Meghalaya, Shillong 793022.
35. The Chief Engineer,
Department of Power Govt. of Nagaland, Kohima-797 001
36. The General Manager, State Load Despatch Centre
Manipur State Power Company Ltd (MSPCL)
Electricity Complex, Keisumphat Junction,
Imphal-795001, Manipur.
37. The Director (Tech.),
Tripura State Electricity Corporation Ltd (TSECL),
Banamalipur, Agartala -799 001
38. Northern Regional Power Committee, New Delhi
Shaheed Jeet Singh Marg,
Qutab Institutional Area,
New Delhi -110016
39. Western Regional Power Committee, Mumbai
M.I.D.C. Central Road,
Krantiveer Lakhuji Salve Marg, Seepz,
Andheri East, Mumbai, Maharashtra-400093
40. Southern Regional Power Committee,
29, Race Course Rd, Nehru Nagar,
Gandhi Nagar, Bengaluru,
Karnataka 560009
41. Eastern Regional Power Committee, Kolkata
14, Golf Club Rd, Golf Gardens,
Tollygunge, Kolkata,
West Bengal- 70003316
42. North Eastern Regional Power Committee,
Jowai Rd, Umpling, Shillong,



Meghalaya-793006

43. Central Electricity Authority,
Sewa Bhawan, R. K. Puram, Sector-1,
New Delhi

...Respondents

ORDER

This Commission, in the exercise of the powers conferred under Section 178 read with Section 79(1)(h) of the Electricity Act, 2003 (hereinafter referred to as “the Act”), has specified CERC (Indian Electricity Grid Code), Regulations 2023 (hereinafter referred to as “the Grid Code”) on 29.05.2023 effective from 1.10.2023. Section 28(2) of the Act provides that the Regional Load Despatch Centre shall comply with such principles, guidelines and methodologies in respect of wheeling and optimum scheduling and despatch of electricity as the Central Commission may specify in the Grid Code. Section 29(1) of the Act provides that the Regional Load Despatch Centre shall issue such directions and exercise such supervision and control as may be required for ensuring the stability of the grid operation and for achieving the maximum economy and efficiency in the operation of the power system in the region under its control. Section 33(3) of the Act provides that the State Load Despatch Centre shall comply with the directions of the Regional Load Despatch Centre (“RLDC”). Section 29(4) of the Act provides that the Regional Power Committee in the region may, from time to time, agree on matters concerning the stability and smooth operation of the integrated grid and the economy and efficiency of the power system within the region. Therefore, the Act envisages and assigns responsibilities to the



Regional Load Despatch Centres and State Load Despatch Centres as apex bodies at the regional level and state level, respectively, to ensure safe, secure, stable, and integrated operation of the power system in the respective region or the state, as the case may be, and to the Regional Power Committees to coordinate among the constituents in their respective regions to achieve agreement with regard to stability and smooth operation of the integrated grid.

2. Regulation 31 of the Grid Code provides for the time horizon for operational planning, demand estimation, generation estimation, and adequacy of resources for the purpose of operational planning in the following manner: -

(a) For operational planning, National Load Despatch Centre, Regional Load Despatch Centres, and State Load Despatch Centres have been assigned the responsibility to carry out operational planning within their respective control areas on Intra-day, Day Ahead, and Weekly time horizons.

(b) For demand estimation, the State Load Despatch Centres are mandated to carry out demand estimation as part of operational planning for both active power and reactive power incidents on the transmission systems based on the details collected from distribution licensees, grid-connected distributed generation resources, captive power plants and other bulk consumers embedded within the State and to estimate the peak and off-peak demand on a weekly and monthly basis for load - generation balance planning as well as for operational planning. Based on the demand estimate furnished by SLDCs and other entities directly connected to the ISTS, RLDCs shall prepare regional

demand estimates based on which NLDC shall prepare national demand estimates.

(c) For generation estimation, RLDCs have been mandated to forecast generation from wind, solar, ESS, and renewable energy hybrid generating stations, which are regional entities, and SLDCs have been mandated to forecast generation from such resources which are intra-State entities for different time horizons, for the purpose of operational planning.

(d) SLDCs are required to estimate and ensure adequacy of resources, identify generation, demand response capacity, and generation flexibility requirements, and furnish time block-wise information for the following day in respect of all intra-State entities to the concerned RLDCs who shall validate the adequacy of resources with due regard to the aggregated demand forecast for the control area, renewable energy generation forecast for the control area, injection schedule of intra-State entity generating stations, requisition from regional entity generating stations, secondary and planned procurement through tertiary reserve requirements, and planned procurement through bilateral or collective transactions.

3. Regulation 33 provides that based on the operational planning analysis data, NLDC, RLDCs, and SLDCs shall carry out operational planning studies in real time, intra-day, day-ahead, and weekly basis, and RPCs shall carry out operational planning studies on monthly/yearly basis. This Regulation further provides that operational studies shall be carried out to assess whether the planned operations would result in



deviations from any of the operational limits defined under the Grid Code and applicable standards issued by the Central Electricity Authority. Regulation 33 further enjoins upon Regional Power Committees to monitor significant deviations for early resolution. NLDCs, RLDCs, RPCs, and SLDCs are required to develop operating plans to address potential deviation from system operational limits identified as a result of the operational planning study and communicate the same to the users in advance for taking corrective measures. The detailed reasons and explanations given by the users shall be discussed in the monthly operation sub-committee of the respective regions, and quarterly reports shall be submitted by RPCs to the Commission and CEA.

4. An extract of Regulations 31 and 33 of the Grid Code is enclosed in this order for the convenience of reference.

5. The Commission sought details of the load-generation scenario for the months of September and October 2024 from NLDC, followed by meetings of the Commission with the officers of NLDC. NLDC has submitted forecast scenarios for the months of September 24 and October 2024. The NLDC has also conducted the meeting of the Forum of Load Despatchers to ensure the proper projection of demand by the State Load Despatch Centre. We have considered the peak demand forecast for the month of October 2024. A summary of these scenarios is as under:-



Table 1: Peak demand forecast and load generation balance during Oct-24
(in GW)

	Oct-24
Demand Forecast	
Peak Demand forecast	230
Peak Demand (including ISTS losses) forecast	232.2
Available generation (other than thermal generation)	59.4
Ex-bus Thermal Requirement (without reserve)	172.8
Gross Thermal Requirement (without reserve)	187.9
Estimated Thermal Generation	
Net available thermal capacity	182.20
Availability of generation required	
Additional generation required	5.7
Additional generation required (with reserve 3% of peak demand)	12.60

It is observed from the above table that the projected load generation balance based on peak demand during October 2024 indicates the requirement for additional generation. The rise in demand during solar generation hours can be met from renewable generation provided the solar generation is as per the past trends. However, during non-solar hours (including evening and morning peaks), there is a requirement of additional requirement of Generation resources of about 12.60 GW with a reserve requirement of 3% to meet contingency.

6. The Grid Code enjoins the responsibility upon all concerned stakeholders to ensure stable and economic operation of power system and resolve the issues of significant deviations, if any. The Commission, taking cognizance of the previous year's record, intends to impress upon all the stakeholders that there is an imperative need for prudent planning of load generation balance and issue of alerts to all the grid-connected user entities of the concerned control areas to make them aware about the

anticipated challenges in the operation of the power system and for undertaking the preventive measures as may be required to maintain load generation balance.

7. The Commission is of the view that there is a need to sensitize all the stakeholders, monitor their actions, and bring about behavioural changes through specific and proactive regulatory interventions. The Commission believes that it is advisable to take preventive *ex-ante* measures instead of the *ex-post* reactive measures of finding instances of violation of the Grid Code, initiating penal proceedings for violation, and imposing penalty under the provisions of the Act. This proactive approach would also help to encourage collective efforts on the part of the National Load Despatch Centre, Regional Load Despatch Centres, State Load Despatch Centres, and the grid connected entities to make concerted efforts to ensure stable and economic operation of the grid.

8. The projected requirement of generation is significantly higher than the annual growth of the electricity demand and the addition of generation capacity. The projected requirement of thermal generation during October, 2024 needs proper operational planning and adequacy of resources in terms of Regulation 31(4) of the Grid Code. Any uncertain variation in the electricity demand arising on account of seasonal variations leading to a rapid increase in demand causes undesirable stress in the power system. The steep rise in electricity demand without adequate generation sources may put the power system operation at risk. It is the statutory responsibility of the RLDCs and SLDCs to carry out the operational planning for the increase in demand due to seasonal variations while discharging their functions under Sections 28



and 32 of the Act, respectively, read with the provisions of Regulations 31 and 33 of the Grid Code. 12. In light of the above, the Commission feels that there is a need to prepare the system operators and the stakeholders to meet the situation arising out of the abrupt increase in demand due to seasonal variations, especially during October 2024. Regulation 60 of the Grid Code empowers the Commission to issue practice directions through suo-moto proceedings with regard to implementation of the provisions of the said Regulations. Regulation 60 of the Grid Code is extracted as under:-

“60. Issue of Suo Motu Orders and Directions

The Commission may from time to time issue suo motu orders and practice directions with regard to implementation of these regulations and matters incidental or ancillary thereto, as the case may be.”

9. In exercise of the powers vested under Regulation 60, read with all relevant provisions of the Grid Code, the Commission issues the following directions to NLDC, RLDCs, and SLDCs in connection with the implementation of Regulations 31 and 33 of the Grid Code to address the anticipated surge in demand of electricity during October 2024 on account of seasonal variations:

- a) All the State Load Despatch Centres and RLDCs shall furnish the details of operational planning undertaken by them in terms of Regulation 31(4) (a) of the Grid Code especially for October 2024. RLDC shall validate the adequacy of resources in terms of Regulation 31(4)(b) of the Grid Code.
- b) All State Load Despatch Centres and Regional Load Despatch Centres shall prepare the worst-case scenario due to possible surge in demand during the



period 1.10.2024 to 31.10.2024 in their respective control area and submit within seven days to the Commission with a copy to National Load Despatch Centre.

- c) The State Load Despatch Centres or Regional Load Despatch Centres, as the case may be, should assess their demand-generation scenario in the upcoming months, ensure the optimum generation, avoid undesirable planned outages, and advise the generating company to offer their availability. The State Load Despatch Centre or Regional Load Despatch Centre shall ensure the optimum scheduling during the shortage period and surplus power to get despatched during the deficit period.
- d) The Distribution Companies, in case of a shortage scenario, can procure the power from surplus or requisitioned capacity of other states so that optimum despatch can be ensured for safe and reliable power system operations. The State Load Despatch Centre shall monitor the generation-demand deficit of the respective distribution companies.
- e) The generating companies operating their plant with capacity less than its installed capacity due to technical issues, i.e., capacity under partial outage or forced outage, are advised to fix the issues to ensure the maximum generation capacity on-bar.
- f) The draw schedule of the respective control area needs to adhere to prevent the reduction of system frequency. The State Load Despatch Centre or Regional Load Despatch Centre, as the case may be, shall monitor the deviation of the key system parameters.

g) The State Load Despatch Centres or Regional Load Despatch Centres, as the case may be, shall issue the system alerts to their respective grid-connected entities for the possible deficit during the likely surge in demand.

10. The Regional Load Despatch Centres and State Load Despatch Centres shall submit the report on the implementation of the above measures, a load-generation scenario in their respective control areas, and any other measures taken to address the deficit of power supply during the period 1.10.2024 to 31.10.2024.

11. The objective of the present proceedings is to prepare the system operators and other stakeholders to meet the challenges and threats to the power system that may arise due to the abrupt increase in demand. The responses of the SLDCs, RLDCs, and NLDC with regard to the implementation of the measures detailed in para 9 of this order shall, in the first instance, be examined in detail by a Single-Member Bench comprising a Member of the Commission. Accordingly, in the exercise of powers under Section 97 of the Electricity Act, 2003, the Commission nominates Shri Ramesh Babu V., Member, to conduct the proceedings for this purpose. The Single Member Bench shall provide due opportunity to the parties to make their submissions. The Single Member Bench shall have the authority to direct the parties to submit such further information and to take such remedial measures as may be considered necessary. The Single Member Bench shall submit a report to the Commission with regard to the preparedness of the System Operators and other stakeholders to meet the challenges arising on account of the sudden surge in demand for power and his recommendations with regard to the remedial measures to be taken for the future. The



Commission, after consideration of the report of the Single Member Bench shall issue appropriate directions as may be considered appropriate.

12. NLDC, RLDCs, and SLDCs are directed to submit their responses to the measures contained in para 9 of this order by 16.10.2024.

Sd./-
(Shri Harish Dudani)
Member

Sd./-
(Shri Ramesh Babu V)
Member

Sd./-
(Shri Jishnu Barua)
Chairperson



Extract of Regulation 31 and 33 of the Grid Code

31. OPERATIONAL PLANNING

(1) Time Horizon

- (a) Operational planning shall be carried out in advance by NLDC, RLDCs and SLDCs within their respective control areas with Monthly and Yearly time horizons in co-ordination with CTU, RPCs or STUs, as applicable.
- (b) Operational planning shall be carried out in advance by NLDC, RLDCs and SLDCs within their respective control areas on Intra-day, Day Ahead, Weekly time horizons.
- (c) RLDCs in consultation with NLDC shall issue procedures and formats for data collection to carry out:
 - (i) Operational planning analysis,
 - (ii) Real-time monitoring,
 - (iii) Real-time assessments.
- (d) SLDC may also issue procedures and formats for data collection for the above purposes.

(2) Demand Estimation

- (a) Each SLDC shall carry out demand estimation as part of operational planning after duly factoring in the demand estimation done by STU as part of resource adequacy planning referred to in Chapter 2 of these regulations. Demand estimation by SLDC shall be for both active power and reactive power incidents on the transmission system based on the details collected from distribution licensees, grid-connected distributed generation resources, captive power plants and other bulk consumers embedded within the State.



- (b) Each SLDC shall develop methodology for daily, weekly, monthly, yearly demand estimation in MW and MWh for operational analysis as well as resource adequacy purposes. Each SLDC, while estimating demand may utilize state of the art tools, weather data, historical data and any other data. For this purpose, all distribution licensees shall maintain a historical database of demand.
- (c) The demand estimation by each SLDC shall be done on day ahead basis with time block wise granularity for the daily operation and scheduling. In case SLDC observes a major change in demand in real time for the day, it shall immediately submit the revised demand estimate to the concerned RLDC for demand estimate correction.
- (d) Each SLDC shall submit node-wise morning peak, evening peak, day shoulder and night off-peak estimated demand in MW and MVA on a monthly and quarterly basis for the nodes 110 kV and above for the preparation of scenarios for computation of TTC and ATC by the concerned RLDC and NLDC.
- (e) SLDC shall also estimate peak and off-peak demand (active as well as reactive power) on a weekly and monthly basis for load - generation balance planning as well as for operational planning analysis, which shall be a part of the operational planning data. The demand estimates mentioned above shall have granularity of a time block. The estimate shall cover the load incident on the grid as well as the net load incident taking into account embedded generation in the form of roof-top solar and other distributed generation.
- (f) The entities such as bulk consumers or distribution licensees that are directly connected to ISTS shall estimate and furnish such a demand estimate to the concerned RLDC.
- (g) Based on the demand estimate furnished by the SLDCs and other entities directly connected to ISTS, each RLDC shall prepare the regional demand estimate and submit it to the NLDC. NLDC, based on regional demand estimates furnished by RLDCs, shall prepare national demand estimate.



- (h) Timeline for submission of demand estimate data by SLDCs or other entities directly connected to ISTS, as applicable, to the respective RLDC and RPC shall be as follows:
- (i) SLDCs, RLDCs and NLDC shall compute forecasting error for intra-day, dayahead, weekly, monthly and yearly forecasts and analyse the same in order to reduce forecasting error in the future. The computed forecasting errors shall be made available by SLDCs, RLDCs and NLDC on their respective websites.

(3) Generation Estimation

- (a) The modalities of generation estimation by entities shall be as per the Procedure referred to in sub-clause (c) of clause (1) of Regulation 31 of these regulations.
- (b) RLDC shall forecast generation from wind, solar, ESS and Renewable Energy hybrid generating stations that are regional entities and SLDC shall forecast generation from such sources that are intra-state entities, for different time horizons as referred to in clause (1) of Regulation 31 of these regulations for the purpose of operational planning.

(4) Adequacy of Resources

- (a) SLDCs shall estimate and ensure the adequacy of resources, identify generation reserves, demand response capacity and generation flexibility requirements with due regard to the resource adequacy framework as specified under Chapter 2 of these regulations.
- (b) SLDCs shall furnish time block-wise information for the following day in respect of all intra-state entities to the concerned RLDC who shall validate the adequacy of resources with due regard to the following:
 - (i) Demand forecast aggregated for the control area;
 - (ii) Renewable energy generation forecast for the control area;

- (iii) Injection schedule for intra-State entity generating station;
- (iv) Requisition from regional entity generating stations;
- (v) Secondary and planned procurement through Tertiary reserve requirement;
- (vi) Planned procurement of power through other bilateral or collective transactions, if any.

33. OPERATIONAL PLANNING STUDY

- (1) Based on the operational planning analysis data, operational planning study shall be carried out by various agencies for time horizons as under:
- (2) SLDCs, RLDCs and NLDC shall utilize network estimation tool integrated in their EMS and SCADA systems for the real time operational planning study. All users shall make available at all times real time error free operational data for the successful execution of network analysis using EMS/SCADA. Failure to make available such data shall be immediately reported to the concerned SLDC, the concerned RLDC and NLDC along with a firm timeline for restoration. The performance of online network estimation tools at SLDC and RLDC shall be reviewed in the monthly operational meeting of RPC. Any telemetry related issues impacting the online network estimation tool shall be monitored by RPC for their early resolution.
- (3) SLDCs shall perform day-ahead, weekly, monthly and yearly operational studies for the concerned State for:
 - (a) assessment and declaration of total transfer capability (TTC) and available transfer capability (ATC) for the import or export of electricity by the State. TTC and ATC shall be revised from time to time based on the commissioning of new elements and other grid conditions and shall be published on SLDC website with all the assumptions and limiting constraints;



- (b) planned outage assessment;
 - (c) special scenario assessment;
 - (d) system protection scheme assessment;
 - (e) natural disaster assessment; and
 - (f) any other study relevant in operational scenario.
- (4) RLDCs and NLDC shall perform day-ahead, weekly, monthly and yearly operational studies for:
- (a) assessment of TTC and ATC at inter-regional, intra-regional, and inter-state levels;
 - (b) planned outage assessment;
 - (c) special scenario assessment;
 - (d) system protection scheme assessment;
 - (e) natural disaster assessment; and
 - (f) any other study relevant to operational scenarios
- (5) RLDC shall assess intra-regional and inter-state level TTC and ATC and submit them to NLDC. NLDC shall declare TTC and ATC for import or export of electricity between regions including simultaneous import or export capability for a region, and crossborder interconnections 11 (Eleven) months in advance for each month on a rolling basis. TTC and ATC shall be revised from time to time based on the commissioning of new elements and other grid conditions and shall be published on the websites of the NLDC and respective RLDCs with all the assumptions and limiting constraints
- (6) Operational planning study shall be done to assess whether the planned operations shall result in deviations from any of the system operational limits defined under these regulations and applicable CEA Standards. The deviations, if



any, shall be reviewed in the monthly operational meeting of RPC and significant deviations shall be monitored by RPC for early resolution.

- (7) NLDC, RLDCs, RPCs and SLDCs shall maintain records of the completed operational planning study, including date specific power flow study results, the operational plan and minutes of meetings on operational study.
- (8) NLDC, RLDCs, RPCs and SLDCs shall have operating plans to address potential deviations from system operational limit identified as a result of the operational planning study. These operating plans shall be communicated to users in advance so that they can take corrective measures. In case any user is unable to adhere to such an operating plan, it shall inform the respective SLDC, RLDC and NLDC in advance with detailed reasons and explanations for the non-adherence. These detailed reasons and explanations shall be discussed in the monthly operation sub-committee of the respective region and a quarterly report shall be submitted by the respective RPC to the Commission and CEA.
- (9) Each SLDC shall undertake a study on the impact of new elements to be commissioned in the intra-state system in the next six (6) months on the TTC and ATC for the State and share the results of the studies with RLDC.
- (10) Each RLDC shall undertake a study on the impact of new elements to be commissioned in the next six (6) months in (a) the ISTS of the region and (b) the intrastate system on the inter-state system and share the results of the studies with NLDC
- (11) NLDC shall undertake study on the impact of new elements to be commissioned in the next six (6) months in (a) inter-regional system, (b) cross-border link and (c) intraregional system on the inter-regional system.
- (12) NLDC, RLDCs and SLDCs shall compare the results of the studies of the impact of new elements on the system and transfer capability addition with those of the interconnection and planning studies by CTU and STUs, and any significant

variations observed shall be communicated to CEA, RPCs, CTU and STUs for immediate and long-term mitigation measures.

- (13) Defense mechanisms like system protection scheme, load-rejection scheme, generation run-back, islanding scheme or any other scheme for system security shall be proposed by the concerned user or SLDC or RLDC or NLDC and shall be deployed as finalized by the respective RPC.

S.No.	Voltage Level	Name of Line	Circuit ID	Tower Configura	Line Length	O&M by	Agency at		Type of conductor	Remarks	Replaced with Polymer Insulator (As a % of Total Line)	Remarks
							End-I	End-II				
1. HVDC lines												
ISTS LINES												
A. POWERGRID												
1	± 800kV	Agra-Bishwanath Chariali Pole-I	1	Bi-pole	1728	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing	HVDC capacity 6000 MW, only two physical lines	Partial (11%)	
2	± 800kV	Agra-Bishwanath Chariali Pole-II	2	Bi-pole	1728	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing		Partial (11%)	
3	± 800kV	Agra-Alipurduar Pole-I	1	Bi-pole	1296*	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing		Partial (11%)	
4	± 800kV	Agra-Alipurduar Pole-II	2	Bi-pole	1296*	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing	HVDC capacity 6000 MW, only two physical lines	Partial (11%)	
5	± 800kV	Kurukshetra-Champa Pole-I	1	Bi-pole	1305	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing		Partial (11%)	
6	± 800kV	Kurukshetra-Champa Pole-II	2	Bi-pole	1305	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing		Partial (11%)	
7	± 800kV	Kurukshetra-Champa Pole-III	3	Bi-pole	1305	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing	HVDC capacity 2500 MW	Partial (11%)	
8	± 800kV	Kurukshetra-Champa Pole-IV	4	Bi-pole	1305	POWERGRID	POWERGRID	POWERGRID	Hexagon Lapwing		Partial (11%)	
9	± 500kV	Balia-Bhiwadi Pole-I	1	Bi-pole	790	POWERGRID	POWERGRID	POWERGRID	ACSR Quad Bersimis		Partial (15%)	
10	± 500kV	Balia-Bhiwadi Pole-II	2	Bi-pole	790	POWERGRID	POWERGRID	POWERGRID	ACSR Quad Bersimis	HVDC capacity 1500 MW	Partial (15%)	
11	± 500kV	Rihand-Dadri Pole-I	1	Bi-pole	815	POWERGRID	POWERGRID	POWERGRID	ACSR Quad Bersimis		Partial (62%)	
12	± 500kV	Rihand-Dadri Pole-II	2	Bi-pole	815	POWERGRID	POWERGRID	POWERGRID	ACSR Quad Bersimis		Partial (43%)	
B. Adani Power Ltd (Adani Transmission India Ltd.)												
1	± 500kV	Adani Mundra - Mahindergarh Pole-I	1	Bi-pole	990	ATIL	APL Mundra	ATIL	ACSR Quad Bersimis	HVDC capacity 2500 MW	Partial (43%)	
2	± 500kV	Adani Mundra - Mahindergarh Pole-II	2	Bi-pole	990	ATIL	APL Mundra	ATIL			Partial (43%)	
2. 765kV Transmission Line												
ISTS LINES												
A. POWERGRID												
1	765kV	Agra-Aligarh	1	D/C	123	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis	LILO of Agra-Gr. Noida at Aligarh (LILO portion)	Polymer Insulator	
2	765kV	Aligarh-Gr.Noida	1	D/C	51	POWERGRID	POWERGRID	WUPPTCL	Quad Bersimis		Polymer Insulator	
3	765kV	Agra-Fatehpur	1	S/C	335	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Conventional	
4	765kV	Agra-Fatehpur	2	S/C	334	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Conventional	
5	765kV	Agra-Jhatikara	1	S/C	252	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Polymer Insulator	
6	765kV	Ajmer-Chittorgarh	1	D/C	211	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available	
7	765kV	Ajmer-Chittorgarh	2	D/C	211	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available	
8	765kV	Ajmer-Bhadla II	1	D/C	326	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra	LILO of 765kV D/C Ajmer-Bikaner-1 at Bhadla II(PG)	Not Available	
9	765kV	Ajmer-Bhadla II	2	D/C	326	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra	LILO of 765kV D/C Ajmer-Bikaner-2 at Bhadla II(PG)	Not Available	
10	765kV	Balia - Lucknow765 (N)	1	S/C	319	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Conventional	
11	765kV	Bikaner - Bhadla	1	D/C	167	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available	
12	765kV	Bikaner - Bhadla	2	D/C	167	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available	
13	765kV	Bikaner- Moga	1	D/C	367	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available	
14	765kV	Bikaner- Moga	2	D/C	367	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available	
15	765kV	Bikaner-Bhadla II	1	D/C	197	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra	LILO of 765kV D/C Ajmer-Bikaner-1 at Bhadla II(PG)	Not Available	
16	765kV	Bikaner-Bhadla II	2	D/C	197	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra	LILO of 765kV D/C Ajmer-Bikaner-2 at Bhadla II(PG)	Not Available	
17	765kV	Kanpur(GIS)-Aligarh	1	D/C	322	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis	LILO of Kanpur-Jhatikara at Aligarh	Polymer Insulator	
18	765kV	Aligarh-Jhatikara	1	D/C	158	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Polymer Insulator	
19	765kV	Jhatikara-Bhiwani (PG)	1	S/C	85	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Polymer Insulator	
20	765kV	Koteshwar(PG)-Meerut	1	S/C	176	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis	Earlier charged at 400kV	Not Available	
21	765kV	Koteshwar(PG)-Meerut	2	S/C	176	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Not Available	
22	765kV	Lucknow-Bareilly	1	S/C	252	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Conventional	
23	765kV	Meerut-Bhiwani(PG)	1	S/C	174	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Partial (99%)	

24	765kV	Meerut-Gr.Noida	1	S/C	119	POWERGRID	POWERGRID	WUPPTCL	Quad Bersimis	Agra-Meerut LILOed at G. Noida by UPPTCL	Polymer Insulator
25	765kV	Moga- Bhiwani (PG)	1	S/C	273	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Partial (96%)
26	765kV	Moga-Meerut	1	S/C	338	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Polymer Insulator
27	765kV	Orai-Aligarh	1	D/C	331	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available
28	765kV	Orai-Aligarh	2	D/C	331	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Not Available
29	765kV	Phagi-Bhiwani(PG)	1	S/C	272	POWERGRID	RRVPNL	POWERGRID	Quad Bersimis		Partial (18%)
30	765kV	Phagi-Bhiwani(PG)	2	S/C	277	POWERGRID	RRVPNL	POWERGRID	Quad Bersimis		Partial (16%)
31	765kV	Varanasi-Balia	1	S/C	166	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Conventional
32	765kV	Varanasi-Fatehpur	1	S/C	223	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis	LILO of Gaya (ER)- Fatehpur at Varanasi	Conventional
33	765kV	Varanasi-Kanpur(GIS)	1	S/C	326	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Polymer Insulator
34	765kV	Varanasi-Kanpur(GIS)	2	S/C	326	POWERGRID	POWERGRID	POWERGRID	Hexa Zebra		Polymer Insulator
B. PKTSL											
1	765kV	Khetri-Jhatikara	1	D/C	146	PKTSL	PKTSL	POWERGRID	Hexa Zebra		Not Available
2	765kV	Khetri-Jhatikara	2	D/C	146	PKTSL	PKTSL	POWERGRID	Hexa Zebra		Not Available
C. PFTL											
1	765kV	Fatehgarh II-Bhadla II	1	D/C	186	PFTL	POWERGRID	POWERGRID	Hexa Zebra		Not Available
2	765kV	Fatehgarh II-Bhadla II	2	D/C	186	PFTL	POWERGRID	POWERGRID	Hexa Zebra		Not Available
D. FBTL											
1	765kV	Fatehgarh II-Bhadla	1	D/C	175	FBTL	POWERGRID	POWERGRID	Hexa Zebra	Loop in of 400kV Fatehgarh (FBTL)-	Polymer Insulator
2	765kV	Fatehgarh II-Bhadla	2	D/C	175	FBTL	POWERGRID	POWERGRID	Hexa Zebra		Polymer Insulator
E. BKTL											
1	765kV	Bikaner-Khetri	1	D/C	241	BKTL	POWERGRID	PKTSL	Hexa Zebra		Polymer Insulator
2	765kV	Bikaner-Khetri	2	D/C	241	BKTL	POWERGRID	PKTSL	Hexa Zebra		Polymer Insulator
F. PAPTL											
1	765kV	Ajmer-Phagi	1	D/C	134	PAPTL	POWERGRID	RRVPNL	Hexa Zebra		Not Available
2	765kV	Ajmer-Phagi	2	D/C	134	PAPTL	POWERGRID	RRVPNL	Hexa Zebra		Not Available
G. PASTL											
1	765kV	Aligarh(PG)-SIKAR_2	1	D/C	265	PASTL	PSTL	POWERGRID	Hexa Zebra	Anti theft charged	Not Available
2	765kV	Aligarh(PG)-SIKAR_2	2	D/C	265	PASTL	PSTL	POWERGRID	Hexa Zebra	from Aligarh(PG) Upto	Not Available
STATE LINES											
A. UPPTCL											
1	765kV	Agra Fatehabad-Ghatampur	1	S/C	229	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis		Not Available
2	765kV	Agra Fatehabad-Gr. Noida	1	S/C	159	UPPTCL	UPPTCL	UPPTCL	ACSR Quad Bersimis		Not Available
3	765kV	Agra(Fatehbad)-Lalitpur	1	S/C	337	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis		Not Available
4	765kV	Agra(Fatehbad)-Lalitpur	2	S/C	335	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis		Not Available
5	765kV	AnparaC-AnparaD	1	S/C	3	UPPTCL	LANCO	UPRVUNL	Quad Bersimis		Not Available
6	765kV	AnparaC-Unnao	1	S/C	409	UPPTCL	LANCO	UPPTCL	Quad Bersimis		Conventional
7	765kV	AnparaD-Obra_C	1	D/C	53	UPPTCL	UPRVUNL	UPPTCL	Quad Bersimis	After LILO of 765 KV	Not Available
8	765kV	Obra_C-Unnao	1	D/C	390	UPPTCL	UPRVUNL	UPPTCL	Quad Bersimis	ANPARA D-UNNAO LINE	Not Available
9	765kV	Bara-Mainpuri	1	S/C	377	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis		Not Available
10	765kV	Gr. Noida-Meerut_PMSTL	1	S/C	100	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis	After LILO of 765 KV	Not Available
11	765kV	Meerut_PMSTL-Hapur	1	S/C	37	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis	GREATER NOIDA	Not Available
12	765kV	Gr. Noida-Jawaharpur	1	D/C	162	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis	After LILO of 765 KV	Not Available
13	765kV	Jawaharpur-Mainpuri	1	D/C	40	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis	MAINPURI(SEUPPTCL)-	Not Available
14	765kV	Hapur(UP)-Rampur_PRSTL (UP)	1	S/C	230	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis	LILO of 765KV Hapur-Ghatampur at Rampur. LILO portion is on D/C tower 2.5km 5towers	Not Available

AnparaB-Unnao shifted to AnparaC and charged at 765kV

15	765kV	Mainpuri(UP)-Hapur(UP)	1	S/C	217	UPPTCL	UPPTCL	UPPTCL	Quad Bersimis		Not Available	
B. RRVPNL												
1	765kV	Anta-Phagi	1	S/C	214	RRVPNL	RRVPNL	RRVPNL	Quad Bersimis		Not Available	
2	765kV	Anta-Phagi	2	S/C	212	RRVPNL	RRVPNL	RRVPNL	Quad Bersimis		Not Available	
3. 765kV Transmission Line charged at 400kV												
ISTS LINES												
A. POWERGRID												
1	765kV charged at 400kV	Kishenpur-Moga	1	S/C	275	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Partial (1%)	
2		Kishenpur-Moga	2	S/C	287	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis		Partial (1%)	
3		Tehri-Koteshwar(PG)	1	S/C	15	POWERGRID	THDC	POWERGRID	Quad Bersimis		Conventional	
4		Tehri-Koteshwar(PG)	2	S/C	17	POWERGRID	THDC	POWERGRID	Quad Bersimis		Conventional	
5		Rihand-Vindhyachal Pool	1	S/C	31	POWERGRID	NTPC	POWERGRID	Quad Bersimis		Not Available	
6		Rihand-Vindhyachal Pool	2	S/C	31	POWERGRID	NTPC	POWERGRID	Quad Bersimis		Not Available	
4. 400kV HVAC Transmission Line												
ISTS LINES												
A. POWERGRID												
1	400kV	Abdullapur- Bawana	1	D/C	167	POWERGRID	POWERGRID	DTL	Triple Snowbird		Partial (99%)	
2	400kV	Abdullapur- Deepalpur	1	D/C	141	POWERGRID	POWERGRID	KT Jhajjar	Triple Snowbird	LILO of Abdullapur-Bawana one ckt at Deepalpur by Jhajjar KT	Partial (99%)	LILO of Abdullapur-Bawana one ckt at Deepalpur
3	400kV	Abdullapur-Kurukshetra	1	D/C	52	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird+Twin HTLS for LILO	LILO of Abdullapur-Sonapat line at Kurukshetra	Polymer Insulator	LILO of Abdullapur-Sonepat ckts at Kurukshetra
4	400kV	Abdullapur-Kurukshetra	2	D/C	52	POWERGRID	POWERGRID	POWERGRID		LILO of Abdullapur-Sonapat line at Kurukshetra	Polymer Insulator	
5	400kV	Agra-Agra(Fatehabad)	1	S/C	45	POWERGRID	POWERGRID	UPPTCL	Twin Moose	LILO of Agra(PG)-Agra(UP) ckt-2 at Fatehabad (765kV Agra UP)	Polymer Insulator	
6	400kV	Agra(UP)-Agra(Fatehabad)	1	S/C	56	POWERGRID	UPPTCL	UPPTCL	Twin Moose		Polymer Insulator	
7	400kV	Agra-Agra(UP)	1	D/C	30	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Polymer Insulator	
8	400kV	Agra-Ballabgarh	1	S/C	181	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
9	400kV	Agra-Bassi	1	S/C	211	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	Planned for insulator replacement in 321nos towers under NR3
10	400kV	Agra-Bhiwadi	1	D/C	209	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
11	400kV	Agra-Bhiwadi	2	D/C	209	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
12	400kV	Agra-Jaipur South	1	D/C	254	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Agra-Bassi D/C at Jaipur South	Partial (4%)	LILO of Agra-Bassi D/C at Jaipur South
13	400kV	Agra-Jaipur South	2	D/C	254	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Agra-Bassi D/C at Jaipur South	Partial (4%)	
14	400kV	Agra-Sikar	1	D/C	386	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (3%)	
15	400kV	Agra-Sikar	2	D/C	386	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (3%)	
16	400kV	Ajmer-Ajmer(PG)	1	D/C	66	POWERGRID	RRVPNL	POWERGRID	Quad Moose		Not Available	
17	400kV	Ajmer-Ajmer(PG)	2	D/C	66	POWERGRID	RRVPNL	POWERGRID	Quad Moose		Not Available	
18	400kV	Allahabad-Fatehpur	3	S/C	154	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Allahabad-Kanpur one ckt at Fatehpur	Polymer Insulator	
19	400kV	Allahabad-Fatehpur	1	D/C	140	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Lilo of Allahabad-Mainpuri (PG) D/C at Fatehpur	Conventional	
20	400kV	Allahabad-Fatehpur	2	D/C	140	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Lilo of Allahabad-Mainpuri (PG) D/C at Fatehpur	Conventional	
21	400kV	Allahabad-Varanasi	1	D/C	99	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Allahabad-Sarnath shifted from Sarnath to varanasi	Conventional	
22	400kV	Allahabad-Kanpur	1	S/C	225	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
23	400kV	Allahabad-Kanpur(New 765)	1	D/C	240	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
24	400kV	Allahabad-Kanpur(New 765)	2	D/C	240	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
25	400kV	Allahabad-Meja(NTPC)	1	D/C	28	POWERGRID	POWERGRID	MUNPL	Twin Moose		Polymer Insulator	MUNPL is joint venture between NTPC and UPPCL
26	400kV	Allahabad-Meja(NTPC)	2	D/C	28	POWERGRID	POWERGRID	MUNPL	Twin Moose		Polymer Insulator	

27	400kV	Amritsar-Jalandhar	1	S/C	60	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
28	400kV	Amritsar-Jalandhar	2	D/C	71	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	LILO of 400kV Amritsar-Hamirpur at Jalandhar
29	400kV	Amritsar-Parbati Pooling (Banala)	1	D/C	251	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (49%)	
30	400kV	Auraiya-Agra	1	D/C	166	POWERGRID	NTPC	POWERGRID	Twin Moose		Partial (86%)	
31	400kV	Auraiya-Agra	2	D/C	166	POWERGRID	NTPC	POWERGRID	Twin Moose		Partial (90%)	
32	400kV	Baglihar II-Kishenpur	1	S/C	130	POWERGRID	JKSPDCL	POWERGRID	Twin Moose	LILO of 400kV Kishenpur-New Wanpoh ckt-2 at Baglihar. LILO portion is of JK PDD	Conventional	
33	400kV	Baglihar II-New Wanpoh	1	S/C	130	POWERGRID	JKSPDCL	POWERGRID	Twin Moose		Not Available	
34	400kV	Bagpat-Kaithal	1	D/C	154	POWERGRID	POWERGRID	POWERGRID	Quad Moose	LILO of Meerut-Kaithal DC at Bagpat	Polymer Insulator	
35	400kV	Bagpat-Kaithal	2	D/C	154	POWERGRID	POWERGRID	POWERGRID	Quad Moose	LILO of Meerut-Kaithal DC at Bagpat	Polymer Insulator	
36	400kV	Bagpat-Saharanpur	1	D/C	121	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Partial (41%)	
37	400kV	Bagpat-Dehradun	1	D/C	165	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Partial (40%)	
38	400kV	Bahadurgarh-Kabulpur	1	S/C	42	POWERGRID	POWERGRID	HVPNL	Twin Moose		Polymer Insulator	LILO of Bahadurgarh-Bhiwani at Kabulpur
39	400kV	Bahadurgarh-Sonepat	1	D/C	53	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		Polymer Insulator	
40	400kV	Bahadurgarh-Sonepat	2	D/C	53	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		Polymer Insulator	
41	400kV	Balia-Mau	1	D/C	9	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Conventional	
42	400kV	Balia-Sohawal	1	D/C	229	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Balia-LUCKNOW D/C at Sohawal	Conventional	LILO of Balia-Lucknow (316 KM) D/C at Sohawal
43	400kV	Balia-Sohawal	2	D/C	229	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Balia-LUCKNOW D/C at Sohawal	Conventional	LILO of Balia-Lucknow (316 KM) D/C at Sohawal
44	400kV	Ballabgarh-Tughlakabad	1	M/C	40	DTL	POWERGRID	POWERGRID	HTLS INVAR (LILO portion) & Bersimis (before LILO)	Tower is quad circuit tower	Polymer	
45	400kV	Ballabgarh-Tughlakabad	2	M/C	40	DTL	POWERGRID	POWERGRID	HTLS INVAR (LILO portion) & Bersimis (before LILO)	Tower is quad circuit tower	Polymer	
46	400kV	Ballabgarh-Gurgaon	1	S/C	43	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
47	400kV	Ballabgarh-Maharanibagh	1	D/C	61	POWERGRID	POWERGRID	POWERGRID	Quad Bersimis	Bypassed at Maharanibagh to form Dadri-Ballabgarh	Polymer Insulator	
48	400kV	Ballabgarh-Nawada	1	D/C	13	POWERGRID	POWERGRID	HVPNL	Quad Bersimis		Polymer Insulator	Ballabgarh-Gnoida LILOed at Nawada (Faridabad, Haryana)
49	400kV	Bareilly PG-Moradabad	1	D/C	93	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Partial (3%)	
50	400kV	Bareilly PG-Rampur_PRSTL	1	S/C	40	POWERGRID	POWERGRID	UPPTCL	Twin Moose	After LILO of 400 KV BAREILLY(PG)-MORADABAD(UPPTCL) CIRCUIT-II at RAMPUR(PRSTL)	Not Available	
51	400kV	Rampur_PRSTL-Moradabad	1	S/C	57	POWERGRID	UPPTCL	UPPTCL	Twin Moose	After LILO of 400 KV BAREILLY(PG)-MORADABAD(UPPTCL) CIRCUIT-II at RAMPUR(PRSTL)	Not Available	
52	400kV	Bareilly PG-Bareilly (765kV)	1	D/C	2	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Conventional	
53	400kV	Bareilly PG-Bareilly (765kV)	2	D/C	2	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Conventional	

54	400kV	Bareilly PG(765kV)-Kashipur	1	D/C	101	POWERGRID	POWERGRID	PTCUL	Quad Moose		Partial (90%)	
55	400kV	Bareilly PG(765kV)-Kashipur	2	D/C	101	POWERGRID	POWERGRID	PTCUL	Quad Moose		Partial (90%)	
56	400kV	Bassi-Bhiwadi	2	S/C	220	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
57	400kV	Bassi-Heerapura	1	D/C	48	POWERGRID	POWERGRID	RRVNL	Twin Moose		Polymer Insulator	
58	400kV	Bassi-Heerapura	2	D/C	49	POWERGRID	POWERGRID	RRVNL	Twin Moose		Polymer Insulator	
59	400kV	Bassi-Kotputli	1	S/C	106	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
60	400kV	Bassi-Phagi	1	D/C	48	POWERGRID	POWERGRID	RRVNL	Quad Moose		Partial (26%)	
61	400kV	Bassi-Phagi	2	D/C	48	POWERGRID	POWERGRID	RRVNL	Quad Moose		Partial (26%)	
62	400kV	Bassi-Sikar	1	D/C	170	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (16%)	
63	400kV	Bassi-Sikar	2	D/C	170	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (17%)	
64	400kV	Bawana(CCGT)-Bahadurgarh	1	D/C	49	POWERGRID	DTL/Pragati CCGT	POWERGRID	Twin Moose		Polymer Insulator	
65	400kV	Bhadla-Bhadla(PG)	1	D/C	27	POWERGRID	RRVNL	POWERGRID	Quad Moose		Not Available	
66	400kV	Bhadla-Bhadla(PG)	2	D/C	27	POWERGRID	RRVNL	POWERGRID	Quad Moose		Not Available	
67	400kV	Bhadla-Bhadla II	1	D/C	52	POWERGRID	POWERGRID	POWERGRID	Twin HTLS+Hexa Zebra	48.309KM Twin HTLS conductor of POWERGRID and 3.73 KM HEXA Zebra of FBTL	Not Available	
68	400kV	Bhadla-Bhadla II	2	D/C	52	POWERGRID	POWERGRID	POWERGRID	Twin HTLS+Hexa Zebra		Not Available	
69	400kV	Bhinmal-Kankroli	1	D/C	202	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Bypassed at Bhinmal to form 400kV Kankroli Zerda ckt-2	Polymer Insulator	
70	400kV	Bhiwadi-Gurgaon	1	S/C	83	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
71	400kV	Bhiwadi-Hissar	1	S/C	212	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
72	400kV	Bhiwadi-Hissar	2	D/C	144	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	LILo of Bhiwadi-Moga both ckts at Hisar
73	400kV	Bhiwadi-Hissar	3	D/C	144	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
74	400kV	Bhiwadi-NeemranaPG	1	D/C	48	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
75	400kV	Bhiwadi-NeemranaPG	2	D/C	48	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
76	400kV	Bhiwani BBMB - Hissar	1	S/C	35	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Bypassed at Hissar to form Bhiwani BBMB-Fatehabad	Polymer Insulator	
77	400kV	Bhiwani (PG) - Hissar	1	S/C	64	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Bypassed at Hissar to form Moga-Bhiwani(PG) bypassed at Mahendergarh(ATL)	Polymer Insulator	LILo of Bawana-Hisar (132KM) at Bhiwani PG
78	400kV	Bhiwani (PG) - Hissar	2	D/C	57	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
79	400kV	Bhiwani (PG) - Hissar	3	D/C	57	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
80	400kV	Bhiwani PG - Jind	1	D/C	82	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
81	400kV	Bhiwani PG - Jind	2	D/C	82	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
82	400kV	Bhiwani PG- BawanaCCGT	1	D/C	97	POWERGRID	POWERGRID	DTL/ CCGT	Twin Moose		Polymer Insulator	LILo of Bawana-Hisar (132KM) at Bhiwani PG
83	400kV	Bhiwani PG- Bhiwani BBMB	1	S/C	34	POWERGRID	POWERGRID	BBMB	Twin Moose		Polymer Insulator	LILo of Bhiwani (BBMB)- Bahadurgarh (84km) at Bhiwani (PG)
84	400kV	Bhiwani PG-Kabulpur	1	S/C	48	POWERGRID	POWERGRID	HVPNL	Twin Moose		Polymer Insulator	LILo of Bahadurgarh-Bhiwani at Kabulpur
85	400kV	Bikaner_2 (PBTSL)-Bikaner(PG)	1	D/C	43	POWERGRID	PBTSL	POWERGRID	Quad Moose		Not Available	
86	400kV	Bikaner_2 (PBTSL)-Bikaner(PG)	2	D/C	43	POWERGRID	PBTSL	POWERGRID	Quad Moose		Not Available	
87	400kV	Chamba pool - Jalandhar	1	D/C	162	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (48%)	
88	400kV	Chamba pool - Jalandhar	2	D/C	162	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (48%)	
89	400kV	Chamera-II - Chamba Pool	1	S/C	0.38	POWERGRID	NHPC	POWERGRID	Twin Moose		Conventional	Two tower is S/C and one tower is D/C
90	400kV	Chamera-II-Chamera-I	1	S/C	36	POWERGRID	NHPC	NHPC	Twin Moose		Conventional	
91	400kV	Chamera-II-Kishenpur	1	S/C	135	POWERGRID	NHPC	POWERGRID	Twin Moose		Conventional	

92	400kV	Chamera-I-Jalandhar	1	D/C	152	POWERGRID	NHPC	POWERGRID	Twin ACAR		Partial (43%)	
93	400kV	Chamera-I-Jalandhar	2	D/C	152	POWERGRID	NHPC	POWERGRID	Twin ACAR		Partial (43%)	
94	400kV	Chittorgarh-Chittorgarh(PG)	1	D/C	49	POWERGRID	RRVPL	POWERGRID	Quad Moose		Not Available	
95	400kV	Chittorgarh-Chittorgarh(PG)	2	D/C	49	POWERGRID	RRVPL	POWERGRID	Quad Moose		Not Available	
96	400kV	Chittorgarh-Kankroli	1	D/C	71	POWERGRID	RRVPL	POWERGRID	Twin Moose		Polymer Insulator	LILO of 400 kV Rapp C-Kankroli at Chhitorgarh
97	400kV	Dadri NCTPP-G. Noida	1	D/C	13	POWERGRID	NTPC	UPPCL	Quad Bersimis		Polymer Insulator	
98	400kV	Dadri NCTPP-Maharanibagh	1	D/C	54	POWERGRID	NTPC	POWERGRID	Quad Bersimis	Bypassed at Maharanibagh to form Dadri-Ballabgarh	Polymer Insulator	
99	400kV	Dadri NCTPP-Kaithal	1	S/C	213	POWERGRID	NTPC	POWERGRID	Twin Moose	LILO of Dadri-Malerkotla at Kaithal	Polymer Insulator	
100	400kV	Dadri NCTPP-Mandola	1	D/C	46	POWERGRID	NTPC	POWERGRID	Quad Bersimis		Polymer Insulator	
101	400kV	Dadri NCTPP-Mandola	2	D/C	46	POWERGRID	NTPC	POWERGRID	Quad Bersimis		Polymer Insulator	
102	400kV	Dadri NCTPP-Muradnagar New	1	S/C	33	POWERGRID	NTPC	UPPTCL	Twin Moose		Polymer Insulator	Line shifted from Muradnagar to Muradnagar New (UPPTCL)
103	400kV	Dadri NCTPP-Panipat	1	S/C	112	POWERGRID	NTPC	BBMB	Twin Moose		Polymer Insulator	
104	400kV	Dadri NCTPP-Panipat	2	S/C	117	POWERGRID	NTPC	BBMB	Twin Moose		Polymer Insulator	
105	400kV	Deepalpur-Bawana	1	D/C	26	POWERGRID	KT-Jhajjar	DTL	Triple Snowbird	LILO of 400kV Bawana-Abdullapur one circuit at Deepalpur by Jhajjar KT	Polymer Insulator	
106	400kV	Dehradun-Abdullapur	1	D/C	89	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Not Available	
107	400kV	Dehradun-Abdullapur	2	D/C	89	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Not Available	
108	400kV	Dulhasti-Kishenpur	1	S/C	120	POWERGRID	NHPC	POWERGRID	Quad Moose		Conventional	
109	400kV	Dulhasti-Kishenpur	2	S/C	120	POWERGRID	NHPC	POWERGRID	Quad Moose		Conventional	
110	400kV	Dwarka-Jhatikara	1	S/C	18	POWERGRID	POWERGRID	POWERGRID	Twin HTLS	After LILO of 400kV Jhatikara-Bamnoli-I at Dwarka(DC)	Not Available	
111	400kV	Dwarka-Bamnauli	1	S/C	10	POWERGRID	POWERGRID	DTL	Twin HTLS		Not Available	
112	400kV	Fatehabad PG-Hissar	1	D/C	89	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Bypassed at Hissar to form Bhiwani BBMB-Fatehabad	Polymer Insulator	
113	400kV	Fatehpur-Kanpur	1	S/C	100	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	LILO of Singrauli-Kanpur at Fatehpur
114	400kV	Fatehpur-Kanpur	2	S/C	107	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Bypassed at Kanpur to form Fatehpur-Panki	Partial (64%)	LILO of Allahabad-Kanpur one ckt at Fatehpur
115	400kV	Kanpur-Panki	1	S/C	6	POWERGRID	POWERGRID	UPPTCL	Twin Moose	Bypassed at Kanpur to form Fatehpur-Panki	Polymer Insulator	
116	400kV	Kanpur-Panki	2	S/C	6	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Polymer Insulator	
117	400kV	Fatehpur-Mainpuri	1	D/C	260	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	LILO of Allahabad-Mainpuri (363 KM) D/C at Fatehpur Series compensated line (Degree of comp. - 40%)
118	400kV	Fatehpur-Mainpuri	2	D/C	260	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
119	400kV	G.Noida-Nawada	1	D/C	30	POWERGRID	UPPTCL	HVPL	Quad Bersimis	Lilo of Ballabgarh-G.Noida at Nawada	Polymer Insulator	Ballabgarh-Gnoida LILoed at Nawada (Faridabad,Haryana)
120	400kV	Gorakhpur PG-Gorakhpur UP	1	D/C	46	POWERGRID	POWERGRID	UPPCL	Twin Moose		Polymer Insulator	Partial Planning has been completed
121	400kV	Gorakhpur PG-Gorakhpur UP	2	D/C	46	POWERGRID	POWERGRID	UPPCL	Twin Moose		Polymer Insulator	Partial Planning has been completed

122	400kV	Gorakhpur PG-Lucknow PG	1	D/C	264	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (3%)	At crossing
123	400kV	Gorakhpur PG-Lucknow PG	2	D/C	264	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (3%)	At crossing
124	400kV	Gorakhpur PG-Basti (UP)	1	D/C	117	POWERGRID	POWERGRID	UPPTCL	Twin Moose	LILO of 400kV Gorakhpur PG-Lucknow PG ckt-4 at Basti (UP). LILO portion is of UP	Not Available	
125	400kV	Gorakhpur PG-Basti (UP)	2	D/C	108	POWERGRID	POWERGRID	UPPTCL	Twin Moose	LILO of 400kV Lucknow Gorakhpur-3 at Basti. LILO portion is of UP	Not Available	
126	400kV	Basti (UP)-Lucknow PG	1	D/C	204	POWERGRID	UPPTCL	POWERGRID	Twin Moose		Not Available	
127	400kV	Gurgaon-Sohna Road	1	D/C	7	POWERGRID	POWERGRID	GPTL	Quad Moose	LILO of 400kV Gurgaon	Not Available	
128	400kV	Gurgaon-Sohna Road	2	D/C	7	POWERGRID	POWERGRID	GPTL	Quad Moose	Manesar D/C at Sohna Road by GPTL	Not Available	
129	400kV	Hamirpur-Parbati Pooling (Banala)	1	D/C	77	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	LILO of Amritsar-Banala-1 at Hamirpur
130	400kV	Jaipur South-Bassi	1	D/C	37	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Agra-Bassi D/C at Jaipur South	Polymer Insulator	LILO of Agra-Bassi D/C at Jaipur South
131	400kV	Jaipur South-Bassi	2	D/C	37	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Agra-Bassi D/C at Jaipur South	Polymer Insulator	
132	400kV	Jaipur South-Kota	1	D/C	180	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
133	400kV	Jaipur South-RAPP D	1	D/C	228	POWERGRID	POWERGRID	NPCIL	Twin Moose		Not Available	
134	400kV	Jalandhar-Nakodar	1	D/C	42	POWERGRID	POWERGRID	PSTCL	Quad Moose		Polymer Insulator	
135	400kV	Jalandhar-Hamirpur	1	D/C	135	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (43%)	LILO of 400kV Amritsar-Hamirpur at Jalandhar
136	400kV	Kaithal-Hissar	1	D/C	113	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		LILO of Patiala-Hissar at Kaithal	
137	400kV	Kaithal-Hissar	2	D/C	113	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		LILO of Patiala-Hissar at Kaithal	
138	400kV	Kaithal-Malerkotla	1	S/C	135	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
139	400kV	Kankroli-Jodhpur	1	S/C	188	POWERGRID	POWERGRID	RRVNL	Twin HTLS		Conventional	
140	400kV	Kanpur-Agra	1	S/C	240	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
141	400kV	Kanpur-Auraiya	1	D/C	73	POWERGRID	POWERGRID	NTPC	Twin Moose		Conventional	
142	400kV	Kanpur-Auraiya	2	D/C	73	POWERGRID	POWERGRID	NTPC	Twin Moose		Conventional	
143	400kV	Kanpur-Ballabgarh	1	S/C	386	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	*Series Compensated, Ckt 1-35%, Ckt-2 & 3-40%
144	400kV	Kanpur-Ballabgarh	2	D/C	371	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	*Series Compensated, Ckt 1-35%, Ckt-2 & 3-40%
145	400kV	Kanpur-Ballabgarh	3	D/C	371	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	*Series Compensated, Ckt 1-35%, Ckt-2 & 3-40%
146	400kV	Kanpur-Kanpur(GIS)	1	D/C	21	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Polymer Insulator	
147	400kV	Kanpur-Kanpur(GIS)	2	D/C	21	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Polymer Insulator	
148	400kV	Kanpur(GIS)-Lucknow(765)	1	D/C	160	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
149	400kV	Kanpur(GIS)-Lucknow(765)	2	D/C	160	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
150	400kV	Kishenpur-NewWanpoh	1	D/C	130	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
151	400kV	Kishenpur-NewWanpoh	3	D/C	135	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
152	400kV	Kishenpur-NewWanpoh	4	D/C	135	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
153	400kV	Kishenpur-Samba	1	D/C	35	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
154	400kV	Kishenpur-Samba	2	D/C	35	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
155	400kV	Kota-Merta	1	D/C	256	POWERGRID	POWERGRID	RRVNL	Twin Moose		Conventional	

156	400kV	Kotputli-Bhiwadi	1	S/C	132	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	LILO of Bassi-Bhiwadi-2 at Kotputli	
157	400kV	Kurukshetra-Jind	1	D/C	103	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Not Available		
158	400kV	Kurukshetra-Jind	2	D/C	103	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Not Available		
159	400kV	Kurukshetra-Sonipat	1	D/C	125	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird (Twin HTLS for LILO portion)	LILO of Abudhapur-Sonipat line at 400kV	Partial (99%)	LILO of Abudhapur-Sonipat at	
160	400kV	Kurukshetra-Sonipat	2	D/C	125	POWERGRID	POWERGRID	POWERGRID				Partial (99%)	
161	400kV	Kurukshetra(PG)-Dhanansu(PS)	1	D/C	165	POWERGRID	POWERGRID	PSTCL	Quad Moose	Kurukshetra-Jalandhar (LILO portion is of	Polymer Insulator	LILO portion to be checked	
162	400kV	Dhanansu(PS)-Jalandhar(PG)	1	D/C	106	POWERGRID	PSTCL	POWERGRID	Quad Moose				Polymer Insulator
163	400kV	Kurukshetra-Nakodar	1	D/C	234	POWERGRID	POWERGRID	PSTCL	Quad Moose		Polymer Insulator		
164	400kV	Lucknow-Basti	1	D/C	203	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Not Available		
165	400kV	Lucknow-Basti	2	D/C	203	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Not Available		
166	400kV	Lucknow PG-Lucknow UP	1	S/C	63	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Conventional		
167	400kV	Lucknow PG-Unnao	1	D/C	74	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Conventional		
168	400kV	Lucknow PG-Unnao	2	D/C	74	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Conventional		
169	400kV	Lucknow UP-Bareilly PG	1	S/C	279	POWERGRID	UPPTCL	POWERGRID	Twin Moose		Conventional		
170	400kV	765 Lucknow (PG) - Lucknow (PG)	1	D/C	3	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Polymer Insulator		
171	400kV	765 Lucknow (PG) - Lucknow (PG)	2	D/C	3	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Polymer Insulator		
172	400kV	LucknowPG-Sohawal	1	D/C	98	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	LILO of Balia-Lucknow (316 KM) D/C at Sohawal	
173	400kV	LucknowPG-Sohawal	2	D/C	98	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional		
174	400kV	Lucknow PG-Shahjahanpur	1	D/C	170	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (10%)		
175	400kV	Lucknow PG-Shahjahanpur	2	D/C	170	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Partial (10%)		
176	400kV	Lucknow-Jehta	1	D/C	32	POWERGRID	POWERGRID	UPPTCL	Twin Moose	LILO of 400kV Lucknow Unnao DC at Jehta (UP). LILO portion is of	Not Available		
177	400kV	Lucknow-Jehta	2	D/C	32	POWERGRID	POWERGRID	UPPTCL	Twin Moose			Not Available	
178	400kV	Ludhiana-Jalandhar	1	S/C	85	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
179	400kV	Ludhiana-Malerkotla	1	S/C	36	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
180	400kV	Ludhiana-Patiala	1	D/C	76	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
181	400kV	Ludhiana-Patiala	2	D/C	76	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
182	400kV	Mainpuri-Ballabgarh	1	D/C	236	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
183	400kV	Mainpuri-Ballabgarh	2	D/C	236	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
184	400kV	Malerkotla-Patiala	1	S/C	62	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
185	400kV	Manesar- Sohna Road	1	D/C	17	POWERGRID	POWERGRID	GPTL	Quad Moose	LILO of 400kV Gurgaon Manesar D/C at Sohna Road by GPTL	Not Available		
186	400kV	Manesar- Sohna Road	2	D/C	17	POWERGRID	POWERGRID	GPTL	Quad Moose			Not Available	
187	400kV	Mandola-Maharanibagh	1	D/C (LILO towers are M/C)	29	POWERGRID	POWERGRID	POWERGRID	Twin HTLS	After LILO of 400KV Mandola-Bawana D/C Lines at 400KV Maharanibagh(PG)	Not Available		
188	400kV	Mandola-Maharanibagh	2	D/C (LILO towers are M/C)	29	POWERGRID	POWERGRID	POWERGRID	Twin HTLS			Not Available	
189	400kV	Maharanibagh-Bawana	1	D/C	29	POWERGRID	POWERGRID	DTL	Twin HTLS			Not Available	
190	400kV	Maharanibagh-Bawana	2	D/C	29	POWERGRID	POWERGRID	DTL	Twin HTLS			Not Available	
191	400kV	Meerut-Bagpat	1	D/C	71	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Meerut-Kaithal DC at Baghpat	Polymer Insulator		
192	400kV	Meerut-Bagpat	2	D/C	71	POWERGRID	POWERGRID	POWERGRID	Twin Moose	LILO of Meerut-Kaithal DC at Baghpat	Polymer Insulator		
193	400kV	Meerut-Mandola	1	D/C	60	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
194	400kV	Meerut-Mandola	2	D/C	60	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
195	400kV	Meerut-Muzzafarnagar	1	S/C	37	POWERGRID	POWERGRID	UPPTCL	Twin Moose		Polymer Insulator		
196	400kV	Moga-Fatehabad	1	D/C	179	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator		
197	400kV	Moga-Hissar	1	D/C	209	POWERGRID	POWERGRID	POWERGRID	Twin Moose	Bypassed at Hissar to form Moga-Bhiwani(PG)	Polymer Insulator		

198	400kV	Moga-Hissar	2	D/C	206	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	LILO of Bhiwadi-Moga both ckts at Hisar
199	400kV	Moga-Hissar	3	D/C	206	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
200	400kV	Moga-Jalandhar	1	D/C	85	POWERGRID	POWERGRID	POWERGRID	Twin ACAR		Polymer Insulator	
201	400kV	Moga-Jalandhar	2	D/C	85	POWERGRID	POWERGRID	POWERGRID	Twin ACAR		Polymer Insulator	
202	400kV	Muradnagar-Hapur	1	S/C	28	POWERGRID	UPPTCL	UPPTCL	Twin Moose	Moradabad- Muradnagar LIL/Oed at Hapur LIL/Oed at	Not Available	
203	400kV	Moradabad-Hapur	2	S/C	109	POWERGRID	UPPTCL	UPPTCL	Twin Moose		Not Available	
204	400kV	Nallagarh-Koldam	1	D/C	46	POWERGRID	POWERGRID	NTPC	Quad Moose		Conventional	Koldam to Parbati and section is of
205	400kV	Nallagarh-Patiala	1	D/C	94	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		Polymer Insulator	
206	400kV	Nallagarh-Patiala	2	D/C	94	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		Polymer Insulator	
207	400kV	Nathpa Jhakri-Gumma	1	D/C	55	POWERGRID	SJVNL	HPPTCL	Triple Snowbird	LILO of DC Jhakri- Panchkula line at Gumma	Not Available	
208	400kV	Nathpa Jhakri-Gumma	2	D/C	55	POWERGRID	SJVNL	HPPTCL	Triple Snowbird		Not Available	
209	400kV	Gumma-Panchkula	1	D/C	112	POWERGRID	HPPTCL	POWERGRID	Triple Snowbird		Not Available	
210	400kV	Gumma-Panchkula	2	D/C	112	POWERGRID	HPPTCL	POWERGRID	Triple Snowbird		Not Available	
211	400kV	Nathpa Jhakri-RampurHEP	1	D/C	21	POWERGRID	SJVNL	SJVNL	Triple Snowbird	Nathpa Jhakri- Nallagarh LIL/Oed at Rampur HEP	Conventional	LILO of Jhakri-Nallagarh 1 at Rampur HEP
212	400kV	Nathpa Jhakri-RampurHEP	2	D/C	21	POWERGRID	SJVNL	SJVNL	Triple Snowbird		Conventional	
213	400kV	NeemranaPG-Manesar	1	D/C	67	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
214	400kV	NeemranaPG-Manesar	2	D/C	67	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
215	400kV	NeemranaPG-Babai	1	D/C	85	POWERGRID	POWERGRID	RRVNL	Twin Moose	LILO PORTION IF OF NRSS36(B), LILO of 400kV Neemrana-Sikar 1 at Babai	Not Available	LILO of 400kV Neemrana-Sikar at Babai by NRSSXXXVI (Essel group): Earlier 29% of Neemrana- Sikar PG
216	400kV	NeemranaPG-Sikar	2	D/C	176	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Not Available	
217	400kV	NewWanpoh-Wagoora	1	D/C	57	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
218	400kV	NewWanpoh-Wagoora	2	D/C	57	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
219	400kV	Orai(PG)-Orai	1	D/C	42	POWERGRID	POWERGRID	UPPTCL	Quad Moose		Not Available	
220	400kV	Orai(PG)-Orai	2	D/C	42	POWERGRID	POWERGRID	UPPTCL	Quad Moose		Not Available	
221	400kV	Panchkula -Abdullapur	1	D/C	63	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		Polymer Insulator	LILO of Jhakri- Abdullapur at Panchkula
222	400kV	Panchkula -Abdullapur	2	D/C	63	POWERGRID	POWERGRID	POWERGRID	Triple Snowbird		Polymer Insulator	LILO of Jhakri- Abdullapur at
223	400kV	Patiala-Panchkula	1	D/C	65	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
224	400kV	Patiala-Panchkula	2	D/C	65	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Polymer Insulator	
225	400kV	Patiala-Patran	1	D/C	79	POWERGRID	POWERGRID	PTCL	Triple Snowbird	LILO of 400kV D/C Patiala – Kaithal Line at Patran SS under the ownership of PTCL.	Polymer Insulator	LILO of 400 kV Kaithal-
226	400kV	Patiala-Patran	2	D/C	79	POWERGRID	POWERGRID	PTCL	Triple Snowbird		Polymer Insulator	
227	400kV	Patran-Kaithal	1	D/C	47	POWERGRID	PTCL	POWERGRID	Triple Snowbird		Polymer Insulator	
228	400kV	Patran-Kaithal	2	D/C	47	POWERGRID	PTCL	POWERGRID	Triple Snowbird		Polymer Insulator	
229	400kV	RampurHEP-Nallagarh	1	D/C	128	POWERGRID	SJVNL	POWERGRID	Triple Snowbird	Nathpa Jhakri- Nallagarh LIL/Oed at Rampur HEP	Conventional	LILO of Jhakri-Nallagarh 1 at Rampur HEP
230	400kV	RampurHEP-Nallagarh	2	D/C	128	POWERGRID	SJVNL	POWERGRID	Triple Snowbird		Conventional	
231	400kV	RAPS-C-Chittorgarh	1	D/C	155	POWERGRID	NPCIL	RRVNL	Twin Moose		Partial (38%)	LILO of 400 kV Rapp C- Kankroli at Chhitorgarh
232	400kV	RAPS-C-Kankroli	1	D/C	199	POWERGRID	NPCIL	POWERGRID	Twin Moose		Partial (51%)	

233	400kV	RAPS-C-Kota	1	S/C	51	POWERGRID	NPCIL	POWERGRID	Twin Moose		Partial (55%)	400kV RAPS-Jaipur line whose work was completed till Kota section is connected with 400kV Raps-Kota#2 (for antitheft purpose) and hence 400kV RapsC-Kota #2 is now two twin moose lines connected in parallel paths
234	400kV	RAPS-C-Kota	2	D/C	55	POWERGRID	NPCIL	POWERGRID	Twin Moose	D/C with 400kV Jaipur-RAPP D line	Not Available	
235	400kV	Rasra-Balia	1	S/C	46	POWERGRID	UPPTCL	POWERGRID	Twin Moose	LILO OF 400kV Bata-Mau-II at Rasara. LILO portion is of UP	Not Available	
236	400kV	Rasra-Mau	1	S/C	38	POWERGRID	UPPTCL	UPPTCL	Twin Moose		Not Available	
237	400kV	Rihand-Allahabad	1	D/C	279	POWERGRID	NTPC	POWERGRID	Twin Moose		Conventional	
238	400kV	Rihand-Allahabad	2	D/C	279	POWERGRID	NTPC	POWERGRID	Twin Moose		Conventional	
239	400kV	Roorkee-Kashipur	1	D/C	151	POWERGRID	POWERGRID	PTCUL	Quad Moose		Partial (72%)	
240	400kV	Roorkee-Kashipur	2	D/C	151	POWERGRID	POWERGRID	PTCUL	Quad Moose		Partial (72%)	
241	400kV	Roorkee-Saharanpur	1	D/C	36	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Polymer Insulator	
242	400kV	Roorkee-Dehradun	1	D/C	80	POWERGRID	POWERGRID	POWERGRID	Quad Moose		Partial (50%)	
243	400kV	Sarnath-Varanasi	1	D/C	70	POWERGRID	UPPTCL	POWERGRID	Quad Moose		Partial (52%)	LILO of Sarnath-Allahabad (144 KM) at 765/400kV Varanasi
244	400kV	Sarnath-Varanasi	2	D/C	107	POWERGRID	UPPTCL	POWERGRID	Quad Moose		Partial (52%)	
245	400kV	Shahjahanpur-Bareilly PG	1	D/C	116	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
246	400kV	Shahjahanpur-Bareilly PG	2	D/C	116	POWERGRID	POWERGRID	POWERGRID	Twin Moose		Conventional	
247	400kV	Shahjahanpur-Rosa	1	D/C	8	POWERGRID	POWERGRID	UPPCL	Twin Moose		Not Available	
248	400kV	Shahjahanpur-Rosa	2	D/C	8	POWERGRID	POWERGRID	UPPCL	Twin Moose		Not Available	
249	400kV	Shree Cement-Kota	1	D/C	208	POWERGRID	Sh. Cement	POWERGRID	Twin Moose		Polymer Insulator	
250	400kV	Shree Cement-Merta	2	D/C	103	POWERGRID	Sh. Cement	RRVPLN	Twin Moose		Polymer Insulator	
251	400kV	Sikar-Babai	1	D/C	95	POWERGRID	POWERGRID	RRVPLN	Twin Moose	LILO PORTION IF OF NRSS36(B), LILO of 400kV Neemrana-Sikar 1 at Babai	Not Available	
252	400kV	Sikar-Ratangarh	1	D/C	76	POWERGRID	POWERGRID	RRVPLN	Twin Moose		Conventional	
253	400kV	Sikar-Ratangarh	2	D/C	76	POWERGRID	POWERGRID	RRVPLN	Twin Moose		Conventional	
254	400kV	Singrauli-Allahabad	1	S/C	224	POWERGRID	NTPC	POWERGRID	Twin Moose		Conventional	
255	400kV	Singrauli-Allahabad	2	S/C	202	POWERGRID	NTPC	POWERGRID	Twin Moose		Conventional	
256	400kV	Singrauli-Allahabad	3	S/C	215	POWERGRID	NTPC	POWERGRID	Twin Moose		Not Available	
257	400kV	Singrauli-Anpara	1	S/C	25	POWERGRID	NTPC	UPPTCL	Twin Moose		Partial (91%)	
258	400kV	Singrauli-Fatehpur	1	S/C	331	POWERGRID	NTPC	POWERGRID	Twin Moose		Conventional	LILO of Singrauli-Kanpur at Fatehpur
259	400kV	Singrauli-LucknowUP	1	S/C	409	POWERGRID	NTPC	UPPTCL	Twin Moose		Conventional	
260	400kV	Singrauli-Rihand	1	S/C	42	POWERGRID	NTPC	NTPC	Twin Moose		Conventional	
261	400kV	Singrauli-Rihand	2	S/C	44	POWERGRID	NTPC	NTPC	Twin Moose		Conventional	
262	400kV	Singrauli-Vindhyachal	1	S/C	3	POWERGRID	NTPC	POWERGRID	Twin Moose		Conventional	
263	400kV	Singrauli-Vindhyachal	2	S/C	5	POWERGRID	NTPC	POWERGRID	Twin Moose		Conventional	
264	400kV	Koteswar(PG)-Koteswar(THDC)	1	D/C	3	POWERGRID	POWERGRID	THDC	Twin Moose		Conventional	
265	400kV	Koteswar(PG)-Koteswar(THDC)	2	D/C	3	POWERGRID	POWERGRID	THDC	Twin Moose		Conventional	
266	400kV	Tehri-Koteswar(PG)	3	S/C	14	POWERGRID	THDC	POWERGRID	Quad Moose		Not Available	

267	400kV	Unnao-Jehta	1	D/C	70	POWERGRID	UPPTCL	UPPTCL	Twin Moose	LILO of 400kV Lucknow Unnao DC at Jehta (UP). LILO portion is of UP	Not Available		
268	400kV	Unnao-Jehta	2	D/C	70	POWERGRID	UPPTCL	UPPTCL	Twin Moose	LILO of 400kV Lucknow Unnao DC at Jehta (UP). LILO portion is of UP	Not Available		
269	400kV	Uri-II - Uri-I	1	S/C	10	POWERGRID	NHPC	NHPC	Twin Moose		Conventional	LILO of 400kV Uri-I - Wagoora D/C at Amargarh	
270	400kV	Uri-II - Wagoora	1	S/C	105	POWERGRID	NHPC	POWERGRID	Twin Moose		Conventional		
271	400kV	Jauljivi-Bareilly_2	1	D/C	205	POWERGRID	POWERGRID	POWERGRID	Twin Moose	After LILO of 400kV Dhauliganga - Bareilly(UP) Double circuit line(Initially LILOed at Pithoragarh and charged at 220kV level) at Jauljivi(PG)	Not Available		
272	400kV	Jauljivi-Bareilly_2	2	D/C	205	POWERGRID	POWERGRID	POWERGRID	Twin Moose	After LILO of 400kV Dhauliganga - Bareilly(UP) Double circuit line(Initially LILOed at Pithoragarh and charged at 220kV level) at Jauljivi(PG)	Not Available		
B. POWERLINK Transmission Ltd													
1	400kV	Bareilly PG-Meerut	1	D/C	250	POWERLINK	POWERGRID	POWERGRID	Twin Moose		Conventional	LILO of Bareilly PG-Mandola-1 (241 Km) at	
2	400kV	Bareilly PG-Meerut	2	D/C	250	POWERLINK	POWERGRID	POWERGRID	Twin Moose		Conventional		
3	400kV	Bareilly UP-Bareilly PG	1	D/C	14	POWERLINK	UPPTCL	POWERGRID	Twin Moose		Polymer Insulator		
4	400kV	Bareilly UP-Bareilly PG	2	D/C	14	POWERLINK	UPPTCL	POWERGRID	Twin Moose		Polymer Insulator		
5	400kV	Gorakhpur PG-Lucknow PG	1	D/C	246	POWERLINK	POWERGRID	POWERGRID	Twin Moose		Conventional	*Series compensated line	
6	400kV	Gorakhpur PG-Lucknow PG	2	D/C	246	POWERLINK	POWERGRID	POWERGRID	Twin Moose		Conventional		
7	400kV	Meerut-Mandola	3	D/C	102	POWERLINK	POWERGRID	POWERGRID	Twin Moose		Conventional	LILO of Bareilly PG-	
8	400kV	Meerut-Mandola	4	D/C	102	POWERLINK	POWERGRID	POWERGRID	Twin Moose		Conventional	Mandola-1&2 (241 Km)	
C. PKTSL													
1	400kV	Khatri-Sikar	1	D/C	78	PKTSL	PKTSL	POWERGRID	Twin HTLS		Not Available		
2	400kV	Khatri-Sikar	2	D/C	78	PKTSL	PKTSL	POWERGRID	Twin HTLS		Not Available		
D. Adani Transmission India Ltd.													
1	400kV	Mahindergarh (APL)-Bhiwani PG	1	D/C	50	ATIL	APL	POWERGRID	Twin Moose		Conventional		
2	400kV	Mahindergarh (APL)-Bhiwani PG	2	D/C	50	ATIL	APL	POWERGRID	Twin Moose		Conventional		
3	400kV	Mahindergarh (APL)-Bhiwani PG	3	D/C	56	ATIL	APL	POWERGRID	Twin Moose	Bypassed at 400kV Bhiwani to form 400kV	Not Available		
4	400kV	Mahindergarh (APL)-Bhiwani PG	4	D/C	56	ATIL	APL	POWERGRID	Twin Moose			Not Available	
5	400kV	MahindergarhHVDC-Dhanonda	1	D/C	5	ATIL	APL	HVPNL	Quad Moose	Bypassed at Dhanonda to form	Conventional		
6	400kV	MahindergarhHVDC-Dhanonda	2	D/C	5	ATIL	APL	HVPNL	Quad Moose			Conventional	
E. APCPL (Aravali Power Corporation Pvt Ltd.)													
1	400kV	Jhajjar (IGSTPS)-Mundka	1	D/C	66	APCPL	APCPL	DTL	Twin Moose		Polymer		
2	400kV	Jhajjar (IGSTPS)-Mundka	2	D/C	66	APCPL	APCPL	DTL	Twin Moose		Polymer		
F. PHTL (Powergrid Himachal Transmission Limited)													
1	400kV	Abdullapur-Kala Amb	1	D/C	39	PHTL	POWERGRID	PKATL	Quad Moose		Conventional		
2	400kV	Abdullapur-Kala Amb	2	D/C	39	PHTL	POWERGRID	PKATL	Quad Moose		Conventional		
3	400kV	Kala Amb- Wangtoo (HP)	1	D/C	174	PHTL	PKATL	HPPTCL	Quad Moose	Karcham-Kala Amb LILOed at Wangtoo (HP)	Not Available		
4	400kV	Karcham Wangtoo - Wangtoo (HP)	1	D/C	1	PHTL	JSW	HPPTCL	Quad Moose			Not Available	
5	400kV	Karcham Wangtoo - Wangtoo (HP)	2	D/C	1	PHTL	JSW	HPPTCL	Quad Moose			Not Available	
6	400kV	Baspa-Karcham Wangtoo	1	D/C	22	PHTL	JPVL	JSW	Triple snowbird		Conventional		
7	400kV	Baspa-Karcham Wangtoo	2	D/C	22	PHTL	JPVL	JSW	Triple snowbird		Conventional		
8	400kV	Karcham Wangtoo-NJPC	1	D/C	34	PHTL	JSW	SJVN	Triple snowbird		Conventional		

9	400kV	Karcham Wangtoo-NJPC	2	D/C	34	PHTL	JSW	SJVNL	Triple snowbird		Conventional
10	400kV	Sorang-Wangtoo	1	D/C	21	PHTL	SORANG	HPPTCL	Quad Moose		Not Available
11	400kV	Sorang-Kala Amb	1	D/C	160	PHTL	SORANG	PKATL	Quad Moose		Not Available
G. PKTCL (Parbati-Koldam Transmission)											
1	400kV	Koldam-Ludhiana	1	D/C	151	PKTCL	NTPC	POWERGRID	Triple Snowbird		27% Polymer & 73% porcelain
2	400kV	Koldam-Ludhiana	2	D/C	151	PKTCL	NTPC	POWERGRID	Triple Snowbird		27% Polymer & 73% porcelain
3	400kV	Koldam-Banala	1	D/C	67	PKTCL	NTPC	POWERGRID	Quad Moose		100% porcelain
4	400kV	Nallagarh-Banala	1	D/C	62	PKTCL	POWERGRID	POWERGRID	Quad Moose		100% porcelain Powergrid owned 46.38km
5	400kV	Parbati-III- Parbati Pooling (Banala)	1	S/C	13	PKTCL	NHPC	POWERGRID	Quad Moose		100% porcelain Some portion is of Powergrid
6	400kV	Parbati-III- Parbati Pooling (Banala)	1	S/C	4	PKTCL	NHPC	POWERGRID	Quad Moose		100% porcelain LILO of 400KV Parbati II- Parbati III at Sainj
7	400kV	Parbati II- Sainj	1	S/C	1	PKTCL	NHPC	HPPCL	Quad Moose		100% porcelain
8	400kV	Parbati III- Sainj	1	S/C	9	PKTCL	NHPC	HPPCL	Quad Moose		100% porcelain
H. INDIGRID:NRSS-29 Transmission Company Limited											
1	400kV	Jalandhar-Samba	1	D/C	135	NRSS-29	POWERGRID	POWERGRID	Twin Moose		Polymer
2	400kV	Jalandhar-Samba	2	D/C	135	NRSS-29	POWERGRID	POWERGRID	Twin Moose		Polymer
3	400kV	Amargarh-Samba	1	D/C	286	NRSS-29	NRSS-29	POWERGRID	Twin Moose		Polymer
4	400kV	Amargarh-Samba	2	D/C	286	NRSS-29	NRSS-29	POWERGRID	Twin Moose		Polymer
5	400kV	Uri-I - Amargarh	1	D/C	62	NRSS-29	NHPC	NRSS-29	Twin Moose	LILO of 400kV D/C Uri-I - Wagoora Line at Amargarh SS under the ownership of NRSS-XXIX	Polymer
6	400kV	Uri-I - Amargarh	2	D/C	62	NRSS-29	NHPC	NRSS-29	Twin Moose		Polymer
7	400kV	Amargarh - Wagoora	1	D/C	36	NRSS-29	NRSS-29	POWERGRID	Twin Moose		Polymer
8	400kV	Amargarh - Wagoora	2	D/C	36	NRSS-29	NRSS-29	POWERGRID	Twin Moose		Polymer
I. Powergrid Unchahar Transmission Ltd.											
1	400kV	Fatehpur-Unchahar	1	D/C	54	PUTL	POWERGRID	NBPPL	Twin Moose		Not Available
2	400kV	Fatehpur-Unchahar	2	D/C	54	PUTL	POWERGRID	NBPPL	Twin Moose		Not Available
J. NRSSXXXI(B) (Sekura Energy)											
1	400kV	Amritsar-Malerkotla	1	D/C	149	NRSSXXXI(B)	POWERGRID	POWERGRID	Twin Moose		Polymer
2	400kV	Amritsar-Malerkotla	2	D/C	149	NRSSXXXI(B)	POWERGRID	POWERGRID	Twin Moose		Polymer
3	400kV	Kurukshetra-Malerkotla	1	D/C	139	NRSSXXXI(B)	POWERGRID	POWERGRID	Twin Moose		Polymer
4	400kV	Kurukshetra-Malerkotla	2	D/C	139	NRSSXXXI(B)	POWERGRID	POWERGRID	Twin Moose		Polymer
K. Gurgaon Palwal Transmission Ltd.											
1	400kV	Dhanoda-Neemrana	1	D/C	47	GPTL	HVPNL	POWERGRID	Twin HTLS	Bypassed at Dhanonda to form	Polymer
2	400kV	Dhanoda-Neemrana	2	D/C	47	GPTL	HVPNL	POWERGRID	Twin HTLS		Polymer
3	400kV	Prithala-Kadarpur	1	D/C	29	GPTL	GPTL	GPTL	Twin HTLS		Polymer
4	400kV	Prithala-Kadarpur	2	D/C	29	GPTL	GPTL	GPTL	Twin HTLS		Polymer
5	400kV	Prithala(GPTL)-Aligarh(PG)	1	D/C	49	GPTL	GPTL	POWERGRID	Twin HTLS		Polymer
6	400kV	Prithala(GPTL)-Aligarh(PG)	2	D/C	49	GPTL	GPTL	POWERGRID	Twin HTLS		Polymer
7	400kV	Kadarpur-Sohna Road	1	D/C	10	GPTL	GPTL	GPTL	Twin HTLS		Polymer
8	400kV	Kadarpur-Sohna Road	2	D/C	10	GPTL	GPTL	GPTL	Twin HTLS		Polymer
L. FBTL											
1	400kV	AREPRL-Fatehgarh Pooling	1	D/C	1	FBTL	FBTL	FBTL	Quad moose		Not Available
2	400kV	AREPRL-Fatehgarh Pooling	2	D/C	1	FBTL	FBTL	FBTL	Quad moose		Not Available
3	400kV	Fatehgarh II-Fatehgarh Pooling	1	D/C	45	FBTL	POWERGRID	FBTL	Hexa Zebra+ Twin HTLS	LILO of 400kV Fatehgarh I-Bhadla-1 at Fatehgarh II. LILO Portion is of Powergrid	Not Available
4	400kV	Fatehgarh II-Fatehgarh Pooling	2	D/C	45	FBTL	POWERGRID	FBTL	Hexa Zebra+ Twin HTLS		Not Available
M. PBTSL											
1	400kV	Bikaner_2 (PBTSL)-Khetri (PKTSL)	1	D/C (some towers M/C)	275	PBTSL	PBTSL	PKTSL	Twin HTLS		Not Available

2	400kV	Bikaner_2 (PBTSL)-Khetri (PKTSL)	2	D/C (some towers M/C)	275	PBTSL	PBTSL	PKTSL	Twin HTLS	Not Available
3	400kV	Bikaner_2 (PBTSL)-Khetri (PKTSL)	3	D/C (some towers M/C)	275	PBTSL	PBTSL	PKTSL	Twin HTLS	Not Available
4	400kV	Bikaner_2 (PBTSL)-Khetri (PKTSL)	4	D/C (some towers M/C)	275	PBTSL	PBTSL	PKTSL	Twin HTLS	Not Available
5	400kV	Khetri (PKTSL)-Bhiwadi(PG)	1	D/C	126	PBTSL	PKTSL	POWERGRID	Twin HTLS	Not Available
6	400kV	Khetri (PKTSL)-Bhiwadi(PG)	2	D/C	126	PBTSL	PKTSL	POWERGRID	Twin HTLS	Not Available
N. PRTL										
1	400kV	Jaisalmer(RS)-Fatehgarh_III(PG)	1	D/C	50	PRTL	RAJASTHAN	PRTL	Twin HTLS	Not Available
2	400kV	Jaisalmer(RS)-Fatehgarh_III(PG)	2	D/C	50	PRTL	RAJASTHAN	PRTL	Twin HTLS	Not Available
3	400kV	Fatehgarh_III(PG)- Fatehgarh_II(PG)	1	D/C	44	PRTL	PRTL	POWERGRID	Twin HTLS	Not Available
4	400kV	Fatehgarh_III(PG)- Fatehgarh_II(PG)	2	D/C	44	PRTL	PRTL	POWERGRID	Twin HTLS	Not Available
O. NRSS-36										
1	400kV	Babai(RS)-Bhiwani(PG)	1	D/C	111	NRSS-36	NRSS-36	POWERGRID	Twin Moose	Not Available
2	400kV	Babai(RS)-Bhiwani(PG)	2	D/C	111	NRSS-36	NRSS-36	POWERGRID	Twin Moose	Not Available
RE Connected at ISTS Dedicated Lines										
A. RENEW										
1	400kV	Bikaner(PG) - Bikaner (Renew)	1	S/C	5	RENEW	POWERGRID	RENEW	Twin Moose	Not Available
B. Avaada										
1	400kV	Bikaner(PG)-Avaada	1	S/C	14	AEPL	POWERGRID	AEPL	Twin Moose	Not Available
C. ARPOPL										
1	400kV	Bikaner(PG)-Ayana	1	S/C	12	ARPOPL	PGCIL	Ayana	ACSR Twin Moose+AL 59	Not Available
D. Azure										
1	400kV	Bikaner(PG)-Azure 43 PSS	1	S/C	9	Azure	POWERGRID	Azure 43 PSS	Twin Moose	Not Available
2	400kV	Azure43(RSS)-Azure 43 PSS	1	S/C	3	Azure	Azure 43 PSS	Azure 43 RSS	Twin Moose	Not Available
E. RSRPL										
1	400kV	Bikaner(RENEW) - Renew Surya Ravi	1	S/C	13	RSRPL	RENEW	RSRPL	Twin Moose	Not Available
F. NTPC										
1	400kV	Bhadla II - Kolayat	1	D/C	29	NTPC	POWERGRID	NTPC	Quad Moose	Not Available
2	400kV	Kolayat - Kolayat_2	1	D/C	2	NTPC	NTPC	NTPC	Quad Moose	Not Available
STATE LINES										
A. DTL										
1	400kV	Bamnauli-Tughlakabad	1	M/C	68	DTL	DTL	POWERGRID	Tower is quad circuit tower	Polymer Insulator
2	400kV	Bamnauli-Tughlakabad	2	M/C	68	DTL	DTL	POWERGRID	Tower is quad circuit tower	Polymer Insulator
3	400kV	Bamnoli-Jhatikara	1	D/C	12	DTL	DTL	POWERGRID	Quad bersimis	Polymer Insulator
4	400kV	Bamnoli-Jhatikara	2	D/C	12	DTL	DTL	POWERGRID	Quad bersimis	Polymer Insulator
5	400kV	Bawana-Mundka	1	D/C	18	DTL	DTL	DTL	Quad bersimis	Polymer Insulator
6	400kV	Bawana-Mundka	2	D/C	18	DTL	DTL	DTL	Quad bersimis	Polymer Insulator
7	400kV	Jhatikara-Mundka	1	D/C	17	DTL	POWERGRID	DTL	Quad bersimis	Polymer Insulator
8	400kV	Jhatikara-Mundka	2	D/C	17	DTL	POWERGRID	DTL	Quad bersimis	Polymer Insulator
B. HVPNL										
1	400kV	CLP Jhajjar -Dhanonda	1	D/C	20	HVPNL	CLP Jhajjar	HVPNL	Twin Moose	Conventional
2	400kV	CLP Jhajjar -Dhanonda	2	D/C	20	HVPNL	CLP Jhajjar	HVPNL	Twin Moose	Conventional
3	400kV	CLP Jhajjar- Kabulpur	1	D/C	35	JKTPL	CLP Jhajjar	HVPNL	Quad Moose	Already had Anti fog
4	400kV	CLP Jhajjar- Kabulpur	2	D/C	35	JKTPL	CLP Jhajjar	HVPNL	Quad Moose	Polymer Insulator
5	400kV	Deepalpur-Kabulpur	1	D/C	67	JKTPL	KT Jhajjar	HVPNL	Quad Moose	Installed on every towers
6	400kV	Deepalpur-Kabulpur	2	D/C	67	JKTPL	KT Jhajjar	HVPNL	Quad Moose	

7	400kV	Dhanoda-Daultabad	1	D/C	73	HVNL	HVNL	HVNL	Quad Moose			
8	400kV	Dhanoda-Daultabad	2	D/C	73	HVNL	HVNL	HVNL	Quad Moose		Already had Polymer Insulator	
9	400kV	Gurgaon-Daultabad	1	D/C	21	HVNL	POWERGRID	HVNL	Quad Moose			Six towers multi-circuit with Bamnauli-
10	400kV	Gurgaon-Daultabad	2	D/C	21	HVNL	POWERGRID	HVNL	Quad Moose			Partial (84%),
11	400kV	Jhajjar-Daulatabad	1	D/C	64	HVNL	APCPL	HVNL	Twin Moose		Polymer Insulator	Remaining pending
12	400kV	Jhajjar-Daulatabad	2	D/C	64	HVNL	APCPL	HVNL	Twin Moose		Polymer Insulator	
13	400kV	Khedar-Fatehabad	1	D/C	40	HVNL	HPGCL	POWERGRID	Twin Moose		Conventional	Presently there is no planning of replacement of Convection disc Insulator with Polymer Insulators
14	400kV	Jind-Kirori	1	D/C	51	HVNL	POWERGRID	HVNL	Twin Moose		Polymer Insulator	
15	400kV	Jind-Kirori	2	D/C	51	HVNL	POWERGRID	HVNL	Twin Moose		Polymer Insulator	
16	400kV	Khedar-Kirori	1	D/C	6.2	HVNL	HPGCL	HVNL	Twin Moose		Conventional	Presently there is no planning of replacement
17	400kV	Khedar-Kirori	2	D/C	6	HVNL	HPGCL	HVNL	Twin Moose		Conventional	Existing disc insulator are of Porcelain
18	400kV	Khedar-Nuhiawali	1	D/C	114	HVNL	HPGCL	HVNL	Twin Moose		Conventional	
19	400kV	Nuhiawali-Fatehabad	1	D/C	78	HVNL	HVNL	POWERGRID	Twin Moose		Conventional	
C. PDD (Jammu & Kashmir)												
1	400kV	Baglihar(stage 1)-Kishenpur	1	D/C	68	JK PDD	JKSPDCL	POWERGRID	Twin Moose		Conventional	
2	400kV	Baglihar(stage 1)-Kishenpur	2	D/C	68	JK PDD	JKSPDCL	POWERGRID	Twin Moose		Not Available	
D. PSTCL												
1	400kV	Behman Jassa- HMEL	1	D/C	17	PSTCL	PSTCL	PSTCL	Twin Moose		Not Available	
2	400kV	Behman Jassa- HMEL	2	D/C	17	PSTCL	PSTCL	PSTCL	Twin Moose		Not Available	
3	400kV	Behman Jassa- Moga	1	S/C	113	PSTCL	PSTCL	PSTCL	Twin Moose	After LILO of 400 KV TSPL to 400 KV Moga at 400 KV Behman Jassa Singh	Not Available	
4	400kV	Makhu-Amritsar	1	D/C	64	PSTCL	PSTCL	PSTCL	Twin Moose		Partial (10%)	
5	400kV	Makhu-Amritsar	2	D/C	64	PSTCL	PSTCL	PSTCL	Twin Moose		Partial (10%)	
6	400kV	Muktsar-Makhu	1	D/C	96	PSTCL	PSTCL	PSTCL	Twin Moose		Conventional	
7	400kV	Muktsar-Makhu	2	D/C	96	PSTCL	PSTCL	PSTCL	Twin Moose		Conventional	
8	400kV	Nakodar-Makhu	1	D/C	52	PSTCL	PSTCL	PSTCL	Twin Moose		Conventional	
9	400kV	Nakodar-Makhu	2	D/C	52	PSTCL	PSTCL	PSTCL	Twin Moose		Conventional	
10	400kV	Nakodar-Moga	1	S/C	78	PSTCL	PSPCL	POWERGRID	Twin Moose		Not Available	LILO of 400KV Talwandi sabo-Nakodar at Moga
11	400kV	Rajpura-Dhuri	1	D/C	86	PSTCL	PSTCL	PSTCL	Twin Moose		Conventional	Lilo of Rajpura th-Dhuri
12	400kV	Rajpura TPS- Rajpura	1	D/C	9	PSTCL	PSPCL	PSTCL	Twin Moose		Conventional	1 at 400KV Rajpura
13	400kV	Rajpura-Dhuri	2	D/C	86	PSTCL	PSTCL	PSTCL	Twin Moose		Conventional	Lilo of Rajpura th-Dhuri
14	400kV	Rajpura TPS- Rajpura	2	D/C	9	PSTCL	PSPCL	PSTCL	Twin Moose		Not Available	2 at 400KV Rajpura
15	400kV	Rajpura TPS-Nakodar	1	D/C	139	PSTCL	PSPCL	PSTCL	Twin Moose		Conventional	
16	400kV	Rajpura TPS-Nakodar	2	D/C	139	PSTCL	PSPCL	PSTCL	Twin Moose		Conventional	
17	400kV	Talwandi Saboo- Dhuri	1	D/C	175	PSTCL	PSPCL	PSTCL	Twin Moose		Partial (22%)	
18	400kV	Talwandi Saboo- Dhuri	2	D/C	175	PSTCL	PSPCL	PSTCL	Twin Moose		Partial (22%)	
19	400kV	Talwandi Saboo- Behman Jassa	1	D/C	20	PSTCL	PSPCL	PSTCL	Twin Moose	After LILO of 400 KV TSPL to 400 KV Moga at 400 KV Behman Jassa Singh	Not Available	
20	400kV	Talwandi Saboo- Nakodar	1	D/C	180	PSTCL	PSPCL	PSTCL	Twin Moose		Conventional	
21	400kV	Talwandi Saboo- Muktsar	1	D/C	100	PSTCL	PSPCL	PSTCL	Twin Moose		Conventional	
22	400kV	Talwandi Saboo- Muktsar	2	D/C	100	PSTCL	PSPCL	PSTCL	Twin Moose		Conventional	
E. PTCUL												
1	400kV	Alaknanda(GVK)-Srinagar(PTCUL)	1	D/C	14	PTCUL	GVKPIL	PTCUL	Twin Moose		Conventional	
2	400kV	Alaknanda(GVK)-Srinagar(PTCUL)	2	D/C	14	PTCUL	GVKPIL	PTCUL	Twin Moose		Conventional	
3	400kV	Muradabad-Kashipur	1	S/C	108	PTCUL	UPPTCL	PTCUL	Twin Moose		Conventional	
4	400kV	Rishikesh-Nehtaur	1	D/C	124	PTCUL	PTCUL	UPPTCL	Twin Moose		Not Available	LILO of 400KV

5	400kV	Nehtaur-Kashipur	2	D/C	80	PTCUL	UPPTCL	PTCUL	Twin Moose		Not Available	Rishikesh-Kashipur	
6	400kV	Roorkee-Rishikesh	1	S/C	50	PTCUL	POWERGRID	PTCUL	Twin Moose	LILO portion is of POWERGRID	Not Available		
7	400kV	Roorkee-Muzaffarnagar	1	S/C	71	PTCUL	POWERGRID	UPPTCL	Twin Moose		Not Available		
F. RRVPNL													
1	400kV	Ajmer-Bhilwara	1	D/C	160	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
2	400kV	Ajmer-Bhilwara	2	D/C	160	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
3	400kV	Akal-Barmer	1	S/C	124	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Conventional		
4	400kV	Akal-Jodhpur	1	S/C	225	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Conventional		
5	400kV	Akal-Ramgarh	1	D/C	99	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
6	400kV	Akal-Ramgarh	2	D/C	99	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
7	400kV	Anta-Chhabra	1	S/C	90	RRVPNL	RRVPNL	RVUNL	Quad Moose	Bypassed at Anta to form Chhabra-Kota(PG)	Not Available		
8	400kV	Anta-Chhabra SC	1	D/C	89	RRVPNL	RRVPNL	RVUNL	Quad Moose		Not Available		
9	400kV	Anta-Chhabra SC	2	D/C	89	RRVPNL	RRVPNL	RVUNL	Quad Moose		Not Available		
10	400kV	Anta-Kalisindh	1	D/C	80	RRVPNL	RRVPNL	RVUNL	Quad Moose		Not Available		
11	400kV	Anta-Kalisindh	2	D/C	80	RRVPNL	RRVPNL	RVUNL	Quad Moose		Not Available		
12	400kV	Anta-Kawai	1	D/C	50	RRVPNL	RRVPNL	Kawai(Adani)	Quad Moose		Not Available		
13	400kV	Anta-Kawai	2	D/C	50	RRVPNL	RRVPNL	Kawai(Adani)	Quad Moose		Not Available		
14	400kV	Anta-Kota (PG)	1	S/C	91	RRVPNL	RRVPNL	POWERGRID	Twin Moose	Bypassed at Anta to form Chhabra-Kota(PG)	Not Available		
15	400kV	Barmer-Bhinmal	1	D/C	144	RRVPNL	RRVPNL	POWERGRID	Twin Moose		Not Available		
16	400kV	Barmer-Bhinmal	2	D/C	144	RRVPNL	RRVPNL	POWERGRID	Twin Moose		Not Available		
17	400kV	Barmer-Jaisalmer-II (Bhaesada)	1	D/C	117	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
18	400kV	Barmer-Jaisalmer-II (Bhaesada)	2	D/C	117	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
19	400kV	Barmer-Rajwest	1	D/C	15	RRVPNL	RRVPNL	RAJWEST	Twin Moose		Conventional		
20	400kV	Bhadla-Jodhpur	1	D/C	106	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
21	400kV	Bhilwara-Chhabra	1	S/C	303	RRVPNL	RRVPNL	RVUNL	Twin Moose		Conventional		
22	400kV	Bhilwara-Chittorgarh(RRVPNL)	1	D/C	49	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
23	400kV	Bhilwara-Chittorgarh(RRVPNL)	2	D/C	49	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
24	400kV	Bikaner-Bhadla	1	D/C	189	RRVPNL	RRVPNL	RRVPNL	Quad Moose		Not Available		
25	400kV	Bikaner-Bhadla	2	D/C	189	RRVPNL	RRVPNL	RRVPNL	Quad Moose		Not Available		
26	400kV	Bikaner-Merta	1	S/C	172	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
27	400kV	Bikaner-Sikar(PG)	1	D/C	171	RRVPNL	RRVPNL	POWERGRID	Twin Moose		Not Available		
28	400kV	Bikaner-Sikar(PG)	2	D/C	171	RRVPNL	RRVPNL	POWERGRID	Twin Moose		Not Available		
29	400kV	Chhabra - Kawai SCTPS	1	S/C	45	RRVPNL	RVUNL	APRL	Twin Moose		Conventional		
30	400kV	Chhabra-Chhabra SC	1	D/C	2	RRVPNL	RRVPNL	RVUNL	Quad Moose		Not Available		
31	400kV	Chhabra-Chhabra SC	2	D/C	2	RRVPNL	RRVPNL	RVUNL	Quad Moose		Not Available		
32	400kV	Heerapura-Hindaun	1	S/C	192	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Conventional		
33	400kV	Hindaun-Chhabra	1	S/C	305	RRVPNL	RRVPNL	RVUNL	Twin Moose		Conventional		
34	400kV	Kakani (Jodhpur New)-Jodhpur	2	S/C	102	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
35	400kV	Kankani (Jodhpur New)-Akal	1	D/C	223	RRVPNL	RRVPNL	RRVPNL	Quad Moose		Not Available		
36	400kV	Kankani(Jodhpur New)-Jaisalmer-II(Bhainsra)	1	D/C	177	RRVPNL	RRVPNL	RRVPNL	Quad Moose	LILO of 400kV Kankani(Jodhpur New)-Akal ckt-2	Not Available		
37	400kV	Jaisalmer-II(Bhainsra)-Akal	1	D/C	61	RRVPNL	RRVPNL	RRVPNL	Quad Moose		Not Available		
38	400kV	Kankani (Jodhpur New)-Jodhpur	1	S/C	67	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available		
39	400kV	Kankani (Jodhpur New)-Merta	1	S/C	140	RRVPNL	RRVPNL	RRVPNL	Twin Moose	LILO of 400kV Jodhpur-Merta-1 at Kakani	Not Available		
40	400kV	Merta-Bhadla	1	D/C	175	RRVPNL	RRVPNL	RRVPNL	Twin Moose	LILO of 400kV Jodhpur-Merta-2 at Bhadla	Not Available		
41	400kV	Merta-Heerapura	1	S/C	175	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Conventional		
42	400kV	Merta-Ratangarh	1	S/C	173	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Conventional		

43	400kV	Phagi-Ajmer(RRVPNL)	1	D/C	109	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available	
44	400kV	Phagi-Ajmer(RRVPNL)	2	D/C	109	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available	
45	400kV	Phagi-Heerapura	1	D/C	52	RRVPNL	RRVPNL	RRVPNL	Quad Moose		Not Available	
46	400kV	Phagi-Heerapura	2	D/C	52	RRVPNL	RRVPNL	RRVPNL	Quad Moose		Not Available	
47	400kV	Rajwest - Kankani (Jodhpur New)	1	S/C	209	RRVPNL	RRVPNL	RRVPNL	Twin Moose	LILO of 400kV Jodhpur-Rajwest-I at Kakani	Not Available	
48	400kV	Rajwest-Jodhpur	1	D/C	209	RRVPNL	RWPL	RRVPNL	Twin Moose		Conventional	
49	400kV	Ramgarh-Bhadla	1	D/C	160	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available	
50	400kV	Ramgarh-Bhadla	2	D/C	160	RRVPNL	RRVPNL	RRVPNL	Twin Moose		Not Available	
51	400kV	Suratgarh-Bikaner	1	S/C	146	RRVPNL	RVUNL	RRVPNL	Twin Moose		Conventional	
52	400kV	Suratgarh-Ratangarh	1	S/C	144	RRVPNL	RVUNL	RRVPNL	Twin Moose		Conventional	
53	400kV	Suratgarh-Ratangarh	2	S/C	144	RRVPNL	RVUNL	RRVPNL	Twin Moose		Conventional	
54	400kV	Suratgarh-Suratgarh SC	1	S/C	2	RRVPNL	RVUNL	RVUNL	Quad Moose		Not Available	
55	400kV	Suratgarh SC-Bikaner	1	D/C	140	RRVPNL	RVUNL	RRVPNL	Twin Moose		Not Available	
56	400kV	Suratgarh SC-Bikaner	2	D/C	140	RRVPNL	RVUNL	RRVPNL	Twin Moose		Not Available	
G. UPPTCL												
1	400kV	Agra (Fatehabad)-Agra South	1	D/C	70	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
2	400kV	Agra (UP)-Agra (Fatehabad)	1	S/C	104	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	LILO of 400 kv Agra(UP)- Muradnagar(N) at Fatehabad(UP)
3	400kV	Agra UP-Unnao	1	S/C	279	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (25%)	
4	400kV	Agra(Fatehabad)-Mathura	1	S/C	142	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
5	400kV	Agra(Fatehabad)-Mathura	2	D/C	151	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	LILO of 400 kv Fatehabad(UP)- Muradnagar at Mathura
6	400kV	Alakhnanda-Vishnuprayag	1	D/C	109	UPPTCL	GVKPIL	JPVL	Twin Moose		Not Available	
7	400kV	Aligarh-Mainpuri	1	D/C	93	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
8	400kV	Aligarh-Mainpuri	2	D/C	93	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
9	400kV	Aligarh-Muradnagar	1	S/C	177	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	*Series Compensated line (40%). It would be shifted
10	400kV	Aligarh-Sikandrabad	1	D/C	95	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
11	400kV	Aligarh-Harduaganj	1	S/C	40	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
12	400kV	AnparaB-AnparaC	1	D/C	0.05	UPPTCL	UPRVUNL	LANCO	Quad Moose		Conventional	
13	400kV	AnparaB-AnparaC	2	D/C	0.05	UPPTCL	UPRVUNL	LANCO	Quad Moose		Conventional	
14	400kV	AnparaB-AnparaD	1	D/C	5	UPPTCL	UPRVUNL	UPPTCL	Twin Moose		Not Available	
15	400kV	AnparaB-AnparaD	2	D/C	5	UPPTCL	UPRVUNL	UPPTCL	Twin Moose		Not Available	
16	400kV	AnparaB-Mau	1	S/C	262	UPPTCL	UPRVUNL	UPPTCL	Twin Moose		Partial (13%)	
17	400kV	AnparaB-Obra B	1	S/C	40	UPPTCL	UPRVUNL	UPPTCL	Twin Moose		Partial	
18	400kV	AnparaB-Sarnath	1	D/C	158	UPPTCL	UPRVUNL	UPPTCL	Twin Moose		Partial	
19	400kV	AnparaB-Sarnath	2	D/C	158	UPPTCL	UPRVUNL	UPPTCL	Twin Moose		Conventional	
20	400kV	Ataur-Hapur	1	D/C	52	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
21	400kV	Ataur-Hapur	2	D/C	52	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
22	400kV	Ataur-Indrapuram	1	D/C	15	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
23	400kV	Ataur(UP)-Noida Sec 123(UP)	1	D/C	19	UPPTCL	UPPTCL	UPPTCL	Quad Moose (LILO portion Twin HTLS)	LILO of 400 KVATAUR- INDIRAPURAM CKT-II	Not Available	
24	400kV	Indrapuram(UP)-Noida Sec 123(UP)	1	D/C	17	UPPTCL	UPPTCL	UPPTCL	Quad Moose (LILO portion Twin HTLS)	at 400 KV NOIDA SECTOR 123	Not Available	
25	400kV	Azamgarh-Mau	1	S/C	48	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (79%)	
26	400kV	Azamgarh-Tanda	1	D/C	153	UPPTCL	UPPTCL	NTPC	Twin Moose		Not Available	
27	400kV	Badaun-Sambhal	1	D/C	77	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
28	400kV	Badaun-Sambhal	2	D/C	77	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
29	400kV	Banda-Orai	1	D/C	108	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	

30	400kV	Banda-Orai	2	D/C	108	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
31	400kV	Banda-Rewa road	1	D/C	177	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
32	400kV	Banda-Rewa road	2	D/C	177	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
33	400kV	Bara-Meja	1	D/C	32	UPPTCL	UPPTCL	MUNPL	Quad Moose		LILO of 400kV Bara-Rewa road D/C at Meja	
34	400kV	Bara-Meja	2	D/C	32	UPPTCL	UPPTCL	MUNPL	Quad Moose			
35	400kV	Bareilly UP-Unnao	1	D/C	271	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (15%)	*Series Compensated line (45%)
36	400kV	Bareilly UP-Unnao	2	D/C	271	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (15%)	*Series Compensated line (45%)
37	400kV	Gorakhpur UP-Azamgarh	1	S/C	90	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (76%)	
38	400kV	Gr. Noida(765)-Sector 148	1	D/C	47	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
39	400kV	Gr. Noida(765)-Sector 148	2	D/C	47	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
40	400kV	Gr. Noida-Gr. Noida (765)	1	D/C	45	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
41	400kV	Gr. Noida-Gr. Noida (765)	2	D/C	45	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
42	400kV	Gr.Noida-Sikandrabad	1	D/C	17	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
43	400kV	Gr.Noida-Sikandrabad	2	D/C	17	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
44	400kV	Hapur-Dasna	1	D/C	14	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
45	400kV	Hapur-Dasna	2	D/C	14	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
46	400kV	Hapur-Moradabad	1	S/C	109	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
47	400kV	Hapur-Muradnagar	1	S/C	28	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
48	400kV	Harudaganj-Sikandarabad	1	S/C	115	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
49	400kV	Mainpuri(UP)-Mainpuri(PG)	1	D/C	25	UPPTCL	UPPTCL	POWERGRID	Twin Moose		Not Available	LILO of 400kV Orai-Mainpuri(PG) at Mainpuri(UP)
50	400kV	Mainpuri(UP)-Mainpuri(PG)	2	D/C	26	UPPTCL	UPPTCL	POWERGRID	Twin Moose		Not Available	
51	400kV	Meja-Musauli	1	D/C	65	UPPTCL	MUNPL	UPPTCL	Quad Moose		Not Available	
52	400kV	Meja-Rewa road	1	D/C	45	UPPTCL	MUNPL	UPPTCL	Quad Moose		Not Available	
53	400kV	Muradnagar New- Mathura	1	D/C	246	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	LILO of 400 kV Fatehabad(UP)-Muradnagar at Mathura
54	400kV	Muradnagar-Ataur	2	D/C	18	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
55	400kV	Musauli-Rewa road	1	D/C	34	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
56	400kV	Muzaffarnagar-Alakhnanda	1	D/C	189	UPPTCL	UPPTCL	GVKPIL	Twin Moose		Not Available	
57	400kV	Muzaffarnagar-Ataur	1	D/C	121	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
58	400kV	Muzaffarnagar-Vishnuprayag	1	D/C	280	UPPTCL	UPPTCL	JPVL	Twin Moose		Conventional	
59	400kV	Noida Sec 148 - Noida Sec 123	1	D/C	20	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
60	400kV	Noida Sec 148 - Noida Sec 123	2	D/C	20	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
61	400kV	Noida Sec 148-Noida Sec 123	1	D/C	20	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
62	400kV	Noida Sec 148-Noida Sec 123	2	D/C	20	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
63	400kV	Obra-Rewa road	1	S/C	179	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
64	400kV	Obra-Sultanpur	1	S/C	230	UPPTCL	UPRVUNL	UPPTCL	Twin Moose		Conventional	
65	400kV	Obra B - Obra C	1	S/C	1	UPPTCL	UPRVUNL	UPRVUNL	Twin Moose		Not Available	
66	400kV	Orai-Mainpuri(UP)	1	D/C	176	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
67	400kV	Orai-Mainpuri(UP)	2	D/C	176	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
68	400kV	Orai-Paricha	1	D/C	111	UPPTCL	UPPTCL	UPRVUNL	Twin Moose		Not Available	
69	400kV	Orai-Paricha	2	D/C	111	UPPTCL	UPPTCL	UPRVUNL	Twin Moose		Not Available	

70	400kV	Panki-Aligarh	1	S/C	285	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (24%)	
71	400kV	Rewa road -Panki	1	S/C	210	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	LILO of Bara-Panki at 400kV Rewa Road
72	400kV	Rosa-Badaun	1	D/C	85	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
73	400kV	Rosa-Badaun	2	D/C	85	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
74	400kV	Sarnath-Azamgarh	1	S/C	97	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
75	400kV	Lucknow_1(PG)-Mohanlalganj (PGYTL)	1	S/C	58	UPPTCL	POWERGRID	UPPTCL	Twin Moose	LILO of 400kV LUCKNOW(PG)-	Conventional	
76	400kV	Sultanpur(UP)-Mohanlalganj (PGYTL)	1	S/C	133	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Conventional	
77	400kV	Sultanpur-Tanda	1	D/C	103	UPPTCL	UPPTCL	NTPC	Twin Moose		Not Available	
78	400kV	Tanda-Basti	1	D/C	44	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
79	400kV	Tanda-Basti	2	D/C	44	UPPTCL	UPPTCL	UPPTCL	Quad Moose		Not Available	
80	400kV	Mohanlalganj (PGYTL)-Unnao(UP)	1	S/C	104	UPPTCL	UPPTCL	UPPTCL	Twin Moose	LILO of 400 KV SAROJANI	Partial (13%)	Status after LILO?
81	400kV	Lucknow(UP)-Mohanlalganj (PGYTL)	1	S/C	89	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (13%)	
82	400kV	Unnao-Panki	1	S/C	49	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Partial (41%)	
83	400kV	Varanasi-Jaunpur	1	D/C	73	UPPTCL	POWERGRID	UPPTCL	Twin Moose		Not Available	
84	400kV	Varanasi-Jaunpur	2	D/C	73	UPPTCL	POWERGRID	UPPTCL	Twin Moose		Not Available	
85	400kV	Jaunpur (UP)-Obra_B(UP)	1	D/C	177	UPPTCL	UPPTCL	UPPTCL	Twin Moose	After LILO of 400 KV OBRA B- OBRA-C CKT-	Not Available	
86	400kV	Obra_C_TPS(UP)-Jaunpur (UP)	1	D/C	176	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
87	400kV	Sambhal-Rampur	1	D/C	74	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
88	400kV	Sambhal-Rampur	2	D/C	74	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
89	400kV	Simbholi-Meerut_PMSTL	1	D/C	29	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
90	400kV	Simbholi-Meerut_PMSTL	2	D/C	29	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
91	400kV	Simbholi_PMSTL (UP)-Muradnagar_2(UP)	1	D/C	71	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
92	400kV	Simbholi_PMSTL (UP)-Muradnagar_2(UP)	2	D/C	71	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
93	400kV	Panki-Panki_TPS	1	S/C	1	UPPTCL	UPPTCL	UPPTCL	Twin Moose		Not Available	
H. PJFTL												
1	400kV	Firozabad-Jawaharpur	1	D/C	40	PJFTL	PJFTL	UPRVUNL	Quad Moose	Anti-theft charging from Firozabad(PJFTL)	Not Available	
2	400kV	Firozabad-Jawaharpur	2	D/C	40	PJFTL	PJFTL	UPRVUNL	Quad Moose		Not Available	
3	400kV	Agra South-Firozabad PJFTL	1	D/C	79	PJFTL	UPPTCL	PJFTL	Twin Moose	LILO of 400kV Agra South-Agra Fatehabad ckt-2 at Firozabad PJFTL	Not Available	
4	400kV	Agra(Fatehabad)-Firozabad PJFT	1	D/C	79	PJFTL	UPPTCL	PJFTL	Twin Moose		Not Available	
I. GTL												
1	400kV	Kanpur(PG)-Ghatampur_TPS(UP)	1	D/C	49	GTL	POWERGRID	UPPTCL	Twin Moose	Antitheft charging from Kanpur(PG) Upto DEAD	Not Available	
2	400kV	Kanpur(PG)-Ghatampur_TPS(UP)	2	D/C	49	GTL	POWERGRID	UPPTCL	Twin Moose		Not Available	
J. HPPTCL												
1	400kV	Lahal-Chamba	1	D/C	35	HPPTCL	HPPTCL	POWERGRID	Twin Moose		Not Available	
2	400kV	Lahal-Chamba	2	D/C	35	HPPTCL	HPPTCL	POWERGRID	Twin Moose		Not Available	
K. NTPC JV												
1	400kV	Dadri-Loni (Harsh Vihar)	1	D/C	54	NTPC	NTPC	DTL	Twin Moose		Polymer	
2	400kV	Dadri-Loni (Harsh Vihar)	2	D/C	54	NTPC	NTPC	DTL	Twin Moose		Polymer	
L. MTSCl												
1	400kV	Ajmer-Deedwana	1	S/C	110	MTSCL	RRVNL	MTSCL	Twin Moose		Not Available	
2	400kV	Bikaner-Deedwana	1	S/C	129	MTSCL	RRVNL	MTSCL	Twin Moose		Conventional	
M. Aravali Transmission Service Company Ltd (ATSCL)												
1	400kV	Alwar-Hindaun	1	S/C	96	ATSCL	ATSL	RRVNL	Twin Moose		Not Available	Partly owned by Aravali Transmission Services lltd.
N. BBMB												
1	400kV	Dehar-Rajpura	1	S/C	129	BBMB	BBMB	PSTCL	Twin Morkulla+ LILO portion is of twin moose	Dehar-Bhiwani LILOed at Rajpura	Antifog	LILO of Dehar-Bhiwani at Rajpura
2	400kV	Bhiwani(BBMB)-Rajpura	1	S/C	213	BBMB	BBMB	PSTCL		Dehar-Bhiwani LILOed at Rajpura	Antifog	

3	400kV	Dehar-Panchkula	1	S/C	125	BBMB	BBMB	POWERGRID	Twin Morkulla+ LILO portion is of twin moose	POWERGRID owned LILO portion of 9.034Km	Antifog	LILO of Dehar-Panipat at Panchkula
4	400kV	Panchkula-Panipat	1	S/C	155	BBMB	POWERGRID	BBMB			Antifog	
OTHER DEDICATED LINES												
A. THDC												
1	400kV	Aligarh-Khurja	1	D/C	35	THDC	POWERGRID	THDC	Twin Moose		Not Available	
2	400kV	Aligarh-Khurja	2	D/C	35	THDC	POWERGRID	THDC	Twin Moose		Not Available	
5. 400kV Transmission Line charged at 220kV												
STATE LINES												
A. RRVPNL												
1	400kV charged at 220kV	Dholpur-Hindaun	1	S/C	100	RRVPNL	RRVUNL	RRVPNL	Twin Moose		Conventional	
2	400kV charged at 220kV	Kota-KTPS	1	D/C	7	RRVPNL	POWERGRID	RRVUNL	Twin Moose		Conventional	
3	400kV charged at 220kV	Kota-KTPS	2	D/C	7	RRVPNL	POWERGRID	RRVUNL	Twin Moose		Conventional	

* - Fixed series capacitor (FSC) is owned by POWERGRID

National Load Despatch Centre
Import Capability of Punjab for December 2024

\
 Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	10300	500	9800	5497	4303		https://www.punjab.sldc.org/ATC_TTC.aspx
Limiting Constraints		N-1 contingency of 400/220KV ICT at Rajpura, Ludhiana, Jalandhar, Muktsar Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla and Patiala ICTs 220 kV underlying network at Jalandhar, Ludhiana and Amritsar						

National Load Despatch Centre
Import Capability of Uttar Pradesh for December 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	17300	600	16700	10165	6535		https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde
Limiting Constraints		N-1 contingency of 400/220kV Obra, Allahabad(PG), Gorakhpur (UP), Agra(PG), Lucknow (PG) ICTs						

National Load Despatch Centre
Import Capability of Haryana for December 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	10300	300	10000	5418	4582		https://hvpn.org.in/#/atcttc
Limiting Constraints		N-1 contingency of 400/220kV ICT at Deepalpur, Hisar, Kabulpur and Panipat(BBMB)						

National Load Despatch Centre
Import Capability of Rajasthan for December 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	7600	600	7000	5755	1245		https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads
Limiting Constraints		N-1 contingency of 400/220kV Heerapura, Jodhpur, Bikaner, Ajmer, Merta, Hindaun and Ratangarh ICTs						

National Load Despatch Centre
Import Capability of Delhi for December 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	7300	300	7000	4810	2190		https://www.delhisldc.org/resources/atcttcreport.pdf
Limiting Constraints		N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs.						

National Load Despatch Centre
Import Capability of Uttarakhand for December 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	1710	100	1610	1402	208		https://uksldc.in/ttc-atc
Limiting Constraints		N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines						

National Load Despatch Centre
Import Capability of HP for December 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	2386	100	2286	1130	1156		https://hpsldc.com/mrm_category/ttc-atc-report/
Limiting Constraints		Overloading of 2*100MVA Giri transformers						

**National Load Despatch Centre
Import Capability of J&K for December 2024**

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	3200	100	3100	1977	1123		
Limiting Constraints		N-1 contingency of 400/220KV ICTs at Amargarh 220 kV underlying network at Amargarh, Wagoora						

National Load Despatch Centre
Import Capability of Chandigarh for December 2024

Issue Date: -

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 31st December 2024	00-24	400	20	380	342	38		
Limiting Constraints		N-1 contingency of 220kV Nallagarh-Kishengarh						