



भारत सरकार

Government of India
विद्युत मंत्रालय
Ministry of Power
उत्तर क्षेत्रीय विद्युत समिति
Northern Regional Power Committee

No. उ.क्षे.वि.स./प्रचालन/107/01/2023/

दिनांक: .06.2023

सेवा में : संरक्षण उप-समिति के सदस्य (सूची के अनुसार) ।

To: Members of Protection Sub-Committee (As per mail list)

विषय: संरक्षण उप-समिति की 47 वीं बैठक की कार्यसूची ।

Subject: Agenda for 47th Protection Sub-Committee Meeting.

संरक्षण उप-समिति की 47 वीं बैठक, **23.06.2023** को **11:00** बजे से **वीडियो कॉन्फ्रेंसिंग** के माध्यम से आयोजित की जाएगी । उक्त बैठक की कार्यसूची संलग्न है । यह उत्तर क्षेत्रीय विद्युत् समिति की वेबसाइट (<http://164.100.60.165/>) पर भी उपलब्ध है । ऑनलाइन बैठक में शामिल होने के लिए लिंक और अपेक्षित जानकारी नियत समय पर सदस्यों को दी जाएगी। कृपया बैठक में उपस्थिति सुनिश्चित करें ।

The 47th meeting of Protection Sub-Committee is scheduled to be held on **23.06.2023** at **11:00 Hrs** through **Video Conferencing**. The agenda for the meeting is attached herewith. The same is also available on NRPC website (<http://164.100.60.165/>). The link and requisite information for joining the online meeting will be shared with the members in due course. Kindly make it convenient to attend the same.

(संतोष कुमार)

अधीक्षण अभियंता (संरक्षण)

Agenda of 47th Protection Sub-Committee Meeting (23rd June, 2023)

Contents

A.1. Confirmation of minutes of 46 th meeting of Protection Sub-Committee.....	3
A.2. Implementation of recommendations of Task Force (agenda by NRPC Sectt.).	3
A.3. Protection Philosophy of NR (agenda by NRPC Sectt.).....	6
A.4. Frequent tripping of Meja-Bara line (agenda by MEJA).....	6
A.5. Non-availability & un-healthiness of PLCC (Agenda by Indigrid).....	7
A.6. Status of remedial actions recommended during 46 th PSC meeting (Agenda by NRLDC).....	8
A.7. Status of Bus bar protection (Agenda by NRLDC).....	8
A.8. Replacement of electromechanical relays with numerical relays (Agenda by NRLDC).....	9
A.9. Unsatisfactory status of submission of DR/EL & tripping report (Agenda by NRLDC).....	10
A.10. Frequent 800kV HVDC Champa-Kurukshetra inter-regional link (Agenda by NRLDC).....	10
A.11. Analysis of the tripping events occurred during Nov-22 to May-23 and status of remedial action taken.....	11

Agenda for

**47th Meeting of Protection Sub-Committee (PSC) of
Northern Regional Power Committee**

Date and time of meeting : 23.06.2023 11.00 Hrs.

Venue : Video-Conferencing

A.1. Confirmation of minutes of 46th meeting of Protection Sub-Committee

A.1.1 46th PSC meeting was held on 22.12.2022. Gist of decisions were issued vide letter dated 09.01.2023. Minutes of the meeting were issued vide letter dtd. 27.02.2023. No comment has been received till the date. Forum may approve the minutes as issued.

Decision required from Forum:

Forum is requested to approve the minutes of 46th PS meeting.

A.2. Implementation of recommendations of Task Force (agenda by NRPC Sectt.)

A.2.1. Database of protection settings

A.2.1.1 As a follow up of one of the recommendations of Enquiry Committee headed by the Chairperson, CEA on grid disturbances that took place on 30th and 31st July 2012, Ministry of Power had constituted a 'Task Force on Power System Analysis under Contingencies' in December 2012. The Task Force had submitted its report in August 2013. In a meeting taken by Union Power Secretary on 11.03.2014, it was decided that the report be given wide circulation and its recommendations be implemented in a time bound manner.

A.2.1.2 In the 44th PSC meeting, it was also deliberated that since majority of data for 400 kV and above Transmission lines, ICTs and reactors has been collected, the process of Web based Protection setting database may be initiated in parallel manner. Hence, it was decided to first constitute a committee for preparing comprehensive specifications for relay setting parameters for Web based database. Thereafter, cost estimation for the work and funding options may be explored. It was also decided that nomination letter with ToR of the committee may be issued by NRPC Sectt.

A.2.1.3 As per decision taken in 43rd PSC meeting, a committee was constituted vide letter

Agenda of 47th Protection Sub-Committee Meeting (23rd June, 2023)

dtd. 06.04.2021 which was reconstituted vide letter dated 27.01.2022 due to the change in the nominations of few members. The 1st meeting of the committee was held on 10.02.2022 and 2nd meeting of the committee was held on 14.06.2022. In these meetings, committee has finalized scope of work (**Annexure-I**) which was deliberated and accepted in 45th Protection sub-committee meeting (held on 24.06.2022). The following was decided in 45th PSC meeting:

- i. A meeting with NIC to be scheduled for exploring the possibility and cost estimate for hosting of portal considering quantum of data.
- ii. Budgetary quotation/EOI to be requested from suitable vendors.

A.2.1.4 In 46th PSC meeting, it was deliberated that as per protection code in draft CERC (Indian Electricity Grid Code) Regulations, 2022 issued by CERC on 07.06.2022, additional responsibilities have been added for RPCs regarding protection setting approval and its database. Hence, it was decided that database work may be taken up further only after notification of final IEGC by Hon'ble CERC as scope of tender may vary as per requirement. It was also decided that implementing agency and funding mode may be discussed in upcoming NRPC meetings.

A.2.1.5 The issue was deliberated in 64th NRPC meeting held on 24.03.2023 wherein members agreed for expenditure from NRPC Fund and POWERGRID was requested to initiate the modalities.

A.2.1.6 CERC (Indian Electricity Grid Code) Regulations, 2023 has been published on 29.05.2023, however it is yet to be notified by the commission. The clauses regarding protection setting are as below:

Quote

14. PROTECTION SETTINGS

(2) All users connected to the grid shall:

- (a) furnish the protection settings implemented for each element to respective RPC in a format as prescribed by the concerned RPC;
- (b) obtain approval of the concerned RPC for (i) any revision in settings, and (ii) implementation of new protection system;
- (c) intimate to the concerned RPC about the changes implemented in protection system or protection settings within a fortnight of such changes;
- (d) ensure correct and appropriate settings of protection as specified by the

Agenda of 47th Protection Sub-Committee Meeting (23rd June, 2023)

concerned RPC.

(e) ensure proper coordinated protection settings.

(3) RPCs shall:

(a) maintain a centralized database and update the same on periodic basis in respect of their respective region containing details of relay settings for grid elements connected to 220 kV and above (132 kV and above in NER). RLDCs shall also maintain such database.

(b) carry out detailed system studies, once a year, for protection settings and advise modifications / changes, if any, to the CTU and to all users and STUs of their respective regions. The data required to carry out such studies shall be provided by RLDCs and CTU.

(c) provide the database access to CTU and NLDC and to all users, RLDC, SLDCs, and STUs of the respective regions. The database shall have different access rights for different users.

(4) The changes in the network and protection settings of grid elements connected to 220kV and above (132 kV and above in NER) shall be informed to RPCs by CTU and STUs, as the case may be.

(5) The elements of network below 66kV and radial in nature which do not impact the National Grid may be excluded as finalized by the respective RPC.

Unquote

A.2.1.7 Therefore, it is proposed that database work may be taken up as per published IEGC by Hon'ble CERC. Accordingly, scope of work may be modified to accommodate provisions of code no. 14 of IEGC 2023. Following major changes are required in scope:

- i. In the finalized scope, only line, ICT, and Reactor has been considered. Now, each element is required to be considered such as Generator, GT, Bus-bar, SVC, STATCOM, HVDC, SPS etc.
- ii. Now, flow for approval of settings may be incorporated in scope.

A.2.1.8 Accordingly, it is proposed that the committee constituted vide letter dated 27.01.2022, may be allowed to review the scope approved in 64th NRPC meeting held on 24.03.2023

Agenda of 47th Protection Sub-Committee Meeting (23rd June, 2023)

Decision required from Forum:

Forum may allow the committee to review the finalized scope of work to accommodate requirement mandated in IEGC 2023.

A.3. Protection Philosophy of NR (agenda by NRPC Sectt.)

- A.3.1 In compliance of decisions of 42nd and 45th PSC meeting, an expert group has been constituted by NRPC vide letter dtd. 08.12.2022, comprising members from NRPC Sectt, NRLDC, BBMB, POWERGRID, STUs, State GENCOs, NTPC, NHPC, and RE Generator to study various recommendations related to Protection setting as well as adopted philosophy in other regions/utilities and further, to propose updated protection philosophy in time bound manner.
- A.3.2 The 1st meeting of the committee has been held on 20.01.2023, members have been requested to either share protection guidelines followed in their organization or any other protection to be added in philosophy along with supporting document.
- A.3.3 BBMB has submitted guidelines followed by them. Other members may submit the same on priority. Practice followed for HVDC, STATCOM, SVC, Cable, RE Inverter, may also be shared.

Decision required from Forum:

Expert members may share practices followed in their organization for protection settings.

A.4. Frequent tripping of Meja-Bara line (agenda by MEJA)

- A.4.1 On 11.06.2023 01:29hrs, B-phase fault was sensed by the relay in Meja-Bara ckt-1 at a distance of 32.3km (100%) from Meja with 8.3kA current. The Circuit Breaker went into auto reclose. Subsequently, the line tripped due to SOTF with fault current of approx. 13kA.
- A.4.2 Such faults lead to heavy stress on all equipment at Generating station including Transformers and Generators. Frequent faults were observed in both Meja-Bara Ckt-1 & 2 in January this year wherein UPPTCL was advised to take corrective action in meetings dt 07.01.2023 and 16.01.2023 with UPSLDC.
- A.4.3 The issue was discussed in 203rd OCC meeting (held on 18.01.2023), wherein, following were discussed:

Agenda of 47th Protection Sub-Committee Meeting (23rd June, 2023)

- i. Pre-winter maintenance of MEJA-BARA transmission lines was not done and there are some protection related issues at generating station end. A joint committee has been formed having officials of Meja, Bara generating utilities and UPPTCL to study the protection related issues at generating station end.
- ii. There are cement factories near Bara generating plant and due to the pollution, dust accumulation was observed till tower no. 13 and subsequently shutdown was taken and porcelain insulators on the cited line were cleaned.
- iii. There is no maintenance of PLCC at the generating station due to ownership issues, henceforth issues of delayed fault clearance are being currently reported. Further, in the meeting held on 16.01.2023, the generating stations have agreed to maintain the PLCC, however, commercial aspects are yet to be sorted out.
- iv. Concerned stakeholders were asked to expeditiously resolve the commercial issues related to PLCC maintenance as it is a serious issues and detrimental to the machines. Further, UPPTCL was requested to explore the possibility for replacement of porcelain insulators with polymer insulators for Meja-Bara lines.

Decision required from Forum:

UP may apprise the status of resolution of the issue.

A.5. Non-availability & un-healthiness of PLCC (Agenda by Indigrd)

- A.5.1 This has reference to the non-availability & un-healthiness of PLCC, installed on the downstream networks of IndiGrid associated SPVs viz. Gurgaon Palwal Transmission Ltd. (GPTL), Patran Transmission Company Ltd. (PTCL), NRSS XXIX Transmission Ltd.(NTL) and Jhajjar KT Transco Private Ltd.(JKTTPL).
- A.5.2 Due to non-availability/un-healthiness of the Tele-protection system in the downstream network lines, there is a risk to associated IndiGrid substations' elements & Grid security as well. In this regard Indigrd has sent communication to the concerned office (PSTCL, HVPN) but have not received any response for the resolution.
- A.5.3 The details pertaining to the said PLCC/ Tele-protection system is mentioned below:
- i. PTCL associated Line -220kV Patran- Patran Ckt-1&2 (PLCC unhealthy)

Agenda of 47th Protection Sub-Committee Meeting (23rd June, 2023)

- ii. GPTL associated Line - 220kV Prithala- Ranglarajpur Ckt-1&2. (PLCC not commissioned)
- iii. JKTTPL associated Line- 220kV Dipalpur-Sector 6 Ckt-1&2. (PLCC unhealthy)
- iv. NTL associated Line- 220kV Amargarh- Zainakote Ckt-1&2 and 220kV Amargarh- Delina Ckt-1&2 (PLCC not commissioned)

Decision required from Forum:

PSTCL and HVPN may apprise the status of resolution of the issue.

A.6. Status of remedial actions recommended during 46th PSC meeting (Agenda by NRLDC)

- A.6.1 The list of tripping events along with remedial actions points recommended during 46 PSC meeting is attached as **Annexure-II**. It is expected that necessary actions would have taken place. In view of the same, constituents are requested to share the status of remedial actions taken.

Decision required from Forum:

Constituents are requested to apprise the status of remedial actions taken.

A.7. Status of Bus bar protection (Agenda by NRLDC)

- A.7.1 Clause - 4 in schedule - V of Central Electricity Authority (Technical Standards for Construction of Electrical Plants and Electric Lines) Regulations, 2010 reads as
"Bus bar protection and local breaker backup protection shall be provided in 220kV and higher voltage interconnecting sub- stations as well as in all generating station switchyards".
- A.7.2 During analysis of many grid incidents/disturbances, it has been found that the Busbar protection at the affected substation was not present or non-operational which resulted in considerably increasing both the number of affected elements and fault clearance time. Accordingly, it becomes critical to monitor and keep Busbar protection at all the 220 kV and above voltage level substations healthy and operational.
- A.7.3 Constituents were requested vide NRLDC letter dated 28th Dec 2022 to furnish status of Busbar protection in the prescribed format in your control area.
- A.7.4 Details are yet to be received from Delhi & J&K.

Agenda of 47th Protection Sub-Committee Meeting (23rd June, 2023)

- A.7.5 Constituent wise status of bus bar protection where bus bar protection is either not installed or installed but not operational is attached as **Annexure-III**.
- A.7.6 Deliberation on the same subject is continued in OCC meetings. Constituents agreed in the last (207th) OCC meeting to share the current status of the bus bar protection, however no details received as of now. Constituents are requested to share the present status w.r.t. to the same and also share the status of follow-up actions/plan regarding the aforementioned subject.

Decision required from Forum:

Constituents are requested to share the present status w.r.t. to the same and also share the status of follow-up actions/plan regarding the aforementioned subject.

A.8. Replacement of electromechanical relays with numerical relays (Agenda by NRLDC)

- A.8.1 Clause-5.2(r) of IEGC, clause-15(4) of CEA Grid standards and clause-48(4) of CEA Construction Standards 2022 mandates that *“each line or transformer or reactor or any other bay shall be provided with facility for disturbance recording, event logging and time synchronizing equipment”*.
- A.8.2 During analysis of grid incidents/disturbances, it has been found that there are few stations where electromechanical relays are still in use and thus disturbance recorder are not available there which accounts for violation of Clause-5.2(r) of IEGC, clause-15(4) of CEA Grid Standards and clause 48(4) CEA Construction Standards 2022.
- A.8.3 In addition, clause-3 in part III (Grid Connectivity Standards applicable to Transmission Line and Sub-Station) of Standards for Connectivity to the Grid, 2007 reads as
“Two main numerical Distance Protection Schemes shall be provided on all the transmission lines of 220 kV and above for all new sub-stations. For existing sub-stations, this shall be implemented in a reasonable time frame”
- A.8.4 It is known that Disturbance recorder (DR) is essential for analysis of grid incidents/disturbances. Its non-availability eventually affects the proper analysis of grid incidents/disturbances and monitoring of protection system.
- A.8.5 Deliberation on same subject has also been done during 207th OCC meeting. During the meeting, all the constituents/SLDC/STU were requested to review the same in their control area and to expedite actions to replace electromechanical relays with

Agenda of 47th Protection Sub-Committee Meeting (23rd June, 2023)

numerical relays. Constituents are requested to share the status of remedial action taken/to be taken regarding replacement of electromechanical relays with numerical relays w.r.t. their control area.

Decision required from Forum:

Constituents are requested to share the status of remedial action taken/to be taken regarding replacement of electromechanical relays with numerical relays w.r.t. their control area.

A.9. Unsatisfactory status of submission of DR/EL & tripping report (Agenda by NRLDC)

- A.9.1 As per the IEGC provision under clause 5.2 (r), *“all the Users, STU/SLDC and CTU shall send information/data including disturbance recorder/sequential event recorder output to RLDC within 24 hours for purpose of analysis of any grid disturbance/event. No Users, SLDC/STU or CTU shall block any data/information required by the RLDC and RPC for maintaining reliability and security of grid and for analysis of an event.”*
- A.9.2 It is known that, DR/EL are very much important in detailed and conclusive analysis of any tripping event. In addition, these data are also base for the availability verification. Unavailability of these details delays the availability verification process also. Hence, timely submission of DR/EL & tripping report is very much necessary.
- A.9.3 It is observed that, reporting status of J&K, Punjab & Delhi is unsatisfactory. Almost in 60-90% cases details are not received from these states. Reporting status from other states/users/utilities also need further improvement. Reporting status of J&K, Punjab & Delhi since Nov-23 is attached as **Annexure-IV**.
- A.9.4 Continuous follow-ups on event to event basis and on monthly basis are done by NRLDC on this subject. Constituents are requested to take follow-ups/necessary actions at their end to improve the status of submission of DR/EL & tripping reports.

Decision required from Forum:

Constituents are requested to take follow-ups/necessary actions at their end to improve the status of submission of DR/EL & tripping reports.

Agenda of 47th Protection Sub-Committee Meeting (23rd June, 2023)

A.10. Frequent 800kV HVDC Champa-Kurukshetra inter-regional link (Agenda by NRLDC)

- A.10.1 It has been observed that frequency of tripping of HVDC Champa-Kurukshetra has increased. 13 nos of trippings has been observed in this link since May 2023. List of all the tripping of HVDC Champa-Kurukshetra is enclosed as **Annexure-V**. The tripping of this high capacity link may cause overloading of other parallel transmission lines and further tripping may cause cascade tripping.
- A.10.2 It is also well known that, paddy season is on the verge of start in Haryana & Punjab and on account of summer, the Northern Region load would remain high till September and therefore, high import requirement exists for the Northern Region. Thus, the HVDC Champa-Kurukshetra inter-regional link is a very important link for fulfilling the Northern Region demand requirement.
- A.10.3 It has been observed that major fault is either due to DC line fault, filter protection, software issues, protection mal-operation etc. The reason of most of the tripping seems similar indicating the repetitive nature of fault/tripping.
- A.10.4 POWERGRID(NR-1) is requested to elaborate on the issues and status of remedial measures taken/to be taken to avoid frequent tripping of this inter-regional link.

Decision required from Forum:

POWERGRID (NR-1) is requested to elaborate on the issues and status of remedial measures taken/to be taken to avoid frequent tripping of this inter-regional link.

A.11. Analysis of the tripping events occurred during Nov-22 to May-23 and status of remedial action taken

- A.11.1 The list of major tripping events occurred during Nov-22 to May-23 is attached as **Annexure-VI**. Concerned constituents/utilities are requested to share the detailed of the tripping elements along with status of remedial action taken/to be taken.

Decision required from Forum:


Forum may decide remedial measure on issues faced by utilities.

Finalized Scope of Work to be incorporated for the web-based protection setting database tender


The committee decided scope of work for tender as below: -

1. Publication of website may be on NIC cloud, in case server of PGCIL/NRLDC is not available.
2. Uploading of Protection settings already received in NRPC Secretariat on database portal shall be in scope of tender. For rest of the equipment, utility may upload their settings. In case of change in existing settings, utility shall upload excel sheet on portal.
3. The website shall have facility to upload relay settings excel sheet by utilities for Line, ICT, and Reactor.
4. Following sequence may be facilitated for upload of protection setting excel sheet:


a) Line:



b) ICT:



c) Reactor:



5. Same flow may be facilitated for download/retrieve of already uploaded excel sheet also.
6. Database will comprise of master list of all elements required for fields as mentioned in flow diagram at point no. 4 above. Editing rights in database will be with admin/NRPC Secretariat only. On request from utilities for addition/alteration in network, database shall be modified accordingly.
7. Login IDs are required to be facilitated to utilities who will upload excel sheet. Only owner of element shall have right to upload excel sheet for concerned equipment. Rest of the users shall have viewing rights only.
8. Log report of activities is required for getting information of time and date of upload of excel sheet.
9. Some major parameters of protection setting may be displayed on screen itself in addition to uploaded excel sheet as below: -

a) Line:

- i. Line length, CT Ratio, PT Ratio
- ii. R, X values

Signature
15/6/22

- iii. SOTF (Enable/Disable status) of both ends of line
- iv. Power Swing (Enable/Disable status) of both ends of line
- v. Zone reach settings and corresponding time delay of both ends of line
- vi. Over-voltage settings (Stage-1 & Stage-2) of both ends of line
- vii. Earth Fault O/C

b) ICT:

- i. Rating, CT Ratio, PT Ratio, percentage impedance, thermal overload
- ii. Differential protection settings (pick up & slopes)
- iii. REF protection (pick up and stabilizing resistance)
- iv. Over-voltage settings
- v. Earth Fault O/C/ Backup O/C

c) Reactor:

- i. MVAR rating, CT ratio
- ii. Differential protection settings (pick up & slopes)
- iii. REF protection (pick up and stabilizing resistance)
- iv. Earth fault (pick up and time delay)

Jeswin
15/6/22

List of Grid events to be discussed in 46th PSC meeting of NRPC

S.No.	Category of Grid Disturbance	Name of Elements (Tripped/Manually opened)	Affected Area	Owner/ Agency	Outage	Remdial actions recommended/agreed during 46 PSC meeting	Status of remedial actions taken (to be shared by concerned utility)
	(GD-I to GD-V)				Date		
	NA	Installation of PLCC in transmission lines and protection audit of substations in J&K(UT) control area				i) In next financial year, work of installation of OPGW in all the transmission lines will be started and follow-up actions are being done regarding the same. ii) OPGW work will be followed by installation of PLCC. iii) J&K will intitate follow-up action to conduct protection audit of J&K S/s with the help of POWERGRID. J&K agreed to check & correct the protection settings at frequently affected S/s.	
1	GD-1	1) 400/220 kV 315 MVA ICT 3 at Muzaffarnagar(UP) 2) 400/220 kV 315 MVA ICT 1 at Muzaffarnagar(UP) 3) 400/220 kV 315 MVA ICT 2 at Muzaffarnagar(UP)	UTTAR PRADESH	UPPTCL	5-May-22	i) Scheme and logic of the bus bar relay needs to be corrected as soon as possible. UP assured that this point would be attended up to Jan-2023. ii) The problem of faulty time sync in protection relays of UP control area is coming up frequently during tripping analysis. UP assured to take some concrete action in this regard and will intimate the same to NRLDC and NRPC. iii) UP was requested to report SPS operations in its control area promptly to NRLDC for onward analysis at NRLDC end. UP assured for the same in future.	
2	GD-1	1) 220 KV Hissar(BB)-Chirawa(RS) (BB) Ckt-1 2) 220 KV Hissar(BB)-Jindal Steel(HR) (HVPNL) Ckt-1 3) 220 KV Hissar-Sangrur (BB) Ckt-2 220 KV Hissar-Sangrur (BB) Ckt-1 4) 220KV Bus 2 at Hissar(BB), 220 KV 5) Bhiwani-Hissar (BB) Ckt-2 6) 220 KV Hissar(PG)-Hissar IA(HV) (PG) Ckt-2 7) 220 KV Hissar(BB)-Hissar IA(HV) (BBMB) Ckt-2 8) 220 KV Bhiwani-Hissar (BB) Ckt-1 9) 220 KV Hissar(BB)-Hissar IA(HV) (HVPNL) Ckt-1 10) 220 KV Hissar(PG)-Hissar IA(HV) (PG) Ckt-1	HARYANA	BBMB, HVPNL, POWERGRID	10-May-22	i) BBMB and Haryana were requested to coordinate and replace distance protection on line Hissar (BB)-Hissar IA (HV) with Differential protection. ii) BBMB was requested to send DR and event logger along with tripping report promptly for every tripping to NRLDC within time stipulated as per IEGC.	
3	GD-1	1) 400/220 kV 315 MVA ICT 1 at Gr.Noida(UPC) 2) 400/220 kV 315 MVA ICT 2 at Gr.Noida(UPC) 3) 400/220 kV 500 MVA ICT 5 at Gr.Noida(UPC) 4) 400/220 kV 500 MVA ICT 6 at Gr.Noida(UPC)	UTTAR PRADESH	UPPTCL	20-May-22	i) Distance protection relay (CSC make) of 220kV Gr. Noida-RC Green ckt. -I am susceptible to faulty operation and needs to be changed. UP assured, that correspondence for the same has already been done with transmission wing and it will be replaced shortly. ii) Follow-up actions for the same may be intimated by UP.	
4	GD-1	1) 220 KV Sohna Road (GPTL)-Badshahpur(HV) (HVPNL) Ckt-2 2) 220 KV Sohna Road (GPTL)-Badshahpur(HV) (HVPNL) Ckt-1 3) 400 KV Gurgaon(PG)-Sohna Road (GPTL) (GPTL) Ckt-1 4) 220 KV Sohna Road (GPTL)-GurgaonSec72(HV) (HVPNL) Ckt-1	HARYANA	HVPNL, POWERGRID	30-May-22	NA (Tripping couldn't be discussed, Haryana represenatives were not present in the meeting)	

S.No.	Category of Grid Disturbance	Name of Elements (Tripped/Manually opened)	Affected Area	Owner/ Agency	Outage	Remdial actions recommended/agreed during 46 PSC meeting	Status of remedial actions taken (to be shared by concerned utility)
	(GD-I to GD-V)				Date		
5	GD-1	1) 132 KV Pithoragarh(PG)-Almora(PTCUL) (PTCUL) Ckt-1, 2) 70 MW Dhauliganga HPS - UNIT 2 3) 70 MW Dhauliganga HPS - UNIT 1	UTTRAKHAND	NHPC, PTCUL	15-Jun-22	NRLDC representative pointed out that the network has changed now and SPS can be disabled now.	
6	GI-2	1) 400 KV Bikaner-Bhadla (RS) Ckt-1 2) 400 KV Bikaner(RS)-Sikar(PG) (RS) Ckt-1 3) 400 KV Bikaner(PG)-Bikaner(RS) (PG) Ckt-1 4) 400 KV Bikaner(RS)-Deedwana(MTS) (RS) Ckt-1 5) 400 KV Suratgarh SCTPS(RVUN)-Suratgarh(RS) (RS) Ckt-1 6) 400 KV Suratgarh SCTPS(RVUN)-Suratgarh(RS) (RS) Ckt-2 7) 400 KV Suratgarh(RVUN)-Bikaner(RS) (RS) Ckt-1 8) 400 KV Bikaner-Merta (RS) Ckt-1 9) 400/33 kV 125 MVA ICT 1 at Bikaner RENEW Solar(RENEW) 10) 400/220 kV 315 MVA ICT 2 at Bikaner(RS) 11) 125 MVAR Bus Reactor No 2 at 400KV Bikaner(RS) 12) 400/220 kV 315 MVA ICT 1 at Bikaner(RS) 13) 400 KV Suratgarh SCTPS(RVUN)-Bikaner(RS) (RS) Ckt-1 14) 400 KV Suratgarh SCTPS(RVUN)-Bikaner(RS) (RS) Ckt-2 15)400 KV Suratgarh(RVUN)-Ratangarh(RS) (RS) Ckt-2	RAJASTHAN	RRVPLN	21-Jun-22	NA (Tripping couldn't be discussed, Rajasthan represenatives were not present in the meeting)	
7	GD-1	1) 132 KV Pilibhit(UP)-Sitarganj(PTCUL) (PTCUL) Ckt-1 2) 220/132 kV 100 MVA ICT 3 at Sitarganj(PG) 3) 220/132 kV 100 MVA ICT 2 at Sitarganj(PG) 4) 220/132 kV 100 MVA ICT 1 at Sitarganj(PG) 5) 132 KV Sitarganj(PG)-Sitarganj(PTCUL) (PTCUL) Ckt-2 6) 132 KV Sitarganj(PG)-Sitarganj(PTCUL) (PTCUL) Ckt-3 7) 132 KV Sitarganj(PG)-Sitarganj(SIDCUL) (PTCUL) Ckt-1 8) 220 KV Tanakpur(NH)-Sitarganj(PG) (PG) Ckt-1	UTTRAKHAND	POWERGRID, PTCUL	17-Jul-22	i) PTCUL representative was requested to take the issue of bus bar protection at 132 kV level. PTCUL informed that it has been included in upcoming budget and will take some time. ii) As an interim measure, PTCUL was requested to install O/C relay as backup protection to take care of Bus faults. PTCUL agreed for the same and assured that O/C relay will be installed within a months' time.	
8	GD-1	1) 220 KV Moga(PG)-MOGAN(PS) (PSTCL) Ckt-2 2) 220 KV Moga(PG)-MOGAN(PS) (PSTCL) Ckt-3 3) 220 KV Moga(PG)-MOGAN(PS) (PSTCL) Ckt-4 4) 220 KV Moga(PG)-MOGAN(PS) (PSTCL) Ckt-1 5) 220kV Mogan-Baghapurana(PS) ckt-1 6) 220kV Mogan-Baghapurana(PS) ckt-2 7) 220kV Mogan-Bajakhanna(PS) ckt 8) 220kV Mogan-Ferozpur(PS) ckt 9) 132kV Mogan-Dhale (PS) ckt	PUNJAB	PSTCL	30-Jul-22	NA (Tripping couldn't be discussed, Punjab represenatives were not present in the meeting)	

S.No.	Category of Grid Disturbance	Name of Elements (Tripped/Manually opened)	Affected Area	Owner/ Agency	Outage	Remdial actions recommended/agreed during 46 PSC meeting	Status of remedial actions taken (to be shared by concerned utility)
	(GD-I to GD-V)				Date		
9	GD-1	1) 400 KV Alaknanda GVK(UPC)-Srinagar(UK) (UK) Ckt-1 2) 220 KV Singoli Bhatwari(Singoli(LTUHP))-Srinagar(UK) (PTCUL) Ckt-1 3) 400 KV Alaknanda GVK(UPC)-Muzaffarnagar (UP) Ckt-1 4) 220 KV Singoli Bhatwari(Singoli(LTUHP))-Srinagar(UK) (PTCUL) Ckt-2 5) 400 KV Alaknanda GVK(UPC)-Vishnuprayag(JP) (UP) Ckt-1 6) 33 MW Singoli Bhatwari HEP - UNIT 2, 33 MW Singoli Bhatwari HEP - UNIT 3	UTTAR PRADESH ; UTTRAKHAND	PTCUL, Singoli(LTUHP), UPPTCL	23-Aug-22	i) GVK representative explained that they have different scheme in with main and tie circuit breakers open simultaneously in case of a fault. UPSLDC and NRLDC representative expressed that this scheme in itself defeats the purpose of having one and a half breaker scheme. ii) GVK expressed that they have planned for third party protection audit through PRDC after which they will go for scheme modification. NRLDC requested for the detailed action plan along with progress report. GVK assured to share the same. iii) GVK was intimated that they are deviating from the already in place approved NR protection philosophy. MS, NRPC and NRLDC representative expressed that the required modifications can be done without going for any third party protection audit as the same can be carried out taking basis of the already approved protection philosophy in place. GVK agreed for the same and assured to go ahead with the modification without waiting for the third party protection audit from PRDC side.	
10	GD-1	1) 40 MW Sewa-II HPS - UNIT 1 2) 40 MW Sewa-II HPS - UNIT 3 3) 40 MW Sewa-II HPS - UNIT 2 4) 220 KV Samba(PG)-Hiranagar(PDD) (PG) Ckt-1 5) 220 KV Samba(PG)-Hiranagar(PDD) (PDD JK) Ckt-2	J & K	NHPC, PDD JK, POWERGRID	29-Aug-22	i) J&K representative informed that bus-bar protection would be made operational at all the substations of JKPTCL by March-2023. NRLDC asked for detailed plan may please be shared. ii) J&K was requested to carryout protection audit as soon as possible as protection system in J&K jurisdiction is having a number of serious issues and needs immediate audit and rectification. MS, NRPC also stressed for the immediate protection audit and instructed all to take promising steps for same.	
11	GD-1	1) 220 KV Hissar(PG)-Fatehabad(HV) (HVPNL) Ckt-2 2) 220 KV Fatehabad(PG)-Fatehabad(HV) (HVPNL) Ckt-2 3) 220 KV Fatehabad(PG)-Fatehabad(HV) (HVPNL) Ckt-1 4) 220 KV Hissar(PG)-Fatehabad(HV) (HVPNL) Ckt-1	HARYANA	HVPNL	3-Sep-22	NA (Tripping couldn't be discussed, Haryana representatives were not present in the meeting)	

S.No.	Category of Grid Disturbance	Name of Elements (Tripped/Manually opened)	Affected Area	Owner/ Agency	Outage	Remdial actions recommended/agreed during 46 PSC meeting	Status of remedial actions taken (to be shared by concerned utility)
	(GD-I to GD-V)				Date		
12	GD-1	1) 125 MVAR Bus Reactor No 1 at 400KV Koteswar(TH) 2) 400 KV Koteswar(TH)-Koteswar(PG) (PG) Ckt-1 3) 400 KV Koteswar(TH)-Koteswar(PG) (PG) Ckt-2 4)100 MW Koteswar HPS - UNIT 4	UTTRAKHAND	POWERGRID, THDC	4-Sep-22	i) The work of replacement of distance protection with differential protection may be taken up on fast pace.	
13	GI-2	1) 400/220 kV 240 MVA ICT 3 at Muradnagar_2(UP) 2) 400 KV Muradnagar_2-Mathura (UP) Ckt-1 3) 400 KV Dadri(NT)-Muradnagar_2(UP) (PG) Ckt-1 4) 400KV Bus 2 at Muradnagar_2(UP) 5) 400/220 kV 240 MVA ICT 1 at Muradnagar_2(UP) 6) 400/220 kV 315 MVA ICT 2 at Muradnagar_2(UP) 7) 400KV Bus 1 at Muradnagar_2(UP)	UTTAR PRADESH	POWERGRID, UPPTCL	7-Sep-22	i) Control room staff to be sensitized to intimate SLDC and maintenance staff if any critical alarms such as circuit breaker lockout, Busbar out of service etc. are observed. ii) UP representative assured that issues related to time sync at Muradnagar station have been taken up and will be solved. iii) NRLDC representative requested to send DRs in native .cfg and .dat format. iv) UP requested to remove compulsory upload of pdf format in tripping portal. NRLDC representative agreed for the same.	
14	GD-1	1) 765 KV Fatehgarh_II(PG)-Bhadla(PG) (FBTL) Ckt-1 2) 220 KV Fatehgarh_II(PG)-AHEJ2L PSS HB_FGRAH_PG (AHEJ2L) (AHEJ2L) Ckt-1 3) 220 KV Fatehgarh_II(PG)-AHEJ3L PSS HB_FGRAH_PG (AHEJ3L) (AHEJ3L) Ckt-1	Rajasthan	POWERGRID, AHEJ2L, AHEJ3L	17-Sep-22	i) The protection system operated as desired and no anomalies were observed as such.	
15	GD-1	1) 220 KV Sarsawan(UP)-Khodri(UK) (UP) Ckt-1 2) 220 KV Saharanpur(UP) -Khodri(UK) (UP) Ckt-1 3) 60 MW UNIT 1 at Khodri HEP 4) 60 MW UNIT 2 at Khodri HEP 5) 60 MW UNIT 4 at Khodri HEP	Uttarakhand	UPPTCL, PTCUL	6-Oct-22	i) 220 KV Saharanpur (UP) -Khodri (UK) (UP) Ckt-1, sharanpur end disturbance record is not getting triggered on DEF protection. UP representative assured to rectify the same and map DEF for trigger of DR.	

S.No.	Category of Grid Disturbance	Name of Elements (Tripped/Manually opened)	Affected Area	Owner/ Agency	Outage	Remdial actions recommended/agreed during 46 PSC meeting	Status of remedial actions taken (to be shared by concerned utility)
	(GD-I to GD-V)				Date		
16	GD-1	1) 220 KV Samba(PG)-Hiranagar(PDD) (PG) Ckt-1 2) 220 KV Samba(PG)-Hiranagar(PDD) (PDD JK) Ckt-2 3) 220kV Bishna – Hiranagar ckt 4) 220kV Ghatti – Hiranagar ckt 5) 220kV BUS 1 Hiranagar(JK PDD) 6) 220/132kV 200 MVA ICT 1 7) 220/132kV 120 MVA ICT2	J&K(UT) & Ladakh(UT)	POWERGRID, JKPTCL	16-Oct-22	i) J&K representative informed that bus-bar protection would be made operational at all the substations of JKPTCL by March-2023. NRLDC asked for detailed plan may please be shared. ii) J&K was requested to carryout protection audit as soon as possible as protection system in J&K jurisdiction is having a number of serious issues and needs immediate audit and rectification. MS, NRPC also stressed for the immediate protection audit and instructed all to take promising steps for same.	
17	GD-1	1) 220kV Hapur_765- Simbholi (UP) Ckt-2 2) 220kV Hapur_765- Simbholi(UP) Ckt-2 3) 220 KV Meerut(PG)-Simbholi(UP) (PG) Ckt-1 4) 220 KV NAPP(NP)-Simbholi(UP) (UP) Ckt-1 5) 220kV Hapur- Simbholi (UP) Ckt	Uttar Pradesh	UPPTCL, POWERGRID, NAPP	20-Oct-22	i) UP intimated that protection audit of 220 kV Simbholi substation was carried out in 2020 and no audit has been there since then. MS, NRPC stressed on the point that protection audit of each substation is very important and should be conducted regularly without any fail. ii) On issue of carrier fail alarm coming in 220 kV NAPP – Simbholi line. UP expressed that testing has been done and LMU has been found to be faulty. New LMU has been received at site and will be replaced up to 31.12.2022.	
18	GD-1	1) 400/220 kV 315 MVA ICT 1 at Kashipur(UK) 2) 400/220 kV 315 MVA ICT 2 at Kashipur(UK) 3) 220 KV Pantnagar(UK)-Bareilly(UP) (UP) Ckt-1 4) 220 KV Kashipur-Pantnagar(UK) Ckt 5) 220 KV Kashipur-Jafarpur(UK) Ckt 6) 132 KV Almora-Bhowali(UK) Ckt	Uttarakhand	PTCUL, UPPTCL	24-Oct-22	i) Commissioning work of bus bar protection at 400/220kV Kashipur S/s need to be expedite. Upto its coming in service reverse zones may be put at 160 ms. ii) Zone-3 time delay setting at Bareilly(UP) end of 220 KV Pantnagar(UK)-Bareilly(UP) (UP) Ckt-1 may be revised to 1200 ms from 800ms for better protection coordination.	

Status of Bus bar protection					
Constituent Name	Name of Station	Status of Bus bar protection(as reported)	Expected date of revival(as reported)	Present Status	Remark
Uttarakhand	220 KV Substation, Ramnagar, Roorkee	Blocked due to more elements added at 220 KV Voltage level.			
	220 KV Sub Station, SIDCUL, Haridwar	Blocked due to more elements added at 220 KV Voltage level.			
	220KV Jhajhra, Dehradun	Not commissioned yet			
	400KV Kashipur	Available but Non operational			
	220kv Haldwani	Not Available			
	220kv Pantnagar	Available but Non operational			
	220kv Rishikesh	Available but Non operational			
	220KV Chamba	Not commissioned yet			
Haryana	220KV S/Stn Badshahpur	Not Installed	15.01.2023		
	220kv S/Stn Sec-52A, Gurgaon	Not Installed	31.03.2023		
	220kv S/Stn Sec-1 Manesar	Installed, Non-Operational	31.01.2023		Additional 100MVA, 220/66kV TF T-4 is required to be added in the existing Bus Bar Protection scheme. Further, testing of the scheme is pending and will be done by 31.01.2023.
	220kv S/Stn Panchgaon	Not Installed	31.03.2023		The firm i.e., M/s ETA has left the work. Now the leftover work is being carried out departmentally. The matter has been taken up with the firm i.e. M/s Siemens for providing offer regarding commissioning of Bus-bar. Presently, one no. 220kV Busbar and 220kV Bus Coupler is not commissioned. So, the Bus Bar protection will be commissioned with all pending work.
	220kv S/Stn Rewari	Not Installed	31.08.2023		Estimate stands sanctioned. Bus Bar will be commissioned subject to the complete allocation of material.
	220kv S/Stn Narnaul	Not Installed	31.03.2023		Till date, busbar protection was not required as the substation is radially fed. However, a new transmission line viz. 220 kV D/C Deroli Ahir-Narnaul line is under construction on turnkey mode. Thus, the work of providing 220 kV take-in bays(02 no.) alongwith the work of providing the requisite busbar protection stands also awarded to other turnkey contractor
	220kv S/Stn Mohinder Garh	Not Installed	01.06.2023		Estimate stands sanctioned. Bus Bar will be commissioned subject to the complete allocation of material.
	220 KV S/Stn Palwal	Not Installed	30.06.2023		Earlier, the necessity of bus bar protection had not been comprehended, however, expanded transmission network with establishment of new substations/transmission elements in synchronism mode, there was call for introduction of Bus Bar Protection Scheme.
	220 KV S/Stn Rangala Rajpur	Installed but Non-Operational	31.03.2023		Defective. Work order has been issued for restoration of bus bar protection at the substation
	220 KV Unispur	Installed but Non-Operational	Mar-23		Relay Mal-functioning
	220 KV Mund	Installed but Non-Operational	Feb-23		Isolator status Ambiguous
	220 KV Nissing	Installed but Non-Operational	May-23		New scheme is being installed at place of old Bus Bar Protection Scheme
	220KV Pehowa	Installed but Non-Operational	BBP will be commissioned within 2 Months after receiving of material		Old & Obsolete, Allocation of New BBP and allied Material awaited.
	220kv Kaithal	Not Installed	Within 2month After Allocation of Bus-Bar Protection Panel		
	220 KV Sonapat	Not Installed	220 KV Bus Bar Protection Scheme will be installed within a month after the availability of the necessary material required for commissioning		
	220 KV REGC, Sonapat	Not Installed	220 KV Bus Bar Protection Scheme will be installed within a month after the availability of the necessary material required for commissioning		
	220KV Jind	Installed but Non-Operational	31.01.2023		Existing Bus bar panel is of old and obsolete design. New Bus Bar protection scheme panel has been drawn from the store. New Panel will be commissioned at earliest.
	220 KV Fatehabad	Installed but Non-Operational			
	220 KV Bhuna	Installed but Non-Operational			
	220 KV Sirsa	Not Installed			
220 KV Rania	Not Installed	31.03.2023			
220 KV Bhiwani	Not Installed	Work likely to be completed in FY 2023- 24.			
220kv Madanpur	Not Installed			The existing BBP was shifted to 220 kv S/Stn. Salempur. The requirement has been sent to CE/ PDF, vide this office letter no Ch-85/W-312/Vol-Vf dt- 28.12.2022	
220kv Tepla	Installed but Non-Operational			The existing BBP is out being old and obsolete. The requirement replacement of existing BBP has been sent to CE/PM, vide this office letter no Ch-85/W-3 12/Vol-VI dt- 28.12.2022	

	220kV Rajokheri	Installed but Non-Operational			The substation is being constructed in turnkey, BBP has been installed. Commissioning is yet to be completed by me firm.
BBMB	220kV Charkhi Dadri	Installed, under commissioning yet	15.01.2023		Old high impedance Charkhi Dadri (SAS) Bus Bar Protection has been replaced with low impedance Bus Bar Protection during SAS. Testing is under process and will be Commissioned shortly
	220kV Samaypur	Installed but Non-Operational	30.04.2023		Failure of modules
	220kV Barnala	Not Installed			
	220kV Dhulkote	Not Installed			
	220kV Jagadhari	Not Installed			
	220kV Narela	Not Installed			
UP	220kV Parichha	Installed but Non-Operational	30.06.2023		Due to 10 to 15% differential current error, busbar protection was not taken in service, an order has been placed to M/s Tirupati Industrial Agency authorized channel partner M/s AB for rectification and of same.
	220kV Partapur	Installed but Non-Operational	Jan-23		Busbar relay configuration problem to be rectified by firm engineer
	220kV Nirpura	Installed but Non-Operational	Jan-23		Bus bar protection has been made out of service by maintenance wing due to defective module for 220kV Baraut line
	220kV IITGNL	Installed but Non-Operational	Expected to be commissioned by Apr-23		commissioning work pending
	220kV Rampur	Installed but Non-Operational			01 no. of 220kV feeder (Rampur -CB Ganj) not configured
	220kV Chandausi	Not Installed			Bus bar protection panel not allotted
	220kV Rampur	Installed but Non-Operational			01 no. of 220kV feeder (Rampur -CB Ganj) not configured
	220kV Sec. - 148, Noida	Installed but Non-Operational	Jan-23		Communication card defective
	220kV sec. 38A, Botanica Garden	Not Installed			Bus Bar protection panel not allotted
	220kV sec.-62, Noida	Not Installed	Feb-23		
	220kV Dadri	Not Installed	Sep-23		
	400kV S/S Agra	Installed but Non-Operational	2023		Old and out dated
	220kV S/S Bah	Not Installed			
	220kV Sirsaganj	Not Installed			
	220kV S/S Farrukhabad (New)	Not Installed			
	220kV Boner	Not Installed			
	220kV Kasganj (Soron)	Installed but Non-Operational			Error alarm in busbar
	220kV Khair	Installed but Non-Operational			New 11kV 160MVA T/F is not configured with busbar protection
	220kV Kidwainagar	Installed but Non-Operational			
	220kV Chhata	Installed but Non-Operational			New 11kV 160MVA T/F is not configured with busbar protection
	Harduaganj	Installed but Non-Operational	31.12.2023		Due to 4 to 7 % differential current error the busbar protection was not taken in service. O.E.M M/s Siemens is being pursued to rectify it.
	220kV Lalitpur	Not Installed	Apr-23		Due to non availability of panel & cable
	220kV Sarnath	Installed but Non-Operational	Apr-23		Old & defective Electorstatic panel (ABB Make)
	220kV Sirathu, Kaushambi	Not Installed	Apr-23		Relay Panel is not available
	220kV substation Fatehpur	Installed but Non-Operational	Apr-23		Breaker status not available
	220kV S/S Raja Talab	Installed but Non-Operational	Apr-23		relay defective
	220kV S/S Bhelupur	Not Installed	Apr-23		Not required due to radial substation
20kV S/S Harahua	Installed but Non-Operational	Apr-23		Not commissioned	
220kV S/S Sahupuri	Installed but Non-Operational	Apr-23		Defective	
220kV S/S Mirzapur	Installed but Non-Operational	Apr-23			
HP	220kV Chamba	Main-2 non operational	30.04.2023		Relay faulty
	220kV MattaSidh	Installed but Non-Operational			Relay faulty
	220kV kangoo	Installed but Non-Operational			Commissioning awaited from firm
	220kV Nangal	Installed but Non-Operational	Jun-23		
	220kV Katha Baddi	Installed but Non-Operational	Jun-23		

**Status of submission of FIR/DR/EL/Tripping Report of Jammu & Kashmir
on NR Tripping Portal**

S. No.	Month	Total No. of tripping	First Information Report (Not Received)		Disturbance Recorder (Not Received)	Disturbance Recorder (NA) as informed by utility	Disturbance Recorder (Not Received)	Event Logger (Not Received)	Event Logger (NA) as informed by utility	Event Logger (Not Received)	Tripping Report (Not Received)	Tripping Report (NA) as informed by utility	Tripping Report (Not Received)
			Value	%	Value		%	Value		%	Value		%
1	Nov-22	10	0	0	10	0	100	10	0	100	10	0	100
2	Dec-22	6	0	0	6	0	100	6	0	100	6	0	100
3	Jan-23	6	0	0	6	0	100	6	0	100	6	0	100
4	Feb-23	7	0	0	7	0	100	7	0	100	7	0	100
5	Mar-23	7	6	86	7	0	100	7	0	100	7	0	100
6	Apr-23	8	0	0	8	0	100	8	0	100	8	0	100

As per the IEGC provision under clause 5.2 (r), detailed tripping report along with DR & EL has to be furnished within 24 hrs of the occurrence of the event

**Status of submission of FIR/DR/EL/Tripping Report of Punjab
on NR Tripping Portal**

S. No.	Month	Total No. of tripping	First Information Report (Not Received)		Disturbance Recorder (Not Received)	Disturbance Recorder (NA) as informed by utility	Disturbance Recorder (Not Received)	Event Logger (Not Received)	Event Logger (NA) as informed by utility	Event Logger (Not Received)	Tripping Report (Not Received)	Tripping Report (NA) as informed by utility	Tripping Report (Not Received)
			Value	%	Value		%	Value		%	Value		%
1	Nov-22	8	0	0	7	0	88	7	0	88	7	0	88
2	Dec-22	62	27	44	31	7	56	33	6	59	39	2	65
3	Jan-23	19	2	11	11	1	61	12	1	67	14	0	74
4	Feb-23	25	3	12	10	4	48	9	2	39	16	0	64
5	Mar-23	16	3	19	11	3	85	12	1	80	15	0	94
6	Apr-23	41	4	10	16	6	46	22	6	63	38	0	93

As per the IEGC provision under clause 5.2 (r), detailed tripping report along with DR & EL has to be furnished within 24 hrs of the occurrence of the event

**Status of submission of FIR/DR/EL/Tripping Report of Delhi
on NR Tripping Portal**

S. No.	Month	Total No. of tripping	First Information Report (Not Received)		Disturbance Recorder (Not Received)	Disturbance Recorder (NA) as informed by utility	Disturbance Recorder (Not Received)	Event Logger (Not Received)	Event Logger (NA) as informed by utility	Event Logger (Not Received)	Tripping Report (Not Received)	Tripping Report (NA) as informed by utility	Tripping Report (Not Received)
			Value	%	Value		%	Value		%	Value		%
1	Nov-22	4	1	25	3	0	75	3	0	75	3	0	75
2	Dec-22	25	2	8	7	5	35	8	4	38	10	0	40
3	Jan-23	9	0	0	5	1	63	6	1	75	6	0	67
4	Feb-23	4	0	0	3	1	100	3	1	100	3	0	75
5	Mar-23	14	2	14	4	6	50	4	6	50	5	5	56
6	Apr-23	25	3	12	8	12	62	8	11	57	13	1	54

As per the IEGC provision under clause 5.2 (r), detailed tripping report along with DR & EL has to be furnished within 24 hrs of the occurrence of the event

-Annexure-III--**List of trippings of 800kV HVDC Champa-Kurukshetra inter-regional link
occurred since May 2023**

S. No	Element Name	Outage Date	Outage Time	Reason
1	800 KV HVDC Kurukshetra(PG) Pole-2	10-May-23	22:24	Blocked due to software malfunction.
2	800 KV HVDC Kurukshetra(PG) Pole-4	10-May-23	22:24	
3	800 KV HVDC Kurukshetra(PG) Pole-3	18-May-23	00:59	Blocked due to DC line fault in DMR-II.
4	800 KV HVDC Kurukshetra(PG) Pole-1	18-May-23	00:58	External blocked due to detection of smoke from switchyard during heavy windstorm in the area.
5	800 KV HVDC Kurukshetra(PG) Pole-2	18-May-23	00:59	Blocked due to DC line fault in DMR-II.
6	800 KV HVDC Kurukshetra(PG) Pole-4	18-May-23	00:59	
7	800 KV HVDC Kurukshetra(PG) Pole-3	25-May-23	09:25	Pole-3 blocked due to DMR-2 transient fault.
8	800 KV HVDC Kurukshetra(PG) Pole-1	25-May-23	09:25	
9	800 KV HVDC Kurukshetra(PG) Pole-2	25-May-23	09:25	Pole-2 blocked by CAT B from Pole-4
10	800 KV HVDC Kurukshetra(PG) Pole-4	25-May-23	09:25	Pole-4 blocked due to issue in measurement panel DCCT.
11	800 KV HVDC Kurukshetra(PG) Pole-3	28-May-23	15:59	Block command received from Champa due to DC Filter Overload Protection
12	800 KV HVDC Kurukshetra(PG) Pole-1	28-May-23	16:00	
13	800 KV HVDC Kurukshetra(PG) Pole-2	07-June-23	21:55	Blocked due to TEED protection operated at Champa end. Contactor got burnt at Champa end.

Annexure-VI

S.No.	Category of Grid Disturbance (GD-I to GD-V)	Name of Elements (Tripped/Manually opened)	Affected Area	Owner/ Agency	Outage		Revival		Outage Duration (hh:mm)	Event (As reported)	Energy Unserved due to Generation loss (MU)	Energy Unserved due to Load loss (MU)	Loss of generation / loss of load during the Grid Disturbance		Fault Clearance time (in ms)	Remarks
					Date	Time	Date	Time					Generation Loss(MW)	Load Loss (MW)		
1	GD-1	1) 220KV Bus 2 at Baddi(HP) 2) 220 KV Baddi(HP)-Pinjore (HV) (HPPTCL) Ckt-2 3) 220 KV Baddi(HP)-Pinjore (HV) (HPPTCL) Ckt-1 4) 220 KV Baddi-Kunihar Ckt-1 5) 220 KV Baddi-Kunihar Ckt-2 6) 220 KV Baddi-Wardhman Ckt	Himachal Pradesh	HPPTCL	6-Nov-22	13:53	6-Nov-22	14:25	00:32	1. During antecedent condition, bus coupler at 220KV Baddi(HP) was in open condition and 220kV circuit to Upper Nangal & Mandhala, 220/66kV 100MVA transformer-1&3 were connected at 220kV Bus-1 and 220kV circuit to Kunihar, Pinjore & Wardhman, 220/66kV 100 MVA transformer-2&4 were connected at 220kV Bus-2 at Baddi(HP). 2. As reported at 13:53 hrs, R-phase insulator string of 220kV Bus-2 burst which created bus fault on 220kV Bus-2. All the elements connected at 220kV Bus-2 tripped on this fault. 3. As per PMU, R-N phase to earth fault with delayed clearance of approx. 400ms is observed. 4. As per SCADA, change in load of approx. 75MW occurred in HP control area.	0	0.041	0	75	400	i) Details of protection operation at 220kV Baddi(HP)? ii) Reason of delayed clearance of fault? iii) DR, EL of all the tripped elements need to be shared. iv) Status of remedial action? v) Analysis deals and major findings of the tripping event?
2	GD-1	1) 400/220 kv 315 MVA ICT 1 at Muzaffarnagar(UP) 2) 400/220 kv 315 MVA ICT 2 at Muzaffarnagar(UP) 3) 400/220 kv 315 MVA ICT 3 at Muzaffarnagar(UP) 4) 400/220 kv 500 MVA ICT 4 at Muzaffarnagar(UP) 5) 220 KV Muzaffarnagar-Shamli(UP) ckt 6) 220 KV Muzaffarnagar-Nara(UP) ckt 7) 220 KV Muzaffarnagar-Charla(UP) ckt 8) 220 KV Muzaffarnagar-Modipuram(UP) ckt	UP	UPPTCL	8-Nov-22	07:04	8-Nov-22	08:00	00:56	1. At 06:18hrs, 220kV Muzaffarnagar-Jansath ckt tripped on Y-N phase to earth fault. 2. As reported at 07:04 hrs, while charging of 220kV Muzaffarnagar-Jansath ckt, Y-N phase to earth fault occurred. However line didn't not trip. 3. As fault was still persisting, all four ICTs tripped on over current earth fault protection operation. At the same time, 220kV feeders to Nara tripped on distance protection operation in Z-1, 220kV feeder to Shamli in Z-4 and 220kV feeders to Modipuram & Charla tripped in Z-3. 4. As per PMU at Muzaffarnagar(UP), Y-N phase to earth fault with delayed clearance in 1000ms is observed. 5. As per SCADA, change in load of approx. 115MW is observed in UP control area. 6. As reported, after inspection and patrolling, earth wire of double ckt. tower of 220kV Muzaffarnagar-Nara line & 220kV Muzaffarnagar-Jansath line found broken between tower 32-33 which led to the persisted Y-N fault and status of breaker contact of 220kV Jansath line was not available to relay panel due to which protection of line did not operate.	0	0.107	0	115	1000	i) Reason of delayed clearance of fault? ii) Healthiness of protection system need to be ensured at Muzaffarnagar(UP). iii) DR, EL of all the tripped elements need to be shared. iv) Status of remedial action? v) Analysis deals and major findings of the tripping event?
3	GI-2	1) 400/220 kv 315 MVA ICT 1 at Bareilly(UP) 2) 400/220 kv 315 MVA ICT 2 at Bareilly(UP) 3) 400/220 kv 315 MVA ICT 3 at Bareilly(UP) 4) 220 KV Pithoragarh(PG)-Bareilly(UP) (PG) Ckt 5) 220 KV Bareilly-CB Ganj2(UP) ckt-1&2 6) 220 KV Bareilly-Pilibhit(UP) ckt-1&2 7) 220 KV Bareilly-Shahjhanpur(UP) ckt 8) 220 KV Pantnagar(UK)-Bareilly(UP) (UP) Ckt-1 9) 220 KV Bareilly-Dohna(UP) ckt-1	UP	UPPTCL	14-Nov-22	13:21	14-Nov-22	14:00	00:39	1. As reported at 13:21 hrs, telemetry data verification of 220 KV Amariya ckt-1 was being done. Bus-2 isolator of the Amariya line was closed for the same purpose, at the same time, a Monkey jumped on B-ph Bus-1 isolator (Bus-1 isolator jumpers were not connected to bus-1 and were grounded) which created B-N phase to earth bus fault on 220kV Bus-2 at 400/220kV Bareilly. 2. As 220 KV Bus Bar protection is out of service due to its exhausted capacity at 400 KV Bareilly, fault cleared after the tripping of 220kV feeders CB to Ganj2-1&2, Shahjhanpur, Pilibhit-2, Dohna-1, Pantnagar and Pithoragarh on distance protection operation at Bareilly end in Z-4, tripping of 220kV feeder to Dohna-2 & Pilibhit-1 from remote end and tripping of 400/220kV 315MVA ICT-1, 2 & 3 on directional earth fault overcurrent protection operation. 3. As per PMU, B-N phase to earth fault with delayed clearance in 840ms is observed. 4. As per SCADA, no change in load is observed in UP & Uttarakhnd control area.	0	0	0	0	840	i) Why did 220kV Pilibhit-1 & Dohna-2 ckt not trip from Bareilly end in Z-4? ii) Status of Bus bar protection at 220kV side of 400/220kV Bareilly(UP)? iii) DR/EL of all the tripped elements need to be shared. iv) Status of remedial action? v) Analysis deals and major findings of the tripping event?
4	GD-1	1) 220kV Bus-1 at Pong(BB) 2) 220kV Bus-2 at Pong(BB) 3) 220 KV Jalandhar-Pong (BB) Ckt-1 4) 220 KV Jalandhar-Pong (BB) Ckt-2 5) 220 KV Jalandhar(BB)-Dasuya(PS) (BB) Ckt-1 6) 220 KV Jalandhar(BB)-Dasuya(PS) (BB) Ckt-2 7) 220 KV Jalandhar(BB)-Jessore(HP) (BB) Ckt 8) 66 MW Pong HPS - UNIT 2 9) 66 MW Pong HPS - UNIT 3 10) 220/66kV 40MVA Transformer-1 at Pong(BB)	Punjab	BBMB	6-Dec-22	15:03	6-Dec-22	18:57	03:54	1. During antecedent condition, 210MW Unit-2&3 were running and generating ~66MW each. Unit-2 & 220kV feeders to Jalandhar ckt-2, Jessore, Dasuya ckt-2 were connected at 220kV Bus-2 and Unit-3, 220/66kV 40MVA Transformer & 220kV feeders to Jalandhar ckt-1, Dasuya ckt-1 were connected at 220kV Bus-1. 2. As reported at 15:03 hrs, during synchronizing 66MW Unit-6 at Pong(BBMB) at 220kV Bus-1, B-phase pole of SF6 circuit breaker of the unit-6 got burst, it also damaged isolators/accessories of adjacent bays/circuits. On this fault bus bar protection of 220kV Bus-2 operated and elements i.e., 66MW Unit-2 & 220kV feeders to Jalandhar ckt-2, Jessore, Dasuya ckt-2 tripped. However, bus coupler didn't open and so fault cleared with the tripping of 66MW Unit-3, 220/66kV 40MVA transformer and 220kV feeders to Jalandhar ckt-1, Dasuya ckt-1 in Z-2 from remote end 3. As per PMU at Jalandhar (PG), B-N fault with delayed clearance in 480ms is observed. 4. As per SCADA, total generation loss of approx. 132MW is observed at Pong HEP(BBMB).	0	0	132	0	480	i) Mechanical healthiness of CB need to be ensured. ii) Why did bus coupler breaker not open on bus bar protection operation? iii) Reason of delayed clearance of fault? iv) DR/EL & tripping report of all the tripped elements need to be shared. v) Remedial action taken report to be shared. vi) Analysis deals and major findings of the tripping event?
5	GD-1	1) 400/220 kv 500 MVA ICT 2 at Panipat(BB) 2) 220 KV Panipat-Dhulkote (BB) Ckt-1 3) 220 KV Panipat-Dhulkote (BB) Ckt-2 4) 220 KV Panipat-Kurukshetra (BB) Ckt-1 5) 220KV Bus 1, 2 & 3 at Panipat(BB) 6) 220 KV Panipat(BB)-Chajpur(HV) (HVPNL) Ckt-2 7) 220 KV Panipat(TH)(HV)-Panipat(BB) (HVPNL) Ckt-2 8) 220 KV Panipat-Charkhi Dadri (BB) Ckt-1 9) 400/220 kv 450 MVA ICT 1 at Panipat(BB) 10) 220 KV Panipat(TH)(HV)-Panipat(BB) (HVPNL) Ckt-4 11) 220 KV Panipat(BB)-Chajpur(HV) (HVPNL) Ckt-1 12) 220 KV Panipat(TH)(HV)-Panipat(BB) (HVPNL) Ckt-3 13) 220 KV Panipat(BB)-Narela(DV) (BBMB) Ckt-2 14) 220 KV Panipat(TH)(HV)-Panipat(BB) (HVPNL) Ckt-1 15) 220 KV Panipat(BB)-Narela(DV) (BBMB) Ckt-1 16) 220 KV Panipat(BB)-Narela(DV) (BBMB) Ckt-3	Haryana	HVPNL	20-Dec-22	00:29	20-Dec-22	03:55	03:26	1. As reported, at 00:29hrs on 20th Dec 2022, all the elements connected at 220kV Panipat(BBMB) tripped on bus bar protection operation at BBMB end. 2. As per the details received from Narela(DTL) end, fault was in its Z-2. 3. As per PMU at Dadri Thermal(NTPC) end, R-N & Y-N fault with delayed clearance of approx. 1080msec is observed. 4. As per SCADA, change in demand of approx. 150MW is observed in Haryana control area.	0	0.49	0	150	1080	i) Exact location and nature of fault? ii) Reason of delayed clearance of fault? iii) DR, EL & tripping report of any of the tripped elements are not received yet. BBMB must ensure the timely uploading of the details on tripping portal. iv) Status of remedial action? v) Analysis deals and major findings of the tripping event?
6	GD-1	1) 220 KV Ballabgarh(BB)-Badarpur(NT) (BB) Ckt-1 2) 220 KV Samaypur(BB)-Palli(HV) (HVPNL) Ckt-1&2 3) 220KV Bus 3&4 at Samaypur(BB) 4) 220 KV Ballabgarh-Samaypur (BB) Ckt-2 5) 400/220 kv 500 MVA ICT 1,2,3&4 at Ballabgarh(PG) 6) 220 KV Palwal(HV)-Samaypur(BB) (HVPNL) Ckt-2 7) 220 KV Samaypur(BB)-Badshahpur(HV) (HVPNL) Ckt-1 & 2 8) 220 KV Ballabgarh-Charkhi Dadri (BB) Ckt-1 9) 220 KV Faridabad Sec-58 (HV)-Faridabad(NT) (HVPNL) Ckt-1	Haryana	BBMB	12-Jan-23	16:56	12-Jan-23	23:47	06:51	1. Multiple elements tripping occurred at Samaypur(BB) while charging of Bus-4 at 220 kv Samaypur S/S which was under planned outage. 2. As per SCADA, approx. 400 MW Load Loss occurred in Haryana. 3. As per PMU at Ballabgarh(PG), B-N phase to earth fault with fault clearing time of 520 ms is observed.	0	2.74	0	400	520	i) Exact location and nature of fault? Sequence of event? ii) Reason of delayed clearance of fault? iii) DR, EL & tripping report of any of the tripped elements are not received yet. BBMB must ensure the timely uploading of the details on tripping portal. iv) Status of remedial action? v) Analysis deals and major findings of the tripping event?
7	GD-1	1) 220kV Hissar_IA(Har)-Narwana ckt 2) 220kV Hissar_IA(Har)-Masudpur ckt-1 3) 220kV Hissar_IA(Har)-Masudpur ckt-2 4) 220kV Hissar(BB)-Bhiwani(BB) ckt-1 5) 220kV Hissar(BB)-Bhiwani(BB) ckt-2 6) 220kV Hissar(BB)-Hissar_IA(Har) ckt-1 7) 220kV Hissar(BB)-Hissar_IA(Har) ckt-2 8) 220kV Hissar_IA(Har)-Hissar(PG) ckt-1 9) 220kV Hissar_IA(Har)-Hissar(PG) ckt-2 10) 220/132kV 100MVA ICT-1 at Hissar(BB) 11) 220/132kV 100MVA ICT-2 at Hissar(BB) 12) 220/132kV 100MVA ICT-3 at Hissar(BB) 13) 220kV Hissar(BB)-Chirawa(RS) ckt-2 14) 220 KV Hissar(BB)-Jindal Steel(HR)(HVPNL) Ckt-1 15) 220 KV Hissar-Sangrur (BB) Ckt-1 16) 220KV Bus 1 at Hissar(BB) 17) 220KV Bus 2 at Hissar(BB)	Haryana	HVPNL, BBMB, POWERGRID	14-Feb-23	11:19	14-Feb-23	12:16	00:57	1. As reported, at 11:19hrs, Y- phase conductor (from terminal tower to gantry) of 220kV Hissar_IA-Hissar_PG ckt-1 snapped from gantry end, due to which 220KV CVT & 220KV LA of Y- phase snapped out, thereby causing damage to 01 no. of 220KV CVT & 3 no. 220KV LA's. 2. LBB protection operated causing tripping of all 220 kv feeders at 220kV Hissar_IA(Har) S/S. 3. As per PMU, Y-B fault with clearance time of 120 msec and B-N fault converted to Y-B fault with delayed clearance time of 840 msec are observed. 4. Due to tripping of all the 220kV feeders, 220kV Hissar_IA(Har) & 220kV Hissar(BB) S/S became dead. 5. As per SCADA, change in demand of approx. 220MW in Haryana control area (as per SCADA data)	0	0.21	0	220	840	i) Fault clearance time is 840msec. Reason of delayed clearance of fault? Sequence of event? ii) Protection coordination between 220kV S/S in the Hissar region need to be reviewed. iii) DR of Hissar_IA(Har) are not time synced, time syncing of all the recording devices/software need to be ensured. iv) DR/EL of all the tripped elements along with tripping report of the event need to be shared. v) Frequent event of equipment failure are being reported at Haryana & BBMB S/S.(Similar event occurred on 12th Feb23. Proper maintenance of equipment and their healthiness need to be ensured. vi) Status of remedial action? vii) Analysis deals and major findings of the tripping event?

S.No.	Category of Grid Disturbance (GD-I to GD-V)	Name of Elements (Tripped/Manually opened)	Affected Area	Owner/ Agency	Outage		Revival		Outage Duration (hh:mm)	Event (As reported)	Energy Unserved due to Generation loss (MU)	Energy Unserved due to Load loss (MU)	Loss of generation / loss of load during the Grid Disturbance		Fault Clearance time (in ms)	Remarks
					Date	Time	Date	Time					Generation Loss(MW)	Load Loss (MW)		
8	GI-2	1) 400 KV Kanpur(PG)-Panki(UP) (PG) Ckt-1 2) 400 KV Kanpur(PG)-Panki(UP) (PG) Ckt-2 3) 400/220 KV 315 MVA ICT 1 at Panki(UP) 4) 400/220 KV 315 MVA ICT 2 at Panki(UP) 5) 400 KV Fatehpur-Kanpur (PG) Ckt-1 6) 400 KV Fatehpur-Kanpur (PG) Ckt-2 7) 220KV Bus-1 at Panki(UP) 8) 220KV Bus-2 at Panki(UP) 9) 220KV Panki-Kanpur South ckt 10) 220KV Panki-Kidwai ckt 11) 220KV Panki-BTHOR ckt 12) 220KV Panki-RPH ckt 13) 220KV Panki-CHIBM ckt	Uttar Pradesh	UPPTCL, PGCIL	23-Mar-23	13:07	23-Mar-23	14:45	01:38	i) During antecedent condition, 400KV Bus-1 at Kanpur(PG) was under shutdown and 400KV Kanpur-Fatehpur ckt-1&2 were connected at same dia with 400KV Kanpur-Panki ckt-1&2 (line length approx. 6km) (Main CB of Kanpur-Fatehpur ckt was in open condition). ii) As reported, at 13:07hrs, R & Y ph pole of CB of at Panki end of 220KV Panki-Kanpur South ckt damaged. On this fault, bus bar protection at 220KV Panki(UP) operated. iii) As per SCADA, elements connected at both the 220KV bus at Panki(UP) tripped. As fault didn't clear in time, 400/220KV 315MVA ICT-1&2 at Panki(UP) and 400KV Kanpur-Panki D/C also tripped with delay. iv) As per SOE & PMU data & DR/EL received, sequence of the event is as follows: a) At 13:06:18:680hrs, fault occurred in R-ph which cleared within 100msec. At the same time, line CB at Kanpur South end of 220KV Panki-Kanpur South ckt opened (as per SOE). b) At 13:07:37:360hrs, again fault occurred in R-phase which didn't clear at that moment. At the same time, line CB at Panki end of 220KV Panki-Kanpur South ckt opened (as per SOE). c) At 13:07:39:880hrs, fault occurred in Y-ph also. d) At 13:07:42:750hrs, fault in R & Y phase cleared and fault in R phase started, R phase fault cleared with the delay of 5.4sec and Y phase fault cleared with the delay of 2.8sec. At the same time, 400/220KV 315MVA ICT-2 at Panki(UP) tripped on directional O/C protection operation at 400KV side (as per SOE & DR). e) At 13:07:45:560hrs, fault in B phase cleared with the delay of 2.8sec. At the same time, 400KV Kanpur-Panki D/C tripped on O/C E/F protection operation at Kanpur end and 400/220KV 315MVA ICT-1 at Panki(UP) tripped on directional O/C protection operation at 400KV side(as per SOE & DR). f) As per fault locator detail of 400KV Kanpur-Panki D/C at Kanpur(PG) end, B phase fault distance was approx. ~200km from Kanpur(PG) end. It shows that fault was at 220KV side of Panki(UP). v) As 400KV Bus-1 at Kanpur(PG) was under shutdown, 400KV Kanpur-Fatehpur D/C tripped with the tripping of 400KV Kanpur-Panki D/C. vi) As per SCADA, load loss of approx. 300MW occurred in Uttar Pradesh control area.	0	0.49	0	300	5400	i) Status of bus bar protection at 220KV Panki? ii) Status of replacement of electromechanical bus coupler relay with numerica relay. iii) Review of protection coordination to minimise the fault clearance time. vi) Status of remedial action? v) Analysis deals and major findings of the tripping event?
9	GI-1	1) 220 KV Moga(PG)-Mogan(PS) (PSTCL) Ckt-1 2) 220 KV Moga(PG)-Mogan(PS) (PSTCL) Ckt-2 3) 220 KV Moga(PG)-Mogan(PS) (PSTCL) Ckt-3 4) 220 KV Moga(PG)-Mogan(PS) (PSTCL) Ckt-4	Punjab	PSTCL, PGCIL	24-Mar-23	19:07	24-Mar-23	20:18	01:11	i) As reported, at 19:07hrs, 220KV Moga(PG)-Mogan(PS) (PSTCL) ckt-1, 2, 3&4 (line length ~400meter) tripped from Moga(PG) end only. No CB opened from Mogan(PS) end. ii) As per DR submitted of Moga(PG) end, over-current earth-fault protection operated in all four lines at Moga(PG) end. Fault current in all the lines were in the range of 750A and cleared after approx. 1.1-1.5Sec. It seems that probably fault was outside the line in the Punjab network. iii) There is differential protection in line which is in blocked condition due to absence of fiber optics. iv) As per PMU at Jalandhar(PG), R-N phase to earth fault with delayed clearance in 1560msec is observed. v) As per SCADA, no load loss has been observed in Punjab control area as Mogan(PS) has alternate connectivity from 220KV Firoz & Botia feeders.	0	0.00	0	0	1560	i) Exact location and nature of fault need to be identified. SLDC Punjab may confirm whether any fault occurred in downward network? ii) Reason for delayed clearance of fault? iii) SLDC-Punjab is requested to share the details of protection implemented at Mogan(PS) S/s in lines along with their protection settings. Whether bus bar protection is healthy at Mogan(PS) S/s? iv) DR, EL status along with tripping report need to be shared. v) Remedial action taken report to be shared. vi) Analysis deals and major findings of the tripping event?
10	GD-1	1) 220KV Bus-1 at Safidon(HS) 2) 220KV Bus-2 at Safidon(HS) 3) 220/132KV ICT-1 at Safidon(HS) 4) 220/132KV ICT-2 at Safidon(HS) 5) 220KV Panipat TPS(HS)-Safidon(HS) ckt-1 6) 220KV Panipat TPS(HS)-Safidon(HS) ckt-2 7) 220KV Panipat TPS(HS)-Safidon(HS) ckt-3 8) 250 MW Unit-6 at Panipat TPS(HS) 9) 250 MW Unit-7 at Panipat TPS(HS) 10) 250 MW Unit-8 at Panipat TPS(HS)	Haryana	HVPNL, PGCIL	11-Apr-23	18:32	11-Apr-23	20:25	01:53	i) As reported, at 18:32 hrs, CTs of 220/132KV ICT-1 & 2 blasted at 220KV Safidon(HS) which resulted in busbar protection operation. Hence, all elements connected to bus-1 & 2 at 200KV Safidon(HS) tripped and S/s became dead. ii) Due to tripping of 220KV Panipat TPS(HS)-Safidon(HS) ckt-1, 2 & 3 fault transferred to 220KV Panipat TPS(HS) which resulted in tripping of 250MW unit-6, 7 & 8 at Panipat TPS(HS) due to heavy jerk. iii) As per DR, 220/132KV ICT-1 at Safidon(HS) tripped on differential protection operation with differential current of approx. 25A in R & Y phase and 50A in B-phase. 220KV Safidon(HS)-Mund(HS) ckt-2 tripped on zone-1 distance protection operation. iv) As per PMU at 400KV Panipat(HS), multiple faults are observed in the system (R-N fault followed by B-N fault followed by R-Y-B-3-phase fault with delayed fault clearance time of 440 ms). v) As per SCADA, generation loss of approx. 610MW is observed in Haryana control area.	0	1.15	0	610	440	i) Exact nature and location of fault? Reason of occurrence of fault? ii) Bus-wise arrangement of elements at 220KV Safidon(HS) need to be shared. iii) Reason of delayed clearance of fault need to be shared. iv) SCADA data was not healthy at Safidon(HS) during the event. Healthiness of SCADA data need to be ensured. v) DR/EL of all the tripped elements along with tripping report of the event need to be shared. vi) DR at 220 kV Safidon end of 220KV Safidon-Mund Ckt-2 is not time synced. The same need to be ensured. vii) Remedial action taken report to be shared. viii) Analysis deals and major findings of the tripping event?
11	GD-1	1) 220 KV Manesar(PG)-Mau(HV) (HVPNL) Ckt-1 2) 220 KV Manesar(PG)-Mau(HV) (HVPNL) Ckt-2 3) 220 KV Bhiwadi(PG)-Mau(HV) (HVPNL) Ckt 4) 220 KV Bus-1 at Mau(HS) 5) 220 KV Bus-2 at Mau(HS) 6) 220 KV MSIL Mau(HS) Ckt 7) 220 KV HS Bawal-Mau(HS) Ckt	Haryana	HVPNL, PGCIL	14-Apr-23	01:43	14-Apr-23	03:24	01:41	i) As reported, at 01:43 hrs, B-phase CT of 220 KV Bhiwadi(PG)-Mau(HV) (HVPNL) Ckt blasted at Mau end. 220 KV Bhiwadi(PG)-Mau(HV) (HVPNL) Ckt tripped on B-N fault, (Zone-2 distance protection operated) with fault current of 11.5kA and fault distance of 13.69km from Bhiwadi(end). ii) Rest of the 220KV lines connected at Mau S/s tripped on Zone-2 from remote end only. Hence, Mau S/s became dead. iii) As per DR at Bhiwadi(PG) end of 220KV Bhiwadi(PG)-Mau(HS) Ckt, earth fault protection relay operated. iv) As per DR at Manesar(PG) end of 220KV Manesar(PG)-Mau(HS) Ckt-2, line tripped on zone-3 from Manesar(PG) end only. v) As per PMU at 400KV Bhiwadi(PG), B-N phase to ground fault converted to 3-phase fault is observed in the system with delayed fault clearance time of 1280ms. vi) As per SCADA, no change in demand is observed in Haryana control area (as per SCADA). Approx. 128 MW load loss occurred as per communication with SLDC-Haryana.	0	0.22	0	128	1280	i) Details of protection operation? ii) As per PMU, fault clearing time was 1280 ms. Reason of delayed clearance of fault need to be ensured. iii) Healthiness of SCADA data need to be ensured. iv) DR/EL of all the tripped elements along with tripping report of the event need to be shared. v) Remedial action taken report to be shared. vi) Analysis deals and major findings of the tripping event?
12	GD-1	1) 220 KV Dasuya(PS)-Jalandhar(BB) (BBMB) Ckt 2) 220 KV Dasuya(PS)-Jalandhar(PG) (PG) Ckt-1 3) 220 KV Dasuya(PS)-Jalandhar(PG) (PG) Ckt-2 4) 220 KV Pong(BB)-Dasuya(PS) (BBMB) Ckt-1 5) 220 KV Pong(BB)-Dasuya(PS) (BBMB) Ckt-2 6) 220 KV Dasuya-Alawalpur (PS) Ckt	Punjab	PSTCL, BBMB, PGCIL	15-Apr-23	17:15	15-Apr-23	18:57	01:42	i) As per the information received and communication with 220KV Dasuya S/s, brief of the event are as follows: a) 220 KV Dasuya(PS) S/s has double bus scheme. b) At 17:15hrs on 15th April'23, Y-ph CT at Railway end of 220KV Dasuya-Railway ckt (~2km) damaged. c) On this fault, Railway ckt didn't trip from Dasuya end and thus adjacent feeders tripped on back up protection. d) 220 KV Dasuya(PS)-Jalandhar(PG) (PG) Ckt-1 & 2 tripped from Jalandhar(PG) end only, fault was in Z-2 (64.25km) from Jalandhar(PG) end. e) 220 KV Dasuya(PS)-Jalandhar(BB) (BBMB) Ckt tripped from Jalandhar(BB) end only in Z-2 (76.8km). f) 220 KV Dasuya-Alawalpur (PS) Ckt and 220 KV Pong(BB)-Dasuya(PS) (BBMB) Ckt-1 tripped from Dasuya end only and 220 KV Pong(BB)-Dasuya(PS) (BBMB) Ckt-2 tripped from Pong end in Z-3 (~70km). g) As per PMU at 400KV Jalandhar(PG), R-φ-N double phase to ground fault with delayed clearance of fault in 680 ms is observed. iii) As reported by SLDC-Punjab, load loss of approx. 60MW occurred in Punjab control area.	0	0.10	0	60	680	i) Exact nature and location of fault? Whether fault was in reverse zone (Z-4) of other feeders at Dasuya end? ii) Reason of delayed clearance of fault? Why did Railway line didn't trip from Dasuya end? Healthiness of protection system need to be ensured. iii) Details of protection operated at Dasuya end need to be shared. iv) DR/EL of all the tripped elements along with tripping report of the event need to be shared from Rajasthan end. v) Remedial action taken report to be shared. vi) Analysis deals and major findings of the tripping event?
13	GI-2	1) 210 MW Anpara TPS - UNIT 1 2) 400KV Bus 2 at Anpara(UP) 3) 400 KV Singrauli(NT)-Anpara(UP) (PG) Ckt-1 4) 400/132 KV 100 MVA ICT 2 at Anpara(UP) 5) 400KV Anpara-Sarnath (UP) Ckt-1 6) 132 KV Rihand(NT)-Anpara(UP) Ckt-1 7) 132 KV Rihand(NT)-Anpara(UP) Ckt-2	Uttar Pradesh	UPPTCL, NTPC	18-Apr-23	08:56	18-Apr-23	10:36	01:40	i) During antecedent condition, 400 KV Anpara-Sarnath (UP) Ckt-1, 400 KV Singrauli(NT)-Anpara(UP) (PG) Ckt-1, 210MW Unit-1 at Anpara TPS & 400/132 KV 100 MVA ICT 2 at Anpara(UP) were connected at 400KV Bus-2 at Anpara (UP) and rest of the elements were connected at 400KV Bus-1. ii) As reported at 08:49hrs, 210 MW Anpara TPS - UNIT 1 tripped due to damage of bushing of GT1. Further at 08:56hrs, busbar protection operated at 400KV Bus-2 at Anpara(UP) and all the elements connected at 400KV Bus-2 tripped and bus-2 became dead. DT received at Sarnath end. iii) As per PMU at Allahabad(UP), B-N phase to ground fault with fault clearance time of 80msec is observed at 08:49hrs and no fault in system observed at 08:56hrs. iv) As per SCADA SOE, 132 KV Rihand(NT)-Anpara(UP) Ckt-1 & 2 tripped at 08:56hrs. v) As per SCADA, generation loss of approx. 155MW in UP control area is observed (210MW Unit-1 at Anpara TPS tripped).	0	0.00	155	0	80	i) Bus-wise arrangement of elements need to be shared. ii) Healthiness of SCADA data and element status need to be ensured. iii) At 08:56hrs, bus bar protection operated at Anpara(UP), however no fault observed in system. Reason of the same need to be shared. iv) Reason of tripping of 132 KV Rihand(NT)-Anpara(UP) Ckt-1 & 2 need to be shared. v) DR & EL of all the tripped elements along with tripping report of the event need to be shared. vi) Remedial action taken report to be shared. vii) Analysis deals and major findings of the tripping event?
14	GD-1	1) 400 KV Gr. Noida_2(UPC)-Noida Sec 148 (UP) Ckt-1 2) 400 KV Gr. Noida_2(UPC)-Noida Sec 148 (UP) Ckt-2 3) 400KV Bus 1 at Noida Sec 148(UP) 4) 400/220 KV 500 MVA ICT 1 at Noida Sec 148(UP) 5) 400/220 KV 500 MVA ICT 2 at Noida Sec 148(UP) 6) 400 KV Noida Sec 148-Noida Sec 123 (UP) Ckt-1	Uttar Pradesh	UPPTCL	18-Apr-23	13:24	18-Apr-23	14:22	00:58	i) 400/220/33kV Noida Sec148 GIS has double main single breaker bus scheme. Power comes from 400 KV Gr.Noida_2(UPC)-Noida Sec 148 (UP) D/C and feeds Noida Sec 123 via 400 KV Noida Sec 148-Noida Sec 123 (UP) D/C and feeders connected at 220KV level at Noida Sec 148. There are 2*500MVA ICT at Noida Sec148, during antecedent condition, both were in service. There is 1*160MVA 220/132kV ICT and 2*100MVA 220/33kV transformer. ii) As reported, brief detail of the event are as follows: iii) There are two (no.) DC source i.e., I & II with automatic changeover mechanism which takes more than 100msec to changeover the DC source. iv) There is a logic for initiation of bus bar protection with the delay of 100msec in the case of gas detector stage-3 (GD-3). v) In addition, there is an issue related to arrangements of contacts of DC source that whenever DC source is not available then it raises flag as gas detector stage-3 (GD-3) which further initiates bus bar tripping as DC source changeover takes more than 100msec. vi) There is also a preexisting issue related to cards of battery charger which lead to DC source failure during any fluctuation in AC supply. vii) So, at 13:24hrs on 18th April'23, DC source-I voltage dropped as two battery cells became dead and battery charger was also not catering load. viii) Before DC source changeover could have occurred, bus bar tripping initiated with the flag of GD-3. ix) Due to bus bar protection operation, all the feeders and elements connected at both the 400KV bus tripped. x) Issue related to logic of bus bar protection is yet to be resolved, follow up has been taken up to resolve the same. iii) As per PMU at 400KV Agra(PG), no fault is observed in the system. iv) As per SCADA, load loss of approx. 140MW occurred in UP control area.	0	0.14	0	140	NA	i) The issues related to battery charger and logic of initiation of Bus bar tripping during DC source changeover had been discussed in 45SPC meeting. Remedial actions were recommended and agreed to complete it within 30days. However, observing recent frequent tripping triggered due to similar issue. Status of remedial actions to avoid such further trippings need to be shared. ii) Time syncing of the DR need to be ensured. iii) SCADA data of 400KV Noida Sec 148 S/s was not healthy during the event timing, healthiness of the same need to be ensured. iv) Remedial action taken report to be shared. v) Similar event occurred on 06th, 08th & 9th of March 2023. vi) Analysis deals and major findings of the tripping event?
15	GD-1	1) 400 KV Sultanpur(UP), Lucknow_1(PG) (PG) ckt 2) 400 KV Obra_B-Sultanpur (UP) Ckt 3) 400 KV Tanda(NT)-Sultanpur(UP) (UP) Ckt 4) 400/220 KV 315 MVA ICT 1 at Sultanpur(UP) 5) 400/220 KV 315 MVA ICT 2 at Sultanpur(UP) 6) 400/220 KV 315 MVA ICT 3 at Sultanpur(UP) 7) 220/132KV Sakatpura ICT-1 at Sultanpur(UP) 8) 220KV Sultanpur-Pratapgarh ckt 9) 220KV Sultanpur-Tanda New ckt 10) 220KV Sultanpur-Tanda ckt 11) 220KV Sultanpur-Sohawal ckt 12) 220KV Sultanpur-Sangpur ckt 13) 220KV Sultanpur-Amethi ckt	Uttar Pradesh	UPPTCL, PGCIL, NTPC	26-Apr-23	08:56	26-Apr-23	10:36	01:40	i) As per the information received and communication with 400/220KV Sultanpur(UP), brief of the event are as follows: a) As reported, switching operations was being done to shift all the elements to 220KV Bus-1 at Sultanpur. b) At 08:56hrs, Y-ph bus isolator of 220KV Sultanpur-Tanda New ckt damaged during switching operation and created Y-N bus fault. c) As bus bar protection at 220KV side of 400/220KV Sultanpur(UP) is not healthy, 220KV lines to Tanda, New Tanda, Sohawal & Pratapgarh tripped on Z-4 distance protection operation with 160msec time delay. 220KV lines to Amethi and Sangpur tripped from remote end in Z-2/Z-3 distance protection operation. d) Further after 600msec, 400/220KV 315MVA ICT-3 at Sultanpur tripped on over current earth fault protection operation. e) As remaining ICTs didn't trip yet, fault was still persisting which led to the tripping of 400KV lines to Tanda, Lucknow and Obra_B from remote end in Z-3 (~1sec time delay) distance protection operation further after 200msec of ICT-3 tripping. f) With the tripping of 400KV lines, fault got cleared. g) Thereafter, 400/220KV 315MVA ICT-3 at Sultanpur was hand tripped. h) As per PMU, Y-N fault which further converted into R-Y and then R-Y-B fault with delayed clearance of 1560msec is observed. iii) As per SOE, tripping of 400/220KV 315MVA ICT-2 not recorded. iv) As per SCADA, change in load loss of approx. 280MW occurred in Uttar Pradesh control area.	0	0.46	0	280	1560	i) Status of bus bar protection at 220KV Sultanpur? ii) Status of replacement of electromechanical relays? iii) Review of protection coordination to minimise the fault clearance time. vi) Status of remedial action? v) Analysis deals and major findings of the tripping event?
16	GI-1	1) 220KV Sakatpura-Mandalgarh ckt 2) 220 KV Kota(PG)-KTPS(RVUN) (RS) Ckt-1 3) 220 KV Anta(NT)-Sakatpura(RS) (RS) Ckt-1 4) 220 KV RAPP_A-NT(Sakatpura(RS)) (RS) Ckt-2 5) 220KV KTPS-Sakatpura ckt-1 6) 220KV KTPS-Sakatpura ckt-2 7) 220KV KTPS-Sakatpura ckt-3 8) 220KV KTPS-Sakatpura ckt-4 9) 210MW Unit-3 at KTPS 10) 210MW Unit-4 at KTPS 11) 210MW Unit-5 at KTPS	Rajasthan	PGCIL, RVPNL, NTPC, NPCL	8-May-23	19:11	8-May-23	22:32	03:21	i) 220/132KV Sakatpura(Raj) S/s have double main & transfer bus scheme. Station is connected with 220KV Kota TPS via 220KV KTPS-Sakatpura ckt-1, 2, 3 & 4. ii) As reported at 19:11 hrs, R & Y ph CT at Sakatpura end of 220KV Sakatpura-Mandalgarh ckt burst and bus fault occurred. iii) As per information received, bus bar protection is not healthy at 220KV Sakatpura S/s and Z-4(reverse) distance protection time delay setting is kept at 160msec. iv) On this bus fault, 220KV line from RAPP_A & Anta(NT) tripped in Z-4 distance protection operation at Sakatpura end and 220KV KTPS-Sakatpura ckt-1, 2, 3&4 tripped on distance protection in Z-2 from KTPS end. 220KV KTPS-Kota(PG) ckt-1 also tripped from KTPS end. v) At the same time, 210MW Unit-4 at Kota TPS tripped followed by tripping of 210MW Unit-3 & 5 at 19:15 hrs & 19:21 hrs respectively due to tripping of auxiliary components (boiler, pulveriser etc.) vi) As per PMU at Kota(PG), R-N fault converted into R-Y-N fault with delayed clearance of 400msec is observed. vii) As per SCADA, change in load of approx. 220MW in Rajasthan control area and loss in generation of approx. 300MW at 19:15hrs due to tripping of 210MW unit-4 at KTPS. Further at 19:15hrs, 210MW unit-3 at KTPS tripped followed by tripping of 210MW unit-5 at KTPS 19:21hrs is observed.	0	0.737	230	220	240	i) DR of KTPS units not received as relays are of electromechanical nature. KTPS & SLDC-Rajasthan are requested to replace the electromechanical relays with numerical relays so that proper analysis of events can be done. ii) Why did 220KV KTPS-Kota(PG) ckt-1 trip? Details of protection operation need to be shared. iii) Bus wise arrangement of 220KV elements at 220KV Sakatpura S/s during antecedent condition of the tripping event need to be shared (isolator status data was not healthy). iv) Remedial action taken report to be shared. v) Analysis deals and major findings of the tripping event?

S.No.	Category of Grid Disturbance (GD-I to GD-V)	Name of Elements (Tripped/Manually opened)	Affected Area	Owner/ Agency	Outage		Revival		Outage Duration (hh:mm)	Event (As reported)	Energy Unserved due to Generation loss (MU)	Energy Unserved due to Load loss (MU)	Loss of generation / loss of load during the Grid Disturbance		Fault Clearance time (in ms)	Remarks
					Date	Time	Date	Time					Generation Loss(MW)	Load Loss (MW)		
17	GD-2	1) 765kV Bhadla-Bikaner ckt-1 2) 400kV Bikaner-Azure43 ckt 3) 400kV Fatehgarh1-Fatehgarh2 ckt-1 4) 400kV Bhadla-Bhadla2 ckt-1 5) 400kV Bhadla-Bhadla_Raj ckt-2 6) 765kV Fatehgarh2-Bhadla ckt-1 7) 400kV Bhadla-Bhadla2 ckt-2 8) 400kV Bhadla-Bhadla_Raj ckt-1 9) 765kV Bhadla2-Bikaner ckt-1 10) 765kV Ajmer-Phagi ckt-1 11) 765kV Fatehgarh2-Bhadla2 ckt-1 12) 765kV Bhadla-Bikaner ckt-2 13) 400kV Bhadla_Raj-Jodhpur ckt 14) 400kV Bhadla_Raj-Ramgarh ckt 15) 400kV Bhadla_Raj-Ramgarh ckt-1 16) 400kV Bhadla_Raj-Ramgarh ckt-2	Rajasthan	PGCIL, RVPNL, Azure Power	15-May-23	11:51	15-May-23	14:38	02:47	i) As reported, at 11:51:55 hrs, 765kV Bhadla-Bikaner ckt-1 tripped on Y-B phase to phase fault during inclement weather condition (wind/dust storm), fault distance was ~111.6km from Bikaner end (line length is ~169km). ii) On this fault during voltage dip, significant dip in RE generation observed. Voltage dipped up to 0.65pu (as per PMU at Fatehgarh2). iii) Due to significant dip in RE generation and de-loading of 765kV EHV lines (as RE generation failed to recover 90% of pre-fault active power within 1 sec and further Inverters tripping on OV, LVRT/HVRT Non-compliant), over voltage [-1.1pu at 765kV & 400kV level at RE Pooling stations] scenario triggered immediately after the fault that led to multiple element tripping in the RE complex. iv) As per PMU & SCADA, total RE generation drop/loss was approx. 7120MW (~6410MW ISTS RE generation and ~710MW Rajasthan RE generation). Due to significant dip in RE generation frequency dropped by 0.58Hz (from 49.98Hz to 49.4Hz). v) As frequency hit 49.40Hz, total all India load relief of approx. 4036MW is observed on operation of UFR & df/dt. Load relief of approx. 1635MW observed in NR region (as per details received from states). Region wise summary of load relief along with state wise details of UFR & df/dt operation is attached in Annexure-II. vi) After the fault, following 765 & 400 kV lines in RE complex tripped on high voltage: 765kV Fatehgarh2-Bhadla ckt-1, 765kV Bhadla2-Bikaner ckt-1, 765kV Ajmer-Phagi ckt-1, 765kV Fatehgarh2-Bhadla2 ckt-1, 765kV Bhadla-Bikaner ckt-2, 400kV Fatehgarh1-Fatehgarh2 ckt-1, 400kV Bhadla-Bhadla2 ckt-1&2, 400kV Bhadla-Bhadla_Raj ckt-1&2, 400kV Bhadla_Raj-Merta ckt, 400kV Bhadla_Raj-Jodhpur ckt, 400kV Bhadla_Raj-Ramgarh ckt-1&2 vii) Multiple 220kV lines dedicated to RE stations also tripped on over voltage during same time. viii) Further at 12:08 hrs, 765kV Fatehgarh2-Bhadla2 ckt-1 was charged.	0	0.755	7120	1635	80	i) 220kV line from Azure41 & Azure Mapple tripped on OV protection operation. OV setting is kept as 1.1pu with 2sec delay, which is uncoordinated over voltage protection setting. OV protection at both the RE stations need to be reviewed. ii) In few of the lines, OV stage-1 protection didn't reset even when voltage dropped to 1.0825pu. Reason of the same need to be identified. Whether implemented flexi logic to increase drop off to pick up ratio is working properly or not. POWERGRID may analyse w.r.t. the same. iii) Voltage prior to the tripping at Ajmer end of 765kV Ajmer-Phagi ckt-1 is 1.06pu however, OV stage-1 pickup setting is 1.08pu. OV stage-1 setting of the line need to be reviewed. iv) Reason of tripping of 220kV Bhadla2(PG)-NTPC Nokhra is not clear from DR. The same need to be shared. v) DR received from Rajasthan end are not time synced. Time syncing of the same need to be ensured. vi) Analysis details and major findings of the tripping event?
18	GD-1	1) 220 KV Ballabgarh(BB)-Badarpur(NT) (BB) Ckt-1 2) 220 KV Ballabgarh(BB)-Badarpur(NT) (BB) Ckt-2 3) 220 KV Ballabgarh-Charhi Dabri (BB) ckt-1 4) 220 KV Ballabgarh-Samaypur (BB) Ckt-1 5) 220 KV Ballabgarh-Samaypur (BB) Ckt-2 6) 220 KV Ballabgarh-Samaypur (BB) Ckt-3 7) 220KV Bus 1 at Ballabgarh(BB) 8) 220KV Bus 2 at Ballabgarh(BB) 9) 220/66kV 100MVA ICT1 at Ballabgarh(BB) 10) 220/66kV 100MVA ICT2 at Ballabgarh(BB) 11) 220/66kV 100MVA ICT3 at Ballabgarh(BB)	Haryana	BBMB, NTPC	16-May-23	01:52	16-May-23	04:23	02:31	i) As reported, at 01:52 hrs, Y-phase PT and R and Y phase breaker poles of 220 KV Ballabgarh(BB)-Badarpur(NT) (BB) Ckt-2 burst at Ballabgarh(BB) end. ii) This resulted in LBB protection operation and all the elements connected to Bus-1 and Bus-2 tripped and 220/66/33kV Ballabgarh(BB) S/s became dead. iii) As per DR of 220 KV Ballabgarh(BB)-Badarpur(NT) Ckt-1, zone-2 distance protection operated at Badarpur(NT) end (Y-B fault, fault current of approx. 6.9kA) and zone-4 distance protection operated at Ballabgarh(BB) end (R-Y-N fault, fault current of approx. 12kA in each phase followed by R-N fault, fault current of approx. 17kA). iv) As per DR of 220KV Bus 1 at Ballabgarh(BB), LBB protection operated (Y-N fault converted to 3-phase fault followed by R-N fault followed by R-Y-N fault were observed) v) As per PMU at Ballabgarh(BB), multiple faults (Y-N fault converted to 3-phase fault followed by R-N fault followed by R-Y-N fault) were observed in system with delayed fault clearing time of 1400 ms. vi) As per SCADA, load loss of approx. 300MW is observed in Haryana control area.	0	0.755	0	300	1400	i) Bus-wise arrangement of elements need to be shared (Isolator status of elements are not clear from SCADA). ii) Why did elements connected at both the bus trip? iii) Reason of delayed clearance of fault need to be shared. iv) DR/EL along with tripping report need to be shared for all the elements from both ends. v) Remedial action taken report to be shared. vi) Analysis details and major findings of the tripping event?
19	GD-1	1) 400KV Bus 1 at Jodhpur(RS) 2) 400KV Bus 2 at Jodhpur(RS) 3) 400 KV Akal-Jodhpur (RS) Ckt 4) 400 KV Rajwest(RW)-Jodhpur (RS) Ckt 5) 400/220 KV 315 MVA ICT 1 at Jodhpur(RS) 6) 400/220 KV 315 MVA ICT 2 at Jodhpur(RS) 7) 400 KV Jodhpur-Kankani (RS) Ckt-1 8) 400 KV Kankol(PG)-Jodhpur(RS) (PG) Ckt	Rajasthan	RVPNL, PGCIL	24-May-23	20:14	24-May-23	23:40	03:26	i) 400/220kV Jodhpur(RS) has one and half breaker bus scheme at 400kV side. ii) As reported at 20:10 hrs, Isolator of 220 kV Jodhpur to Bilara line and the IPS tube of 400 kV main bus-A got damaged due to heavy storm at 400 kV GSS, Jodhpur. iii) On this fault, Bus bar protection operated at 400kV Bus-A (as reported and as verified from DR). iv) As reported, at the same time, all the elements connected to 400kV Bus-A & Bus-B tripped and substation became dead. v) As per PMU at Bhadla(PG), R-N phase to earth fault which further converted into three phase fault with delayed clearance of 2080ms is observed. vi) As per DR of 400 KV Jodhpur-Kankani (end) (RS) Ckt-1, at 20:14 hrs, line tripped on R-N phase to earth fault (zone-3 distance protection) with fault current of 1.16kA from Kankani(RS) end and fault clearance time of ~800msec. As reported, fault distance was 211km from Kankani(RS) end. vii) As per DR of 400 KV Kankol(PG) (end)-Jodhpur(RS) (PG) Ckt, at 20:14 hrs, line tripped on R-N phase to earth fault later converted into R-Y-N fault is observed. Fault current was ~1.38kA from Kankol(PG) end. Fault clearing time was ~1560ms. As reported, fault distance was 187.5km from Kankol(PG) end. viii) As per DR of 400/220 KV 315 MVA ICT 1 & 2 at Jodhpur(RS), ICTs tripped on directional over current protection operation with the delay of approx. ~1300msec. Fault in R-phase which converted into R-Y-B is observed. ix) As per SCADA, change in demand of approx. 275MW in Rajasthan control area x) The damaged IPS tube of 400kV main bus-A has been fixed.	0	0.944	0	275	2080	i) Bus wise arrangement of 400kV elements during antecedent condition of the tripping event need to be shared. ii) Reason of delayed clearance of fault? iii) Time sync issue in DR of 400/220 kv 315 MVA ICT 1 & 2 and 400kV Bus-A at Jodhpur(RS) (end) is observed. The same need to be rectified. iv) Details of trippings at 220kV side also need to be shared. v) Remedial action taken report to be shared. vi) Analysis details and major findings of the tripping event?
20	GD-1	1) 220 KV Dasuya(PS)-Jalandhar(BB) (BBMB) Ckt 2) 220 KV Dasuya(PS)-Jalandhar(PG) (PG) Ckt-1 3) 220 KV Dasuya(PS)-Jalandhar(PG) (PG) Ckt-2 4) 220 KV Pong(BB)-Dasuya(PS) (BBMB) Ckt-1 5) 220 KV Pong(BB)-Dasuya(PS) (BBMB) Ckt-2 6) 220 KV Dasuya-Alawalpur (PS) Ckt 7) 220 KV Sama(PS)-Dasuya(PS) (PG) Ckt-1 8) 220 KV Sama(PS)-Dasuya(PS) (PG) Ckt-2 9) 220kV Dasuya-Railwat ckt	Punjab	PSTCL, PGCIL, BBMB	31-May-23	04:48	31-May-23	07:08	02:20	i) 220 kV Dasuya(PS) S/s has double bus scheme. ii) As reported, brief of the event is as follows: a) At 04:48hrs on 31st May'23, 220 KV Dasuya-Alawalpur (PS) Ckt tripped on R-N phase to earth fault from Alawalpur end only; fault sensed in zone-1 from Alawalpur end. This fault was not sensed from Dasuya end. Hence distance protection did not operate and line did not trip from Dasuya end on this fault. b) On this fault, other lines from 200kV Dasuya(PS) tripped on back-up protection (2-/2-/3/directional E/F) operation from remote end only. c) Back up over current earth fault protection of 220 KV Dasuya-Alawalpur (PS) Ckt also didn't operate. iii) As per DR of 220 KV Dasuya(PS)-Jalandhar(PG) (end) (PG) Ckt-1 & 2, directional E/F protection operated at Jalandhar(PG) end. Fault current in R-phase were 700A and 950A respectively for Ckt-1 & 2 from Jalandhar(PG) end. iv) As per PMU at 400kV Jalandhar(PG), R-N phase to earth fault with delayed clearance of fault in 3520 ms is observed. v) As per SCADA change in demand of approx. 90MW is observed in Punjab control area.	0	0.21	0	90	3520	i) Exact reason and location of fault? ii) Reason of delayed clearance of fault? iii) Why did 220 KV Dasuya-Alawalpur (PS) Ckt not trip from Dasuya end? Main & backup protection in 220 KV Dasuya-Alawalpur (PS) Ckt didn't sense the fault. Healthiness of protection system need to be ensured. iv) DR/EL of all the tripped elements along with tripping report of the event need to be shared. v) Remedial action taken report to be shared. vi) Analysis details and major findings of the tripping event?

Utilities are requested to prepare and present the event details in 46th PSC meeting. Events involving more than one utility may be jointly prepared and presented.